



Indianapolis Power & Light Company  
Eagle Valley Generating Station

Liner Documentation for  
Existing CCR Surface Impoundments

Prepared by



55 East Monroe Street  
Chicago, IL 60603-5780 USA  
312-269-2000  
[www.sargentlundy.com](http://www.sargentlundy.com)

S&L Project No. 10572-085

Rev. 0  
Issue Date: October 14, 2016  
Issue Purpose: Use

# 1 LINER DOCUMENTATION

## **Federal CCR Rule Reference: 40 CFR 257.71(a)(1)**

Indianapolis Power & Light Company (IPL) operates the Eagle Valley Generating Station (EVS). The site's existing coal combustion residual (CCR) surface impoundments – Pond A, Pond B, and Pond C – presently do not accept CCR and are planned to be closed in the future. This document addresses the liner design to satisfy 40 CFR 257.71(a)(1):

“No later than October 17, 2016, the owner or operator of an existing CCR surface impoundment must document whether or not such unit was constructed with any one of the following:

- (i) A liner consisting of a minimum of two feet of compacted soil with a hydraulic conductivity of no more than  $1 \times 10^{-7}$  cm/sec;
- (ii) A composite liner that meets the requirements of § 257.70(b); or
- (iii) An alternative composite liner that meets the requirements of § 257.70(c).”

While the EVS existing CCR surface impoundments were constructed with compacted soil, ash, and/or clay, they do not meet the requirements above. Therefore, for the purposes of 40 CFR 257.71(a)(1), Ponds A, B, and C are considered to be existing unlined CCR surface impoundments and are subject to 40 CFR 257.101(a).

## 2 CERTIFICATION

### Federal CCR Rule Reference: 40 CFR 257.71(b)

The documentation presented herein to meet the requirements of 40 CFR 257.71(a) is accurate.

I certify that this document was prepared by me or under my direct supervision and that I am a registered professional engineer under the laws of the State of Indiana.

Certified By:  Date: 10-14-2016

Seal:

