

RATE PL
PRIMARY SERVICE (LARGE)

AVAILABILITY:

Available for power and lighting delivered at primary distribution voltage. Minimum contract five hundred (500) kilowatts of demand. Not for resale.

CHARACTER OF SERVICE:

Standard Characteristics: Three phase, sixty cycle alternating current supplied from overhead lines through transformers and other substation equipment owned by the Company, delivered at one point on Customer's premises, and at primary distribution voltage, approximately 4,160 or 13,200 volts. All distribution transformers, lines and other equipment on the Customer's side of the point of delivery shall be installed, owned, operated and maintained by the Customer.

Non-Standard Characteristics: If the Customer desires service necessitating transformers (including circuit breakers, supporting structure and supplementary equipment) which do not conform to the standard of the Company as to design, voltage ratio or capacity; or if the Customer desires the exclusive use and/or control of the transformers of standard or non-standard characteristics, energy will be delivered in either case at the high tension side of such transformers, which, however, shall be installed, owned, operated and maintained by the Customer.

Demand and energy measurements may be made at either the high tension (input) or low tension (load) side of the transformers, but, if measured at the high tension side, will be adjusted before billing by the deduction of one-half percent (½%), so that they will be equivalent to measurement at a standard primary distribution voltage, approximately 4,160 or 13,200 volts. The Company, for engineering or other practical reasons, may at its option supply and measure service at sub-transmission voltage.

RATE:

The Customer Charge; plus the sum of the Demand Charge and the Energy Charge adjusted according to the "Power Factor" clause shown hereafter; plus the Standard Contract Riders shown hereafter in the Standard Contract Riders Applicable section.

<u>Customer Charge</u>	\$120.00
<u>Demand Charge</u> All KW of billing demand per month @	\$23.23 net per KW
<u>Energy Charge</u>	3.6204¢ net per KWH

APPROVED BY
CONFERENCE MINUTES
30-Day Filing No. 50409
April 7, 2021

INDIANA UTILITY REGULATORY COMMISSION

Issued Pursuant to
Cause No. 50409
Effective
April 7, 2021
Indiana Utility Regulatory Commission
Effective _____ Energy Division _____, 2021

RATE PL (Continued)

DETERMINATION OF BILLING DEMAND:

The billing demand shall be determined as being the average of the three (3) highest fifteen (15) minute interval demands, expressed in kilowatts, established by the Customer during the billing month under consideration but with the further provision that the demand charge shall be based upon not less than sixty percent (60%) of the highest billing demand that has been established in any of the immediately preceding eleven (11) months, and in no case upon less than five hundred (500) kilowatts.

MINIMUM CHARGE PER MONTH:

The sum of the Customer Charge and Demand Charge, which is to be in no case for less than five hundred (500) kilowatts.

POWER FACTOR:

The Customer's bill will be adjusted by multiplying the sum of the demand and energy charges by the multiplier set out in the table below whenever the average monthly power factor of his operation varies from eighty-five percent (85%) lagging, as determined by suitable instruments connected at the point where the energy and the demand are measured for billing purposes. In determining the average power factor for the month, no credit will be given for leading power factor. Any equipment installed to control or to correct the power factor shall be of such design, and it shall be so controlled and operated at all times, that its use will not create any undesirable operating characteristics (including voltage rise) in the supply circuits, beyond the limits of good practice.

<u>POWER FACTOR</u>	<u>MULTI-PLIER</u>	<u>POWER FACTOR</u>	<u>MULTI-PLIER</u>	<u>POWER FACTOR</u>	<u>MULTI-PLIER</u>	<u>POWER FACTOR</u>	<u>MULTI-PLIER</u>
1.00	.951	.87	.9919	.74	1.0563	.61	1.1661
.99	.9535	.86	.9958	.73	1.0627	.60	1.1785
.98	.9562	.85	1.0000	.72	1.0694	.59	1.1897
.97	.9590	.84	1.0041	.71	1.0764	.58	1.2025
.96	.9618	.83	1.0085	.70	1.0835	.57	1.2159
.95	.965	.82	1.0131	.69	1.0913	.56	1.2300
.94	.9677	.81	1.0178	.68	1.0992	.55	1.2455
.93	.9709	.80	1.0230	.67	1.1075	.54	1.2607
.92	.9741	.79	1.0277	.66	1.1161	.53	1.2773
.91	.9774	.78	1.0330	.65	1.1255	.52	1.2950
.90	.981	.77	1.0386	.64	1.1347	.51	1.3136
.89	.9844	.76	1.0442	.63	1.1447	.50	1.3335
.88	.9881	.75	1.0500	.62	1.1551		

APPROVED BY
CONFERENCE MINUTES
30-Day Filing No. 50409
April 7, 2021

INDIANA UTILITY REGULATORY COMMISSION

Issued Pursuant to
Cause No. 50409
Effective
April 7, 2021
Indiana Utility Regulatory Commission
Effective _____, 2021
Energy Division

RATE PL (Continued)

STANDARD CONTRACT RIDERS APPLICABLE:

No. 1	Customer Load Characteristics	see Page 150
No. 2	Stand-by Service	see Page 152
No. 3	Transmission, Distribution and Storage System Improvement Charge	see Page 153
No. 4	Additional Charges for Transformers and Other Facilities Furnished by Company to Customer	see Page 154
No. 5	Short Term Service	see Page 156
No. 6	Fuel Cost Adjustment	see Page 157
No. 8	Off-Peak Service	see Page 160
No. 9	Net Metering	see Page 161
No. 13	Air Conditioning Load Management Adjustment	see Page 165
No. 14	Interruptible Power	see Page 166
No. 15	Load Displacement	see Page 171
No. 17	Curtailement Energy	see Page 175
No. 18	Curtailement Energy II	see Page 178
No. 20	Environmental Compliance Cost Recovery Adjustment	see Page 179.2
No. 21	Green Power Initiative	see Page 179.3
No. 22	Demand-Side Management Adjustment	see Page 179.5
No. 23	Market Based Demand Response Rider	see Page 179.6
No. 24	Capacity Adjustment	see Page 179.7
No. 25	Off-System Sales Margin Adjustment	see Page 179.8
No. 26	Regional Transmission Organization Adjustment	see Page 179.9

PAYMENT:

The above rates and charges are net. If the net bill is not paid within seventeen (17) days after its date of issue, a charge will be added in the amount of ten percent (10%) of the first Three Dollars (\$3.00) plus three percent (3%) of the excess of Three Dollars (\$3.00).

STANDARD TERM:

Three years.

RULES:

Service hereunder shall be subject to the Company's Rules and Regulations for Electric Service, and to the Rules and Standards of Service for the Electrical Public Utilities of Indiana prescribed by the Indiana Utility Regulatory Commission, as the same are now in effect, and as they may be changed from time to time hereafter.

APPROVED BY
CONFERENCE MINUTES
30-Day Filing No. 50409
April 7, 2021

INDIANA UTILITY REGULATORY COMMISSION

Issued Pursuant to
Cause No. 50409
Effective
April 7, 2021
Indiana Utility Regulatory Commission
Energy Division
Effective _____, 2021