



2022 Integrated Resource Plan (IRP)

Public Advisory Meeting #3 6/27/2022



Agenda and Introductions

Stewart Ramsay, Managing Executive, Vanry & Associates

2022 IRP

2



Agenda

Time	Торіс	Speakers
Morning Starting at 10:00 AM	Virtual Meeting Protocols and Safety, Schedule	Chad Rogers
	IRP Midway Touchpoint	Kristina Lunc
	Stakeholder Presentations	Wendy Bredl Ray Wilson,
	IRP Schedule & Meeting #2 Recap	Erik Miller, M
	2022 All-Source RFP & Replacement Resource Cost Update	Erik Miller, M
	Commodity Forecasts	Erik Miller, M
	RTO Reliability Planning: Resource Adequacy & Seasonal Construct	Lynn Hecker
Break 12:00 PM – 12:30 PM	Lunch	
Afternoon Starting at 12:30 PM	Modeling Reliability Assumptions	Erik Miller, M
	Reliability Analysis	Hisham Othr
	Portfolio Metrics & Scorecard	Erik Miller, M
	AES Indiana Distribution System Planning	Kathy Storm, Mike Russ, S
	Final Q&A and Next Steps	

- s, Senior Manager, Regulatory Affairs, AES Indiana
- I, President & CEO, AES Indiana
- hold, Senior Campaign Representative, Sierra Club Faith in Place
- lanager, Resource Planning, AES Indiana
- lanager, Resource Planning, AES Indiana
- lanager, Resource Planning, AES Indiana
- , Senior Manager, Resource Adequacy Policy and Analytics, MISO

lanager, Resource Planning, AES Indiana

man, VP Transmission and Regulatory Consulting, Quanta

lanager, Resource Planning, AES Indiana

- Vice President, US Smart Grid, AES Indiana
- Senior Manager, T&D Forecasting, AES Indiana

Virtual Meeting Protocols and Safety

Chad Rogers, Senior Manager, Regulatory Affairs, AES Indiana



IRP Team Introductions



AES Indiana Leadership Team

Kristina Lund, President & CEO, AES Indiana Aaron Cooper, Chief Commercial Officer, AES Indiana Brandi Davis-Handy, Chief Public Relations Officer, AES Indiana

Ahmed Pasha, Chief Financial Officer, AES Indiana Tom Raga, Vice President Government Affairs, AES Indiana

Sharon Schroder, Managing Director, Regulatory Affairs, AES Indiana

Kathy Storm, Vice President, US Smart Grid, AES Indiana

AES Indiana IRP Planning Team

Joe Bocanegra, Load Forecasting Analyst, AES Indiana Erik Miller, Manager, Resource Planning, AES Indiana Scott Perry, Manager, Regulatory Affairs, AES Indiana Chad Rogers, Senior Manager, Regulatory Affairs, AES Indiana

Mike Russ, Senior Manager, T&D Planning & Forecasting, AES Asset Management

Brent Selvidge, Engineer, AES Indiana

Will Vance, Senior Analyst, AES Indiana

Kelly Young, Director, Public Relations, AES Indiana

AES Indiana IRP Partners

Annette Brocks, Senior Resource Planning Analyst, ACES Patrick Burns, PV Modeling Lead and Regulatory/IRP Support, Brightline Group Eric Fox, Director, Forecasting Solutions, Itron Jeffrey Huber, Overall Project Manager and MPS Lead, GDS Associates Jordan Janflone, EV Modeling Forecasting, GDS Associates Patrick Maguire, Executive Director of Resource Planning, ACES Hisham Othman, Vice President, Transmission and Regulatory Consulting, Quanta Technology Stewart Ramsey, Managing Executive, Vanry & Associates Mike Russo, Forecast Consultant, Itron Jacob Thomas, Market Research and End-Use Analysis Lead, GDS Associates Melissa Young, Demand Response Lead, GDS Associates

AES Indiana Legal Team

Nick Grimmer, Indiana Regulatory Counsel, AES Indiana Teresa Morton Nyhart, Counsel, Barnes & Thornburg LLP



Welcome to Today's Participants

ACES	
Advanced Energy Economy	IBEW
All Souls Indianapolis	Indiar
Barnes & Thornburg LLP	Indiar
Boardwalk Pipelines	Indiar
Butler University	Indiar
Carmel Green Initiative	Indiar
CCR	Indiar
CenterPoint Energy	IUPU
Citizens Action Coalition	NIPS
City of Indianapolis	NuSc
Clean Grid Alliance	Office
Develop Indy Indy Chamber	Powe
	Purdi
EQU Earth Charton Indiana	Pana
Earth Charter Indiana EDE Donowoblog NA	Rang
EDF Reliewables NA Eporav Euturos Group	Reliat
Energy Futures Group	Rolls-
Fluence Energy	Sierra
GDS Associates	Solar
Hallador Energy	Synar
Hoosier Energy	Warts

... and members of the AES Indiana team and the public!

- V Local Union 1395
- na Chamber
- na DG
- na Distributed Energy Alliance
- na Energy Association
- na Utility Regulatory Commission
- na State Conference of the NAACP
-]]
- CO
- cale Power
- e of Utility Consumer Counselor
- er Takeoff
- ue State Utility Forecasting Group
- ger Power
- ble Energy
- -Royce/ISS
- a Club
- ^r United Neighbors
- pse Energy Economics sila



Virtual Meeting Best Practices

Questions

- \rightarrow Your candid feedback and input is an integral part to the IRP process.
- Questions or feedback will be taken at the \rightarrow end of each section.
- \rightarrow Feel free to submit a question in the chat function at any time and we will ensure those questions are addressed.





2022 IRP

7

Audio

 \rightarrow All lines are muted upon entry.

 \rightarrow For those using audio via Teams, you can unmute by selecting the microphone icon.

 \rightarrow If you are dialed in from a phone, press *6 to unmute.

Video

 \rightarrow Video is not required. To minimize bandwidth, please refrain from using video unless commenting during the meeting.



AES Purpose & Values

Accelerating the future of energy, together.



Safety first



Highest standards



All together



Our safety beliefs

- 1. Safety comes first for our people, our contractors and our communities.
- 2. All occupational incidents can be prevented.
- 3. Working safely is a condition of employment.
- 4. All AES people and contractors have the right and obligation to stop work when they identify a situation they believe to be unsafe

We can all be safety leaders.





IRP Midway Touchpoint

AES

- Fortune 200 company with operations in 14 countries across 4 continents. \rightarrow
- Track record of innovation in the technologies that are transforming the energy sector. \rightarrow
- AES is a global energy company and with the addition of 5 GW of new renewables in \rightarrow 2021, is now positioned as the fastest growing US renewables developer and the largest supplier of corporate renewables contracts in the world.
- AES announced a target to exit coal by year-end 2025 at the global portfolio level, \rightarrow subject to meeting regulatory obligations. The exit may be achieved through asset sales, fuel conversions or retirements.

AES Indiana

- 20-year IRP plan created with stakeholder input. \rightarrow
- Modeling and analysis culminates in a preferred resource portfolio and a short-term action plan. \rightarrow
- The need for a utility to engage in a rigorous stakeholder process and describe how the utility plans to deliver safe, reliable and \rightarrow efficient electricity at just and reasonable rates is a legal requirement in Indiana and is an obligation AES Indiana will meet.





Leading the inclusive, clean energy transition

- 1. AES Indiana has a diverse power generation portfolio that serves our customers' needs today and well into the future.
- 2. Our 2019 IRP projected that AES Indiana would achieve a reduction in carbon intensity of more than 40% from 2015 to 2025.
- 3. AES Indiana has been incorporating new technologies and fuels into its generation fleet for more than a decade.
 - Signed power purchase agreements with wind farms back beginning in 2009
 - Converted Harding Street from coal to natural gas
 - Retired Eagle Valley coal and started operations of a new CCGT in 2018
 - Announced plans to retire Petersburg Unit 1 in 2021 and Unit 2 in 2023 and signed the acquisitions of Hardy Hills (195 MW solar project) and the Petersburg Energy Center (250 MW solar and 180 MWh energy storage project)
- 4. AES Indiana is committed to safety and compliance of all environmental regulations and will responsibly close ash ponds in the manner required by Indiana state law.





Stakeholder Presentations

Wendy Bredhold, Senior Campaign Representative, Sierra Club **Tony Mendoza**, Senior Attorney, Sierra Club





Stakeholder Presentations

Ray Wilson, Faith in Place



IRP Schedule & Meeting #2 Recap

Erik Miller, Manager, Resource Planning, AES Indiana



Updated 2022 IRP Timeline





= Preferred Resource Portfolio selected

2022 IRP

Issue Generation RFP - Date TBD in 2022

AES Indiana is available for additional touchpoints with stakeholders to discuss IRP-related topics.



Public Advisory Schedule



Topics for meetings 4-5 are subject to change depending on modeling progress.



IRP Process Overview





Meeting #2 Recap: Portfolio Matrix Update

Strategies & Scenarios for Scorecard Evaluation

Combining Strategies and Scenarios results in the Portfolio Matrix or framework for IRP evaluation:

		Scenarios			
		No Environmental Action	Current Trends (Reference Case)	Aggressive Environmental	Decarbonized Economy
	No Early Retirement				
egies	Pete Refuel to 100% Gas (est. 2025)	Portfo	nlin cost (P\/RR) w	ill he
ר Strat	One Pete Unit Retires (2026)		otod for o	a a b b a c t f c	
eratior	Both Pete Units Retire (2026 & 2028)	Calcul		ach portic	
Gen	"Clean Energy Strategy" Both Pete Units Retire and Replaced	con	nplete Por	rtfolio Mat	trix
	with Wind, Solar & Storage (2026 & 2028)				
	Encompass Optimization without predefined Strategy				

> The Current Trends portfolios defined above will be evaluated using a Scorecard that includes cost, environmental, reliability & risk metrics. \rightarrow A Preferred Resource Portfolio will be selected using this rigorous Scorecard evaluation process.



Other Updates from Meeting #2

Energy Efficiency Bundles 1)

> After stakeholder collaboration AES Indiana decided to split Efficient Products and Residential Vintage 2 & 3 into higher and lower cost bundles to provide the opportunity for additional cost-effective energy efficiency to get selected.



*IQW Program will be predefined in the IRP modeling

*IQW Program will be predefined in the IRP modeling

2) Petersburg 3 & 4 Refuel Cost Updates

- > Estimated capital costs for Petersburg Units 3 & 4 refuel to natural gas presented in Advisory Meeting 2 (April 12, 2022) have been refined.
- \rightarrow Estimated capital cost (excluding gas infrastructure upgrade) is ~\$160/kW
- → Capital expenditure still based on cost to refuel Harding Street units 5, 6, 7

	AFTER		
Vintage 1	Vintage 2	Vintage 3	
2024 - 2026	2027 - 2029	2030 - 2042	
nt Products - Lower Cost	Lower Cost Posidential	Lower Cost Posidential	
nt Products - Higher Cost		(excluding IQW)	
Behavioral	(cherading i Q W)		
School Education	Higher Cost Pesidential	Higher Cost Posidential	
ppliance Recycling			
Multifamily	(Excluding (QW)	(excluding iQw)	
*IQW	*IQW	*IQW	
Prescriptive			
Custom	All C&I	All C&I	
Custom RCx	All Col	All Col	
Custom SEM			



2022 All-Source RFP & Replacement Resource Costs Update

Erik Miller, Manager, Resource Planning, AES Indiana





2022 All-Source Generation RFP

AES Indiana is conducting an All-Source RFP

- Positions AES Indiana to efficiently procure generation consistent with final IRP Preferred Resource Portfolio
- → Informs IRP Replacement Resource Costs
- \rightarrow RFP offers requested for Commercial Operation Date (COD) of 2025-2027
- \rightarrow Projects leveraging Petersburg Unit 3 & 4 injection rights (~1,000MW) if retired through IRP process
- \rightarrow RFP issued April 14, 2022
- \rightarrow All proposals received by May 19, 2022

Department of Commerce Anti-Dumping/Countervailing Duties (AD/CVD) investigation

- \rightarrow Initiated in March 2022 DOC reviewing additional tariffs on solar panels manufactured in countries that are practicing improper biproduct disposal
- Creates uncertainty for solar developers current RFP offers include impacts from this uncertainty

Update

- \rightarrow Biden Administration has issued Executive Order that waives the solar tariffs for 24 months
- \rightarrow AES Indiana asking solar developers to refresh offers



Summary of All-Source RFP Responses

All projects received by May 19, 2022

- > Eleven different developer respondents
- \rightarrow Total # of projects = 24
 - \rightarrow Total # of proposals = 140

→ Prices higher than initial 2022 IRP
replacement resource costs shared in Meeting
#2 – with wide distribution in some categories

→ Currently tariff uncertainty, supply chain challenges and COVID impacts affecting prices – capturing this in IRP

Dynamic market conditions – subsequent
RFP may result in lower prices

Techno	
Ther	
So	

A project is defined as a unique site and each site may have multiple proposal offerings (PPA, Asset Transfer, etc.).

logy	# of Projects	
Solar	14	
Wind	**Confidential** Competitively Sensitive Information	
mal-Aero CT		
lar + Storage		
Storage		
TOTAL	24	



All-Source RFP Capacity Summary

Key Proposal Summary:

- Total proposed installed capacity = ~4 GW
 - → Proposed storage capacity =
 - ~2.1 GW in both 4- and 6-hour durations

Robust amount of solar capacity =
~1.7 GW despite uncertainty around AD/CVD Tariffs

- Low volume of wind capacity possibly due to limited siting availability in Indiana and uncertainty around PTC
- Capacity volumes help to inform resource build constraints included in the IRP planning model (EnCompass)





Commodity Forecasts

Erik Miller, Manager, Resource Planning, AES Indiana

2022 IRP



IRP Commodity Price Updates

- AES Indiana initially used Horizon Energy Fall 2021 commodity price outlook for gas and coal to inform \rightarrow the custom fundamental power price studies performed by Horizon Energy.
- However gas, coal and power prices have increased over the past few months \rightarrow
 - In response to stakeholder comment and in order to ensure reasonable forecasts are included in this \rightarrow IRP – AES Indiana has had Horizon Energy update the custom fundamental power price studies using the Spring gas and coal price outlook. Thus, this IRP reflects the recent upward trend in gas, coal and power prices. The following commodity review slides reflect this update.



Summary of Scenario Commodity Assumptions

Scenario	Gas	Coal	Power	Capacity	NOx	CO ₂
No Environmental Action – "No Env"	Low	Base	Custom	Base	Base	None
Current Trends (Reference Case) – "Ref"	Base	Base	Custom	Base	Base	Base
Aggressive Environmental – "AE"	High	Base	Custom	Base	High	High
Decarbonized Economy – "Decarb"	Base	Base	Custom	Base	High	None – Clean Energy Mandate



Methodology: Blending Curves

Power prices, gas prices and coal prices are a blend of forward market curves and Fundamental Curves from Horizon Energy.

Blending prices in near-term captures near-term market impacts.





2023 = 40% Horizon Curve; 60% Forward Curve

2024 = 65% Horizon Curve: 35% Forward Curve

2025 = 85% Horizon Curve; 15% Forward Curve

2026 – 2042 = 100% Horizon Curve

2038 2039 2040 2041 2042



Fuel Price Forecasts





Blended Long-term Coal Prices –

2023 – 2025 Blended: Internal Mkt Intelligence,

→ 2026 – 2042: Internal Mkt Intelligence with Horizon Energy Spring Case growth rate for Illinois Basin



Power Price Forecast

Blended Long-term Power Prices – \rightarrow

- 2023 2025 Blended: ICE Power Forward Curves 5/31/2022 and Horizon Energy Custom Fundamental Forecasts \rightarrow
- 2026 2042: Horizon Energy Custom Fundamental Forecasts \rightarrow





Capacity Price Forecast

Long-term Capacity Prices – \rightarrow

2023 – 2042: Cost of New Entry (CONE) captured in all four-seasons based on MISO Seasonal Capacity Construct \rightarrow





NOx Price Forecast

	Seasonal NOx Prices
9000	
8000	
7000	
<u>ခ</u> 6000	
[↓] \$ 5000	Near Term Projections are
uic 4000	Confidential
N 3000	
2000	
1000	
0	
	2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042

 \rightarrow **Base NOx** – forecast held flat at \$1,700/ton from 2029 – 2042

 \rightarrow High NOx – forecast held flat at \$8,500/ton from 2029 – 2042



RTO Reliability Planning: Resource Adequacy & Seasonal Construct

Lynn Hecker, Senior Manager, Resource Adequacy Policy and Analytics, MISO



Break for Lunch

Time	Торіс	Speakers
Afternoon Starting at 12:30 PM	Modeling Reliability Assumptions	Erik Miller
	Reliability Analysis & Reliability Metric	Hisham O
	Portfolio Metrics & Scorecard	Erik Miller
	AES Indiana Distribution System Planning	Kathy Sto Mike Ruse
	Final Q&A and Next Steps	

5

r, Manager, Resource Planning, AES Indiana

Othman, VP Transmission and Regulatory Consulting, Quanta

r, Manager, Resource Planning, AES Indiana

orm, Vice President, US Smart Grid, AES Indiana s, Senior Manager, T&D Forecasting, AES Indiana



Modeling Reliability Assumptions

Erik Miller, Manager, Resource Planning, AES Indiana



Reliability Overview

As utilities retire and replace baseload generation with intermittent renewable generation, it has become critical to ensure that customers receive energy during critical peak periods or system emergencies.

In this IRP, AES Indiana will measure and compare the reliability of the candidate portfolios in selecting a Preferred Resource Portfolio that provides electricity safely, reliably, efficiently, and cost-effectively.





The Importance of Measuring Reliability

→ Guiding research on reliability

→ MISO's Renewable Integration Impact Assessment (RIIA) – completed Feb 2021

- MISO analysis to understand the bulk electric system needs and risks as intermittent renewable resources increasingly replace baseload resources.
- Analysis finds increasing risk and need for coordinated action as renewables increase to 30% and 50% of the MISO system portfolio.

\rightarrow RIIA's three key areas of focus

- The RIIA analysis suggests three key focus areas for MISO and stakeholders.
- Utilities can consider two of the three within the context of the IRP.

	Торіс	Definition	Planning Responsibility
1	Resource Adequacy	Having sufficient resources to reliably serve peak demand	AES Indiana will address in this IRP
2	Energy Adequacy	Ability to provide energy in all operating hours continuously throughout the year	AES Indiana will address in this IRP
3	Operating Reliability	Ability to withstand unanticipated component losses or disturbances	Joint coordination between AES Indiana and MISO

https://www.misoenergy.org/planning/policy-studies/Renewable-integration-impact-assessment/




Reliability in the IRP

Resource Adequacy: Having sufficient resources to reliably serve load

MISO Seasonal Resource Adequacy Construct

- On November 30, 2021 MISO filed with FERC to include seasonal and accreditation requirements for the MISO \rightarrow **Resource Adequacy Construct.**
- Reason: Ensure resource adequacy across all seasons after significant increase in MaxGen events resulting from the \rightarrow retirement of baseload generation, increased intermittent resources and extreme weather events.
- MISO's proposed filing would require MISO member utilities to meet an unforced capacity requirement in each season \rightarrow as opposed to only Summer (current requirement).
- MISO has proposed these changes begin in the 2023/2024 planning y \rightarrow

Planning Implications

- AES Indiana will model a four-season Resource Adequacy Construct s \rightarrow in 2023/2024 to align with MISO's FERC filing.
- Per MISO guidance, AES Indiana will include these reserve margin \rightarrow targets in the IRP analysis:

ear	Target Seasonal Planning Reserve Margin:						
cur.	PRM% Summer	7.51%					
starting	PRM% Fall	11.82%					
	PRM% Winter	21.35%					
	PRM% Spring	26.27%					



Reliability in the IRP

Resource Adequacy: Having sufficient resources to reliably serve load

Effective Load Carrying Capacity (ELCC) of Wind and Solar

Shifting Peak: As the penetration of wind and solar increases within the MISO footprint, the availability of wind and solar resources during the new high risk period decreases.



^{*}Charts from MISO RIIA Report pp.27 & 29

AES Indiana presented ELCC of wind, solar and storage resources in Public Stakeholder Meeting #2 – also provided in slide appendix of this deck

Planning Implications:

- \rightarrow The planning model will capture the changing availability of wind and solar through the ELCC, i.e. capacity value for wind and solar
- → AES Indiana has consulted with MISO to understand the ELCC value for seasonal planning - Summer, Winter, Spring & Fall







Reliability in the IRP

2 Energy Adequacy: Ability to provide energy in all operating hours continuously throughout the year Production Cost Modeling (8,760)

- As part of the core IRP modeling, AES Indiana will perform a production cost analysis on each candidate portfolio.
- The analysis provides an understanding of economic energy adequacy or how much AES Indiana will rely on the market for sales and purchases.

System Reliability Analysis

- AES Indiana contracted Quanta Energy to perform a System Reliability Analysis as part of the IRP Scorecard evaluation.
- → The analysis looks at eight system metrics with the objective of evaluating how well the candidate portfolios deliver sufficient energy and system stability in every hour.
- Quanta Energy will review the methodology for the System Reliability Analysis in the slides that follow.

2022 IRP



Reliability Analysis

Hisham Othman, VP Transmission and Regulatory Consulting, Quanta

2022 IRP





ECHNOLOGY



Essential Reliability Services



2022 IRP

Power systems rely on several reliability services to \rightarrow operate and deliver expected services. Some have traditionally been assumed to be provided by the supply resources, while others are procured by the market. As the resource portfolio changes, the associated essential reliability services should be assessed and secured.

NERC (2022 Summer Reliability Assessment – \rightarrow MISO):

Midcontinent ISO (MISO) faces a capacity shortfall \rightarrow in its North and Central areas, resulting in high risk of energy emergencies during peak summer conditions.

More extreme temperatures, higher generation \rightarrow outages, or low wind conditions expose the MISO North and Central areas to higher risk of temporary operatorinitiated load shedding to maintain system reliability.

PJM (Grid of the Future - May 2022): \rightarrow

A proliferation of IBRs can significantly impact reactive control, stability, short-circuit current, inertia and frequency control – all critical dimensions of future grid planning.



OUANTA TECHNOLOGY



Year

Resource Reliability Attributes

→ Resources have many attributes aside from energy and capacity that are critical to reliable operation.

- Selecting a portfolio with the right attributes is crucial to ensure reliability and resilience.
- → Portfolio evaluation should account for their reliability attributes.
- System needs for reliability attributes increases with higher levels of inverter-based resources (IBRs).



Reliability and Resilience Attributes/Metrics:

- → Dispatchability
- → Predictability

 \rightarrow

- Dependability (e.g., Supply Resilience, firmness)
- → Performance Duration Limits
- → Flexibility (e.g., ramping speed, operating range)
- → Intermittency (e.g., intra-hour and multi-hour ramping)
- → Dynamic VAR support
- → Energy Profile (e.g., capacity value / ELCC)
- → Inertial Response
- Primary Frequency Response
- → Minimum Short Circuit Ratio
- Locational Characteristics (e.g., deliverability, resilience to grid outages)
- Blackstart and system restoration support
- → Harmonics





Assuring System Reliability – Traditional Approach

 Traditional planning ensures provision of sufficient generation and transmission capacity, based on:

- → Centralized synchronous generation
- Dispatchable resources
- → Predictable flow patterns
- Excludes fuel constraints
- → Few operating snapshots
- → Separate T and D planning
- → However, with increasing retirements and dependance on solar/wind/storage resources, distributed and utility-scale, this planning paradigm is not sufficient to assure operational reliability.







Assuring System Reliability – Evolving Approaches

→ Traditional planning methods are evolving:

- Resource Adequacy: Seasonal Construct & Effective Load Carrying Capability (ELCC)
- Time-series transmission security (8760 hours)
- Stochastic production cost simulations (renewable/load profiles)
- Integrated T&D planning
- Scenario planning approaches to address increased uncertainty

→ More analysis is required - Essential Reliability Services:

- → 1. Energy Adequacy
- → 2. Operational Flexibility and Frequency Support
- → 3. Short Circuit Strength Requirement
- \rightarrow 4. Power Quality (Flicker)
- → 5. Blackstart
- → 6. Dynamic VAR Deliverability
- 7. Dispatchability and Automatic Generation Control
- → 8. Predictability and Firmness of Supply
- → 9. Geographic Location Relative to Load



T E C H N O L O G Y

Reliability Assessment & Portfolio Eval. Methodology

Review & Update Reliability **Metrics**

	Criteria	Description	Rationale
Ī		Resource has the ability to be started without support from the wider system or is designed to remain energized without connection to the remainder of the system, with the ability to energize a bus, supply real and reactive power, frequency and voltage control	In the event of a black out condition, Must have a blackstart plan to restore its local electric system. The plan can either rely on ISCIRTO to energize a cranking path or on internal resources within the service territory.
		Resources are able to meet the energy and capacity duration requirements. Portfolio resources are able to supply the energy demand of customers during MISO's emergency max gen events, and also to supply the energy needs of critical loads during islanded operation events.	Must have long duration resources to serve the needs of its customers during emergency and islanded operation events.
	3 Dispatchability and Automatic Generation Control	The unit will respond to directives from system operators regarding its status, output, and timing. The unit has the ability to be placed on Automatic Generation Control (AGC) allowing its output to be ramped up or down automatically to respond immediately to changes on the system.	ISOIRTO provides dispatch signals under normal conditions, but utility requires AGC attributes under emergency restoration procedures or other operational considerations
	4 Operational Flexibility and Frequency Support	Ability to provide inertial energy reservoir or a sink to stabilize the system. The resource can adjust its output to provide frequency support or stabilization in response to frequency deviations with a droop of 5% or better	ISO/RTO provides market construct under normal conditions, but preferable that utility possess the ability to maintain operation during under-frequency-conditions in emergencies
		The resource can be used to deliver VARs out onto the system or absorb excess VARs and so can be used to control system robage under steady- state and dynamic tronsing to the resource can provide dynamic reactive capability (VARs) even when not producing energy. The resource must have Automic volgar englider (VAR) capability. The resource factor of the capability ranging from 0.85 legging (producing) to 0.95 leading (absorbing) power factor.	Must retain resources electrically close to load centers to provide this attribute in accordance with NERC and IEEE Standards
	6 Geographic Location Relative to Load	The resource will be located in utility footprint (electric Transmission Operator Area) near existing 138/4/ pr 348/4 facilities and is not restricted by fuel infrantacture. The resources can be interconnected at 138/4/or 348/4/. Prefered locations are ones that have multiple power evacuation/deliverability paths and are clube to major tack enteries.	ISORTO requires location appoint yearourse and non an LMP market to provide locational energy signals, under emergency voltation procedures, a backtart prin reliant on external resources would create agrificant fail. Location provides economic value in the form of reduced losses, congestion, cutalitenent risk, and address and capacity requirements. Additionally, how making to prepared, resources that are interconnected to buses with multiple power evolution paths and bose to load creates are more realisant of transmission system outgage and provide batter assistance in the backtariant entrotation processor.
	7 Predictability and Firmness of Supply	Ability to predict/forecast the output of resources and to counteract forecast errors.	Energy is scheduled with ISORTO in the day-ahead houty market and in the real-time 5-minute market. Deviations from these schedules have financial consequences and thus the ability to accurately forecast the output of a resource up to 38 hours ahead of time for the day-ahead market and 30 minutes for the real time market is advertageoux.
	8 Short Circuit Strengtl Requirement	Ensure the strength of the system to enable the stable integration of all inverter-based resources (IBRs) within a portfolio.	The referement of synchronous generators within utility footprint and also within ISO/RTO and replacements with increasing levels of investr-based resources will lower the short circuit strength of the system. Resources then can operate a lower levels of SCR and those that provide higher short circuit current provide a better future proofing without the need for expensive mitigation measures.

Assemble Data and Configure Analysis Tools

- **Existing Resources**
- **IRP** Portfolios
- Grid Models
- Solar & Wind Profiles
- Load Profile
- Transfer Capability with Outside



- 9. Geographic Location

2022 IRP

Indicative Scope of Reliability Studies

	Reliability Study Area	Normal (50/50, Connected)	Max- (90/10, Limit
-	Resource Adequacy	X (also 90/10)	
-	Energy Adequacy	X (8760)	
-	Transmission Reliability / Deliverability / Interconnections	Х	
1	Energy Adequacy		Х
2	Operational Flexibility and Frequency Support	Х	
3	Short Circuit Strength Requirement	Х	
4	Power Quality (Flicker)	Х	
5	Blackstart		
6	Dynamic VAR Deliverability	Х	
7	Dispatchability and Automatic Generation Control	Х	
8	Predictability and Firmness of Supply	Х	
9	Geographic Location Relative to Load	Х	



→ Typically, Part of IRP Portfolio Design

Additional Reliability
 Analysis





Reliability Metrics (1/2)

	Metric	Description	
1	Energy Adequacy	Resources are able to meet the energy and capacity duration requirements. Portfolio resources are able to supply the energy demand of customers during normal and emergency max gen events, and also to supply the energy needs of critical loads during islanded operation events.	Utility emer
2	Operational Flexibility and Frequency Support	Ability to provide inertial energy reservoir or a sink to stabilize the system. Additionally, resources can adjust their output to provide frequency support or stabilization in response to frequency deviations with a droop of 5% or better.	Regio time prefe unde
3	Short Circuit Strength Requirement	Ensure the strength of the system to enable the stable integration of all inverter-based resources (IBRs) within a portfolio.	The real increal system that p need
4	Power Quality (Flicker)	The "stiffness of the grid" affect the sensitivity of grid voltages to the intermittency of renewable resources. Ensuring the grid can deliver power quality in accordance with IEEE standards is essential.	Retire increa unles
5	Blackstart	Ensure that resources have the ability to be started without support from the wider system or are designed to remain energized without connection to the remainder of the system, with the ability to energize a bus, supply real and reactive power, frequency and voltage control	In the electr start
6	Dynamic VAR Support	Customer equipment driven by induction motors (e.g., air conditioning or factories) requires dynamic reactive power after a grid fault to avoid stalling. The ability of portfolio resources to provide this service depends on their closeness to the load centers.	Utility accor

Rationale

y must have long duration resources to serve the needs of its customers during gency and islanded operation events.

onal markets and/or control centers balance supply and demand under different frames according to prevailing market construct under normal conditions, but erable that local control centers possess the ability to maintain operation during er-frequency conditions in emergencies.

retirement of synchronous generators within utility footprint and replacements with asing levels of inverter-based resources will lower the short circuit strength of the m. Resources that can operate at lower levels of short circuit ratio (SCR) and those provide higher short circuit current provide a better future proofing without the for expensive mitigation measures.

ement of large thermal generation plants lower the strength of the grid and ases its susceptibility to voltage flicker due to intermittency of renewable resources, so properly assessed and mitigated.

e event of a black out condition, utility must have a blackstart plan to restore its local ric system. The plan should demonstrate the ability to energize a cranking path to large flexible resources with sufficient energy reservoir.

y must retain resources electrically close to load centers to provide this attribute in dance with NERC and IEEE Standards





Reliability Metrics (2/2)

	Metric	Description	
7	Dispatchability and Automatic Generation Control	Resources should respond to directives from system operators regarding their status, output, and timing. Resources that can be ramped up and down automatically to respond immediately to changes in the system contribute more to reliability than resources which can be ramped only up or only down, and those in turn are better than ones that cannot be ramped.	Abilit quali dispa or ot
8	Predictability and Firmness of Supply	Ability to predict/forecast the output of resources and to counteract forecast errors.	The a minin is sch minu the a for th
9	Geographic Location Relative to Load (Resilience)	Ensure the ability to have redundant power evacuation or deliverability paths from resources. Preferrable to locate resources at substations with easy access to multiple high voltage paths, unrestricted fuel supply infrastructure, and close to major load centers.	Locat risk, resou those prov

Rationale

ity to control frequency is paramount to stability of the electric system and the lity of power delivered to customers. Control centers (regional or local) provide atch signals under normal conditions, and under emergency restoration procedures ther operational considerations.

ability to predict resource output from a day-ahead to real-time is advantageous to imize the need for spinning reserves. In places with an active energy market, energy heduled with the market in the day-ahead hourly market and in the real-time 5ute market. Deviations from these schedules have financial consequences and thus ability to accurately forecast the output of a resource up to 38 hours ahead of time the day-ahead market and 30 minutes for the real time market is advantageous.

ation provides economic value in the form of reduced losses, congestion, curtailment and address local capacity requirements. Additionally, from a reliability perspective, burces that are interconnected to buses with multiple power evacuation paths and se close to load centers are more resilient to transmission system outages and vide better assistance in the blackstart restoration process.





Sample Analysis

The following are illustrative sample analyses, not related to AES-Indiana system or portfolios.





(1) Energy Adequacy during Market Emergency Events

Illustrative sample analyses, not related to AES-Indiana system or portfolios

→ Example: Portfolio P1 (using 50/50 Load Forecast)



The analysis shows that a sample Portfolio P1 is energy long and relies on energy purchases only 136 hours in a year \rightarrow (i.e., 2% of time) to meet its energy needs with a maximum purchase of 475MW, while it has excess energy to potentially sell 6,658 hours in a year (i.e., 76% of time).



OUANTA F E C H N O L O G Y



(1) Energy Adequacy – Scenario & Stochastic Study Approaches

Illustrative sample analyses, not related to AES-Indiana system or portfolios



(3) Importance and Impacts of Short Circuit Strength

Illustrative sample analyses, not related to AES-Indiana system or portfolios

→ Importance:

- Short Circuit MVA (SCMVA) is a measure of the strength of a bus in a system. The larger SCMVA, the stronger the bus. That indicates the bus is close to large voltage sources, and thus it will take large injections of real or reactive power to change its voltage. SCMVA changes depending on grid configuration and on-line resources. The lowest SCMVA is usually utilized for engineering calculations.
- When IBRs are interconnected to a system, it is desirable to maintain a stable bus voltage irrespective of the fluctuation of the IBR's output. Similarly, grid following (GFL) inverters rely on stable voltage and frequency to synchronize to the grid using their phase locked loops (PLL).
- The maximum allowable size of IBR desiring to interconnect to a bus is limited to a fraction of the bus's short circuit MVA, say less than 20-50%. This is expressed as Short Circuit Ratio (SCR) of the ratio of SCMVA to the rating of the IBR. This will translate to SCR of 2-5.
- When multiple IBRs are interconnected at a close electrical distance, their controls interact, and the impact of system voltages will increase. Thus, a modified measure was adopted to be ESCR (Effective SCR) to capture this interaction.

→ Impact:

When conventional power plants with synchronous generators are retired and/or the system tie-lines are severed, the short circuit currents will dramatically decline. IBRs are not a substitute because their short circuit contribution is limited, and also the phase of their current (real) is not aligned with typical short circuit currents (reactive).

Declining SCMVA and increasing IBRs will eventually violate the ESCR limits, requiring either a prohibition on additional IBR interconnections, or provisioning additional mitigation measures.

Mitigations can come in the form of optimal placement of IBRs to avoid clustering them in a manner that violates the ESCR limits, provisioning synchronous condensers, or requiring inverters to have grid-forming (GFM) capability.

(3) Short Circuit Strength: Equivalent Short Circuit Ratio

Illustrative sample analyses, not related to AES-Indiana system or portfolios

SCR is not a good indicator under high IBR penetration

Synchronous Condensers (SC) can increase short circuit strength

*Inverter Based Resource (IBR)

$$ESCR_i = \frac{S_i}{P_i + \sum_j IF_{ji} * P_j}$$

where $IF_{ji} = \frac{\Delta V_j}{\Delta V_i}$ is the interaction factor between buses i and j and can be calculated using Zbus.

Pi and Pj are the inverter ratings at buses i and j respectively, while Si is the minimum short circuit MVA at bus i.

Optimal Placement of IBRs* from Short Circuit perspective to avoid ESCR limitation:

$$\begin{array}{ll} MAXIMIZE \quad \sum_{j \in buses} P_j \\ \mbox{Subject to} \quad \sum_j IF_{ji} * P_j &\leq \frac{S_i}{ESCR \ Threshold} \\ P_j &\geq 0 \end{array}$$

(5) Black Start Studies – Key Considerations

Illustrative sample analyses, not related to AES-Indiana system or portfolios

\rightarrow	Modeling:	Resul
	 Sequencing of Essential Motors (Startup and Shutdown) Modeling of Induction Motors (dynamic characteristics) Protection system Modeling Fast bus transfer Battery System Transformers 	$ \rightarrow $ Inve $ \rightarrow $ BES $ \rightarrow $ BES $ \rightarrow $ Trai $ \rightarrow $ Pro
\rightarrow	Analysis: → Transient and steady-state simulations	
÷	 Considerations: Inverter short-circuit current limitations Soft-start techniques Dynamic interactions Frequency and Voltage control Protective relay operation in view of limited short circuit currents 	BESS 10 MW/12 N

54

Its:

- erter Size (MVA, PF)
- SS Size (MW, MWh)
- SS control and protection settings
- ansformer tap settings
- tection setting adjustments

Q U A N T A T E C H N O L O G Y

PV Plant 550 MW

(8) Resource Predictability & Firmness: Variability Analysis

Illustrative sample analyses, not related to AES-Indiana system or portfolios

- The hourly profiles of Solar, Wind, and Solar plus Storage are characterized across two dimensions:
 - Forecast Error
 - Alignment with Load
- This characterization is utilized in subsequent evaluation of portfolios of these resources.

Forecast Error%	Solar	Wind	S+S
Standard Deviation	9.9%	7.5%	9.2%
min Error	-39%	-42%	-33%
max Error	39%	48%	33%
90% Percentile	19%	8%	12%

(8) Resource Predictability & Firmness: Net Load Power Ramps

Illustrative sample analyses, not related to AES-Indiana system or portfolios

Significant change in Net Load profile from a conventional shape in 2020 to a "Duck Curve" in 2030 \rightarrow

QUANTA TECHNOLOGY

(8) Resource Predictability & Firmness: Net Load Power Ramps

Illustrative sample analyses, not related to AES-Indiana system or portfolios

> Portfolio P3 (without Storage/Peakers Dispatch)

Year	Ramp UP	Ramp DN	Ramp Rate UP	Ramp Rate DN
2021	1,238	-966	322	-334
2022	929	-733	319	-332
2023	1,309	-1,101	431	-415
2024	1,308	-1,101	430	-414
2025	1,307	-1,101	430	-414
2026	1,490	-1,255	468	-414
2027	1,490	-1,255	468	-414
2028	1,490	-1,255	468	-414
2029	1,490	-1,255	468	-414
2030	1,490	-1,255	468	-413
2031	1,489	-1,255	467	-413
2032	1,489	-1,255	467	-413
2033	1,489	-1,255	467	-413
2034	1,489	-1,255	467	-413
2035	1,489	-1,255	467	-413
2036	1,489	-1,255	467	-413

Ramping Category	20 MW 9	20 %Peak	Increased MW 2030 vs. 2020		
1-hr Up	306	13.1%	468	20.5%	162
1-hr Down	-222	9.5%	-413	18.1%	191
Day Up	1,044	44.6%	1,489	65.2%	445
Day Down	-852	36.4%	-1,255	54.9%	403

57

(8) Resource Predictability & Firmness: Net Load Power Ramps (Y2030 vs Y2020)

Illustrative sample analyses, not related to AES-Indiana system or portfolios

Portfolio	Solar	BTM Solar	Wind	Solar + Storage	Day Ramping Up (MW)	Day Ramping Down (MW)	1hr Ramping Up (MW)	1hr Ramping Down (MW)	Peaker/ Storage (MW)	Forecast Error 90th Percentile	Excess Ramping Capability (MW)
2020	22	270	103	87	1,013	-860	243	-299	465	89	375
P1	1,225	359	103	224	1,851	-1,557	506	-446	605	342	262
P2	1,725	359	103	224	1,988	-1,557	591	-455	605	434	171
P3	2,225	359	103	224	1,988	-1,557	676	-682	605	526	79
P4	2,725	359	103	224	2,258	-1,827	801	-817	1,225	618	607
P5	3,225	359	103	224	2,258	-1,827	872	-817	1,225	710	515
P6	3,975	359	103	224	2,258	-1,827	936	-817	1,225	848	377
P7	4,225	359	103	224	2,438	-2,007	1,026	-907	2,365	894	1,471
P8	4,225	359	103	224	2,438	-2,007	1,026	-907	2,365	894	1,471
P9	4,225	359	103	224	2,438	-2,007	1,026	-907	2,365	894	1,471

- Balancing areas are required per BAL-003 to comply with CPS1 and CPS2. CPS2 is a monthly standard intended to limit unscheduled flows. It requires compliance \rightarrow better than 90% that the average ACE will remain below a threshold over all 10-min intervals in the month. For a balancing area with a peak load of 2945 MW, the threshold is around 89MW.
- A small percentage (~20%) of the hourly ramps in Net Load can be forecasted an hour ahead using a persistent forecast method and thus can scheduled in the real \rightarrow time market or accounted for in the dispatch algorithm, Example, Portfolio P5 has total 1-hour ramp up of 872 MW while its forecast error is 710 MW, or 81%.
- The unforecasted changes in renewable resource outputs should be mitigated using fast ramping resources. \rightarrow
- Portfolios will be ranked according to their ability to mitigate unscheduled flow. \rightarrow

Summary – Next Steps

	Reliability Study Area	Normal (50/50, Connected)	Max-((90/10, I Limite
1	Energy Adequacy		Х
2	Operational Flexibility and Frequency Support	Х	
3	Short Circuit Strength Requirement	Х	
4	Power Quality (Flicker)	Х	
5	Blackstart		
6	Dynamic VAR Deliverability	Х	
7	Dispatchability and Automatic Generation Control	Х	
8	Predictability and Firmness of Supply	Х	
9	Geographic Location Relative to Load	Х	

Portfolio Score

Thank you

(919) 334-3000

quanta-technology.com

info@quanta-technology.com

LinkedIn.com/company/quanta-technology

Join us on LinkedIn and visit our website for live Knowledge Sharing Webinars and more!

Portfolio Metrics & Scorecard

Erik Miller, Manager, Resource Planning, AES Indiana

Guidance for the IRP Scorecard Framework

21st Century Policy Development Task Force – IURC/SUFG/LBNL/Indiana University – Ongoing

House Enrolled Act 1278 (2019) directed the Indiana Utility Regulatory Commission (IURC) to conduct a comprehensive study of the statewide impacts, both near and long term, of

- (1) Transitions in the fuel sources and other resources used to generate electricity by electric utilities; and \rightarrow
- (2) New and emerging technologies for the generation of electricity, including the potential impact of such \rightarrow technologies on local grids or distribution infrastructure; on electric generation capacity, system reliability, system resilience, and the cost of electric service for consumers. In conducting the study required, the Commission shall consider the likely timelines for the transitions in fuel sources and other resources described in subdivision (1) and for the implementation of new and emerging technologies described in subdivision (2).

http://iga.in.gov/legislative/2020/committees/21st century energy policy development task force

Categorical Framework for AES Indiana's IRP Scorecard

21st Century Energy Policy Development Task Force Framework #1: The Five Attributes or "Pillars" of Electric Utility Service

- Reliability 1)
- Resilience 2)
- Stability 3)
- Affordability 4)
- **Environmental Sustainability** 5)

Additional Scorecard Categories

- **Risks & Opportunities** 6)
- Social & Economic Impact 7)

Each category has one or more metrics that quantitively measure portfolio performance.

IRP Scorecard for Portfolio Evaluation

The Current Trends (Reference Case) will be evaluated using the Scorecard below: \rightarrow

	Affordability	Environmental Sustainability				Reliability, Stability & Resiliency	Risk & Opportunity					Economic Impact		
	20-yr PVRR	CO₂ Emissions	SO₂ Emissions	NO _x Emissions	Other Emissions	Reliability Sco <i>r</i> e	Environmental Policy Opportunity	Environmental Policy Risk	Cost Opportunity	Cost Risk	Market Exposu <i>r</i> e	Renewable Capital Cost Risk	Employees (+/-)	Property Taxes
	Present Value of Revenue Requirements	Total portfolio CO2 Emissions	Total portfolio SO2 Emissions	Total portfolio NOx Emissions	Water Use & Coal Ash	Composite score from Reliability Analysis	Lowest PVRR across policy scenarios	Highest PVRR across policy scenarios	Mean - P5	P95 - Mean	20-year avg sales + purchases	TBD	Total # of AES IN generation employees	Total amount of property tax paid from AES IN assets
1)														
2)			Ca		ation	e fo	r ogr	h cr	orina	n mo	tric v	vill		
3)			0a			13 10			Onit	JIIIC				
4)			he	incl	DUID	d to	com	nlote	the	Sco	roca	rd		
5)					uuc		COIII	picic				U		
6)														

→ Strategies

- → 1. No Early Retirement
- \rightarrow 2. Pete Refuel to 100% Natural Gas (est. 2025)
- 3. One Pete Unit Retires in 2026
- \rightarrow 4. Both Pete Units Retire in 2026 & 2028
- → 5. "Clean Energy Strategy" Both Pete Units Retire and replaced with Renewables in 2026 & 2028
- → 6. Encompass Optimization without Predefined Strategy

2022 IRP

A Preferred Resource Portfolio will be selected after evaluation of the Scorecard results

Affordability Metric

- **20-year Present Value of the Revenue Requirements (PVRR)** \rightarrow
 - \rightarrow Calculation:

Market Revenues

- → MISO Energy Revenue
- → Net Capacity Revenue

Environmental Sustainability Metrics

CO2 Emissions \rightarrow

Calculation: Total portfolio short tons of CO2

SO2 Emissions \rightarrow

 \rightarrow Calculation: Total portfolio short tons of SO2

NOx Emissions \rightarrow

Calculation: Total portfolio short tons of NOx

Other Emissions & Byproducts – Water Use, Coal Ash \rightarrow

Calculation Example: Portfolio receives a 0 if it includes coal past 2028 and 1 if it does not

Note: Portfolios that score poorly on Environmental Sustainability also present higher cost risk to customers in the form of environmental compliance for pollutants and biproducts.

Reliability, Resilience and Stability Metric

Reliability Metric \rightarrow

- Calculated through Quanta's Analysis
- \rightarrow Composite score of reliability, resilience and stability metrics that include:
 - → Energy Adequacy
 - Operational Flexibility and Frequency Support
 - → Short Circuit Strength Requirement
 - \rightarrow Power Quality (Flicker)
 - → Blackstart
 - \rightarrow Dynamic VAR Deliverability
 - Dispatchability and Automatic Generation Control \rightarrow
 - → Predictability and Firmness of Supply
 - → Geographic Location Relative to Load

Risk & Opportunity Metrics

Environmental Policy Sensitivity Analysis

- \rightarrow AES Indiana will model environmental policy sensitivities on the optimized capacity expansion results from the Current Trends (Reference Case) to understand how the PVRR may change in a very different policy future.
- \rightarrow The results will help to answer the question "How would the optimized Reference Case perform in a very different policy future, e.g. Reference Case in a Decarbonized Economy future?"

gressive onmental	Decarbonzied Econoi	my
e Optir	nized	
ence C	Case	
s/Gene	eration	
ough th	ne other	
enario	S	

Metrics

For each strategy, the analysis will capture:

- \rightarrow Risk potential using the highest scenario **PVRR** for each strategy
- \rightarrow Opportunity potential using the **lowest** scenario PVRR for each strategy

Risk & Opportunity Metrics

→ Cost Risk & Opportunity Metric **Stochastic Analysis**

- Stochastic analysis will be performed to understand the risks and opportunities to each Strategy from:
 - \rightarrow Gas price volatility
 - → Energy price volatility
 - \rightarrow Load volatility
 - → Renewable generation volatility
- → Each variable will be varied across a full stochastic distribution using 100 iterations of potential outcomes.
- → Metrics to measure cost risks and cost opportunities will include:
 - → Risk Metric = P95 Mean
 - \rightarrow Opportunity Metric = Mean P5

Risk & Opportunity Metrics

Market Exposure \rightarrow

70

- \rightarrow When a utility generates energy in excess of load, the energy is sold into the market. Conversely, when a utility is short energy, the utility must purchase energy to supply load.
- \rightarrow Generally, the less sales and purchases in a portfolio, the less risky the portfolio or strategy is for the customer because the sales and purchases aren't exposed to price volatility in the market.
- \rightarrow For example what if prices drop to zero when wind is available in excess of load or what if prices spike when energy purchases are needed to meet load?

Market Exposure Metric

To estimate the risk for each strategy, AES Indiana will calculate the average of the absolute value of the annual sales and purchases and sum those over the 20-yr period.

Economic Impact Metrics

Number of AES Indiana Generation Employees \rightarrow

- \rightarrow Unit retirements and replacement generation mixes across the Generation Strategies will look very different. For example, the IRP analysis will compare a strategy that leaves Petersburg in operation through the entire period to a strategy that retires and replaces Petersburg with all renewables in the nearterm.
- \rightarrow These different strategies will have very different impacts on AES Indiana employees.
- To compare this impact, AES Indiana will include a metric that estimates the total number of AES Indiana \rightarrow generation employees for each strategy.

Total amount of property taxes paid for AES Indiana Generation Assets \rightarrow

- \rightarrow Similarly, unit retirements and replacement generation mixes across the Generation Strategies will also have very different impacts on local property taxes.
- \rightarrow To compare this impact, AES Indiana will include a metric that estimates the total property taxes paid for each generation strategy.

IRP Scorecard for Portfolio Evaluation

The Current Trends (Reference Case) will be evaluated using the Scorecard below: \rightarrow

	Affordability	lity Environmental Sustainability				Reliability, Stability & Resiliency	Risk & Opportunity					Economic Impact		
	20-yr PVRR	CO ₂ Emissions	SO ₂ Emissions	NO _X Emissions	Other Emissions	Reliability Score	Environment al Policy Opportunity	Environment al Policy Risk	Cost Opportunity	Cost Risk	Market Exposure	Renewable Capital Cost Risk	Employees (+/-)	Property Taxes
	Present Value of Revenue Requirements	Total portfolio CO2 Emissions	Total portfolio SO2 Emissions	Total portfolio NOx Emissions	Water Use & Coal Ash	Composite score from Reliability Analysis	Lowest PVRR across policy scenarios	Highest PVRR across policy scenarios	Mean - P5	P95 - Mean	20-year avg sales + purchases	TBD	Total # of AES IN generation employees	Total amount of property tax paid from AES IN assets
1)														
2)				مام	Intic		foro	ooh			motr			
3)				alcu	nauc	JIIS		acri	2001	шуı	neu			
4)			h	o in	ماريط			mnl	oto t	ho C	oorc	oor		
5)			D	еш	CIUU	eui		IIIPI			CUIE	car		
6)														

Strategies \rightarrow

- → 1. No Early Retirement
- \rightarrow 2. Pete Refuel to 100% Natural Gas (est. 2025)
- \rightarrow 3. One Pete Unit Retires in 2026
- \rightarrow 4. Both Pete Units Retire in 2026 & 2028
- → 5. "Clean Energy Strategy" Both Pete Units Retire and replaced with Renewables in 2026 & 2028
- → 6. Encompass Optimization without Predefined Strategy 2022 IRP

A Preferred Resource Portfolio will be selected after evaluation of the Scorecard results

AES Indiana Distribution System Planning

Kathy Storm, Vice President, US Smart Grid, AES Indiana Mike Russ, Senior Manager, T&D Planning & Forecasting, AES Indiana



Agenda

- Building the AES Grid of the Future
- → Smart Grid Vision
- Integration of Resource & System Planning
- Demand Forecasting & Multi-Scenario Planning
- Distribution Planning Tools
- Distributed Energy Resources (DERs)
- → Electric Vehicles
- → FERC Order 2222
- Onclusion



Building the AES of the Future







An interactive two-way intelligent platform

Electric Vehicle

Wind Power Plant



Smart Grid Vision

- AES Smart Grid creates a compelling and competitive advantage in the clean energy market to build value for AES customers, employees, and shareholders.
- Vision Customers are the center of everything we do. Together, we drive innovation and new value while \rightarrow delivering a positive customer experience.



Engage with our customers through a more personalized experience and build a trusted

Build a distribution system that attracts new customers through innovative clean energy

Transform to a customer-focused, data-driven culture that empowers our people to reimaging

Transform our energy system and services to improve resiliency and seamlessly integrate renewables, distributed generation, energy storage and electrification technologies.



Operations Future State Vision



DER Dispatch DER Forecast DER Monitoring and Control DER Market Interface DER Scheduling DER Estimation Storm Management Outage Analysis Call Management Planned Outage Management Outage Reporting Crew Management

Distribution Network Operating Model

Network Model F

 \longleftrightarrow

TopologyGraphicalProcessingUser Interface

DER Modeling

Operations Technology Platform

SCADA, Alarming, Trending, Visualization, Historian, Load Shed, Study Mode

Real-Time/DER Communication



Substation

Devices

Feeder

Devices

Dispatchable

Generators



EVs and

Charging

Stations



Wind



DR and Smart

DR and Sma Appliance

77

ŧ

Switch Order Management Volt/Var Optimization Distribution Power Flow Feeder Reconfiguration Fault Location Restoration Short Circuit Analysis

DER ng Aggregation







 \longleftrightarrow

rt Energy Storage Solar Microgrids Pv DMS – Distribution Management System
OMS – Outage Management System
DERMS – Distributed Energy Resources Management System
AMI – Advance Metering Infrastructure

Mobile Application

Real Time Map View

Job Management

Damage Assessment

Field Switching

Off-Line Operation

GPS Integration



Connected Planning & Operations

Advanced Suite of Planning & Operational Tools



- Collecting all technical data at the front of the \rightarrow interconnection process and translating it directly to standardized forecasting and modeling tools in planning & operations.
- Leveraging Smart Grid investments for better forecasting and model inputs.
- Devices are utilized for better operational visibility & \rightarrow orchestration leading to better customer outcomes.

Smart Grid Devices

AMI, Smart Reclosers, Sensors, SCADA/Pi, Weather data utilized to build better modes and provide an operations technology platform that enhances planning and operations



AMI – Smart Meters Substation Devices

Grid Upgrades

Develop solutions for grid interconnection, capacity, and reliability needs



DER Dispatch DER Forecast DER Monitoring and Control DER Market Interface DER Scheduling DER Estimation

Storm Management Outage Analysis Call Management Planned Outage Management Outage Reporting Crew Management

Switch Order Management **Volt/Var Optimization Distribution Power Flow Feeder Reconfiguration Fault Location Restoration Short Circuit Analysis**

DMS – Distribution Management System **OMS** – Outage Management System **DERMS** – Distributed Energy Resources Management System **AMI** – Advance Metering Infrastructure



Aligned Planning at AES Indiana

- Aligned resource, distribution, transmission, reliability teams and processes for integrated solutions
- → AES Indiana has moved to combine the traditional T&D planning roles under one department that works closely with our reliability teams to develop holistic solutions.
 - Processes are mapped such that resource planning and T&D forecasting work off same assumptions for top-down and bottom-up load forecasting.
- T&D system forecasting, modeling, and analysis built off common assumptions
- Focus on building the foundation with an aligned organization, smart grid devices, demand forecasting and network modeling that will enable AES to effectively plan for multiple scenarios and test non-traditional solutions.





T&D Demand Forecasting Future State Process

Connecting Smart Grid Devices to Future State, Multi-Scenario Planning Models



System Modeling & Analysis Output

Multi-Scenario Development

- \rightarrow Short, Mid, Long-Term **Scenarios**
- \rightarrow Low, Medium, **High Growth** Rates
- \rightarrow DER/EV **Sensitivities**
- \rightarrow Weather **Sensitivities**



CYME Power Engineering Software

Power Flow Models

- \rightarrow CYME
- \rightarrow PSSE
- \rightarrow Export to GIS for Visualization
- → Aligned Study Models for T&D in Indiana + Ohio



Load Flow Analysis for Distribution Systems

- AES uses CYME for distribution system modeling and analysis
- CYME takes advanced forecasts/scenarios from our demand forecasting tool (LoadSEER) to develop power flow models of the system
 - These forecasts and scenarios will be analyzed to forecast future system capacity, redundancy, and voltage needs
 - Contingency & Scenario Planning present new challenges for distribution since multiple circuit configurations are possible with smart grid devices
- Time series for load profiles
 - Will become more important over time with changing load profiles due to DER, EV charging, etc. being major load modifiers
- Advanced Capabilities Under Development
 - Reliability Assessment
 - Recloser Placement Module
 - Time Series
 - Hosting Capacity



Example of a Battery Energy Storage System (BESS) (a Non-Wire Alternative)





Distributed Energy Resources

- Growing DERs on the system as result of lower costs, desire for renewable resources
- With an influx of DER on the system, DER will shift from a \rightarrow load modifier to a potential resource, solution to grid capacity issues, solution to voltage control, and other applications
- This presents opportunities for distribution system planning \rightarrow to think differently about capacity planning, voltage control, and utilization of non-traditional resources such as batteries in solution planning
- The advancement of power flow models and network modeling of the distribution systems will allow AES Indiana to study and make future recommendations on how we can extract maximum value to DER connected to the system







Electric Vehicles

Distribution planning considerations for electric vehicles (ev's)

- → Level 1 and 2 charging are generally manageable for capacity planning assuming effective time of use (TOU) charging rates are in place.
- → Level 3 charging is more problematic due to the peak load occurring simultaneously with the grid peak and at much higher magnitudes.
- → Fleet charging requests have been limited but we see the potential for very large loads in this space that may have a major impact on system planning.

Demand forecasting & network modeling

- → AES will account for EV growth by taking the resource planning topdown forecast and utilizing our demand forecasting parcel level EV propensity model to allocate it down to the circuits and feeders.
- → AES will study the multiple scenarios developed around EV charging in our network models to determine if capacity upgrades will be required. In combination with other system needs on a particular circuit, there could be multiple ways to plan for solutions such as traditional asset upgrades, strategic battery placements, optimally placed circuit ties, optimal DER placements, etc.





FERC Order 2222

- **Distributed Energy Resource (DER):** \rightarrow Any resource connected to the distribution system
- **Demand Response (DR):** Any activity used \rightarrow to reduce load for wholesale market
- **DER Aggregation (DERA):** An aggregation of one \rightarrow or more DER/DRs participating together in wholesale markets
- **DER Aggregator:** The market participant for \rightarrow the DERA
- A DERA is a virtual power plant consisting \rightarrow of multiple smaller DER resources connected to the distribution system being offered into the MISO under one bid by an Aggregator

Management System





Importance of FERC Order 2222

- FERC Order No. 2222 enables distributed energy resources (DERs) aggregators to compete in \rightarrow wholesale electric markets such as MISO
- DERs can range from solar to battery storage, demand response, energy efficiency, thermal storage, \rightarrow electric vehicles and their charging equipment. DERs can locate on the distribution system and/or behind a customer meter

Distribution Planning Considerations:

- \rightarrow Distribution Aggregation studies will need to be completed.
- \rightarrow Furthers the need for connected T&D systems, processes, and interconnection portals as DER is integrated into MISO markets.
- → Modernization of interconnection databases for tracking all DERs and their technical specifications.
- \rightarrow Potential for significant increases to DER interconnection study volumes, complexity, and size expected.
- \rightarrow Long-term forecasting of DERs, DERAs, and their performance impacts
- \rightarrow Potential need for distribution energy storage locally to manage the variability on each circuit.

Expedites and further justifies the need to expand smart grid operations & programs (AMI, ADMS, GIS, etc.).

- \rightarrow Basic levels of visibility and monitoring will be required for the continued safe operation of the system.
- \rightarrow Need to perform RTO day ahead and real time market studies with adequate visibility and monitoring.
- \rightarrow Enhancement of distribution system operator and market roles.



Conclusion

Strategic Organizational **Alignment between Resource & T&D** planning

Advanced Demand Forecasting, **Connected top-down** & bottom-up load forecasting



Advanced Modeling & Analysis, utilization of advanced power flow tools

Cutting-Edge Grid Operations, **Utilization of ADMS** to be Grid of the Future



Final Q&A and Next Steps



Public Advisory Meeting



- \rightarrow All meetings will be available for attendance via Teams. Meetings in 2022 may also occur inperson.
- → A Technical Meeting will be held the week preceding each Public Advisory Meeting for stakeholders with nondisclosure agreements. Tech Meeting topics will focus on those anticipated at the next Public Advisory Meeting.
- → Meeting materials can be accessed at <u>www.aesindiana.com/integrated-resource-plan</u>.

Public	Public
Advisory	Advisory
Meeting #4	Meeting #5
August 2022	October 2022



Thank You

2022 IRP



Appendix



Wind Parameters

\rightarrow	Location: Indiana	Wind ELCC
\rightarrow	Annual Capacity Factor: 33 6 – 40 4%	90%
\rightarrow	Source Profile: NREL System	80%
Advisory M	Advisory Model (SAM)	60%
\rightarrow	Project Size: 50 MW ICAP	50%
\rightarrow	Useful Life: 30 years	40%
\rightarrow	Source: Horizons Energy	20%
	Source. Honzons Energy	10%
\rightarrow	Winter ELCC: 20%; Source: MISO RAN	0% 2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042 Wind (Summer)Wind (Winter)



Solar Parameters

- → Location: Petersburg, Indiana
- → Annual Capacity Factor: 24.5%
- → Source Profile: NREL System Advisory Model (SAM)
- → **Project Size:** 25 MW ICAP
- → **Useful Life:** 35 years
- → Summer ELCC (2025): 58.7%; Source: Horizon Energy
- → Winter ELCC: 0%; Source: MISO RAN

Solar ELCC				
100%				
90%				
80%				
70%				
60%				
50%				
40%				
30%				
20%				
10%				
0%	2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042			
	-Solar (Summer) -Solar (Winter)			

*Summer ELCC forecast presented in chart is from the Horizon Custom Reference Case – ELCC forecast will vary by custom scenario



Solar + Storage Parameters

- **Location:** Petersburg, Indiana \rightarrow
- System: DC Coupled Solar + \rightarrow Storage System, Storage charges exclusively from the solar array
- \rightarrow Solar Component: Identical to stand-alone solar (25 MW ICAP)
- Storage Component: 12.5 MW \rightarrow ICAP | 50 MWh
- \rightarrow Synergies: 4.3% reduction in capital costs, 2% improvement of RTE
- Summer ELCC (2025): 100% \rightarrow
- Winter ELCC: 48% \rightarrow

	Hybrid (Solar+Storage) ELCC			
100%				
90%				
80%				
70%				
60%				
50%				
40%				
30%				
20%				
10%				
0%				

*Summer forecast presented in chart above is from the Horizon Custom Reference Case – forecast will vary by custom scenario



IRP Acronyms

Note: A glossary of acronyms with definitions is available at <u>https://www.aesindiana.com/integrated-resource-plan</u>.



IRP Acronyms

- → ACEE: The American Council for an Energy-Efficient Economy
- → AMI: Advanced Metering Infrastructure
- \rightarrow AD: Ad Valorem
- → AD/CVD: Antidumping and Countervailing Duties
- → ADMS: Advanced Distribution Management System
- → BESS: Battery Energy Storage System
- → BNEF: Bloomberg New Energy Finance
- → BTA: Build-Transfer Agreement
- → BTU: British Thermal Unit
- → C&I: Commercial and Industrial
- → CAA: Clean Air Act
- → CAGR: Compound Annual Growth Rate
- → CCGT: Combined Cycle Gas Turbines
- → CCS: Carbon Dioxide Capture and Storage
- → CDD: Cooling Degree Day
- → CIS: Customer Integrated System
- → COD: Commercial Operation Date
- → CONE: Cost of New Entry
- → CP: Coincident Peak

- → CPCN: Certificate of Public Convenien Necessity
- \rightarrow CT: Combustion Turbine
- → CVD: Countervailing Duties
- → CVR: Conservation Voltage Reduction
- → DER: Distributed Energy Resource
- → DERA: Distributed Energy Resource A
- DERMS: Distributed Energy Resource Management System
- → DG: Distributed Generation
- DGPV: Distributed Generation Photovo System
- → DLC: Direct Load Control
- → DOC: U.S. Department of Commerce
- → DOE: U.S. Department of Energy
- → DR: Demand Response
- → DRR: Demand Response Resource
- → DSM: Demand-Side Management
- → DMS: Distribution Management System
- → DSP: Distribution System Planning
- → EE: Energy Efficiency

nce and	\rightarrow	EFORd: Equivalent Forced Outage Rate Demand
	\rightarrow	EIA: Energy Information Administration
	\rightarrow	ELCC: Effective Load Carrying Capability
	\rightarrow	EM&V: Evaluation Measurement and Verification
	\rightarrow	ESCR: Effective Selective Catalytic Reduction System
	\rightarrow	EV: Electric Vehicle
ggregation	\rightarrow	FLOC: Federated Learning of Cohorts
9	\rightarrow	GDP: Gross Domestic Product
	\rightarrow	GFL: Grid-Following System
oltaia	\rightarrow	GIS: Geographic Information System
ollaic	\rightarrow	GT: Gas Turbine
	\rightarrow	HDD: Heating Degree Day
	\rightarrow	HVAC: Heating, Ventilation, and Air Conditioning
	\rightarrow	IAC: Indiana Administrative Code
	\rightarrow	IBR: Inverter-Based Resource
	\rightarrow	IC: Indiana Code
	\rightarrow	ICE: Intercontinental Exchange
n	\rightarrow	ICAP: Installed Capacity
	\rightarrow	IEEE: Institute of Electrical and Electronics Engineers
	\rightarrow	IRP: Integrated Resource Plan



IRP Acronyms

- **ICE:** Internal Combustion Engine \rightarrow
- **IQW:** Income Qualified Weatherization \rightarrow
- **ITC:** Investment Tax Credit \rightarrow
- **IURC:** Indiana Regulatory Commission \rightarrow
- kW: Kilowatt \rightarrow
- kWh: Kilowatt-Hour \rightarrow
- MATS: Mercury and Air Toxics Standards \rightarrow
- MaxGen: Maximum Generation \rightarrow
- MDMS: Meter Data Management System \rightarrow
- MISO: Midcontinent Independent System Operator \rightarrow
- MPS: Market Potential Study \rightarrow
- MW: Megawatt \rightarrow
- NDA: Nondisclosure Agreement \rightarrow
- NOX: Nitrogen Oxides \rightarrow
- NPV: Net Present Value \rightarrow
- NREL: National Renewable Energy Laboratory \rightarrow
- NTG: Net to Gross \rightarrow
- **OMS: Outage Management System** \rightarrow
- PLL: Phase-Locked Loop \rightarrow
- **PPA:** Power Purchase Agreement \rightarrow

- PRA: Planning Resource Auction \rightarrow
- **PSSE:** Power System Simulator for \rightarrow
- PTC: Renewable Electricity Producti \rightarrow
- PRMR: Planning Reserve Margin Re \rightarrow
- PV[.] Photovoltaic \rightarrow
- PVRR: Present Value Revenue Requ \rightarrow
- PY: Planning Year \rightarrow
- **RA:** Resource Adequacy \rightarrow
- RAN: Resource Availability and Nee \rightarrow
- **RAP:** Realistic Achievable Potential \rightarrow
- RCx: Retrocommissioning \rightarrow
- **REC:** Renewable Energy Credit \rightarrow
- **REP: Renewable Energy Production** \rightarrow
- RFP: Request for Proposals \rightarrow
- **RIIA: MISO's Renewable Integration** \rightarrow Assessment
- **RTO: Regional Transmission Organi** \rightarrow
- SAC: MISO's Seasonal Accredited C \rightarrow
- SAE: Small Area Estimation \rightarrow
- SCADA: Supervisory Control and Data Acquisition \rightarrow

	\rightarrow	SCR: Selective Catalytic Reduction System
Engineering	\rightarrow	SEM: Strategic Energy Management
ion Tax Credit	\rightarrow	SO2: Sulfur Dioxide
equirement	\rightarrow	SMR: Small Modular Reactors
	\rightarrow	ST: Steam Turbine
uirement	\rightarrow	SUFG: State Utility Forecasting Group
	\rightarrow	T&D: Transmission and Distribution
	\rightarrow	TOU: Time-of-Use
d	\rightarrow	TRM: Technical Resource Manual
	\rightarrow	UCT: Utility Cost Test
	\rightarrow	UCAP: Unforced Capacity
	\rightarrow	VAR: Volt-Amp Reactive
ı	\rightarrow	VPN: Virtual Private Network
	\rightarrow	WTP: Willingness to Participate
Impact	\rightarrow	XEFORd: Equivalent Forced Outage Rate Demand excluding causes of outages that are outside
ization		management control
Capacity		

