

2016 CCR Fugitive Dust Control Report – Harding Street Station

Indianapolis Power & Light Company

This document has been prepared to meet the requirements of 40 CFR Part 257, Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule April 17, 2015



December 16, 2016



Introduction

Indianapolis Power & Light Company – Harding Street Generating Station is located at 3700 South Harding Street, Indianapolis, IN 46217 about 4.4 miles southwest of downtown Indianapolis in Decatur Township.

Harding Street Generating Station is a fossil fuel electric power generation station that began operation in 1931. Harding Street's primary fuel source from 1931- 2016 was coal. All coal fired boilers have either been converted to natural gas combustion or decommissioned. All ash handling areas except the coal ash ponds are either decommissioned or removed.

Description of the Actions Taken to Control CCR Fugitive Dust

Harding Street Generating Station personnel and 24/7 security personnel visually monitor affected areas and respond to issues and concerns in accordance with the Harding Street Site CCR Fugitive Dust Control Plan. Actions taken to prevent and control CCR fugitive dust are as follows:

- Running of water trucks on driving surfaces
- Periodic street sweeping
- Operating dust control equipment such as portable water spray system to address dusting on non-driving surfaces.
- Application of tackifier to prevent wind-blown fugitive dust on ponds 1, 2, 4, 4a and 4b

Record of Citizen Complaints

There have been no citizen complaints since the Fugitive Dust Control Plan was placed in the Operating Record on October 16, 2015.

Summary of Any Corrective Measures Taken

There have been no citizen complaints during the time period of this report, therefore, no corrective actions have been required.