

Annual Inspection - IPL Harding Street Station Surface Impoundment Elevations, Capacity and Volume

Parameters	Surface impoundment		
	Pond 1	Pond 2A/2B	Pond 3
Minimum Depth/Elevation	670	670	670
Maximum Depth/Elevation	688	686	685
Present Depth/Elevation	687	685	678
Storage Capacity (acre-ft)	101.8	39.5	120
Approximate Volume Water (acre-ft)	Dry	Minimal	92.1
Approximate Volume CCR (acre-ft)	94.8	27	27.9