

RATE CW
WATER HEATING -- CONTROLLED SERVICE

AVAILABILITY:

This Rate is closed and not available for service to new installations after the effective date of this tariff but remains in effect for current Customers. When new or upgraded facilities are required to maintain service to a Rate CW Customer, the Customer shall be removed from Rate CW and be required to take service under an appropriate general service tariff for which the Customer qualifies. Available for separately metered domestic and other water heating service, through a non-inductive pressure type heater, with resistance elements of either immersion or "wrap-around" type; provided that the applicant is a user of the Company's electric service supplied under some other rate at the same location. Not available for booster heaters, or in any case if the energy is to be used for space heating, either directly or indirectly, or for any purpose other than water heating.

The Company shall have the right to install or place in operation time control equipment to regulate the operation of the water heater at any time demands on the Company's system or other conditions, in the judgment of the Company, require installation or operation of such devices. The off-service period or periods will not exceed an aggregate of six hours per day.

CHARACTER OF SERVICE:

Single phase, sixty cycle alternating current, at a voltage of approximately 208 or 240 volts, or 208, 240 or 480 volts three phase, at the option of the Company.

SPECIFICATIONS AND CONDITIONS OF SERVICE:

All water heaters shall be non-inductive storage type heaters having a minimum tank capacity of forty (40) gallons, and may be either the single or twin unit electric heating element type. If the heater has two elements, each heating element shall be separately controlled by an adjustable thermostat, and the thermostats shall be wired so that only one unit shall be energized at a time. One heating element shall be located near the bottom of the tank and the upper unit shall be located approximately one-fourth the distance down from the top of the tank.

The heating elements in all water heaters shall be limited in size to a maximum of 5500 watts each.

The general specifications relating to the design, element size and operating characteristics of all water heaters connected to the Company's lines and the necessary electrical protection of the circuit furnishing water heating service under this schedule shall be subject to approval by the Company. All installations shall comply with all applicable State, County and Municipal laws, ordinances, rules and regulations.

Subject to the written approval of the Company, in special cases, and only when the elements are a maximum of 4500 watts, the capacity of the storage tank may be less than forty (40) gallons.

The necessary time control equipment, if installed or placed in operation, will be owned, operated, maintained and sealed by the Company.

If the Customer's water heating requirements necessitate two heaters of the type described in this rate, service will be provided for the two heaters through a single metering installation under the provisions of this rate; provided that beyond the point of the service entrance, the circuit or circuits supplying the heaters shall not be contained in a conduit, cable or raceway with any other circuits. If the number of heaters required exceeds two, but the requirements of this rate are otherwise met, service will be furnished only upon special written approval of the Company.

APPROVED BY
CONFERENCE MINUTES
30-Day Filing No. 50409
April 7, 2021
INDIANA UTILITY REGULATORY COMMISSION

Issued Pursuant to
Cause No. 50409
Effective
Effective April 7, 2021, 2021
Indiana Utility Regulatory Commission
Energy Division

Indianapolis Power & Light Company
d/b/a AES Indiana
One Monument Circle, Indianapolis, Indiana

I.U.R.C. No. E-18

2nd Revised No. 20
Superseding
3rd Revised No. 20

RATE CW (Continued)

RATE:

The sum of the Customer Charge and Energy Charge shown hereafter plus the Standard Contract Riders shown hereafter in the Standard Contract Riders Applicable section.

<u>Customer Charge</u>	\$18.22 per month
<u>Energy Charge</u>	5.3587¢ net per KWH

MINIMUM CHARGE PER MONTH:

The Customer Charge which is payable each month the service is connected for the Customer's use.

STANDARD CONTRACT RIDERS APPLICABLE:

No. 1	Customer Load Characteristics	see Page 150
No. 3	Transmission, Distribution and Storage System Improvement Charge	see Page 153
No. 6	Fuel Cost Adjustment	see Page 157
No. 9	Net Metering	see Page 161
No. 13	Air Conditioning Load Management Adjustment	see Page 165
No. 16	Excess Distributed Generation Credit	see Page 172
No. 20	Environmental Compliance Cost Recovery Adjustment	see Page 179.2
No. 21	Green Power Initiative	see Page 179.3
No. 22	Demand-Side Management Adjustment	see Page 179.5
No. 24	Capacity Adjustment	see Page 179.7
No. 25	Off-System Sales Margin Adjustment	see Page 179.8
No. 26	Regional Transmission Organization Adjustment	see Page 179.9

PAYMENT:

The above rates and charges are net. If the net bill is not paid within seventeen (17) days after its date of issue, a charge will be added in the amount of ten percent (10%) of the first Three Dollars (\$3.00) plus three percent (3%) of the excess of Three Dollars (\$3.00).

RULES:

Service hereunder shall be subject to the Company's Rules and Regulations for Electric Service, and to the Rules and Standards of Service for the Electrical Public Utilities of Indiana prescribed by the Indiana Utility Regulatory Commission, as the same are now in effect, and as they may be changed from time to time hereafter.