

Required Action

None
Monitor
Maintenance
Engineer

EROSION [no problem, could not inspect thoroughly]

Runoff Erosion (Gullies): Quantity: _____ Depth: _____ Width: _____ Length: _____

Location: _____

Notes/Causes: _____

INSTABILITIES [no problem, could not inspect thoroughly]

Slides: Transverse Length: _____ Longitudinal Length: _____

Scarp: Width: _____ Length: _____

Location: _____

Crack: Width: _____ Length: _____

Notes/Causes: _____

Cracks: Transverse Longitudinal Other

Quantity: _____ Length: _____ Width: _____ Depth: _____

Location: _____

Notes/Causes: _____

Cracks: Transverse Longitudinal Other

Quantity: _____ Length: _____ Width: _____ Depth: _____

Location: _____

Notes/Causes: _____

Bulges: Depressions Hummocky

Size: _____ Height: _____ Depth: _____

Location: _____

Notes/Causes: _____

OTHER [no problem, could not inspect thoroughly]

Rodent Burrows: (few, numerous) _____

Location: _____

Notes: _____

Other: _____

Notes: _____

SEEPAGE [no problem, could not inspect thoroughly]

Wet Area Flow Boil Sinkhole

Flow Rate _____ Size: _____

Location: _____

Aquatic Vegetation None

Rust Colored Deposits None

Sediment in Flow None

Other: _____

Notes/Causes: _____

{Inside Slope, Crest, Outside Slope, Outlet/Inlet Structures, Pond Drain}

None
Monitor
Maintenance
Engineer

Required Action

Required
Action

None
Monitor
Maintenance
Engineer

Wet Area Flow Boil Sinkhole

Flow Rate _____ Size: _____

Location: _____

Aquatic Vegetation None

Rust Colored Deposits None

Sediment in Flow None

Other: _____

Notes/Causes: _____

8) OUTLET/INLET STRUCTURES

GENERAL INLET [no problem, could not inspect thoroughly]

Inlet Pipe Dimensions: _____ (adequate, too small)

Type: (steel, concrete, aluminum, stainless steel, corrugated metal wood, other): _____

Location: _____

Deterioration: (missing sections, rusted, collapsed) _____

In Use: (Yes, No) _____

Pond Erosion at Inlet: (Describe) _____

Other _____

OUTLET STRUCTURES [no problem, could not inspect thoroughly]

Number of Outlet Structures: _____

Description/Location of Outlet Structures: _____

Outlet Structure 1:

Type: (steel, concrete, aluminum, stainless steel, corrugated metal wood, other): _____

Deterioration:(missing section, collapsed, rusted): _____

Erosion at Outlet Structure: (soil piping, seep collar, etc.) _____

Debris: (leaves, trash, logs, ice, etc.) _____

Notes: _____

{Inside Slope, Crest, Outside Slope, Outlet/Inlet Structures, Pond Drain}

None
Monitor
Maintenance
Engineer
Required
Action

Required
Required
Action
None
Monitor
Maintenance
Engineer

Outlet Structure 2
 Type: (steel, concrete, aluminum, stainless steel, corrugated metal wood, other): _____

 Deterioration:(missing section, collapsed, rusted): _____

 Erosion at Outlet Structure: (soil piping, seep collar, etc.) _____

 Debris: (leaves, trash, logs, ice, etc.) _____

 Notes: _____

Outlet Structure 3 Dimensions: _____
 Type: (steel, concrete, aluminum, stainless steel, corrugated metal wood, other): _____

 Deterioration:(missing section, collapsed, rusted): _____

 Erosion at Outlet Structure: (soil piping, seep collar, etc.) _____

 Debris: (leaves, trash, logs, ice, etc.) _____

 Notes: _____

9) POND DRAIN

GENERAL
 None Found Does not have one
 Type of Pond Drain
 (isolated control/intake tower, valve vault w/outlet conduit, valve in riser/drop inlet, siphon)
 Notes: _____

Operated During Inspection (yes, no)
 Notes: _____

ACCESS TO VALVE/SLUICE GATE [no problem, could not inspect thoroughly]
 Type (not accessible, from shore, boat, walkway, other) _____
 Notes: _____

Walkway/Platform: _____
 Concrete Deterioration Cracks (platform, piers, end supports, railing)
 Location: _____
 Notes: _____

{Inside Slope, Crest, Outside Slope, Outlet/Inlet Structures, Pond Drain}

None
Monitor
Maintenance
Engineer
Required
Action

Required Action

None
Monitor
Maintenance
Engineer

Wood Deterioration
Notes: _____

Metal Deterioration (minor, moderate, extensive, other)
Notes: _____

POND DRAIN COMPONENTS [no problem, could not inspect thoroughly]

Concrete Structure
Locations: _____
Description: (deterioration, misalignment, cracks): _____
Notes/Causes: _____

Valve Control (Operating Device)
 No Operating Device No Stem Bent/Broken Stem Other
Notes/Operability: _____

Metal Deterioration: (surface rust, minor, moderate, extensive, other)
Location: _____
Flow Rate: _____
Notes/Causes: _____

Mis-alignment
Notes/Causes: _____

Leakage – Flow Rate:
Notes/Causes: _____

Outlet Conduit
 Metal: (loss of coating/paint, surface rust, corrosion (pitting, scaling), rusted out)
Location: _____
Notes/Causes: _____

Concrete (bug holes, hairline crack, efflorescence)
(spalling, popouts, honeycombing, scaling, craze/map cracks)
(isolated crack, exposed rebar, disintegration, other)
Dimensions/Location: _____
Notes/Causes: _____

Plastic: (deterioration, cracking) _____
Location: _____
Notes/Causes: _____

{Inside Slope, Crest, Outside Slope, Outlet/Inlet Structures, Pond Drain}

None
Monitor
Maintenance
Engineer

Required Action

None
Monitor
Maintenance
Engineer

Conduit Deformation Mis-Alignment:
Location: _____
Notes/Causes: _____

Separated Joint Loss of Joint Material
Location/Description: _____
Notes/Causes: _____

Undermining
Location/Description: _____
Notes/Causes: _____

Vegetation (trees, brush)
Notes: _____

Other
Notes: _____

Discharge Outlet
 Type (pipe outlet, concrete channel, rock-lined channel, none)
Notes: _____

Riprap: Average Diameter:
(adequate, sparse, displaced, weathered, vegetation) bedding/fabric noted – yes, no))
Notes: _____

Concrete (bug holes, hairline crack, efflorescence)
(spalling, popouts, honeycombing, scaling, craze/map cracks)
(isolated crack, exposed rebar, disintegration, other)
Dimensions/Location: _____
Notes/Causes: _____

Mis-alignment
Location/Description: _____
Notes/Causes: _____

Separated Joint Loss of Joint Material
Location/Description: _____
Notes/Causes: _____

Undermining
Location/Description: _____
Notes/Causes: _____

Other
Notes: _____

None
Monitor
Maintenance
Engineer

{Inside Slope, Crest, Outside Slope, Outlet/Inlet Structures, Pond Drain}

APPENDIX C

Example Maintenance Forms

**Ash Pond Maintenance Form
Petersburg Generating Station
Indianapolis Power & Light Company
Petersburg, Indiana**

Date: _____

Personnel: _____

Maintenance Performed:

Reason for Maintenance:

Follow-up Inspection Required?

APPENDIX D

Completed Forms

ATTACHMENT F

PONDS A & A' EMERGENCY SPILLWAY DESIGN

ISSUE SUMMARY
Form SOP-0402-07, Revision 11

DESIGN CONTROL SUMMARY			
CLIENT:	Indianapolis Power & Light Company	UNIT NO.:	N/A
PROJECT NAME:	EVHSP CCR – Petersburg Station	PAGE NO.:	1
PROJECT NO.:	10572-096	S&L NUCLEAR QA PROGRAM	
CALC. NO.:	10572-096-PGS-ESW	APPLICABLE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
TITLE:	Ponds A and A' Emergency Spillway Design		
EQUIPMENT NO.:	N/A		
IDENTIFICATION OF PAGES ADDED/REVISED/SUPERSEDED/VOIDED & REVIEW METHOD			
Main Document: 10 pages. Total pages are 23 pages including 13 pages of the attachments.		INPUTS/ ASSUMPTIONS	
		<input checked="" type="checkbox"/> VERIFIED	
		<input type="checkbox"/> UNVERIFIED	
REVIEW METHOD:	Detailed	REV.:	0
STATUS:	<input checked="" type="checkbox"/> APPROVED <input type="checkbox"/> SUPERSEDED BY CALCULATION NO. <input type="checkbox"/> VOID	DATE FOR REV.:	5/16/2016
PREPARER:	Cheegwan Lee <i>Cheegwan Lee</i>	DATE:	5/16/2016
REVIEWER:	Nikhil M. Patel <i>Nikhil M. Patel</i>	DATE:	5/16/2016
APPROVER:	Darrel J. Packard <i>Darrel J. Packard</i>	DATE:	5/16/2016
IDENTIFICATION OF PAGES ADDED/REVISED/SUPERSEDED/VOIDED & REVIEW METHOD			
		INPUTS/ ASSUMPTIONS	
		<input type="checkbox"/> VERIFIED	
		<input type="checkbox"/> UNVERIFIED	
REVIEW METHOD:		REV.:	
STATUS:	<input type="checkbox"/> APPROVED <input type="checkbox"/> SUPERSEDED BY CALCULATION NO. <input type="checkbox"/> VOID	DATE FOR REV.:	
PREPARER:		DATE:	
REVIEWER:		DATE:	
APPROVER:		DATE:	
IDENTIFICATION OF PAGES ADDED/REVISED/SUPERSEDED/VOIDED & REVIEW METHOD			
		INPUTS/ ASSUMPTIONS	
		<input type="checkbox"/> VERIFIED	
		<input type="checkbox"/> UNVERIFIED	
REVIEW METHOD:		REV.:	
STATUS:	<input type="checkbox"/> APPROVED <input type="checkbox"/> SUPERSEDED BY CALCULATION NO. <input type="checkbox"/> VOID	DATE FOR REV.:	
PREPARER:		DATE:	
REVIEWER:		DATE:	
APPROVER:		DATE:	

NOTE: PRINT AND SIGN IN THE SIGNATURE AREAS



	Calcs. For Ponds A and A' Emergency Spillway Design			Calc. No. 10572-096-PGS-ESW			
				Rev. 0 Date: 5/16/2016			
	Safety-Related	X	Non-Safety Related	Page 2 of 10			
Client	Indianapolis Power & Light Company			Prepared by	Cheegwan Lee	Date	5/16/2016
Project	EVHSP CCR - Petersburg			Reviewed by	Nikhil M Patel	Date	5/16/2016
Project No.	10572-096			Approved by	Darrel J. Packard	Date	5/16/2016

TABLE OF CONTENTS

1. PURPOSE & SCOPE.....	3
2. DESIGN INPUTS	3
3. ASSUMPTIONS.....	3
4. METHODOLOGY & ACCEPTANCE CRITERIA.....	4
5. CALCULATIONS	6
6. RESULTS.....	8
7. REFERENCES.....	9
8. ATTACHMENTS	10

 Sargent & Lundy	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	3	of	10

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

1. PURPOSE & SCOPE

- 1.1. The purpose of this calculation is to determine the dimension of two emergency spillways for Pond A and Pond A' respectively (i.e. width and crest elevation) to meet the allowable maximum water elevation of 438 feet. The maximum allowable water elevation was determined in the inundation calculation for the Petersburg emergency action plan to reduce the inundation depth in the plant area due to Pond A breach scenario (Ref. 7.9).
- 1.2. The purpose of this calculation is also to determine the level of erosion protection that is necessary for passing the peak discharge flow for each spillway.
- 1.3. The scope of this calculation is limited to preparing a spillway calculation for the detailed design.


2. DESIGN INPUTS

- 2.1. Vertical Datum is NAVD 88, feet (Ref. 7.7)
- 2.2. Design rainfall event is a 1000-year recurrence for a surface impoundment with significant hazard potential (Section 257.82 in Ref. 7.1). The design rainfall depth is 10.1 inches for the 1000-yr/24-hr event (Ref. 7.2).
- 2.3. The elevation-storage curves of Ponds A and A' are shown in Attachment A (per Ref. 7.8).
- 2.4. The surface area of Pond A is 57.7 acres. The surface area of Pond A' is 7.1 acres (per Ref. 7.9).
- 2.5. Conservatively, initial water elevations are set to the crest elevations for the emergency spillways, 437 feet for Pond A' and 437.5 feet for Pond A, respectively.

3. ASSUMPTIONS

There are no unverified assumptions.

- 3.1. The discharge coefficient for Pond A' is considered to be 2.97, considering the sloping embankment with lower tailwater condition per Page 410 of Ref. 7.4. For Pond A, a standard discharge coefficient is considered to be 2.6 because the sloped embankment condition is not met due to the higher tailwater condition in Pond A' (i.e. tailwater level at the crest elevation of Pond A).
- 3.2. The existing embankment side slope protection for Pond A' spillway is sufficient for handling the discharge flow for a 1000-year storm event. Thus, the top of weir crest erosion protection is only evaluated in this calculation.

	Calcs. For Ponds A and A' Emergency Spillway Design			Calc. No. 10572-096-PGS-ESW
				Rev. 0 Date: 5/16/2016
	Safety-Related	X	Non-Safety Related	Page 4 of 10

Client	Indianapolis Power & Light Company	Prepared by	Cheegwan Lee	Date	5/16/2016
Project	EVHSP CCR - Petersburg	Reviewed by	Nikhil M Patel	Date	5/16/2016
Project No.	10572-096	Approved by	Darrel J. Packard	Date	5/16/2016

4. METHODOLOGY & ACCEPTANCE CRITERIA

4.1. Methodology

Emergency spillways are intended to be used for the routing of Inflow Design Flood (IDF) in the event of a malfunction of the flow control structures that safely pass the normal operational flow (Page 24 of Ref. 7.6).

The HEC-HMS hydrologic modeling system (Ref. 7.5), developed by the US Army Corps of Engineers, was used to determine the spillway dimensions required to meet the maximum allowable water elevation in Pond A and Pond A'.

Erosion protection requirement is evaluated per the flow depth in the guideline on Page 347 in Ref. 7.10.


The steps followed in performing the calculation are shown below:

- 4.1.1. Estimate and/or obtain the model input parameter values including the pond surface area, weir crest, elevation-storage curve, rainfall depth, spillway dimension, and weir discharge coefficients.
- 4.1.2. Set up the HEC-HMS model using the input data.
- 4.1.3. Find the optimal spillway dimension to meet the acceptance criteria through a model sensitivity analysis.
- 4.1.4. Determine the type of erosion protection based on the spillway water depth.

4.2. Acceptance Criteria

The following acceptance criteria were used to determine if the results satisfy the purpose and scope of the calculation:

- 4.2.1. The computed maximum water elevation in Pond A does not exceed the maximum allowable water level of 438 feet (Refs. 7.8 and 7.9).
- 4.2.2. The computed maximum water elevation in Pond A' does not exceed the crest elevation (i.e. 437.5feet) of Pond A emergency spillway to maintain a free flow broad-crested weir condition over the emergency spillway of Pond A. Note that this free flow broad-crested weir condition will ensure that the maximum allowable water level in Pond A is not exceeded.
- 4.2.3. The significant decimal digit of accuracy for the elevation computation is one (1).
- 4.2.4. The type of erosion protection meets the spillway water depth criteria on Page 347 in Ref. 7.10.

	Calcs. For Ponds A and A' Emergency Spillway Design		
	<input type="checkbox"/>	Safety-Related	X


Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	5	of	10

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

4.3. Computer Programs Used

- 4.3.1. HEC-HMS Version 3.5, S&L program No. 03.7.852.3.5, run on PC ZD8684. This program is verified and validated per S&L requirements.

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW	
Rev. 0	Date:	5/16/2016
Page	6	of 10

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

5. CALCULATIONS

The HEC-HMS model setup and calculation procedures are summarized as follows:

5.1. Primary input parameter values for HEC-HMS model are as follows:

	Design Spillway Crest EL. (ft)	Weir Discharge Coefficient (ft ^{0.5} /sec)	Initial Water EL. (ft)	Subbasin Area (acre)	Pond Storage (acre-ft)	Rainfall (inch)	Runoff Transformation
Pond A'	437.0	2.97	437.0	7.1	Elevation-Storage Curve (p.A3)	SCS Type II Distribution	SCS Unit Hydrograph
Pond A	437.5	2.60	437.5	57.7	Elevation-Storage Curve (p.A2)	SCS Type II Distribution	SCS Unit Hydrograph

Note: No rainfall loss is considered.





Figure 5-1 Schematics of Emergency Spillway

5.1.1. The design spillway crest elevation of Pond A is 437.5 feet NAVD 88. The design spillway crest elevation of Pond A' is 437.0 feet NAVD 88 per engineering judgment. Note that the dike elevation at the spillway location is 439 feet NAVD88 for both Ponds A and A' based on the topographic data available (Ref. 7.7).

5.1.2. The spillway is considered as a broad-crested weir with free flow condition. The discharge coefficient for Pond A is conservatively considered to be 2.6 (i.e. lower bound of standard broad-crested weir coefficient), considering that the design maximum pool elevation (i.e. 437.5 feet) of Pond A' (or A-discharge) is close to the design spillway crest elevation of Pond A (i.e. the upper

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	7	of	10

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

limit of a submerged weir condition). The discharge coefficient for Pond A' is considered to be 2.97 per Page 401 of Ref. 7.4. The tailwater condition for the normal river flow is far below the spillway crest elevation, which meets the sloping embankment criteria with free flow (i.e. higher discharge coefficient).

- 5.1.3. The initial water elevations are conservatively considered to be the same as the design crest elevations of the spillway for each pond. This is a consistent approach with the inundation map calculation for Petersburg Emergency Action Plan (Ref. 7.9).
- 5.1.4. The subbasin area is the pond surface area.
- 5.1.5. The NRCS (SCS) Type II rainfall distribution (per Ref. 7.3) is considered to generate the time-varying rainfall hyetograph in the HEC-HMS model.
- 5.1.6. The SCS Unit Hydrograph method was used to transform the rainfall to discharge into the ponds. No loss is considered. No time lag is considered. Thus, the discharge rate is likely to be a direct precipitation runoff.
- 5.2. The model setup schematic and results are shown in Attachment B.
- 5.3 The optimal effective crest widths (i.e. considering rectangular shape) of spillway were determined to be 50 feet for both Pond A and Pond A'. The design crest width considering the side slope of 10H:1V of spillway is computed as follows:


Maximum flow area (A) = effective crest width ($W_e=50$ feet) x maximum allowable water depth above crest ($H=6$ inch) = 25 feet².

Considering the trapezoidal weir with 10H:1V side slope and 6-inch water depth,

$$\text{Maximum flow area (A)} = W \times H + (10 \times H \times H)$$

$$W = (A - 10 \times H \times H)/H = (25 - 10 \times 0.5 \times 0.5)/0.5 = 45 \text{ feet.}$$

- 5.4 Per Pages 345 and 347 of Ref. 7.10, 6-inch coarse gravel (i.e. $d_{50}=6$ inch) protection is required on the crest of spillway. The peak water depth is significantly less than 2 feet and the peak velocity at the crest of Pond A' is 2.3 feet/s. Type 1 protection (i.e. next higher type) is selected from the table on Page 347 of Ref. 7.10 (Pages C2 and C3) because critical depth may occur beyond the road crossing.

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW	
Rev. 0	Date:	5/16/2016
Page	8	of 10

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

6. RESULTS


- 6.1. The minimum crest width (W) of spillway is determined to be **45 feet** for both Pond A and Pond A' considering the 10H:1V side slopes on each side of each spillway crest.
- 6.2. The primary output values of this calculation are reported as follows (see Attachment B).

	Top of Dike Elevation (ft)	Spillway Crest Elevation (ft)	Peak Water Elevation (ft)	Min. Spillway Crest Width (ft)	Min. Spillway Top Width (ft)	Peak Outflow (cfs)
Pond A'	439	437	437.5	45	85	57.4
Pond A	439	437.5	438.0	45	75	51.7

Notes:


- 1) The top of dike elevation is at the spillway location. The actual elevation along the dike varies generally 439 to 440 feet.
- 2) Spillway Top Width = Spillway Crest Width + 2 x [10 x (Dike Elevation – Spillway Crest Elevation)]. Freeboard is available 1.5ft for Pond A' and 1.0ft for Pond A.

- 6.3 The recommended erosion protection needed to pass the peak discharge flow over the spillway crest is 6-inch median size gravel and 1 foot thick.

	Calcs. For Ponds A and A' Emergency Spillway Design			Calc. No. 10572-096-PGS-ESW			
				Rev. 0 Date: 5/16/2016			
	Safety-Related	X	Non-Safety Related	Page 9 of 10			
Client	Indianapolis Power & Light Company			Prepared by	Cheegwan Lee	Date	5/16/2016
Project	EVHSP CCR - Petersburg			Reviewed by	Nikhil M Patel	Date	5/16/2016
Project No.	10572-096			Approved by	Darrel J. Packard	Date	5/16/2016

7. REFERENCES

- 7.1. Federal Register, Vol. 80, No. 74, April 17, 2015, Part II Environmental Protection Agency, 40 CFR Part 257.
- 7.2. NOAA Atlas 14, Volume 2, Version 3, Location Name: Petersburg, Indiana, US, Latitude: 38.5357°, Longitude: -87.2464°.
- 7.3. United States Department of Agriculture, Natural Resources Conservation Service, 1986, Urban Hydrology for Small Watersheds, TR 55.
- 7.4. Haun, Stefan, Reidar, N., and Feurich R., 2011, Numerical Modeling of Flow over Trapezoidal Broad-Crested Weir, Engineering Application of Computational Fluid Mechanics, Vol. 5, No. 3, pp. 397-405.
- 7.5. US Army Corps of Engineers, Hydrologic Engineering Center, 2010, Hydrologic Modeling System HEC-HMS, User's Manual, Version 3.5, S&L Program No. 03.7.852-3.5.
- 7.6. FEMA, 2013, Selecting and Accommodating Inflow Design Floods for Dams, FEMA P-94.
- 7.7. DLZ Industrial, LLC, 2015, Petersburg Generating Station, Overall Ash Pond Survey.
- 7.8. S&L, 2016, Ash Pond System Emergency Action Plan, Petersburg Generating Station, Indianapolis Power & Light Company.
- 7.9. S&L, 2016, Investigation and Analyses of Surface Impoundment Breach Floods for Emergency Action Plan, Petersburg Generating Station, Indianapolis Power & Light Company.
- 7.10. United States Department of the Interior, Bureau of Reclamation, Design of Small Canal Structures.

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related


Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	10	of	10

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

8. ATTACHMENTS

	<u>Total No. of Pages</u>
A. Elevation-Storage Curves	3
B. HEC-HMS Model Setup and Results	7
C. Erosion Protection Guideline	3


	Calcs. For Ponds A and A' Emergency Spillway Design		
	<input type="checkbox"/> Safety-Related	X	<input type="checkbox"/> Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	A1	of	A3

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

ATTACHMENT A: ELVATION-STORAGE CURVES

	Calcs. For Ponds A and A' Emergency Spillway Design		Calc. No. 10572-096-PGS-ESW
	Safety-Related	X	Non-Safety Related
Rev. 0	Date: 5/16/2016		Page A2 of A3
Client Indianapolis Power & Light Company	Prepared by Cheegwan Lee	Date 5/16/2016	
Project EVHSP CCR - Petersburg	Reviewed by Nikhil M Patel	Date 5/16/2016	
Project No. 10572-096	Approved by Darrel J. Packard	Date 5/16/2016	

Elevation ft	Cum. Storage acre-ft
415	0
416	48.4
417	97.1
418	146.3
419	195.9
420	245.8
421	296.2
422	347.0
423	398.1
424	449.7
425	501.7
426	554.1
427	607.0
428	660.2
429	713.8
430	767.9
431	822.4
432	877.3
433	932.6
434	988.4
435	1044.6
436	1101.2
437	1158.3
438	1215.7
439	1251.0
440	1303.8





Table A1- Pond A Elevation-Storage Curve

	Calcs. For Ponds A and A' Emergency Spillway Design		Calc. No. 10572-096-PGS-ESW
			Rev. 0 Date: 5/16/2016
	Safety-Related	X	Non-Safety Related
Client Indianapolis Power & Light Company	Prepared by Cheegwan Lee	Date 5/16/2016	
Project EVHSP CCR - Petersburg	Reviewed by Nikhil M Patel	Date 5/16/2016	
Project No. 10572-096	Approved by Darrel J. Packard	Date 5/16/2016	

Elevation ft	Cum. Storage acre-ft
415	0
416	3.6
417	7.4
418	11.3
419	15.4
420	19.6
421	23.9
422	28.3
423	32.9
424	37.7
425	42.6
426	47.6
427	52.8
428	58.1
429	63.6
430	69.3
431	75.1
432	81.0
433	87.1
434	93.4
435	99.9
436	106.5
437	113.3
438	120.2
439	127.3
440	134.3





Table A2- Pond A' Elevation-Storage Curve


	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	B1	of	B7

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

ATTACHMENT B: HEC-HMS MODEL SETUP AND RESULTS

	Calcs. For Ponds A and A' Emergency Spillway Design			Calc. No. 10572-096-PGS-ESW
				Rev. 0 Date: 5/16/2016
	Safety-Related	X	Non-Safety Related	Page B2 of B7

Client Indianapolis Power & Light Company	Prepared by Cheegwan Lee	Date 5/16/2016
Project EVHSP CCR - Petersburg	Reviewed by Nikhil M Patel	Date 5/16/2016
Project No. 10572-096	Approved by Darrel J. Packard	Date 5/16/2016





Figure B1- Schematic of HEC HMS Model Setup (including Pond A' Spillway)

	Calcs. For Ponds A and A' Emergency Spillway Design		Calc. No. 10572-096-PGS-ESW
	Safety-Related	X	Non-Safety Related
Rev. 0	Date: 5/16/2016		
Page	B3	of	B7

Client	Indianapolis Power & Light Company	Prepared by	Cheegwan Lee	Date	5/16/2016
Project	EVHSP CCR - Petersburg	Reviewed by	Nikhil M Patel	Date	5/16/2016
Project No.	10572-096	Approved by	Darrel J. Packard	Date	5/16/2016




Figure B2- Schematic of HEC HMS Model Setup (including Pond A Spillway)



Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	B4	of	B7

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

Subbasin "Pond A Surface" Results for Run "Run 1"





Figure B3- Pond A Precipitation and Outflow from Subbasin from HEC-HMS Model Results

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	B5	of	B7

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016




Figure B4- Summary Results for Pond A



Calcs. For Ponds A and A' Emergency Spillway Design		
Safety-Related		
X	Non-Safety Related	

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	B6	of	B7

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

Subbasin "Pond A' Surface" Results for Run "Run 1"





Figure B5- Pond A' Precipitation and Outflow from Subbasin from HEC-HMS Model Results

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	B7	of	B7

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016





Figure B6- Summary Results for Pond A'


	Calcs. For Ponds A and A' Emergency Spillway Design		
	<input type="checkbox"/>	Safety-Related	X

Calc. No.	10572-096-PGS-ESW		
Rev. 0	Date:	5/16/2016	
Page	C1	of	C3

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

ATTACHMENT C: EROSION PROTECTION GUIDELINE

	Calcs. For Ponds A and A' Emergency Spillway Design			Calc. No. 10572-096-PGS-ESW
				Rev. 0 Date: 5/16/2016
	Safety-Related	X	Non-Safety Related	Page C2 of C3
Client	Indianapolis Power & Light Company			Prepared by Cheegwan Lee Date 5/16/2016
Project	EVHSP CCR - Petersburg			Reviewed by Nikhil M Patel Date 5/16/2016
Project No.	10572-096			Approved by Darrel J. Packard Date 5/16/2016

TRANSITIONS AND EROSION PROTECTION

345

by reducing the depth and velocity for flows less than design flow.

To provide adequate canal bank freeboard, the inlet water surface for design flow should be at least 2 feet below the top of the canal bank. The orifice equation [1], $Q = CA\sqrt{2gh}$, may be used to calculate the inlet water surface required to discharge the design flow. For a type 4 inlet transition, a discharge coefficient, $C = 0.6$ may be used. The head, h , measured from the centerline of the opening to the water surface for free flow may be conveniently determined by rearranging the orifice equation and making appropriate substitutions:

$$h = 0.0433V^2$$

where V is the design velocity of the pipe.

7-10. Type 5 Transitions.—Figure 7-3 shows a typical type 5 transition. These transitions are simply an extension of the concrete canal lining which matches the normal concrete-lined section at one end and has a headwall on the pipe end. These transitions may be used where minimum head loss is not a factor. Figure 7-3 has a table of dimensions for pipes up to 36 inches in diameter. Because of headwall stability considerations, the maximum pipe diameter used with type 5 transitions is 36 inches.

The table of dimensions provide for the following:

1. Full-pipe velocity of 5 feet per second.

2. Transition length equal to 3 pipe diameters or 5 feet minimum.

3. Maximum invert slope of 4 to 1.

4. Inlet pipe submergence of at least 1.5 pipe velocity heads when full-pipe velocity equals 5 feet per second.

5. Pipe submergence at outlet sufficient to cause pipe to flow full.

6. Inlet and outlet freeboard varying from the lining freeboard to about 1.5 feet at the headwall.

7-11. Earth Transitions.—Earth transitions may be used for transitioning from a canal section to a canal structure where structure velocities do not exceed 3.5 feet per second. Lengths of earth transitions are usually related to the size of the structure. For pipe structures, inlet and outlet earth transition lengths are both usually equal to 3 pipe diameters or a minimum of 5 feet. For other structures, earth transition lengths are usually 5 feet for relatively small capacity structures and 10 feet for other structures. Invert slopes should not be steeper than 4 to 1 for both inlet and outlet transitions.

Lengths used for earth transitions in conjunction with concrete transitions should be 10 feet long or as otherwise required so that invert slopes are not steeper than the maximum allowable for the type 1 concrete transitions, 4 to 1 for inlets and 6 to 1 for outlets.

B. EROSION PROTECTION

7-12. Purpose and Description.—Riprap and gravel protection (fig. 7-8) is often used adjacent to structures and at other locations in earth-surfaced canals where erosion may occur. Local conditions must be considered in determining the type and the amount of protection to be provided. These conditions include the cost of riprap; cost of gravel; danger to structures and crops or to human life should scour occur; rodent damage; type of soil; and velocity of water. The following protection requirements should be used as a guide only. The types shown represent minimum thicknesses and sizes of material to be used, and adjustments should be made to meet the local conditions mentioned above.

Type 1—6-inch coarse gravel


Type 2—12-inch coarse gravel

Type 3—12-inch riprap on 6-inch sand and gravel bedding

Type 4—18-inch riprap on 6-inch sand and gravel bedding

Except for cross-drainage structures, type 3 minimum protection should be used where velocities exceed 5 feet per second, regardless of water depth.

7-13. Inverted Siphons.—The following protection is considered minimum for inverted siphons.

	Calcs. For Ponds A and A' Emergency Spillway Design		
	Safety-Related	X	Non-Safety Related

Calc. No. 10572-096-PGS-ESW		
Rev. 0	Date: 5/16/2016	
Page	C3	of C3

Client	Indianapolis Power & Light Company
Project	EVHSP CCR - Petersburg
Project No.	10572-096

Prepared by	Cheegwan Lee	Date	5/16/2016
Reviewed by	Nikhil M Patel	Date	5/16/2016
Approved by	Darrel J. Packard	Date	5/16/2016

TRANSITIONS AND EROSION PROTECTION

Water depth, feet	Type of protection		Length of inlet protection	Length of outlet protection
	Inlet	Outlet		
0 to 2.00	None	None	--	--
2.01 to 3.50	None	Type 1	--	2.5 depths (5 ft. min.)
3.51 to 7.00	Type 1	Type 2	1 depth (3 ft. min.)	2.5 depths (5 ft. min.)

7-14. *Cross-drainage Structures.*—The following protection is considered minimum for cross-drainage structures with concrete transitions.

Q, cfs	Type of protection		Outlet length, feet
	Inlet	Outlet	
0 to 30	None	Type 2	8
31 to 90	None	Type 2	12
91 to 240	Type 1	Type 3	16

Where the velocity in the conduit is greater than 15 feet per second at the outlet, use the protection type for the next higher discharge (type 3 minimum). Where baffled outlets are provided at the outlet of a structure the protection should be a thickness of $\frac{W}{6}$ with the minimum diameter of rock equal to $\frac{W}{20}$ and extending a distance W (5 feet minimum) beyond the baffled outlet. W is the inside width of the baffled outlet box.

7-15. *Other structures.*—The following protection is considered minimum for Parshall flumes, checks, check-drops, inclined drops, chutes, turnouts, road crossings and pipe drops with the hydraulic control section on concrete, that is, where critical depth does not occur beyond the concrete structure. Where critical depth may occur beyond the concrete, the

next higher type of protection should be used at the inlet.

Water depth, feet	Type of protection	
	Inlet	Outlet
0 to 2.00	None	Type 2
2.01 to 3.50	None	Type 2
3.51 to 7.00	Type 1	Type 3

Length of protection for outlets should normally be 2.5 depths (5.0 feet minimum), but where turbulent water may occur at the outlet, the length of protection should be increased to 4 depths. Gates or stoplogs near the outlet increase turbulence.

The rock for riprap and gravel protection should be hard, dense, durable, and should be reasonably well graded. The size range of rock used for 18-inch riprap should have a maximum size of 1/8 cubic yard and a minimum size of 1/10 cubic foot. The size range used for 12-inch riprap should have a maximum size of 1 cubic foot and a minimum size of 1-1/2 inches. The size range used in coarse gravel protection should have a maximum size of 1/8 cubic foot and a minimum size of 3/16 inches.

The 6-inch sand and gravel bedding for riprap should be a continuous layer of sand and gravel or sand and crushed rock, reasonably well graded to a maximum of 1-1/2 inches in size.