ENVIRONMENTAL • GEOTECHNICAL
BUILDING SCIENCES • MATERIALS TESTING

January 30, 2023
Revised on February 27, 2023

ATC Group Services LLC

7988 Centerpoint Dr.
Suite 100
Indianapolis, IN 46256

**Phone** **+1 317 849 4990**
Fax +1 317 849 4278

**www.atcgroupservices.com**

Mr. David M. Heger
Senior Counsel
AES US Services, LLC
One Monument Circle, Suite 701A
Indianapolis, Indiana 46204-2901

Re: **2022 CCR Annual Groundwater Monitoring and Corrective Action Report**
Indianapolis Power & Light Company d/b/a AES Indiana (AESI)
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

Dear Mr. Heger:

ATC Group Services LLC (ATC) has prepared this 2022 CCR Annual Groundwater Monitoring and Corrective Action Report for the Ash Pond System at the AESI Harding Street Generating Station in Indianapolis, Marion County, Indiana. This report has been prepared to comply with reporting requirements described in the United States Environmental Protection Agency's (USEPA) Coal Combustion Residuals (CCR) Rule § 257.90(e). This annual report documents the status of the groundwater monitoring and corrective action program for the ash pond system and includes information required by § 257.90(e)(1) through § 257.90(e)(6).

Federal CCR Rule § 257.90(e)(6) specifies the following:

*A section at the beginning of the annual report that provides an overview of the current status of groundwater monitoring and corrective action programs for the CCR unit. At a minimum, the summary must specify all of the following: (i) At the start of the current annual reporting period, whether the CCR unit was operating under the detection monitoring program in § 257.94 or the assessment monitoring program in § 257.95; (ii) At the end of the current annual reporting period, whether the CCR unit was operating under the detection monitoring program in § 257.94 or the assessment monitoring program in § 257.95; (iii) If it was determined that there was a statistically significant increase over background for one or more constituents listed in appendix III to this part pursuant to § 257.94(e): (A) Identify those constituents listed in appendix III to this part and the names of the monitoring wells associated with such an increase; and (B) Provide the date when the assessment monitoring program was initiated for the CCR unit. (iv) If it was determined that there was a statistically significant level above the*

*groundwater protection standard for one or more constituents listed in appendix IV to this part pursuant to § 257.95(g) include all of the following: (A) Identify those constituents listed in appendix IV to this part and the names of the monitoring wells associated with such an increase; (B) Provide the date when the assessment of corrective measures was initiated for the CCR unit; (C) Provide the date when the public meeting was held for the assessment of corrective measures for the CCR unit; and (D) Provide the date when the assessment of corrective measures was completed for the CCR unit. (v) Whether a remedy was selected pursuant to § 257.97 during the current annual reporting period, and if so, the date of remedy selection; and (vi) Whether remedial activities were initiated or are ongoing pursuant to § 257.98 during the current annual reporting period.*

**Overview of 2022 Groundwater Monitoring and Corrective Action**

For the duration of the 2022 reporting period, the CCR units at the Harding Street Generating Station - Ash Pond System were being monitored under the Assessment Monitoring Program defined in § 257.95. Pursuant to 40 CFR 257.94(e)(2), 257.94(e)(3) and 257.95(b), the facility had previously established an Assessment Monitoring Program in accordance with the requirements of § 257.95 on July 16, 2018. Therefore, evaluation of statistically significant increase over background for one or more constituents listed in Appendix III to this part pursuant to § 257.94(e) was not performed in 2022.

At the end of the 2022 reporting period, it was determined that the following Appendix IV constituents were at statistically significant levels (SSLs) above the associated groundwater protection standards (GWPS) pursuant to § 257.95(g)[1]. The SSLs are as follows:

Antimony

Shallow: MW-3S, MW-9S

Arsenic

Shallow: MW-1S, MW-2S, MW-6S, MW-7S, MW-10S, MW-12S, MW-13S
Deep: MW-7D, MW-10D, MW-11D, MW-12D, MW-13D, MW-14D

Lithium

Shallow: MW-5S, MW-6S, MW-7S, MW-8S, MW-9S, MW-10S, MW-12S, MW-13S
Deep: MW-2D, MW-7D, MW-10D, MW-11D, MW-12D, MW-13D, MW-14D

Molybdenum

Shallow: MW-5S, MW-6S, MW-7S, MW-8S, MW-12S, MW-13S
Deep: MW-7D, MW-9I, MW-12D, MW-13D, MW-14D

[1] SSLs provided are based on the May 2022 monitoring event as November 2022 sampling data was not finalized in 2022. SSLs listed for MW-9S and MW-12S (dry in November 2021 and May 2022) are based on SSLs identified during the previous event the wells generated sufficient water for sampling (November 2020).

The above listed SSLs are not new constituent SSLs and were previously identified. Therefore, no new SSL notification was required pursuant to § 257.94(e).

The assessment of corrective measures was initiated for the Harding Street Generating Station CCR regulated units on April 15, 2019 in response to SSLs of Appendix IV constituents exceeding GWPS. Pursuant to 40 CFR §257.96(a), a demonstration of need for a 60-day extension for the assessment of corrective measures was completed on July 12, 2019. The Corrective Measures Assessment (CMA) Report was completed and placed in the facility operating record on September 13, 2019 and subsequently amended on October 11, 2019. Groundwater nature and extent work is ongoing at the facility in support of characterizing the extent of the CCR impacted groundwater and further support of the CMA. Once the nature and extent (N&E) is sufficiently completed, a public meeting will be held, a remedy will be selected pursuant to § 257.97, and implementation of the selected remedy will be initiated thereafter in accordance with § 257.98.

Federal CCR Rule § 257.90(e) specifies the following:

> *For existing CCR landfills and existing CCR surface impoundments, no later than January 31, 2019, and annually thereafter, the owner or operator must prepare an annual groundwater monitoring and corrective action report. For new CCR landfills, new CCR surface impoundments, and all lateral expansions of CCR units, the owner or operator must prepare the initial annual groundwater monitoring and corrective action report no later than January 31 of the year following the calendar year a groundwater monitoring system has been established for such CCR unit as required by this subpart, and annually thereafter. For the preceding calendar year, the annual report must document the status of the groundwater monitoring and corrective action program for the CCR unit, summarize key actions completed, describe any problems encountered, discuss actions to resolve the problems, and project key activities for the upcoming year. For purposes of this section, the owner or operator has prepared the annual report when the report is placed in the facility's operating record as required by § 257.105(h)(1).*

The following key actions have been completed in 2022 to comply with 40 CFR 257.90-98:

- November 2021 laboratory analytical reports were finalized and placed in the facility operating record pursuant to 40 CFR 257.95(d)(1).

- Efforts to determine the N&E of the Appendix IV SSLs continued pursuant to § 257.95(g) including but not limited to the enhancement of the existing CCR monitoring well network[2] and continued off-site installation of additional monitoring equipment[3] and associated gauging and

[2] On-site monitoring Wells MW-2D1, MW-4SR, MW-4I, MW-4D, MW-5D, MW-6I, MW-6D, MW-7D1, MW-8D, MW-9SR, MW-12D1, MW-14I, MW-14IL, MW-14D1, MW-16D, MW-16S, MW-17D, MW-17IL, MW-17I, and MW-17S were installed between November and December 2022. Well locations are depicted on Figure 2.
[3] Off-site monitoring Wells MW-109S, MW-109I, MW-109D, MW-110S, MW-110I, and MW-110D were installed in November 2022. Well locations are depicted on Figure 2.

sampling at the Hanson Aggregates facility, review of groundwater analytical results/data to improve the groundwater site conceptual model, and modeling to support the CMA.

- Supplemental soil samples were collected from the screen intervals of the new enhancement monitoring wells, installed in 2022. These samples were analyzed for select Appendix IV constituents and geochemical indicator constituents to evaluate potential contributions from naturally occurring sources and to evaluate the geochemical conditions that can impact the attenuation, or mobility, of Appendix IV constituents in groundwater.

- Semi-annual assessment monitoring sampling events were conducted in 2022 as required by § 257.95(b) and § 257.95(d)(1). Pursuant to 40 CFR 257.95(b), all Appendix IV constituents were sampled in 2022. Pursuant to 40 CFR 257.95(d)(1), semi-annual sampling of all Appendix III parameters and Appendix IV constituents detected in response to 40 CFR 257.95(b) was conducted in 2022. All sampling events were performed consistent with 40 CFR 257.93(e). Subsequent SSLs evaluation of the November 2021 and May 2022 data were performed within 90 days of completing the sampling and analysis pursuant to § 257.93(h)(2)[4].

- Semi-Annual Remedy Selection Progress Reports pursuant to § 257.97(a) for the period of September 14, 2021 through March 10, 2022, and for the period of March 11, 2022 through September 12, 2022 were completed and placed in the facility's operating record and posted to AESI's CCR Website.

To report on the activities conducted during the prior calendar year and document compliance with the CCR Rule, the specific requirements listed in § 257.90(e)(1) through § 257.90(e)(5) are provided below in bold/italic type followed by a short narrative addressing how that specific requirement has been met.

***At a minimum, the annual groundwater monitoring and corrective action report must contain the following information, to the extent available:***

***§ 257.90(e)(1) A map, aerial image, or diagram showing the CCR unit and all background (or upgradient) and downgradient monitoring wells, to include the well identification numbers, that are part of the groundwater monitoring program for the CCR unit;***

AESI operates the Harding Street Station located in Indianapolis, Indiana. It is located at 3700 South Harding Street. A Site Location Map is provided as Figure 1. A map showing the location of each CCR management unit, associated upgradient and downgradient CCR monitoring wells, and N&E monitoring equipment installed between 2019 and 2022 is provided as Figure 2.

***§ 257.90(e)(2) Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken;***

[4] Sampling results for the November 2021 and May 2022 semi-annual assessment monitoring events are summarized in Table 3 and Table 4, respectively. Please refer to Section § 257.90(e)(4) on Page 10 of this report regarding SSL evaluation results.

The CCR ash pond groundwater monitoring system at the Harding Street Station consists of twenty-seven (27) monitoring wells: MW-1S, MW-1D, MW-2S, MW-2D, MW-3S, MW-3D, MW-4S, MW-5S, MW-6S, MW-7S, MW-7D, MW-8S, MW-9S, MW-9I, MW-9D, MW-10S, MW-10D, MW-11S, MW-11D, MW-12S, MW-12D, MW-13S, MW-13D, MW-14D, MW-15S, MW-15I, and MW-15D. Monitoring wells MW-15S, MW-15I, and MW-15D represent upgradient/background wells, while the remaining locations represent downgradient wells. The wells were installed in accordance with the requirements of Federal CCR Rule § 257.91 between September 25, 2015 and August 17, 2018.

The groundwater monitoring system was re-certified in 2019 in accordance with the requirements of Federal CCR Rule § 257.91 to account for the utilization of MW-15S, MW-15I, and MW-15D as the upgradient/background monitoring wells for the CCR well network.

Pre-existing piezometer M-4, located south of Former Pond 2 adjacent to the property boundary, was converted to a N&E monitoring well in September 2019 to serve as a facility boundary well pursuant to § 257.95(g)(1)(iii).

AESI initiated N&E investigative work at the Hanson site in late 2019 to determine the extent of the plume and to support the selection of remedy. Four N&E monitoring wells (PZ-100S, PZ-100D, PZ-101S, and PZ-101D) were installed in October 2019 and sampled in December 2019. Based on the identification of groundwater concentrations above applicable GWPSs at the PZ-100 and PZ-101 well nests, seven N&E monitoring wells (MW-102S, MW-102D, MW-103S, MW-103I, MW-103D, MW-104S, and MW-104D) were installed in April 2020 in order to further evaluate the lateral extent of the off-site plume.

Eleven monitoring wells (MW-105S, MW-105I, MW-105D, MW-106S, MW-106I, MW-106D, MW-107S, MW-107I, MW-107D, MW-108S, and MW-108D) were installed at Hanson between June and July 2021 in order to refine the lateral and vertical extent of the off-site plume.

Six monitoring wells (MW-109S, MW-109I, MW-109D, MW-110S, MW-110I, and MW-110D, were installed at Hanson in November 2022 to define the southern extent of the off-site plume.

Eighteen (18) new monitoring wells (MW-2D1, MW-4I, MW-4D, MW-5D, MW-6I, MW-6D, MW-7D1, MW-8D, MW-12D1, MW-14I, MW-14IL, MW-14D1, MW-16D, MW-16S, MW-17D, MW-17IL, MW-17I, and MW-17S) and one test boring (EB-10) were installed at the facility between November and December 2022 in order to enhance the existing CCR network. Planned well MW-2IL, along with a planned nest at the proposed MW-18 location had not been installed by the end of 2022.

Two monitoring wells (MW-4SR and MW-9SR) were installed in November 2022 as replacements for shallow wells (MW-4S and MW-9S) that had typically been dry during recent sampling events.

No monitoring equipment was abandoned during 2022. Monitoring wells MW-4S and MW-9S will remain in place until a decision is made to permanently abandon them.

The location of the CCR groundwater monitoring well network, N&E wells, and N&E piezometers are depicted on Figure 2.

***§ 257.90(e)(3) In addition to all the monitoring data obtained under § 257.90 through § 257.98, a summary including the number of groundwater samples that were collected for analysis for each background and downgradient well, the dates the samples were collected, and whether the sample was required by the detection monitoring or assessment monitoring programs;***

Table 1 provides a summary of the number of groundwater samples collected at each CCR monitoring well and N&E monitoring equipment, sampling dates, and designation of whether samples were required by the detection or assessment monitoring program.

Groundwater elevation data is provided in Table 2.

Assessment monitoring groundwater analytical results for the November 2021 combined semi-annual assessment monitoring event, including on site N&E well M-4, and off-site N&E wells PZ-100S, PZ-100D, PZ-101S, PZ-101D, MW-102D, MW-103S, MW-103I, MW-103D, MW-104D, MW-105S, MW-105I, MW-105D, MW-106S, MW-106I, MW-106D, MW-107S, MW-107I, MW-107D, MW-108S, MW-108D are summarized in Table 3.

Groundwater analytical results for the May 2022 combined semi-annual assessment monitoring sampling event, including on-site N&E well M-4 and off-site N&E wells PZ-100S, PZ-100D, PZ-101S, PZ-101D, MW-102S, MW-102D, MW-103S, MW-103I, MW-103D, MW-104S, MW-104D, MW-105S, MW-105I, MW-105D, MW-106S, MW-106I, MW-106D, MW-107S, MW-107I, MW-107D, MW-108S, MW-108D are summarized in Table 4.

Groundwater results for the November 2022 combined semi-annual assessment monitoring sampling event and on-site and off-site N&E event, and for the December 2022 sampling event for the new MW-4 nest wells were not finalized in 2022 and therefore are not included with this submittal.

Supplemental soil sample analytical results from screened intervals of enhancement and N&E wells are summarized on Table 5.

Potentiometric surface maps for the November 2021 sampling event are provided as Figure 3 and Figure 4. Potentiometric surface maps for the May 2022 sampling event are provided as Figure 5 and Figure 6. Flow rate vectors are depicted on the maps. Gauging summary tables and flow velocity calculations for each event are provided as supporting documentation in Attachment A. Laboratory certificates of analysis are provided in Attachment B.

***Statistical Evaluation Procedures***

The statistical evaluation procedures created for the Harding Street Generating Station define the statistical tests to be used for this site's CCR groundwater detection monitoring system. The aforementioned evaluation methods specify statistical tests for the detection monitoring program (Appendix III parameters) and assessment monitoring program (Appendix IV parameters) described in 40 CFR 257. These evaluation methods were created to comply with the requirements of § 257.93(f).

This plan is based on the use of the commercial software DUMPStat[5] (Version 3.0). The DUMPStat program uses statistical tests, procedures, and testing sequences described in Statistical Methods for Groundwater Monitoring[6] (Gibbons et. al., 2009). The statistical methods for the HSGS CCR monitoring system are designed to be consistent with ASTM International Standard Guide for Developing Appropriate Statistical Approaches for Groundwater Detection Monitoring Programs *at Waste Disposal Facilities* (D6312-17) along with federal and state guidance, and are also consistent with Indiana's regulations addressing statistical evaluation of groundwater at solid waste landfills.

The CCR ash pond groundwater monitoring system at the HSGS consists of twenty-seven (27) monitoring wells: MW-1S, MW-1D, MW-2S, MW-2D, MW-3S, MW-3D, MW-4S, MW-5S, MW-6S, MW-7S, MW-7D, MW-8S, MW-9S, MW-9I, MW-9D, MW-10S, MW-10D, MW-11S, MW-11D, MW-12S, MW-12D, MW-13S, MW-13D, MW-14D, MW-15S, MW-15I, and MW-15D. Monitoring wells MW-15S, MW-15I, and MW-15D represent upgradient/background wells, while the remaining wells represent waste boundary (downgradient) wells. The wells were installed in accordance with the requirements of Federal CCR Rule § 257.91 between September 25, 2015 and August 17, 2018.

The original upgradient well set consisted of monitoring wells MW-1S, MW-1D, MW-2S, MW-2D, MW-3S, MW-3D, MW-4S, and MW-8S. The groundwater monitoring system was re-certified in 2019 in accordance with the requirements of Federal CCR Rule § 257.91 to account for the utilization of MW-15S, MW-15I, and MW-15D as the new upgradient/background monitoring wells for the CCR well network, replacing the original upgradient/background wells. For evaluation purposes, the unconsolidated aquifer materials are split into a shallow zone and a deep zone. Currently, data from MW-15I is used to provide background for the shallow aquifer zone, while data from MW-15D is used to provide background data for the deeper aquifer zone. Data from MW-15S, while collected, is currently not incorporated into the background database for statistical purposes. MW-15S has been interpreted as monitoring a shallower, hydraulically separated and/or perched zone relative to the aquifer zone where the downgradient shallow compliance wells are typically screened, while MW-15I is interpreted to be screened at a more representative position with respect to the shallow compliance wells. As the site conceptual model become more refined, a decision may be made to incorporate the MW-15S data into the shallow zone statistical background database, as appropriate.

Statistical levels defined in this evaluation plan depend, in part, on the values defined for certain settings in DUMPStat. The Plan is based on making interwell comparisons for all wells and all parameters. The background database contains results from September 2018 through the respective November 2021 and May 2022 semi-annual events for the upgradient monitoring wells, and from April 2016 through the respective November 2021 and May 2022 semi-annual events for the downgradient wells. The minimum background sample size was set to eight (8). Under this plan, if a detection monitoring result in a compliance well exceeds a statistical limit, a statistically significant increase, or SSI, will be declared.

Semi-annual assessment monitoring sampling events were conducted in 2022 as required by § 257.95(b) and § 257.95(d)(1). Pursuant to 40 CFR 257.95(b), all Appendix IV constituents were sampled in 2022. Pursuant to 40 CFR 257.95(d)(1), semi-annual sampling of all Appendix III

5 DUMPStat Version 3.0 was written by Robert D. Gibbons and is distributed and supported by Discerning Systems Inc.
6 Gibbons, R.D., Bhaumik D. K., Aryal S., 2009, Statistical Methods for Groundwater Monitoring, Second Edition, John Wiley & Sons, Inc. New York, 374 pages.

parameters and Appendix IV constituents detected in response to 40 CFR 257.95(b) was conducted in 2022. All sampling events were performed consistent with 40 CFR 257.93(e). Subsequent Statistically Significant Level (SSL) evaluation of the November 2021 and May 2022 data were performed within 90 days of completing the sampling and analysis pursuant to § 257.93(h)(2).

Background Data

Pursuant to 257.94(b), the monitoring well network has been sampled to establish a minimum eight background data sets prior to completion of initial statistical analyses. Groundwater samples were analysed for the Appendix III parameters: boron (total), calcium (total), chloride, fluoride, pH, sulfate, and total dissolved solids (TDS); and for the Appendix IV parameters: antimony (total), arsenic (total), barium (total), beryllium (total), cadmium (total), chromium (total), cobalt (total), fluoride, lead (total), lithium (total), mercury (total), molybdenum (total), selenium (total), thallium (total), and total radium.

Available historical data were used to calculate the background database for the system.

Included in this attachment are summaries of the historical data for the statistically evaluated parameters for the HSGS. Historical data from groundwater sampling events were imported into the DUMPStat database. Table C-1 in Attachment C contains groundwater quality data collected from the background monitoring wells MW-15I and MW-15D. Prediction limits based on groundwater quality reported from the background monitoring wells were calculated for each parameter and are presented in Table C-5 of Attachment C.

Defined Statistical Tests - Interwell Statistical Comparisons

Appendix IV assessment monitoring parameters are statistically evaluated using the appropriate upgradient versus downgradient statistical test also known as an interwell statistical comparison. To assign the appropriate upgradient versus downgradient statistical test, DUMPStat first checks the parameter concentration to determine the detection frequencies (Attachment C, Table C-3). It then applies the Shapiro-Wilk Test of Normality for Multiple Groups to determine if the data for each parameter are normally or lognormally distributed, or if a nonparametric prediction limit must be used (Attachment C, Table C-4). The statistics are then calculated and the prediction limits established (Attachment C, Table C-5). DUMPStat screens the background data using Dixon's test to remove the outliers. The results of the Dixon's test are listed in Attachment C, Table C-6. The parameters that exceed statistical limits in the downgradient monitoring wells, along with the associated historical data for those parameters, are listed in Attachment C Table C-7. A statistical power curve is also included.

Among the background measurements, if the constituent fits normal/lognormal distribution, the parametric prediction limit is calculated; if the constituent does not fit normal/lognormal distribution, the non-parametric prediction limit is calculated.

False Positive Rates and Statistical Power

Included in this attachment is the power curve calculated by DUMPStat for both the shallow and deep monitoring zones at the site for this interwell monitoring plan. As indicated in the US EPA Unified

Guidance[7] document, as a general guide, when background is approximately normal in distribution, a statistical test should be able to detect a 3-standard deviation increase at least 55-60% of the time, and a 4-standard deviation increase with at least 80-85% probability. The calculated statistical power curve indicates general compliance with this guidance; the facility's statistical program has the annual power to detect 3- and 4-standard deviation increases above the true background mean. It is expected that the power curves will also improve as additional background data are added over time.

Interwell Statistics Comparisons

Future groundwater quality results at monitoring wells MW-1S, MW-1D, MW-2S, MW-2D, MW-3S, MW-3D, MW-4S, MW-5S, MW-6S, MW-7S, MW-7D, MW-8S, MW-9S, MW-9I, MW-9D, MW-10S, MW-10D, MW-11S, MW-11D, MW-12S, MW-12D, MW-13S, MW-13D, MW-14D will be statistically compared to results from Monitoring Wells MW-15I and MW-15D.

Background Sample Size

The number of background samples for Appendix IV parameters is listed in the "N" column of Attachment C Table C-5. The minimum background sample size is eight.

Appendix IV Assessment Monitoring – Statistical Procedures to Determine GWPS Exceedances

In accordance with 257.95(a), as SSIs have previously been identified for one or more Appendix III constituents at one or more downgradient wells, an Appendix IV assessment monitoring program has been established. Prediction limits are calculated for each Appendix IV parameter. A groundwater protection standard (GWPS) for each Appendix IV parameter will also be established. The GWPS will be the larger of the background prediction limit, the regulatory standard (maximum contaminant level, MCL), or the USEPA Screening Level[8] for those Appendix IV constituents (cobalt, lithium, molybdenum) that do not have a defined MCL.

Appendix IV parameters are evaluated by calculating the lower confidence limit (LCL) on the mean of the last four reported concentrations for each Appendix IV parameter in each downgradient (compliance) well to the GWPS. This approach is discussed in technical literature (Gibbons and Coleman, 2001, Equation 19.5, p. 231)[9] and the US EPA Unified Guidance (2009). The 95% LCL of the mean of the last four measurements for each Appendix IV constituent will be calculated as follows:

$$LCL = \bar{x} - ts/\sqrt{m}$$

LCL = lower confidence limit for mean;

t = one-tailed 100(1-α) percentage point of Students *t*-distribution on m-1 degrees of freedom;

7 Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities Unified Guidance, March 2009, EPA 530-R-09-007.

8 USEPA Amendments to the National Minimum Criteria (Phase One, Part One), Disposal of Coal Combustion Residuals from Electric Utilities; effective August 29, 2018 (page 36444).

9 Gibbons, R.D., and Coleman, D.E., 2001. Statistical Methods for Detection and Quantification of Environmental Contamination, John Wiley & Sons, 384 pp.

m = number of sample measurements;

$s/\sqrt{m}$ = standard error of the mean; and

$\bar{x}$ = sample mean of m measurements.

At each downgradient well, the lower confidence limit will be calculated to the 95% confidence level for each Appendix IV parameter. The 95% LCL will be compared to the associated GWPS (the greater of the background prediction limit, MCL, or USEPA Screening Level as described above). A GWPS exceedance will be identified if the 95% LCL exceeds the GWPS; this corresponds to identification of an SSL. The 95% LCL will be re-calculated following each sampling event using a rolling average of the four most recent sample results.

Appendix III detection monitoring will continue during the completion of the Appendix IV assessment monitoring program.

***§ 257.90(e)(4) A narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from detection monitoring to assessment monitoring in addition to identifying the constituent(s) detected at a statistically significant increase over background levels);***

AESI Harding Street operated under the assessment monitoring program in accordance with § 257.95 during 2022. No transition between monitoring programs was conducted in 2022.

During 2022, statistical evaluations of the November 2021 and May 2022 analytical data were performed in order to determine whether there was a SSL of a new Appendix IV constituent detected above the relevant GWPS in accordance with § 257.95(g) and 257.93(h). The evaluations were completed in May 2022 and October 2022, respectively. Based on the evaluations, it was determined that the Appendix IV constituents that exceeded the GWPS include antimony, arsenic, lithium, and molybdenum; however, these are the same constituent SSLs previously identified. SSLs and associated wells are summarized on Page 2.

Since there were no new Appendix IV constituent SSLs identified, an additional notification was not triggered pursuant to 40 CFR 257.95(g).

***§ 257.90(e)(5) Other information required to be included in the annual report as specified in § 257.90 through § 257.98.***

Table 6 summarizes the groundwater protection standards established in accordance with § 257.95(d)(2) and § 257.95(h) associated with both the November 2021 and May 2022 semi-annual assessment monitoring events.

Projected key activities for the upcoming year include the following:

- Assessment monitoring sampling events in accordance with § 257.95 and consistent with § 257.90(e).

- Finalize November 2022 analytical data and complete statistical evaluation of November 2022 analytical data to determine whether there is a SSL above GWPS for Appendix IV constituents in accordance with § 257.95(g) and 257.93(h). Perform SSL evaluations of final May 2023 assessment monitoring analytical data.

- Finalize December 2022 analytical data collected from replacement/enhancement monitoring wells MW-4SR, MW-4I, and MW-4D.

- Complete on-site monitoring well enhancement installation activities at MW-2IL and MW-18. Collect groundwater samples from new on-site enhancement wells and off-site N&E monitoring wells.

- Continue N&E work pursuant to § 257.95(g) including but not limited to review of off-site N&E data.


- After delineation of groundwater impacts is determined to be complete, begin preparing estimates quantity of Appendix IV material released.

- Potentially conduct public meeting to discuss the results of the corrective measures assessment at least 30 days prior to the selection of remedy pursuant to § 257.96(e).

- Prepare semi-annual report(s) describing progress in selecting and designing the remedy pursuant to § 257.97(a).

We appreciate the opportunity to assist with AESI's CCR Rule groundwater monitoring program at Harding Street Station's Ash Pond System. Please contact either of the undersigned at 317.849.4990 if you have any questions regarding this report.

Sincerely,
**ATC Group Services LLC**



Mark E. Breting, L.P.G.
Senior Project Geologist



Robert T. Duncan, L.P.G.
Principal Geologist

Copies: Ms. Pilar Cuadra
Mr. Thom O'Leary

# FIGURES

Figure 1: Site Location Map
Figure 2: Groundwater Monitoring System – CCR Network Wells and N&E Wells/Piezometers
Figure 3: Potentiometric Surface Map – Shallow Zone – October 29, 2021
Figure 4: Potentiometric Surface Map – Deep Zone – October 29, 2021
Figure 5: Potentiometric Surface Map – Deep Zone - May 2, 2022
Figure 6: Potentiometric Surface Map – Shallow Zone - May 2, 2022

## LEGEND:

- APPROXIMATE BOUNDARY OF ASH POND SYSTEM
- APPROXIMATE LIMITS OF REGULATED CCR SURFACE IMPOUNDMENT
- APPROXIMATE LIMITS OF NON-REGULATED CCR SURFACE IMPOUNDMENT

NOTE:
ASH POND BOUNDARY OBTAINED FROM EXHIBIT 3 IN THE HARDING STREET GENERATING STATION ASH POND SYSTEM CLOSURE AND POST-CLOSURE PLAN, REV.A. JULY 28, 2016.

664
675
Substation
HARDING STREET GENERATING STATION
WHITE RIVER
POND 1
POND 3
Well
Well
POND 2A
POND 2B
FORMER POND 2
FORMER POND 4A
FORMER POND 4B
FORMER POND 4
670
DITCH

N

400 0 100 200 300 400

SCALE: 1" = 400'

NOTE:
ORIGINAL MAP SCALE = 1" TO 2,000'

| Drn. By: | Ckd. By: | App'd By: | Ckd. Date: |
|---|---|---|---|
| BH | MB | | |

Project Number: 170LF01115

Drawing File: SEE LOWER LEFT

ATC

# SITE LOCATION MAP

AES INDIANA HARDING STREET STATION
3700 SOUTH HARDING STREET
INDIANAPOLIS, INDIANA

Date: 12/21

Scale: AS SHOWN

Figure: 1

H:\2021\PL\HARDING STREET\170LF01115\170LF01115-VIC.DWG, HARDING

WHITE RIVER

HARDING STREET GENERATING STATION

MW-15S
MW-15I
MW-15D

MW-16S
MW-16D

MW-1S
MW-1D

MW-2S
MW-2D
MW-2IL
MW-2D1

POND 1

P1 PZ-1S
P1 PZ-1D

P2 PZ-1S
P2 PZ-1D

P3 PZ-1S
P3 PZ-1D

POND 3

MW-17S
MW-17IL
MW-17D

MW-8S
MW-8D

FORMER POND 2

P2A/B PZ-2S
P2A/B PZ-2D

P2A/B PZ-1S
P2A/B PZ-1D

P2 PZ-2S
P2 PZ-2D

P2 PZ-3D
P2 PZ-3S

MW-3S
MW-3D

FORMER POND 4B

MW-18

MW-11S
MW-11D

MW-13S
MW-13D

MW-10S
MW-10D

FORMER POND 4A

MW-14I
MW-14IL
MW-14D
MW-14D1

M-4

MW-7S
MW-7D
MW-7DI

MW-6S
MW-6I
MW-6D

MW-5S
MW-5D

FORMER POND 4

MW-106S
MW-106I
MW-106D

MW-102S
MW-102D

MW-103S
MW-103I
MW-103D

MW-105S
MW-105I
MW-105D

PZ-100S
PZ-100D

MW-107S
MW-107I
MW-107D

MW-12S
MW-12D
MW-12D1

MW-4S
MW-4I
MW-4D
MW-4SR

MW-108S
MW-108D

MW-9S
MW-9I
MW-9D
MW-9SR

PZ-101S
PZ-101D

MW-104S
MW-104D

MW-109

MW-110

N

600 0 200 400 600

SCALE: 1" = 600'

## LEGEND:

- MW-1S — CCR MONITORING WELL, Well Identification
- M-4 — EXISTING NATURE AND EXTENT MONITORING WELL, Well Identification
- P2 PZ-1D — 2019 ASH POND PIEZOMETERS, Piezometer Identification
- MW-109 — 2022 NATURE AND EXTENT MONITORING WELL, Well Identification
- APPROXIMATE BOUNDARY OF ASH POND SYSTEM
- ℄ — PROPERTY BOUNDARY

NOTE:
-MW-1 THROUGH MW-14 MONITORING WELL LOCATIONS ARE BASED ON COORDINATES PROVIDED IN TABLE 1 OF THE JULY 28, 2016 SAMPLING AND ANALYSIS PLAN.
MW-15 NEST LOCATIONS BASED ON OCTOBER 5, 2018 SURVEY DATA.
-ASH POND BOUNDARY OBTAINED FROM EXHIBIT 3 IN THE HARDING STREET GENERATING STATION ASH POND SYSTEM CLOSURE AND POST-CLOSURE PLAN, REV.A. JULY 28, 2016.
-PZ-100 AND PZ-101 NEST LOCATIONS BASED ON NOVEMBER, 2019 SURVEY.
-MW-102, MW-103, AND MW-104 NEST LOCATIONS BASED ON MAY 11, 2020 SURVEY.
-IMAGERY PROVIDED BY MAP DATA © 2018 GOOGLE, INEGI
-MW-105, MW-106, MW-107, AND MW-108 NEST LOCATIONS BASED ON AUGUST 6, 2021 SURVEY.
-AS-BUILT SURVEY DATA PENDING FOR LATE 2022 WELL INSTALLATIONS.

H:\2023\AES\HARDING STREET\170LF01277\170LF01277-WELL MAP.DWG, LOCATIONS

Drn. By: BH | Ckd. By: MB | App'd By: | Ckd. Date:

Project Number: 170LF01277

Drawing File: SEE LOWER LEFT

ATC

# GROUNDWATER MONITORING SYSTEM
## CCR NETWORK AND NATURE AND EXTENT WELLS/PIEZOMETERS
AES INDIANA HARDING STREET STATION
3700 SOUTH HARDING STREET
INDIANAPOLIS, INDIANA

Date: 1/23

Scale: AS SHOWN

Figure: 2

LEGEND:

MW-1S 663.00 — MONITORING WELL — Well Identification — Groundwater Elevation (ft. MSL)

PZ-11 663.51 — PIEZOMETER — Well Identification — Groundwater Elevation (ft. MSL)

APPROXIMATE BOUNDARY OF ASH POND SYSTEM

NOTE:
FR = FLOW RATE (FT/DAY)
-MW-1 THROUGH MW-14 MONITORING WELL LOCATIONS ARE BASED ON COORDINATES PROVIDED IN TABLE 1 OF THE JULY 28, 2016 SAMPLING AND ANALYSIS PLAN.
MW-15 NEST LOCATIONS BASED ON OCTOBER 5, 2018 SURVEY DATA.
-ASH POND BOUNDARY OBTAINED FROM EXHIBIT 3 IN THE HARDING STREET GENERATING STATION ASH POND SYSTEM CLOSURE AND POST-CLOSURE PLAN, REV.A, JULY 28, 2016.
-PZ-100 AND PZ-101 NEST LOCATIONS BASED ON NOVEMBER, 2019 SURVEY
-MW-102, MW-103, AND MW-104 NEST LOCATIONS BASED ON MAY 11, 2020 SURVEY.
-IMAGERY PROVIDED BY MAP DATA © 2018 GOOGLE, INEGI
-* DATA NOT USED TO INFER POTENTIOMETRIC SURFACE CONTOURS

650 — INFERRED GROUNDWATER ELEVATION CONTOUR — CONTOUR INTERVAL: 5 ft (DASHED WHERE INFERRED)

653 — INFERRED GROUNDWATER ELEVATION CONTOUR — CONTOUR INTERVAL: 1 ft (DASHED WHERE INFERRED)

GROUNDWATER FLOW DIRECTION

USGS GAUGING STATION 03/353611
668.17 FT. MSL
10/29/21 (08:00)

EXISTING DAM

WHITE RIVER

HARDING STREET GENERATING STATION

FORMER POND 1

FORMER POND 2

POND 3

FORMER POND 4A

FORMER POND 4B

FORMER POND 4

P-4 668.58
P-5 668.63
P-6 667.79
P-2 666.26

MW-15S 650.39
MW-15I 669.50
MW-15D

M-6 668.81
HA PZ-1 666.46
SG-1
SG-2
HA SG-3
HA PZ-3 681.63
HA SG-4
HA PZ-4 659.93
HA SG-5
HA PZ-5 659.56
MW-1S 664.72
MW-1D
HA PZ-2 663.19
FR 1: 4.8
PZ-1
MW-8S 660.92
PZ-2
PZ-6
MW-2S 667.22
MW-2D
PZ-7 669.60
P3 PZ-1S
P3 PZ-1D 666.69
P1 PZ-1S
P1 PZ-1D 665.94
P2 PZ-1S
P2 PZ-1D 662.26
PZ-5
P2A/B PZ-2S
P2A/B PZ-2D 662.23
P2A/B PZ-1S
P2A/B PZ-1D 665.13
P2 PZ-2S
P2 PZ-2D 659.02
P2 PZ-3S
PZ-14
PZ-3
PZ-12
M-3
M-4 658.21
PZ-13
MW-7S 658.64
MW-7D
MW-13D
MW-13S 659.96
MW-6S 662.47
MW-10S 664.36
MW-10D
PZ-11
PZ-8
MW-3S 664.13
MW-3D
MW-11S 657.75
MW-11D
MW-14D
FR 3: 58
MW-102D
MW-102S 621.08
MW-103S 650.58
MW-103I
MW-103D
MW-107S 653.58
MW-107I 624.47
MW-5S 658.42
FR 2: 7.5
PZ-100D
PZ-100S 653.30
FR 4: 29
MW-106I 610.03
MW-106S 637.92
MW-105S 635.60
MW-105I
MW108S 619.77
MW-12D DRY
MW-12S DRY
PZ-9 657.03
MW-4S 658.29
PZ-10
MW-9D
MW-9I 653.28
MW-9S DRY
PZ-101D
PZ-101S 645.80
MW-104D
MW-104S 619.72

N

SCALE: 1" = 400'

Revision:

Project Number: 170LF00975
Drawing File: SEE LOWER LEFT
Date: 01/12/2023
Scale: AS SHOWN

| Appd By: | Ckd. By: | Drn. By: |
|---|---|---|
| | MB | BH |

Company Name:
IPL HARDING STREET STATION
3700 SOUTH HARDING STREET
INDIANAPOLIS, INDIANA


ATC GROUP SERVICES LLC
7988 CENTERPOINT DR.
SUITE 100
INDIANAPOLIS, IN 46256
PHONE +1 317 849 4990
FAX +1 317 849 4970
WWW.ATCGROUPSERVICES.COM


Drawing Title:
SHALLOW POTENTIOMETRIC SURFACE MAP
OCTOBER 29, 2021
AES INDIANA HARDING STREET STATION
3700 SOUTH HARDING STREET INDIANAPOLIS, INDIANA

Sheet:
3

K:\2021-IPL\HARDING STREET\170LF00975\170LF00975-POT SHALLOW OCT 2021.dwg, Pot Date: 1/12/2023 2:33 PM

LEGEND:

MW-1S 663.00 — MONITORING WELL Well Identification / Groundwater Elevation (ft. MSL)

PZ-11 663.51 — MONITORING WELL Well Identification / Groundwater Elevation (ft. MSL)

APPROXIMATE BOUNDARY OF ASH POND SYSTEM

668 — INFERRED GROUNDWATER ELEVATION CONTOUR CONTOUR INTERVAL: 5 ft (DASHED WHERE INFERRED)

GROUNDWATER FLOW DIRECTION

NOTE:
FR = FLOW RATE (FT/DAY)
-MW-1 THROUGH MW-14 MONITORING WELL LOCATIONS ARE BASED ON COORDINATES PROVIDED IN TABLE 1 OF THE JULY 28, 2016 SAMPLING AND ANALYSIS PLAN.
MW-15 NEST LOCATIONS BASED ON OCTOBER 5, 2018 SURVEY DATA.
-ASH POND BOUNDARY OBTAINED FROM EXHIBIT 3 IN THE HARDING STREET GENERATING STATION ASH POND SYSTEM CLOSURE AND POST-CLOSURE PLAN, REV A, JULY 28, 2016.
-PZ-100 AND PZ-101 NEST LOCATIONS BASED ON NOVEMBER, 2019 SURVEY
-MW-102, MW-103, AND MW-104 NEST LOCATIONS BASED ON MAY 11, 2020 SURVEY.
-IMAGERY PROVIDED BY MAP DATA © 2018 GOOGLE, INEGI
^ DATA NOT USED TO INFER POTENTIOMETRIC SURFACE CONTOURS

USGS GAUGING STATION 03353611
668.17 FT. MSL
10/29/2021 (08:00)

EXISTING DAM

WHITE RIVER

HARDING STREET GENERATING STATION

FORMER POND 1

FORMER POND 2

FORMER POND 3

FORMER POND 4A

FORMER POND 4B

FORMER POND 4

FR 1: 3.8

FR 2: 5.2

FR 3: 120

FR 4: 32

N

SCALE: 1" = 400'

| Revision: |
|---|

Project Number: 170LF00975
Drawing File: SEE LOWER LEFT
Date: 01/12/2023
Scale: AS SHOWN

| Appd By: | Ckd. By: | Drn. By: |
|---|---|---|
| | MB | BH |

Company Name:
IPL HARDING STREET STATION
3700 SOUTH HARDING STREET
INDIANAPOLIS, INDIANA


ATC GROUP SERVICES LLC
7988 CENTERPOINT DR.
SUITE 100
INDIANAPOLIS, IN 46256
PHONE +1 317 849 4990
FAX +1 317 849 4923
WWW.ATCGROUPSERVICES.COM


Drawing Title:
DEEP POTENTIOMETRIC SURFACE MAP
OCTOBER 29, 2021
AES INDIANA HARDING STREET STATION
3700 SOUTH HARDING STREET INDIANAPOLIS, INDIANA

Sheet:
4


This drawing and design is the property of ATC Group Services LLC and must not be loaned, copied or used directly or indirectly in any manner detrimental thereto without our written consent.



C:\2021\IPL\HARDING STREET\TIA\170F00975\TIA\170F00975-POT DEEP OCT.DWG, PM Date: 1/12/2023 2:59 PM

LEGEND:

MW-1S 663.32 — MONITORING WELL; Well Identification; Groundwater Elevation (ft. MSL)

PZ-7 670.35 — PIEZOMETER; Well Identification; Groundwater Elevation (ft. MSL)

APPROXIMATE BOUNDARY OF ASH POND SYSTEM

NOTE:
FR = FLOW RATE (FT/DAY)
-MW-1 THROUGH MW-14 MONITORING WELL LOCATIONS ARE BASED ON COORDINATES PROVIDED IN TABLE 1 OF THE JULY 28, 2016 SAMPLING AND ANALYSIS PLAN.
MW-15 NEST LOCATIONS BASED ON OCTOBER 5, 2018 SURVEY DATA.
-ASH POND BOUNDARY OBTAINED FROM EXHIBIT 3 IN THE HARDING STREET GENERATING STATION ASH POND SYSTEM CLOSURE AND POST-CLOSURE PLAN, REV.A, JULY 28, 2016.
-PZ-100 AND PZ-101 NEST LOCATIONS BASED ON NOVEMBER, 2019 SURVEY
-MW-102, MW-103, AND MW-104 NEST LOCATIONS BASED ON MAY 11, 2020 SURVEY.
-IMAGERY PROVIDED BY MAP DATA © 2018 GOOGLE, INEGI
-* DATA NOT USED TO INFER POTENTIOMETRIC SURFACE CONTOURS

650 — INFERRED GROUNDWATER ELEVATION CONTOUR; CONTOUR INTERVAL: 5 ft (DASHED WHERE INFERRED)

GROUNDWATER FLOW DIRECTION

USGS GAUGING STATION 03/353611
669.60 FT. MSL
5/2/22 (09:00)

EXISTING DAM

WHITE RIVER

HARDING STREET GENERATING STATION

FORMER POND 1

FORMER POND 2

POND 3

FORMER POND 4A

FORMER POND 4B

FORMER POND 4

P-4 667.50
P-5 668.35
P-6 667.44
P-2 665.07

MW-15S 656.46
MW-15I
MW-15D

SG-1
SG-2
HA SG-3
HA SG-4
HA SG-5

HA PZ-1 666.45
HA PZ-2 661.22
HA PZ-3 659.51
HA PZ-4 661.34
HA PZ-5 660.20

MW-1S 663.32
MW-1D
M-6 668.85
FR 1: 4.6

PZ-6
MW-2S 665.67
MW-2D
P3 PZ-1S
P3 PZ-1D 665.90
PZ-7 670.35
670

P1 PZ-1S
P1 PZ-1D 665.10
PZ-1
MW-8S 658.29
P2 PZ-1S
P2 PZ-1D 660.89
PZ-5
PZ-2

P2A/B PZ-1S
P2A/B PZ-1D 664.66
P2A/B PZ-2S
P2A/B PZ-2D 663.19
665

P2 PZ-2S
P2 PZ-2D 658.39
P2 PZ-3S
P2 PZ-3D 657.65
PZ-14
PZ-3
PZ-12
M-4 657.40
PZ-13
MW-7S 658.13
MW-7D
MW-13D
MW-13S 659.71
MW-6S 661.91
MW-10S 663.65
MW-10D
PZ-11
660

MW-11S 655.43
MW-11D
MW-14D

PZ-8
MW-3S 662.96
MW-3D

MW-5S 657.11
655

FR 3: 66
FR 2: 7.7
FR 4: 29

MW-102D
MW-102S 620.13
MW-103S 665.92*
MW-103I
MW-103D

MW-107S 652.75
MW-107I

PZ-100D
PZ-100S 651.71
650

MW-12D
MW-12S DRY
PZ-9 657.03
MW-4S DRY
PZ-10
MW-9S DRY
MW-9D
MW-9I

MW-106I
MW-106S 649.44
MW-105S 636.53
MW-105I
MW108S 639.41

PZ-101D
PZ-101S 645.24

MW-104D
MW-104S DRY

650 645 640 635 630 625 620 615 610

N

SCALE: 1" = 400'

Revision:

Project Number: 170LF00975
Drawing File: SEE LOWER LEFT
Date: 01/19/2023
Scale: AS SHOWN

| Appr'd By: | Ckd. By: | Drn. By: |
|---|---|---|
| | MB | BM |


Company Name:
IPL HARDING STREET STATION
3700 SOUTH HARDING STREET
INDIANAPOLIS, INDIANA

ATC GROUP SERVICES LLC
7988 CENTERPOINT DR.
SUITE 100
INDIANAPOLIS, IN 46256
PHONE +1 317 849 4990
FAX +1 317 849 4970
WWW.ATCGROUPSERVICES.COM

Drawing Title:
SHALLOW POTENTIOMETRIC SURFACE MAP
MAY 2, 2022
AES INDIANA HARDING STREET STATION
3700 SOUTH HARDING STREET INDIANAPOLIS, INDIANA

Sheet:
5

IN 2020 IPL HARDING STREET\170LF00975\170LF00975-POT SHALLOW MAY 22.DWG, Plot Date: 1/19/2023 10:51 AM




| | | | | | |
|---|---|---|---|---|---|
| Sheet: 9 | Drawing Title: DEEP POTENTIOMETRIC SURFACE MAP<br>MAY 2, 2022<br>AES INDIANA HARDING STREET STATION<br>3700 SOUTH HARDING STREET INDIANAPOLIS, INDIANA | ATC | ATC GROUP SERVICES LLC<br>7988 CENTERPOINT DR.<br>SUITE 100<br>INDIANAPOLIS, IN 46256<br>PHONE +1 317 849 4990<br>FAX +1 317 849 4278<br>WWW.ATCGROUPSERVICES.COM | Company Name:<br>IPL HARDING STREET STATION<br>3700 SOUTH HARDING STREET<br>INDIANAPOLIS, INDIANA | Project Number: 170LF00975<br>Scale: AS SHOWN<br>Date: 01/19/2023<br>Drawn By: BEE<br>Check By: LOWER LEFT |

# TABLES


Table 1: Well Sampling Summary
Table 2: Groundwater Elevation Data
Table 3: Summary of Monitoring Results – November 2021
Table 4: Summary of Monitoring Results – May 2022
Table 5: Summary of Soil Results – 2022 Monitoring Well Locations
Table 6: Groundwater Protection Standards Summary – November 2021 and May 2022

**Table 1**
Well Sampling Summary
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Identification | Date Installed | Upgradient/Background, Downgradient, or Nature & Extent | Number of Samples | Sample Date | Detection or Assessment Monitoring Program |
|---|---|---|---|---|---|
| MW-1S | 9/25/2015 | Downgradient | 2 | 5/9/2022<br>11/9/2022 | Assessment |
| MW-1D | 9/25/2015 | Downgradient | 2 | 5/9/2022<br>11/9/2022 | Assessment |
| MW-2S | 9/29/2015 | Downgradient | 2 | 5/4/2022<br>11/8/2022 | Assessment |
| MW-2D | 2/9/2016 | Downgradient | 2 | 5/4/2022<br>11/8/2022 | Assessment |
| MW-3S | 9/28/2015 | Downgradient | 1 | 5/2/2022 | Assessment |
| MW-3D | 2/10/2016 | Downgradient | 2 | 5/2/2022<br>11/8/2022 | Assessment |
| MW-4S | 9/28/2015 | Downgradient | 1 | 5/4/2022 | Assessment |
| MW-4SR | 11/29/2022 | Downgradient | 1 | 12/8/2022 | Assessment |
| MW-4I | 11/4/2022 | Downgradient | 1 | 12/8/2022 | Assessment |
| MW-4D | 11/3/2022 | Downgradient | 1 | 12/8/2022 | Assessment |
| MW-5S | 10/1/2015 | Downgradient | 2 | 5/4/2022<br>11/11/2022 | Assessment |
| MW-6S | 9/28/2015 | Downgradient | 2 | 5/4/2022<br>11/2/2022 | Assessment |
| MW-7S | 9/30/2015 | Downgradient | 2 | 5/4/2022<br>11/2/2022 | Assessment |
| MW-7D | 2/17/2016 | Downgradient | 2 | 5/4/2022<br>11/2/2022 | Assessment |
| MW-8S | 10/1/2015 | Downgradient | 2 | 5/13/2022<br>11/8/2022 | Assessment |
| MW-9S | 2/11/2016 | Downgradient | 0 | NS | Assessment |
| MW-9I | 2/24/2016 | Downgradient | 2 | 5/6/2022<br>11/2/2022 | Assessment |
| MW-9D | 2/11/2016 | Downgradient | 2 | 5/6/2022<br>11/2/2022 | Assessment |
| MW-10S | 2/16/2016 | Downgradient | 2 | 5/2/2022<br>11/3/2022 | Assessment |
| MW-10D | 2/16/2016 | Downgradient | 2 | 5/2/2022<br>11/3/2022 | Assessment |
| MW-11S | 2/17/2016 | Downgradient | 2 | 5/11/2022<br>11/8/2022 | Assessment |
| MW-11D | 2/18/2016 | Downgradient | 2 | 5/10/2022<br>11/7/2022 | Assessment |

**Table 1**
Well Sampling Summary
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Identification | Date Installed | Upgradient/Background, Downgradient, or Nature & Extent | Number of Samples | Sample Date | Detection or Assessment Monitoring Program |
|---|---|---|---|---|---|
| MW-12S | 2/19/2016 | Downgradient | 1 | 5/6/2022 | Assessment |
| MW-12D | 2/18/2016 | Downgradient | 2 | 5/6/2022<br>11/2/2022 | Assessment |
| MW-13S | 2/15/2016 | Downgradient | 2 | 5/4/2022<br>11/1/2022 | Assessment |
| MW-13D | 2/12/2016 | Downgradient | 2 | 5/4/2022<br>11/1/2022 | Assessment |
| MW-14D | 2/23/2016 | Downgradient | 2 | 5/11/2022<br>11/7/2022 | Assessment |
| MW-15S | 8/17/2018 | Upgradient/Background | 2 | 5/5/2022<br>11/11/2022 | Assessment |
| MW-15I | 8/17/2018 | Upgradient/Background | 2 | 5/5/2022<br>11/4/2022 | Assessment |
| MW-15D | 8/17/2018 | Upgradient/Background | 2 | 5/11/2022<br>11/4/2022 | Assessment |
| M-4 | 12/18/1986 | Nature & Extent | 2 | 5/12/2022<br>11/3/2022 | Assessment |
| MW-102S | 4/15/2020 | Nature & Extent | 1 | 5/13/2022 | Assessment |
| MW-102D | 4/15/2020 | Nature & Extent | 2 | 5/13/2022<br>11/14/2022 | Assessment |
| MW-103S | 4/8/2020 | Nature & Extent | 2 | 5/4/2022<br>11/1/2022 | Assessment |
| MW-103I | 4/8/2020 | Nature & Extent | 2 | 5/4/2022<br>11/1/2022 | Assessment |
| MW-103D | 4/8/2020 | Nature & Extent | 2 | 5/4/2022<br>11/1/2022 | Assessment |
| MW-104S | 4/17/2020 | Nature & Extent | 1 | 5/13/2022 | Assessment |
| MW-104D | 4/16/2020 | Nature & Extent | 2 | 5/13/2022<br>11/3/2022 | Assessment |
| MW-105S | 7/12/2021 | Nature & Extent | 2 | 5/11/2022<br>11/7/2022 | Assessment |
| MW-105I | 7/9/2021 | Nature & Extent | 2 | 5/11/2022<br>11/7/2022 | Assessment |

**Table 1**
Well Sampling Summary
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Identification | Date Installed | Upgradient/Background, Downgradient, or Nature & Extent | Number of Samples | Sample Date | Detection or Assessment Monitoring Program |
|---|---|---|---|---|---|
| MW-105D | 7/8/2021 | Nature & Extent | 2 | 5/11/2022<br>11/7/2022 | Assessment |
| MW-106S | 7/7/2021 | Nature & Extent | 2 | 5/5/2022<br>11/14/2022 | Assessment |
| MW-106I | 7/2/2021 | Nature & Extent | 1 | 5/12/2022 | Assessment |
| MW-106D | 7/1/2021 | Nature & Extent | 2 | 5/5/2022<br>11/14/2022 | Assessment |
| MW-107S | 6/29/2021 | Nature & Extent | 2 | 5/5/2022<br>11/2/2022 | Assessment |
| MW-107I | 6/24/2021 | Nature & Extent | 2 | 5/5/2022<br>11/2/2022 | Assessment |
| MW-107D | 6/25/2021 | Nature & Extent | 2 | 5/5/2022<br>11/2/2022 | Assessment |
| MW-108S | 7/15/2021 | Nature & Extent | 2 | 5/10/2022<br>11/8/2022 | Assessment |
| MW-108D | 7/14/2021 | Nature & Extent | 2 | 5/10/2022<br>11/8/2022 | Assessment |
| PZ-100S | 10/24/2019 | Nature & Extent | 2 | 5/13/2022<br>11/3/2022 | Assessment |
| PZ-100D | 10/23/2019 | Nature & Extent | 2 | 5/13/2022<br>11/3/2022 | Assessment |
| PZ-101S | 10/29/2019 | Nature & Extent | 2 | 5/4/2022<br>11/3/2022 | Assessment |
| PZ-101D | 10/25/2019 | Nature & Extent | 2 | 5/4/2022<br>11/2/2022 | Assessment |

Notes

NS = Not sampled during year.

MW-9S was dry in May 2022 and was not sampled.

MW-3S, MW-4S, MW-9S, MW-12S, MW-102S, MW-104S and MW-106I were dry in November 2022 and were not sampled.

**Table 2**
Groundwater Elevation Data
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Monitoring Well/Piezometer Location | Gauging Date | TOC Elevation (ft-MSL) | Depth to Water (ft) | Water Elevation (ft-MSL) |
|---|---|---|---|---|
| MW-1S | 5/2/2022 | 675.33 | 12.01 | 663.32 |
| | 10/31/2022 | | 14.72 | 660.61 |
| MW-1D | 5/2/2022 | 675.17 | 11.74 | 663.43 |
| | 10/31/2022 | | 14.44 | 660.73 |
| MW-2S | 5/2/2022 | 684.99 | 19.32 | 665.67 |
| | 10/31/2022 | | 22.12 | 662.87 |
| MW-2D | 5/2/2022 | 685.20 | 18.55 | 666.65 |
| | 10/31/2022 | | 22.32 | 662.88 |
| MW-3S | 5/2/2022 | 688.98 | 26.02 | 662.96 |
| | 10/31/2022 | | 29.59 | 659.39 |
| MW-3D | 5/2/2022 | 688.82 | 26.07 | 662.75 |
| | 10/31/2022 | | 29.63 | 659.19 |
| MW-4S | 5/2/2022 | 689.29 | Dry to top of pump (33.5 ft) | <655.79 |
| | 10/31/2022 | | 27.37 | 661.92 |
| MW-4SR | 12/8/2022 | Not Surveyed | 36.38 | Not Surveyed |
| MW-4I | 12/8/2022 | Not Surveyed | 39.13 | Not Surveyed |
| MW-4D | 12/8/2022 | Not Surveyed | 39.08 | Not Surveyed |
| MW-5S | 5/2/2022 | 689.43 | 32.32 | 657.11 |
| | 10/31/2022 | | 35.33 | 654.10 |
| MW-6S | 5/2/2022 | 695.67 | 33.76 | 661.91 |
| | 10/31/2022 | | 36.27 | 659.40 |
| MW-7S | 5/2/2022 | 696.76 | 38.63 | 658.13 |
| | 10/31/2022 | | 41.06 | 655.70 |
| MW-7D | 5/2/2022 | 696.29 | 38.21 | 658.08 |
| | 10/31/2022 | | 41.75 | 654.54 |
| MW-8S | 5/2/2022 | 672.78 | 14.49 | 658.29 |
| | 10/31/2022 | | 17.57 | 655.21 |
| MW-9S | 5/6/2022 | 689.02 | 37.4 | 651.62 |
| | 10/31/2022 | | 36.4 | 652.62 |

**Table 2**
Groundwater Elevation Data
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Monitoring Well/Piezometer Location | Gauging Date | TOC Elevation (ft-MSL) | Depth to Water (ft) | Water Elevation (ft-MSL) |
|---|---|---|---|---|
| MW-9I | 5/2/2022 | 689.11 | 36.25 | 652.86 |
| | 10/31/2022 | | 39.65 | 649.46 |
| MW-9D | 5/2/2022 | 689.27 | 36.48 | 652.79 |
| | 10/31/2022 | | 39.84 | 649.43 |
| MW-10S | 5/2/2022 | 691.10 | 27.45 | 663.65 |
| | 10/31/2022 | | 30.54 | 660.56 |
| MW-10D | 5/2/2022 | 691.28 | 27.68 | 663.60 |
| | 10/31/2022 | | 30.75 | 660.53 |
| MW-11S | 5/2/2022 | 686.17 | 30.74 | 655.43 |
| | 10/31/2022 | | 35.00 | 651.17 |
| MW-11D | 5/2/2022 | 686.17 | 29.13 | 657.04 |
| | 10/31/2022 | | 31.87 | 654.30 |
| MW-12S | 5/2/2022 | 688.82 | Dry to top of pump (36.9 ft) | <651.92 |
| | 10/31/2022 | | 39.81 | 649.01 |
| MW-12D | 5/2/2022 | 688.73 | 37.05 | 651.68 |
| | 10/31/2022 | | 39.77 | 648.96 |
| MW-13S | 5/2/2022 | 696.08 | 36.37 | 659.71 |
| | 10/31/2022 | | 38.64 | 657.44 |
| MW-13D | 5/2/2022 | 696.78 | 37.12 | 659.66 |
| | 10/31/2022 | | 39.37 | 657.41 |
| MW-14D | 5/2/2022 | 697.88 | 40.62 | 657.26 |
| | 10/31/2022 | | 43.09 | 654.79 |
| MW-15S | 5/2/2022 | 685.46 | 17.00 | 668.46 |
| | 10/31/2022 | | Dry to top of pump (20.8 ft) | <664.66 |
| MW-15I | 5/2/2022 | 685.59 | 16.40 | 669.19 |
| | 10/31/2022 | | 20.90 | 664.69 |
| MW-15D | 5/2/2022 | 685.20 | 16.43 | 668.77 |
| | 10/31/2022 | | 20.62 | 664.58 |

**Table 2**
Groundwater Elevation Data
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Monitoring Well/Piezometer Location | Gauging Date | TOC Elevation (ft-MSL) | Depth to Water (ft) | Water Elevation (ft-MSL) |
|---|---|---|---|---|
| M-4 | 5/2/2022 | 693.25 | 35.85 | 657.40 |
| | 10/31/2022 | | 38.29 | 654.96 |
| PZ-100S | 5/2/2022 | 681.79 | 30.08 | 651.71 |
| | 10/31/2022 | | 32.52 | 649.27 |
| PZ-100D | 5/2/2022 | 681.84 | 46.93 | 634.91 |
| | 10/31/2022 | | 48.86 | 632.98 |
| PZ-101S | 5/2/2022 | 689.36 | 44.12 | 645.24 |
| | 10/31/2022 | | 47.03 | 642.33 |
| PZ-101D | 5/2/2022 | 689.40 | 85.38 | 604.02 |
| | 10/31/2022 | | 85.55 | 603.85 |
| MW-102S | 5/2/2022 | 677.10 | 56.97 | 620.13 |
| | 10/31/2022 | | 58.52 | 618.58 |
| MW-102D | 5/2/2022 | 677.48 | 59.90 | 617.58 |
| | 10/31/2022 | | 60.43 | 617.05 |
| MW-103S | 5/2/2022 | 701.27 | 35.35 | 665.92 |
| | 10/31/2022 | | 35.63 | 665.64 |
| MW-103I | 5/2/2022 | 701.26 | 89.93 | 611.33 |
| | 10/31/2022 | | 90.00 | 611.26 |
| MW-103D | 5/2/2022 | 701.54 | 91.90 | 609.64 |
| | 10/31/2022 | | 93.00 | 608.54 |
| MW-104S | 5/2/2022 | 676.60 | Dry to top of pump (54.8 ft) | <621.80 |
| | 10/31/2022 | | Dry to top of pump (54.8 ft) | <621.80 |
| MW-104D | 5/2/2022 | 677.01 | 87.80 | 589.21 |
| | 10/31/2022 | | 87.94 | 589.07 |
| MW-105S | 5/2/2022 | 661.47 | 24.94 | 636.53 |
| | 10/31/2022 | | 27.15 | 634.32 |
| MW-105I | 5/2/2022 | 661.37 | 53.28 | 608.09 |
| | 10/31/2022 | | 54.15 | 607.22 |

**Table 2**
Groundwater Elevation Data
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Monitoring Well/Piezometer Location | Gauging Date | TOC Elevation (ft-MSL) | Depth to Water (ft) | Water Elevation (ft-MSL) |
|---|---|---|---|---|
| MW-105D | 5/2/2022 | 661.04 | 46.65 | 614.39 |
| | 10/31/2022 | | 60.22 | 600.82 |
| MW-106S | 5/2/2022 | 671.05 | 21.61 | 649.44 |
| | 10/31/2022 | | 33.98 | 637.07 |
| MW-106I | 5/2/2022 | 671.05 | 60.95 | 610.10 |
| | 10/31/2022 | | 61.83 | 609.22 |
| MW-106D | 5/2/2022 | 671.00 | 62.59 | 608.41 |
| | 10/31/2022 | | 62.98 | 608.02 |
| MW-107S | 5/2/2022 | 658.23 | 5.48 | 652.75 |
| | 10/31/2022 | | 36.99 | 621.24 |
| MW-107I | 5/2/2022 | 658.47 | 34.66 | 623.81 |
| | 10/31/2022 | | 35.44 | 623.03 |
| MW-107D | 5/2/2022 | 658.55 | 35.92 | 622.63 |
| | 10/31/2022 | | 36.39 | 622.16 |
| MW-108S | 5/2/2022 | 642.22 | 32.81 | 609.41 |
| | 10/31/2022 | | 32.85 | 609.37 |
| MW-108D | 5/2/2022 | 642.03 | 46.11 | 595.92 |
| | 10/31/2022 | | 46.24 | 595.79 |

Notes:

Monitoring wells MW-4SR, MW-4I, and MW-4D (installed in November 2022) had not yet been surveyed at the end of 2022.

TOC = Top of Casing

ft-MSL = feet above Mean Sea Level

ft-bgs = feet below ground surface

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-1D | MW-1S | MW-2D | MW-2S | MW-3D |
|---|---|---|---|---|---|---|
| Sample Date | | 11/3/2021 | 11/3/2021 | 11/1/2021 | 11/1/2021 | 11/1/2021 |
| Pace Lab ID | | 50302027002 | 50302027001 | 50301756002 | 50301756001 | 50301756004 |
| | | | | | | |
| Static Water Elevation | ft MSL | 664.86 | 664.75 | 667.27 | 667.22 | 664.02 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 13.17 | 12.75 | 18.95 | 19.77 | 14.71 |
| Dissolved Oxygen, Field | mg/L | 0.23 | 0.06 | 7.70 | 0.12 | 0.36 |
| Conductivity, Field | uS/cm | 900 | 1110 | 1940 | 1370 | 1040 |
| ORP, Field | mV | 4.8 | 21.5 | -7.1 | -58.9 | -31.1 |
| pH, Field | Std. Units | 7.25 | 7.28 | 7.06 | 7.30 | 7.19 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 259 | 260 | 309 | 200 | 216 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 259 | 260 | 309 | 200 | 216 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | 3.4 | 7.4 | 3.8 | 28.9 | 3.4 |
| Barium, Total | ug/L | 72 | 64.8 | 57.4 | 103 | 66.9 |
| Boron, Total | ug/L | 231 | 558 | 2020 | 413 | 393 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 95000 | 101000 | 223000 | 83100 | 107000 |
| Chloride | mg/L | 126 | 179 | 291 | 206 | 178 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 2.4 | 2.6 | 2.6 | 2.7 | 1.2 |
| Fluoride | mg/L | 0.31 | 0.31 | 0.86 | 0.5 | 0.15 |
| Iron, Total | ug/L | 2280 | 1840 | 2300 | 3800 | 1650 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 23.4 | <20.0 | 56.1 | <20.0 | <20.0 |
| Magnesium, Total | ug/L | 21800 | 27100 | 54300 | 21000 | 26100 |
| Manganese, Total | ug/L | 227 | 304 | 494 | 373 | 241 |
| Manganese, Dissolved | ug/L | 229 | 293 | 517 | 356 | 233 |
| Molybdenum, Total | ug/L | 33.6 | 28.1 | 56.4 | 38.4 | <10.0 |
| Molybdenum, Dissolved | ug/L | 33.7 | 25 | 56.8 | 38.7 | <10.0 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.28 | 1.2 | <0.15 | 0.93 | <0.15 |
| Potassium, Total | ug/L | 5690 | 5250 | 14700 | 7140 | 3850 |
| Radium-226 | pCi/L | <0.264 | <0.0676 | <0.189 | 1.11 | 0.342 |
| Radium-228 | pCi/L | 0.769 | 1.04 | 1.39 | 1.12 | 1.14 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 13300 | 10700 | 16100 | 11400 | 10200 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 93600 | 132000 | 190000 | 186000 | 77600 |
| Sulfate | mg/L | 87.8 | 135 | 453 | 167 | 76.4 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 616 | 738 | 1470 | 870 | 615 |
| Total Organic Carbon | mg/L | 2.3 | 2.6 | 2.2 | 2.8 | 1.1 |
| Total Radium | pCi/L | 1.03 | 1.11 | 1.58 | 2.23 | 1.48 |
| pH at 25 Degrees C | Std. Units | 7.5 | 7.6 | 7.1 | 7.4 | 7.3 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-3S | MW-4S | MW-5S | MW-6S | MW-7D |
|---|---|---|---|---|---|---|
| Sample Date | | 11/1/2021 | 11/1/2021 | 11/1/2021 | 11/1/2021 | 11/2/2021 |
| Pace Lab ID | | 50301756003 | 50301756007 | 50301756008 | 50301756009 | 50301927002 |
| | | | | | | |
| Static Water Elevation | ft MSL | 664.13 | 656.29 | 658.42 | 662.47 | 658.59 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 15.28 | 13.74 | 15.11 | 15.66 | 14.65 |
| Dissolved Oxygen, Field | mg/L | 0.19 | 3.66 | 0.42 | 0.41 | 0.40 |
| Conductivity, Field | uS/cm | 900 | 261.04 | 1749.2 | 1930 | 1640 |
| ORP, Field | mV | 20.2 | 74.3 | 62.1 | 24.3 | -48.0 |
| pH, Field | Std. Units | 7.07 | 6.70 | 6.96 | 6.99 | 7.58 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 279 | 406 | 291 | 426 | 221 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 279 | 406 | 291 | 426 | 221 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | 3380 |
| Antimony, Total | ug/L | 7.3 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | 1.6 | <1 | <1 | 11.8 | 457 |
| Barium, Total | ug/L | 55.4 | 80.8 | 24.3 | 117 | 53.9 |
| Boron, Total | ug/L | 194 | 3160 | 2370 | 6210 | 13900 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 99000 | 155000 | 145000 | 233000 | 190000 |
| Chloride | mg/L | 122 | 27.6 | 205 | 202 | 187 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | 1.6 | 1.8 |
| Dissolved Organic Carbon | mg/L | <1 | 1.9 | 1.7 | 1.8 | 2.2 |
| Fluoride | mg/L | 0.14 | 0.1 | 1.9 | 1.2 | 0.38 |
| Iron, Total | ug/L | <100 | <100 | <100 | 5810 | 7440 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | 23.4 | 46.2 | 73 | 103 |
| Magnesium, Total | ug/L | 20800 | 31500 | 41200 | 62900 | 41200 |
| Manganese, Total | ug/L | 1110 | <10.0 | 744 | 1690 | 486 |
| Manganese, Dissolved | ug/L | <10.0 | <10.0 | 727 | 1460 | 393 |
| Molybdenum, Total | ug/L | 46.7 | <10.0 | 152 | 186 | 688 |
| Molybdenum, Dissolved | ug/L | 34.5 | <10.0 | 147 | 150 | 684 |
| Nitrogen, Nitrate | mg/L | 2.8 | 3.4 | <0.10 | 0.77 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | <0.15 | <0.15 | 0.62 | 1 |
| Potassium, Total | ug/L | 2200 | 2100 | 7620 | 11500 | 16000 |
| Radium-226 | pCi/L | <-0.325 | <0.12 | <0.0401 | <-0.234 | 0.417 |
| Radium-228 | pCi/L | 0.591 | <-0.064 | 0.979 | <0.392 | 0.675 |
| Selenium, Total | ug/L | 3.6 | 20.3 | <1.0 | 6 | <1.0 |
| Silica, Total | ug/L | 9140 | 11800 | 13900 | 13100 | 24300 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 76200 | 22100 | 174000 | 171000 | 171000 |
| Sulfate | mg/L | 98.5 | 98.7 | 301 | 485 | 528 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 548 | 616 | 1140 | 1440 | 1300 |
| Total Organic Carbon | mg/L | <1.0 | <1.0 | 1.8 | 1.8 | 1.9 |
| Total Radium | pCi/L | <0.591 | <0.12 | 1.02 | <0.392 | 1.09 |
| pH at 25 Degrees C | Std. Units | 7.2 | 7 | 7.2 | 7 | 7.3 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-7S | MW-8S | MW-9D | MW-9I | MW-10D |
|---|---|---|---|---|---|---|
| Sample Date | | 11/2/2021 | 11/4/2021 | 11/4/2021 | 11/4/2021 | 11/2/2021 |
| Pace Lab ID | | 50301927001 | 50302158001 | 50302158003 | 50302158002 | 50301927004 |
| | | | | | | |
| Static Water Elevation | ft MSL | 658.64 | 660.92 | 653.19 | 653.28 | 664.36 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 14.14 | 15.60 | 13.00 | 13.27 | 14.65 |
| Dissolved Oxygen, Field | mg/L | 0.14 | 0.16 | 0.24 | 0.14 | 0.12 |
| Conductivity, Field | uS/cm | 1710 | 1550 | 960 | 890 | 2140 |
| ORP, Field | mV | -23.9 | 24.0 | -37.1 | -26.2 | -48.5 |
| pH, Field | Std. Units | 7.41 | 7.07 | 7.11 | 7.14 | 7.46 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 234 | 345 | 269 | 269 | 267 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 234 | 345 | 269 | 269 | 267 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | 209 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | 376 | <1 | 9 | 5.2 | 173 |
| Barium, Total | ug/L | 41.8 | 32.2 | 46.3 | 73.4 | 33.3 |
| Boron, Total | ug/L | 12200 | 10500 | 1080 | 972 | 3670 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 195000 | 226000 | 110000 | 103000 | 205000 |
| Chloride | mg/L | 220 | 138 | 86.1 | 94 | 413 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 2.3 | 2.7 | 1.1 | <1 | 2.2 |
| Fluoride | mg/L | 0.5 | 0.12 | 0.36 | 0.98 | 2 |
| Iron, Total | ug/L | 3640 | <100 | 1880 | 1010 | 1840 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 85.8 | 137 | 23 | 28.5 | 67.4 |
| Magnesium, Total | ug/L | 45800 | 84400 | 31200 | 24600 | 73400 |
| Manganese, Total | ug/L | 426 | 107 | 238 | 241 | 184 |
| Manganese, Dissolved | ug/L | 393 | 98.3 | 229 | 228 | 178 |
| Molybdenum, Total | ug/L | 625 | 270 | 41.3 | 123 | 84.1 |
| Molybdenum, Dissolved | ug/L | 623 | 274 | 42.2 | 122 | 83.2 |
| Nitrogen, Nitrate | mg/L | <0.10 | 0.51 | <0.10 | 0.2 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.82 | <0.15 | <0.15 | <0.15 | 0.29 |
| Potassium, Total | ug/L | 15100 | 21600 | 5820 | 5280 | 12900 |
| Radium-226 | pCi/L | <0.209 | <0.00 | 0.65 | 1.16 | 0.524 |
| Radium-228 | pCi/L | <0.467 | <0.336 | 0.772 | 0.637 | 0.673 |
| Selenium, Total | ug/L | <1.0 | 1.3 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 14000 | 13800 | 11600 | 11500 | 14200 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 178000 | 140000 | 73300 | 77900 | 244000 |
| Sulfate | mg/L | 500 | 610 | 129 | 79.7 | 546 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 1360 | 1520 | 629 | 562 | 1700 |
| Total Organic Carbon | mg/L | 2.2 | 1.7 | 1.1 | <1.0 | 2.2 |
| Total Radium | pCi/L | <0.676 | <0.336 | 1.42 | 1.8 | 1.2 |
| pH at 25 Degrees C | Std. Units | 7.2 | 7.2 | 7.6 | 7.5 | 7.4 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-10S | MW-11D | MW-11S | MW-12D | MW-12S |
|---|---|---|---|---|---|---|
| Sample Date | | 11/2/2021 | 11/1/2021 | 11/1/2021 | 11/1/2021 | 11/1/2021 |
| Pace Lab ID | | 50301927003 | 50301756010 | 50301756012 | 50301756013 | 50301756011 |
| | | | | | | |
| Static Water Elevation | ft MSL | 664.38 | 659.79 | 657.75 | 652.92 | DRY |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 13.91 | 12.20 | 12.64 | 16.32 | 15.97 |
| Dissolved Oxygen, Field | mg/L | 0.15 | 0.39 | 1.93 | 0.09 | 1.08 |
| Conductivity, Field | uS/cm | 2030 | 1420 | 590 | 2019.4 | 1687.8 |
| ORP, Field | mV | -32.8 | 21.3 | 35.8 | 10.4 | 48.4 |
| pH, Field | Std. Units | 7.59 | 6.90 | 7.63 | 7.12 | 6.95 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 264 | 249 | 195 | 254 | 315 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 264 | 249 | 195 | 254 | 315 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | 2.8 |
| Arsenic, Total | ug/L | 429 | 14.8 | 2.2 | 428 | 43.4 |
| Barium, Total | ug/L | 73.3 | 23.6 | 74.3 | 26.8 | 31.6 |
| Boron, Total | ug/L | 1540 | 10900 | 617 | 7730 | 5870 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 201000 | 213000 | 50300 | 218000 | 198000 |
| Chloride | mg/L | 348 | 67.3 | 25.1 | 168 | 177 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 2.4 | 1.3 | <1 | 1.3 | 2.6 |
| Fluoride | mg/L | 2.5 | 0.36 | 1.4 | 1.3 | 1.8 |
| Iron, Total | ug/L | 1190 | 5300 | 194 | 2340 | <100 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 53.3 | 150 | <20.0 | 95.5 | 73.2 |
| Magnesium, Total | ug/L | 44600 | 49900 | 29600 | 51400 | 57000 |
| Manganese, Total | ug/L | 385 | 39.5 | <10 | 316 | 393 |
| Manganese, Dissolved | ug/L | 359 | 35.6 | <10 | 343 | 404 |
| Molybdenum, Total | ug/L | 71.2 | <10.0 | 76.1 | 176 | 144 |
| Molybdenum, Dissolved | ug/L | 69 | <10.0 | 70.8 | 171 | 137 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | 0.24 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 1.4 | <0.15 | <0.15 | 0.57 | <0.15 |
| Potassium, Total | ug/L | 9900 | 3010 | 2000 | 13400 | 9480 |
| Radium-226 | pCi/L | <0.179 | <0.0864 | 0.497 | <0.205 | <0.00 |
| Radium-228 | pCi/L | 0.985 | 1 | 0.571 | 0.755 | 0.912 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | 10.7 |
| Silica, Total | ug/L | 13200 | 16500 | 13600 | 13700 | 15600 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 257000 | 74200 | 20800 | 166000 | 157000 |
| Sulfate | mg/L | 483 | 530 | 103 | 614 | 486 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 1580 | 1160 | 421 | 1450 | 1350 |
| Total Organic Carbon | mg/L | 2.3 | <1.0 | <1.0 | 1.1 | 1.3 |
| Total Radium | pCi/L | 1.16 | 1.09 | 1.07 | 0.96 | 0.912 |
| pH at 25 Degrees C | Std. Units | 7.6 | 7.1 | 7.6 | 7.5 | 7.3 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-13D | MW-13S | MW-14D | MW-15D | MW-15I |
|---|---|---|---|---|---|---|
| Sample Date | | 11/1/2021 | 11/2/2021 | 11/1/2021 | 11/3/2021 | 11/3/2021 |
| Pace Lab ID | | 50301756014 | 50301927005 | 50301756015 | 50302027005 | 50302027004 |
| | | | | | | |
| Static Water Elevation | ft MSL | 659.95 | 659.96 | 658.94 | 669.38 | 669.50 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 16.01 | 15.61 | 14.05 | 13.94 | 13.89 |
| Dissolved Oxygen, Field | mg/L | 0.19 | 0.04 | 0.38 | 0.48 | 0.09 |
| Conductivity, Field | uS/cm | 1900.0 | 1740.0 | 3240.0 | 660.0 | 670.0 |
| ORP, Field | mV | -74.70 | -45.20 | -64.20 | -2.00 | 26.10 |
| pH, Field | Std. Units | 7.70 | 7.51 | 7.89 | 7.31 | 7.09 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 182 | 264 | 133 | 325 | 318 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 182 | 264 | 133 | 325 | 318 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | 328 | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | 231 | 368 | 113 | 1.2 | <1 |
| Barium, Total | ug/L | 30.7 | 44.2 | 51.5 | 69.2 | 67.9 |
| Boron, Total | ug/L | 11400 | 8620 | 42400 | 127 | 101 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 191000 | 179000 | 504000 | 106000 | 116000 |
| Chloride | mg/L | 299 | 282 | 283 | 27 | 19.9 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 2.2 | 4 | 2 | <1 | 1.1 |
| Fluoride | mg/L | 0.55 | 0.83 | 0.2 | <0.1 | <0.1 |
| Iron, Total | ug/L | 1940 | 1970 | 2460 | 1230 | <100 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 84.7 | 73.3 | 751 | <20.0 | <20.0 |
| Magnesium, Total | ug/L | 53200 | 51900 | 123000 | 30700 | 29900 |
| Manganese, Total | ug/L | 196 | 434 | 293 | 118 | 16.4 |
| Manganese, Dissolved | ug/L | 182 | 385 | 288 | 112 | 16 |
| Molybdenum, Total | ug/L | 599 | 553 | 257 | <10.0 | <10.0 |
| Molybdenum, Dissolved | ug/L | 554 | 562 | 242 | <10.0 | <10.0 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | 9.2 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.4 |
| Phosphate as P04 | mg/L | 0.34 | 0.45 | 0.52 | <0.15 | <0.15 |
| Potassium, Total | ug/L | 15800 | 13200 | 55200 | 2050 | 1450 |
| Radium-226 | pCi/L | 0.37 | <0.0749 | <0.117 | 0.373 | 0.429 |
| Radium-228 | pCi/L | 1.09 | 1.93 | 1.37 | 0.761 | 0.747 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 13300 | 14000 | 11000 | 12300 | 13100 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 180000 | 185000 | 290000 | 19500 | 13500 |
| Sulfate | mg/L | 484 | 434 | 1830 | 61.5 | 39.3 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 1430 | 1340 | 3380 | 451 | 456 |
| Total Organic Carbon | mg/L | 1.8 | 3.2 | 1.9 | <1.0 | <1.0 |
| Total Radium | pCi/L | 1.46 | 2 | 1.49 | 1.13 | 1.18 |
| pH at 25 Degrees C | Std. Units | 7.6 | 7.4 | 7.5 | 7.4 | 7.4 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-15S | M-4 | MW-102D | MW-103D | MW-103I |
|---|---|---|---|---|---|---|
| Sample Date | | 11/3/2021 | 11/4/2021 | 11/8/2021 | 11/5/2021 | 11/3/2021 |
| Pace Lab ID | | 50302027003 | 50302158005 | 50302256001 | 50302159001 | 50302028002 |
| | | | | | | |
| Static Water Elevation | ft MSL | 669.39 | 658.21 | 617.38 | 611.53 | 614.34 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 15.55 | 14.79 | 16.49 | 12.54 | 11.85 |
| Dissolved Oxygen, Field | mg/L | 4.00 | 0.15 | 1.43 | 0.98 | 1.94 |
| Conductivity, Field | uS/cm | 790.0 | 1440.0 | 2711.6 | 950.0 | 960.0 |
| ORP, Field | mV | 45.30 | -23.10 | -140.80 | -63.90 | -39.60 |
| pH, Field | Std. Units | 7.18 | 7.45 | 7.56 | 7.31 | 7.38 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 349 | 392 | 96.4 | 248 | 281 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 349 | 392 | 96.4 | 248 | 281 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | <1 | 867 | 50 | <1 | <1 |
| Barium, Total | ug/L | 61.2 | 151 | 62.8 | 321 | 221 |
| Boron, Total | ug/L | 111 | 19000 | 21300 | 357 | 263 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 117000 | 262000 | 310000 | 89100 | 96600 |
| Chloride | mg/L | 53 | 100 | 164 | 146 | 147 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | <1 | 5.5 | 2.1 | 2.9 | 3.5 |
| Fluoride | mg/L | <0.1 | 0.17 | 0.15 | 0.13 | 0.18 |
| Iron, Total | ug/L | <100 | 4150 | 5030 | 2190 | 1670 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | 235 | 66.2 | <20.0 | <20.0 |
| Magnesium, Total | ug/L | 30000 | 47600 | 60800 | 29600 | 29300 |
| Manganese, Total | ug/L | <10 | 807 | 461 | 132 | 303 |
| Manganese, Dissolved | ug/L | <10 | 785 | 446 | 131 | 300 |
| Molybdenum, Total | ug/L | <10.0 | 266 | 512 | <10.0 | <10.0 |
| Molybdenum, Dissolved | ug/L | <10.0 | 265 | 505 | <10.0 | <10.0 |
| Nitrogen, Nitrate | mg/L | 2.8 | <0.10 | <0.10 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.17 | 2.8 | 0.64 | <0.15 | <0.15 |
| Potassium, Total | ug/L | 2130 | 18600 | 14900 | 5500 | 7590 |
| Radium-226 | pCi/L | 0.488 | 1.15 | 0.439 | 1.02 | 1.20 |
| Radium-228 | pCi/L | <0.0506 | 1.31 | <0.529 | <0.381 | 0.935 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 12700 | 13000 | 12900 | 12600 | 10900 |
| Silicon | ug/L | NS | NS | 6040 | NS | NS |
| Sodium, Total | ug/L | 42800 | 113000 | 167000 | 80600 | 73700 |
| Sulfate | mg/L | 55.7 | 525 | 1180 | 39.2 | 25 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 542 | 1370 | 1990 | 581 | 597 |
| Total Organic Carbon | mg/L | <1.0 | 7.8 | 1.8 | 2.9 | 3.5 |
| Total Radium | pCi/L | <0.539 | 2.46 | 0.968 | 1.4 | 2.14 |
| pH at 25 Degrees C | Std. Units | 7.4 | 7.5 | 7.5 | 7.6 | 7.5 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-103S | MW-104D | MW-105D | MW-105I | MW-105S |
|---|---|---|---|---|---|---|
| Sample Date | | 11/3/2021 | 11/2/2021 | 11/5/2021 | 11/2/2021 | 11/2/2021 |
| Pace Lab ID | | 50302028001 | 50301920005 | 50302159002 | 50301920007 | 50301920006 |
| | | | | | | |
| Static Water Elevation | ft MSL | 665.56 | 590.19 | 601.29 | 608.25 | 635.60 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 13.11 | 15.10 | 13.97 | 13.50 | 13.83 |
| Dissolved Oxygen, Field | mg/L | 0.24 | 2.50 | 0.19 | 0.40 | 0.16 |
| Conductivity, Field | uS/cm | 1640.0 | 1382.7 | 910.0 | 930.0 | 2180.0 |
| ORP, Field | mV | -3.20 | 67.00 | -55.90 | -49.80 | -40.10 |
| pH, Field | Std. Units | 6.83 | 6.73 | 7.17 | 7.12 | 7.06 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 605 | 348 | 254 | 319 | 267 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 605 | 348 | 254 | 319 | 267 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | 1500 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | 14.5 | <1 | 4.6 | 2.4 | 5.8 |
| Barium, Total | ug/L | 63.7 | 52.1 | 326 | 336 | 31.6 |
| Boron, Total | ug/L | 845 | 3460 | 628 | 587 | 21000 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 268000 | 224000 | 106000 | 127000 | 333000 |
| Chloride | mg/L | 65.2 | 115 | 113 | 97.3 | 113 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | 2.7 | <1 | <1 | 1.2 | <1 |
| Dissolved Organic Carbon | mg/L | 5.6 | 2 | 1.9 | 2.6 | 2.1 |
| Fluoride | mg/L | 0.17 | 0.12 | 0.2 | 0.14 | 0.3 |
| Iron, Total | ug/L | 11800 | 305 | 6010 | 7490 | 8330 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | 24.2 | <20.0 | <20.0 | 300 |
| Magnesium, Total | ug/L | 77200 | 60000 | 26000 | 29900 | 81300 |
| Manganese, Total | ug/L | 334 | 405 | 125 | 190 | 192 |
| Manganese, Dissolved | ug/L | 327 | 336 | 120 | 117 | 176 |
| Molybdenum, Total | ug/L | 17.3 | <10.0 | 12.2 | <10.0 | 64.2 |
| Molybdenum, Dissolved | ug/L | 17.3 | <10.0 | 13 | <10.0 | 61.2 |
| Nitrogen, Nitrate | mg/L | <0.10 | 0.13 | <0.10 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | <0.15 | 0.39 | 0.3 | <0.15 |
| Potassium, Total | ug/L | 2520 | 7460 | 5280 | 6140 | 17000 |
| Radium-226 | pCi/L | <0.0114 | <0.213 | 1.00 | 1.02 | 0.648 |
| Radium-228 | pCi/L | 1.12 | <-0.0312 | 0.85 | 1.18 | 1.22 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 24100 | 9260 | 12700 | 17500 | 16600 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 49600 | 84200 | 69300 | 65200 | 126000 |
| Sulfate | mg/L | 356 | 455 | 87.8 | 74 | 1020 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 1280 | 1160 | 590 | 594 | 1890 |
| Total Organic Carbon | mg/L | 5.3 | <1.0 | 1.8 | 1.8 | 1.3 |
| Total Radium | pCi/L | 1.13 | <0.213 | 1.85 | 2.2 | 1.87 |
| pH at 25 Degrees C | Std. Units | 6.8 | 7.3 | 7.4 | 7.5 | 7.3 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-106D | MW-106I | MW-106S | MW-107D | MW-107I |
|---|---|---|---|---|---|---|
| Sample Date | | 11/3/2021 | 11/3/2021 | 11/3/2021 | 11/5/2021 | 11/5/2021 |
| Pace Lab ID | | 50302028007 | 50302028006 | 50302028005 | 50302159004 | 50302159003 |
| | | | | | | |
| Static Water Elevation | ft MSL | 608.40 | 610.03 | 637.92 | 622.64 | 624.47 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 14.20 | 15.61 | 16.36 | 13.13 | 14.18 |
| Dissolved Oxygen, Field | mg/L | 0.43 | 0.18 | 0.06 | 2.31 | 1.35 |
| Conductivity, Field | uS/cm | 2363.8 | 2270.4 | 1766.8 | 1490 | 900 |
| ORP, Field | mV | 137.1 | 69.4 | 47.6 | 24.3 | -30 |
| pH, Field | Std. Units | 7.19 | 7.13 | 7.09 | 7.17 | 7.35 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 214 | 236 | 204 | 194 | 307 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 214 | 236 | 204 | 194 | 307 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | 291 | <200 | <200 | 243 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | 227 | 92.6 | 3.2 | 2.1 | 3.6 |
| Barium, Total | ug/L | 32.5 | 68.6 | 25.8 | 70 | 222 |
| Boron, Total | ug/L | 14700 | 12900 | 548 | 9680 | 3490 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 271000 | 253000 | 289000 | 261000 | 185000 |
| Chloride | mg/L | 283 | 258 | 23.5 | 214 | 147 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | 1.1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 2.8 | 1.9 | <1 | 3 | 4.7 |
| Fluoride | mg/L | 0.24 | 0.3 | 0.38 | 0.21 | 0.29 |
| Iron, Total | ug/L | 3860 | 7240 | 1130 | 7960 | 6880 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 121 | 98.3 | 33.2 | 53.5 | <20.0 |
| Magnesium, Total | ug/L | 54100 | 55100 | 111000 | 49400 | 55100 |
| Manganese, Total | ug/L | 272 | 500 | 976 | 366 | 243 |
| Manganese, Dissolved | ug/L | 260 | 484 | 935 | 346 | 227 |
| Molybdenum, Total | ug/L | 262 | 292 | 23.2 | 140 | 15.4 |
| Molybdenum, Dissolved | ug/L | 270 | 298 | 23.2 | 161 | 18.8 |
| Nitrogen, Nitrate | mg/L | 0.13 | <0.10 | 0.57 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.78 | 0.81 | <0.15 | 0.51 | 0.66 |
| Potassium, Total | ug/L | 14800 | 15100 | 7460 | 9880 | 2930 |
| Radium-226 | pCi/L | 1.02 | <0.191 | 0.337 | 0.908 | 0.585 |
| Radium-228 | pCi/L | <0.227 | 0.89 | <0.415 | 0.644 | 0.859 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 14600 | 15600 | 9430 | 17500 | 20700 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 218000 | 212000 | 24700 | 174000 | 72600 |
| Sulfate | mg/L | 723 | 691 | 947 | 696 | 312 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 1790 | 1680 | 1670 | 1630 | 982 |
| Total Organic Carbon | mg/L | 1.8 | 1.8 | <1.0 | 3.1 | 4.9 |
| Total Radium | pCi/L | 1.25 | 1.08 | 0.752 | 1.55 | 1.44 |
| pH at 25 Degrees C | Std. Units | 7.3 | 7.2 | 7.3 | 7.2 | 7.4 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-107S | MW-108D | MW-108S | PZ-100D | PZ-100S |
|---|---|---|---|---|---|---|
| Sample Date | | 11/8/2021 | 11/2/2021 | 11/2/2021 | 11/2/2021 | 11/2/2021 |
| Pace Lab ID | | 50302256004 | 50301920009 | 50301920008 | 50301920002 | 50301920001 |
| | | | | | | |
| Static Water Elevation | ft MSL | 653.58 | 596.38 | 609.77 | 635.74 | 653.30 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 17.02 | 13.89 | 11.65 | 15.53 | 15.53 |
| Dissolved Oxygen, Field | mg/L | 0.07 | 0.67 | 0.36 | 1.30 | 0.80 |
| Conductivity, Field | uS/cm | 2380 | 2250 | 2410 | 1650.6 | 2097.9 |
| ORP, Field | mV | -34.0 | -52.7 | -29.4 | 62.30 | 30.10 |
| pH, Field | Std. Units | 7.19 | 7.26 | 7.01 | 7.41 | 7.09 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 201 | 257 | 304 | 222 | 312 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 201 | 257 | 304 | 222 | 312 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Arsenic, Total | ug/L | <1 | <1 | <1 | 59.7 | 2.3 |
| Barium, Total | ug/L | 22.4 | 46.3 | 39.2 | 54.5 | 32.6 |
| Boron, Total | ug/L | 7120 | 4440 | 2450 | 7500 | 2290 |
| Cadmium, Total | ug/L | <2 | <2 | <2 | <2 | <2 |
| Calcium, Total | ug/L | 246000 | 230000 | 261000 | 211000 | 161000 |
| Chloride | mg/L | 296 | 285 | 275 | 204 | 314 |
| Chromium, Total | ug/L | <10 | <10 | <10 | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 | <1 | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 1.6 | 1.8 | 1.8 | 1.9 | 2.9 |
| Fluoride | mg/L | 0.65 | 0.35 | 0.54 | 0.37 | 1.6 |
| Iron, Total | ug/L | 2270 | 5530 | 3940 | 3110 | 1750 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 82.5 | 95.2 | 87.4 | 76.9 | 63.2 |
| Magnesium, Total | ug/L | 84800 | 61200 | 84200 | 52200 | 56300 |
| Manganese, Total | ug/L | 455 | 384 | 480 | 228 | 353 |
| Manganese, Dissolved | ug/L | 447 | 366 | 462 | 214 | 326 |
| Molybdenum, Total | ug/L | 82.5 | 149 | 116 | 164 | 133 |
| Molybdenum, Dissolved | ug/L | 80.3 | 148 | 118 | 161 | 132 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | 0.29 | 0.16 | 0.42 | <0.15 |
| Potassium, Total | ug/L | 12800 | 14400 | 14800 | 11100 | 10700 |
| Radium-226 | pCi/L | 0.526 | <0.321 | <0.0646 | 0.711 | <0.124 |
| Radium-228 | pCi/L | 0.977 | <0.291 | 0.636 | 0.919 | 2.29 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 12700 | 13100 | 13700 | 11700 | 14600 |
| Silicon | ug/L | NS | NS | NS | NS | NS |
| Sodium, Total | ug/L | 242000 | 219000 | 208000 | 152000 | 240000 |
| Sulfate | mg/L | 834 | 639 | 784 | 547 | 397 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 1830 | 1660 | 1880 | 1370 | 1300 |
| Total Organic Carbon | mg/L | 1.5 | 1.8 | 1.7 | 1.6 | 2.5 |
| Total Radium | pCi/L | 1.5 | <0.612 | <0.701 | 1.63 | 2.41 |
| pH at 25 Degrees C | Std. Units | 7.7 | 7.5 | 7.5 | 8 | 7.8 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 3**
Summary of Monitoring Results - November 2021
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | PZ-101D | PZ-101S |
|---|---|---|---|
| Sample Date | | 11/2/2021 | 11/2/2021 |
| Pace Lab ID | | 50301920004 | 50301920003 |
| | | | |
| Static Water Elevation | ft MSL | 605.44 | 645.80 |
| | | | |
| **Field Parameters** | **Units** | | |
| Temperature | °C | 15.44 | 14.82 |
| Dissolved Oxygen, Field | mg/L | 1.74 | 0.88 |
| Conductivity, Field | uS/cm | 1157.5 | 1252.0 |
| ORP, Field | mV | 23.90 | 0.70 |
| pH, Field | Std. Units | 7.16 | 7.16 |
| | | | |
| **Analytical Data** | | | |
| Alkalinity, Total as CaCO3 | mg/L | 256 | 289 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 256 | 289 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 |
| Antimony, Total | ug/L | <1 | <1 |
| Arsenic, Total | ug/L | 4 | 18.1 |
| Barium, Total | ug/L | 51.5 | 118 |
| Boron, Total | ug/L | 5240 | 5350 |
| Cadmium, Total | ug/L | <2 | <2 |
| Calcium, Total | ug/L | 124000 | 147000 |
| Chloride | mg/L | 108 | 97.9 |
| Chromium, Total | ug/L | <10 | <10 |
| Cobalt, Total | ug/L | <1 | <1 |
| Dissolved Organic Carbon | mg/L | 1.5 | 2.6 |
| Fluoride | mg/L | 0.2 | 0.19 |
| Iron, Total | ug/L | 2070 | 4890 |
| Lead, Total | ug/L | <10.0 | <10.0 |
| Lithium, Total | ug/L | 93.6 | 69.4 |
| Magnesium, Total | ug/L | 29800 | 41000 |
| Manganese, Total | ug/L | 268 | 698 |
| Manganese, Dissolved | ug/L | 253 | 665 |
| Molybdenum, Total | ug/L | 229 | 116 |
| Molybdenum, Dissolved | ug/L | 228 | 120 |
| Nitrogen, Nitrate | mg/L | 0.12 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | 0.27 |
| Potassium, Total | ug/L | 10200 | 5810 |
| Radium-226 | pCi/L | <0.185 | 0.434 |
| Radium-228 | pCi/L | 0.872 | 0.762 |
| Selenium, Total | ug/L | <1.0 | <1.0 |
| Silica, Total | ug/L | 9820 | 12400 |
| Silicon | ug/L | NS | NS |
| Sodium, Total | ug/L | 84300 | 80600 |
| Sulfate | mg/L | 230 | 288 |
| Sulfide | mg/L | <0.10 | <0.10 |
| Total Dissolved Solids | mg/L | 762 | 836 |
| Total Organic Carbon | mg/L | <1.0 | 1.3 |
| Total Radium | pCi/L | 1.06 | 1.2 |
| pH at 25 Degrees C | Std. Units | 7.9 | 7.9 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-1D | MW-1S | MW-2D | MW-2S | MW-3D |
|---|---|---|---|---|---|---|
| Sample Date | | 5/9/2022 | 5/9/2022 | 5/4/2022 | 5/4/2022 | 5/2/2022 |
| Pace Lab ID | | 50316084002 | 50316084001 | 50315730007 | 50315730005 | 50315350003 |
| | | | | | | |
| Static Water Elevation | ft MSL | 663.43 | 663.32 | 666.65 | 665.67 | 662.75 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 18.77 | 18.04 | 11.20 | 9.37 | 13.14 |
| Dissolved Oxygen, Field | mg/L | 2.12 | 0.01 | 0.19 | 0.04 | 0.16 |
| Conductivity, Field | uS/cm | 811.8 | 897.4 | 1842.6 | 1193.60 | 797.33 |
| ORP, Field | mV | -104.7 | -126.0 | -30.6 | -81.9 | -55.8 |
| pH, Field | Std. Units | 7.33 | 7.32 | 6.89 | 7.19 | 6.98 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 259 | 260 | 353 | 295 | 236 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 259 | 260 | 353 | 294 | 236 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | 4.5 | 9.6 | 4.0 | 8.8 | 3.3 |
| Barium, Total | ug/L | 78.0 | 69.9 | 44.2 | 97.1 | 66.0 |
| Beryllium, Total | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Boron, Total | ug/L | 288 | 375 | 1950 | 396 | 250 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 85300 | 92200 | 243000 | 100000 | 62900 |
| Chloride | mg/L | 93.7 | 124 | 194 | 110 | 104 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.3 | 2.3 | 1.6 | 1.7 | 2.0 |
| Fluoride | mg/L | 0.42 | 0.41 | 0.95 | 0.39 | 0.14 |
| Iron, Total | ug/L | 2270 | 3380 | 2650 | 1120 | 970 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | <20.0 | 49.4 | <20.0 | <20.0 |
| Magnesium, Total | ug/L | 19100 | 23600 | 51200 | 30800 | 15200 |
| Manganese, Total | ug/L | 197 | 268 | 481 | 382 | 157 |
| Manganese, Dissolved | ug/L | 189 | 250 | 459 | 395 | 162 |
| Mercury | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Molybdenum, Total | ug/L | 37.7 | 25.9 | 52.8 | 15.5 | <10.0 |
| Molybdenum, Dissolved | ug/L | 37.1 | 25.2 | 53.4 | 15.8 | <10.0 |
| Nitrogen, Nitrate | mg/L | 0.12 | <0.10 | <0.10 | 0.15 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.3 | 2 | <0.15 | 0.73 | <0.15 |
| Potassium, Total | ug/L | 6300 | 5790 | 10800 | 4140 | 3040 |
| Radium-226 | pCi/L | 0.408 | 0.559 | 1.35 | 0.909 | 0.278 |
| Radium-228 | pCi/L | 0.603 | <0.397 | 0.534 | 0.756 | 0.726 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 15400 | 12600 | 15100 | 8450 | 9630 |
| Sodium, Total | ug/L | 60300 | 63700 | 140000 | 106000 | 76600 |
| Sulfate | mg/L | 48.2 | 56.1 | 406 | 113 | 38.5 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Total Dissolved Solids | mg/L | 470 | 529 | 1280 | 678 | 441 |
| Total Organic Carbon | mg/L | 2.1 | 2.0 | 1.8 | 2.0 | 1.3 |
| Total Radium | pCi/L | 1.01 | 0.956 | 1.88 | 1.67 | 1.00 |
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 7.3 | 7.7 | 7.6 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-3S | MW-4S | MW-5S | MW-6S | MW-7D |
|---|---|---|---|---|---|---|
| Sample Date | | 5/2/2022 | 5/4/2022 | 5/4/2022 | 5/4/2022 | 5/4/2022 |
| Pace Lab ID | | 50315350004 | 50315730001 | 50315730002 | 50315730003 | 50315730004 |
| | | | | | | |
| Static Water Elevation | ft MSL | 662.96 | Dry to top of pump (<655.79) | 657.11 | 661.91 | 658.08 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 12.48 | 13.45 | 15.15 | 16.17 | 16.32 |
| Dissolved Oxygen, Field | mg/L | 2.55 | 4.48 | 1.33 | 0.81 | 0.18 |
| Conductivity, Field | uS/cm | 762.69 | 1463.2 | 2111.1 | 2048.1 | 1977.2 |
| ORP, Field | mV | 78.0 | 57.3 | 67.4 | -0.6 | -124.9 |
| pH, Field | Std. Units | 6.87 | 6.74 | 7.21 | 6.88 | 7.42 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 242 | 452 | 364 | 528 | 248 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 242 | 452 | 364 | 528 | 248 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | 4.9 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | 1.3 | 1.1 | <1.0 | 6.9 | 484 |
| Barium, Total | ug/L | 31.4 | 90.7 | 37.4 | 132 | 42.4 |
| Beryllium, Total | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Boron, Total | ug/L | 447 | 3510 | 2460 | 6290 | 14300 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 89700 | 275000 | 233000 | 279000 | 241000 |
| Chloride | mg/L | 56.6 | 9.0 | 231 | 129 | 174 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | 1.5 | <1.0 |
| Dissolved Organic Carbon | mg/L | 1.8 | 1.2 | 2.3 | 3.4 | 1.9 |
| Fluoride | mg/L | <0.10 | <0.10 | 1.8 | 1.3 | 0.51 |
| Iron, Total | ug/L | <100 | <100 | <100 | 4190 | 2020 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | <0.20 | 0.23 | 0.21 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | <20.0 | 46.5 | 71.2 | 100 |
| Magnesium, Total | ug/L | 20600 | 53500 | 58800 | 72500 | 46800 |
| Manganese, Total | ug/L | 60 | <10.0 | 1060 | 1900 | 493 |
| Manganese, Dissolved | ug/L | <10.0 | <10.0 | 1120 | 1870 | 496 |
| Mercury | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Molybdenum, Total | ug/L | 32.9 | <10.0 | 122 | 150 | 592 |
| Molybdenum, Dissolved | ug/L | 34.7 | <10.0 | 131 | 158 | 615 |
| Nitrogen, Nitrate | mg/L | 0.41 | 4 | <0.10 | 0.67 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | <0.15 | <0.15 | 0.16 | 0.89 |
| Potassium, Total | ug/L | 1390 | 2150 | 8500 | 11700 | 16000 |
| Radium-226 | pCi/L | 0.369 | <0.131 | <0.206 | <0.00 | 0.479 |
| Radium-228 | pCi/L | <0.162 | 0.492 | 0.806 | 0.508 | 0.518 |
| Selenium, Total | ug/L | 26.4 | 119 | <1.0 | 4.4 | <1.0 |
| Silica, Total | ug/L | 7270 | 13700 | 15400 | 14000 | 13200 |
| Sodium, Total | ug/L | 31000 | 14600 | 171000 | 127000 | 167000 |
| Sulfate | mg/L | 71.5 | 415 | 574 | 572 | 671 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Total Dissolved Solids | mg/L | 457 | 1060 | 1500 | 1520 | 1480 |
| Total Organic Carbon | mg/L | <1.0 | <1.0 | 2.4 | 2.9 | 2.3 |
| Total Radium | pCi/L | 0.531 | <0.623 | 1.01 | <0.508 | 0.997 |
| pH at 25 Degrees C | Std. Units | 7.4 | 7.1 | 7.3 | 7.1 | 7.6 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-7S | MW-8S | MW-9D | MW-9I | MW-10D |
|---|---|---|---|---|---|---|
| Sample Date | | 5/4/2022 | 5/13/2022 | 5/6/2022 | 5/6/2022 | 5/2/2022 |
| Pace Lab ID | | 50315730006 | 50316507001 | 50315857002 | 50315857001 | 50315350001 |
| | | | | | | |
| Static Water Elevation | ft MSL | 658.13 | 658.29 | 652.79 | 652.86 | 663.60 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 16.28 | 13.76 | 14.35 | 13.84 | 15.95 |
| Dissolved Oxygen, Field | mg/L | 0.13 | 2.44 | 1.92 | 1.74 | 0.18 |
| Conductivity, Field | uS/cm | 1878.4 | 1759.8 | 1157.7 | 976.7 | 3044.7 |
| ORP, Field | mV | -113.3 | 150.0 | -68.2 | 33.6 | -153.0 |
| pH, Field | Std. Units | 7.34 | 6.79 | 7.20 | 7.32 | 7.26 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 252 | 436 | 262 | 268 | 279 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 252 | 436 | 262 | 268 | 279 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | 374 | <1.0 | 21.3 | 11.3 | 140 |
| Barium, Total | ug/L | 37.7 | 36.8 | 56 | 78.1 | 33.0 |
| Beryllium, Total | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Boron, Total | ug/L | 12300 | 8280 | 1260 | 1350 | 2190 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 196000 | 232000 | 134000 | 104000 | 193000 |
| Chloride | mg/L | 186 | 96.8 | 127 | 123 | 504 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.0 | 1.6 | 2.3 | 1.0 | 2.6 |
| Fluoride | mg/L | 0.72 | <0.10 | 0.48 | 1.2 | 1.9 |
| Iron, Total | ug/L | 2990 | <100 | 1900 | 927 | 1880 |
| Iron, Ferrous | mg/L | 0.24 | <0.20 | <0.20 | 0.65 | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 86.7 | 101 | 22.6 | 25.6 | 65.6 |
| Magnesium, Total | ug/L | 43800 | 70800 | 35700 | 27300 | 69100 |
| Manganese, Total | ug/L | 392 | 18.3 | 283 | 238 | 163 |
| Manganese, Dissolved | ug/L | 395 | 19.1 | 278 | 246 | 176 |
| Mercury | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Molybdenum, Total | ug/L | 582 | 165 | 47.5 | 111 | 82.4 |
| Molybdenum, Dissolved | ug/L | 594 | 177 | 47.5 | 109 | 91.2 |
| Nitrogen, Nitrate | mg/L | <0.10 | 0.84 | 0.67 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.66 | <0.15 | <0.15 | <0.15 | 0.32 |
| Potassium, Total | ug/L | 14600 | 15300 | 6200 | 6100 | 11200 |
| Radium-226 | pCi/L | <0.0784 | <0.0805 | <0.229 | 0.328 | 0.30 |
| Radium-228 | pCi/L | 0.711 | 0.514 | 0.302 | 0.783 | 0.928 |
| Selenium, Total | ug/L | <1.0 | 5.2 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 14300 | 12200 | 11800 | 11000 | 13400 |
| Sodium, Total | ug/L | 167000 | 89200 | 77900 | 76900 | 355000 |
| Sulfate | mg/L | 578 | 571 | 200 | 106 | 669 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Total Dissolved Solids | mg/L | 1360 | 1440 | 724 | 628 | 1960 |
| Total Organic Carbon | mg/L | 2.1 | 1.2 | <1.0 | <1.0 | 2.5 |
| Total Radium | pCi/L | 0.789 | 0.595 | <0.531 | 1.11 | 1.23 |
| pH at 25 Degrees C | Std. Units | 7.6 | 6.9 | 7.5 | 7.5 | 7.6 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-10S | MW-11S | MW-11D | MW-12D | MW-12S |
|---|---|---|---|---|---|---|
| Sample Date | | 5/2/2022 | 5/11/2022 | 5/10/2022 | 5/6/2022 | 5/6/2022 |
| Pace Lab ID | | 50315350002 | 50316356003 | 50316219001 | 50315857004 | 50315857003 |
| | | | | | | |
| Static Water Elevation | ft MSL | 663.65 | 655.43 | 657.04 | 651.68 | Dry to top of pump (<651.92) |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 15.65 | 21.06 | 14.06 | 15.84 | 15.40 |
| Dissolved Oxygen, Field | mg/L | 0.13 | 8.83 | 0.10 | 0.14 | 1.41 |
| Conductivity, Field | uS/cm | 1983.0 | 8.11 | 1534.4 | 1844.8 | 1589.2 |
| ORP, Field | mV | -71.4 | 43.7 | -94.2 | -101.5 | 44.1 |
| pH, Field | Std. Units | 7.37 | 6.22 | 7.08 | 7.17 | 7.16 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 272 | 309 | 264 | 295 | 344 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 272 | 309 | 264 | 295 | 344 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2 | <2 |
| Aluminum, Total | ug/L | <200 | 10100 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | 2 |
| Arsenic, Total | ug/L | 448 | 10.5 | 16.1 | 387 | 46 |
| Barium, Total | ug/L | 75.8 | 175 | 25.6 | 26.7 | 31.1 |
| Beryllium, Total | ug/L | <0.20 | 0.4 | <0.20 | <0.20 | <0.20 |
| Boron, Total | ug/L | 1130 | 712 | 11900 | 6050 | 3240 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 171000 | 108000 | 225000 | 214000 | 178000 |
| Chloride | mg/L | 288 | 25.5 | 71.0 | 161 | 174 |
| Chromium, Total | ug/L | <10.0 | 14.8 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | 4.9 | <1.0 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.0 | 1.1 | 1.1 | 1.3 | 3.4 |
| Fluoride | mg/L | 2.6 | 1.8 | 0.3 | 1.9 | 2.1 |
| Iron, Total | ug/L | 766 | 12800 | 5990 | 1950 | <100 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 40.8 | 25.1 | 147 | 74.8 | 67.8 |
| Magnesium, Total | ug/L | 45500 | 49500 | 52500 | 49800 | 50600 |
| Manganese, Total | ug/L | 304 | 281 | 45.2 | 450 | 523 |
| Manganese, Dissolved | ug/L | 302 | 34.3 | 40.1 | 462 | 536 |
| Mercury | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Molybdenum, Total | ug/L | 65 | 82.5 | <10.0 | 154 | 118 |
| Molybdenum, Dissolved | ug/L | 64.1 | 79.8 | <10.0 | 151 | 120 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | 0.67 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 1.2 | 0.61 | <0.15 | 0.36 | <0.15 |
| Potassium, Total | ug/L | 7980 | 5580 | 3080 | 11700 | 8480 |
| Radium-226 | pCi/L | 0.363 | <0.218 | 0.19 | 0.567 | <0.064 |
| Radium-228 | pCi/L | 0.614 | 0.529 | 1.33 | 0.823 | 0.671 |
| Selenium, Total | ug/L | <1.0 | 1.1 | <1.0 | <1.0 | 26.3 |
| Silica, Total | ug/L | 13900 | 49100 | 16500 | 14700 | 16000 |
| Sodium, Total | ug/L | 192000 | 21300 | 79400 | 145000 | 155000 |
| Sulfate | mg/L | 412 | 108 | 598 | 551 | 425 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Total Dissolved Solids | mg/L | 1320 | 440 | 1210 | 1380 | 1240 |
| Total Organic Carbon | mg/L | 2 | <1.0 | <1.0 | 1.3 | 1.9 |
| Total Radium | pCi/L | 0.977 | <0.747 | 1.52 | 1.39 | <0.735 |
| pH at 25 Degrees C | Std. Units | 7.7 | 7.9 | 7.0 | 7.5 | 7.4 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-13D | MW-13S | MW-14D | MW-15D | MW-15I |
|---|---|---|---|---|---|---|
| Sample Date | | 5/4/2022 | 5/4/2022 | 5/11/2022 | 5/11/2022 | 5/5/2022 |
| Pace Lab ID | | 50315730009 | 50315730008 | 50316356002 | 50316356001 | 50315836008 |
| | | | | | | |
| Static Water Elevation | ft MSL | 659.66 | 659.71 | 657.26 | 668.77 | 669.19 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 16.69 | 16.66 | 16.47 | 15.37 | 13.56 |
| Dissolved Oxygen, Field | mg/L | 0.13 | 0.06 | 9.81 | 10.13 | 0.14 |
| Conductivity, Field | uS/cm | 1930.7 | 1804.00 | 18.89 [1] | 0.28 [1] | 630.02 |
| ORP, Field | mV | -142.6 | -100.3 | -43.0 | 79.2 | 217.80 |
| pH, Field | Std. Units | 7.55 | 7.38 | 7.45 | 7.08 | 7.16 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 196 | 262 | 276 | 339 | 301 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 196 | 262 | 276 | 339 | 301 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2 | <2 | <2 | <2.0 | <2.0 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | 245 | 312 | 127 | 1.2 | <1.0 |
| Barium, Total | ug/L | 30.4 | 43.6 | 44.3 | 75.1 | 56.0 |
| Beryllium, Total | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Boron, Total | ug/L | 14900 | 11800 | 54100 | 157 | 110 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 196000 | 171000 | 383000 | 106000 | 99900 |
| Chloride | mg/L | 226 | 171 | 171 | 29.1 | 15.8 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.5 | 3.6 | 2.6 | <1.0 | <1.0 |
| Fluoride | mg/L | 0.76 | 1.1 | 0.33 | 0.12 | 0.12 |
| Iron, Total | ug/L | 1950 | 1700 | 2610 | 1220 | <100 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 76.3 | 62.2 | 768 | <20.0 | <20.0 |
| Magnesium, Total | ug/L | 50300 | 46500 | 216000 | 31300 | 26000 |
| Manganese, Total | ug/L | 184 | 412 | 320 | 115 | 13.9 |
| Manganese, Dissolved | ug/L | 176 | 415 | 329 | 117 | 14.4 |
| Mercury | ug/L | <0.20 | <0.20 | <0.20 | <0.20 | <0.20 |
| Molybdenum, Total | ug/L | 565 | 557 | 203 | <10.0 | <10.0 |
| Molybdenum, Dissolved | ug/L | 567 | 573 | 205 | <10.0 | <10.0 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | 2.7 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.27 | 0.46 | 0.71 | <0.15 | <0.15 |
| Potassium, Total | ug/L | 15300 | 12600 | 61200 | 2280 | 1270 |
| Radium-226 | pCi/L | <0.28 | <0.00 | <-0.0383 | <0.134 | <0.16 |
| Radium-228 | pCi/L | 1.26 | 0.448 | 1.03 | 0.631 | <0.155 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | 1.9 |
| Silica, Total | ug/L | 14000 | 14700 | 11900 | 12600 | 12300 |
| Sodium, Total | ug/L | 177000 | 168000 | 357000 | 22800 | 8210 |
| Sulfate | mg/L | 688 | 522 | 2190 | 73.2 | 49.0 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Total Dissolved Solids | mg/L | 1420 | 1270 | 3610 | 512 | 399 |
| Total Organic Carbon | mg/L | 2 | 3 | 2.1 | 1.1 | <1.0 |
| Total Radium | pCi/L | 1.54 | <0.448 | 1.03 | <0.765 | <0.315 |
| pH at 25 Degrees C | Std. Units | 7.7 | 7.6 | 7.6 | 7.4 | 7.5 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-15S | M-4 | MW-102D | MW-102S | MW-103D |
|---|---|---|---|---|---|---|
| Sample Date | | 5/5/2022 | 5/12/2022 | 5/13/2022 | 5/13/2022 | 5/4/2022 |
| Pace Lab ID | | 50315836007 | 50316495001 | 50316511006 | 50316511003 | 50315733003 |
| | | | | | | |
| Static Water Elevation | ft MSL | 668.46 | 657.40 | 617.58 | 620.13 | 609.6423 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 12.35 | 17.10 | 18.37 | 21.52 | 14.45 |
| Dissolved Oxygen, Field | mg/L | 5.87 | 0.02 | 0.37 | 1.37 | 0.58 |
| Conductivity, Field | uS/cm | 731.33 | 2134.3 | 2231.1 | 2049.7 | 1050.3 |
| ORP, Field | mV | 283.30 | -145.2 | -129.3 | 68.5 | -103.4 |
| pH, Field | Std. Units | 6.95 | 7.06 | 7.23 | 6.57 | 7.26 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 326 | 291 | 107 | NS | 259 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 326 | 291 | 107 | NS | 257 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2.0 | <2.0 | <2.0 | NS | <2.0 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | 5320 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | <1.0 | 926 | 51.3 | 83.6 | <1.0 |
| Barium, Total | ug/L | 49.0 | 159 | 55.2 | 74.3 | 370 |
| Beryllium, Total | ug/L | <0.20 | NS | NS | NS | NS |
| Boron, Total | ug/L | 120 | 28200 | 20300 | 5710 | 359 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 106000 | 367000 | 364000 | 256000 | 92700 |
| Chloride | mg/L | 28.1 | 121 | 183 | NS | 209 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | 13.7 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | 2.8 | <1.0 |
| Dissolved Organic Carbon | mg/L | <1.0 | 3.2 | 2.7 | 10.9 | 3.7 |
| Fluoride | mg/L | 0.12 | <0.10 | 0.21 | NS | 0.19 |
| Iron, Total | ug/L | 101 | 6630 | 5210 | 23800 | 2350 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | <0.20 | NS | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | 367 | 63.1 | 62.9 | <20.0 |
| Magnesium, Total | ug/L | 27600 | 58600 | 62600 | 83900 | 30600 |
| Manganese, Total | ug/L | 12.1 | 1050 | 476 | 631 | 130 |
| Manganese, Dissolved | ug/L | <10.0 | 1220 | 484 | 550 | 126 |
| Mercury | ug/L | <0.20 | NS | NS | NS | NS |
| Molybdenum, Total | ug/L | <10.0 | 300 | 448 | 44.9 | <10.0 |
| Molybdenum, Dissolved | ug/L | <10.0 | 293 | 444 | 40.3 | <10.0 |
| Nitrogen, Nitrate | mg/L | 3.8 | <0.10 | <0.10 | NS | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | NS | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | 2.2 | 0.71 | 0.23 | <0.15 |
| Potassium, Total | ug/L | 1550 | 24400 | 16000 | 12000 | 6080 |
| Radium-226 | pCi/L | 0.20 | 0.571 | 18.2 | 0.27 | 0.728 |
| Radium-228 | pCi/L | 0.395 | 1.39 | 0.637 | 0.587 | 1.17 |
| Selenium, Total | ug/L | 1.1 | <1.0 | <1.0 | 1.1 | <1.0 |
| Silica, Total | ug/L | 11300 | 13100 | 13800 | 32500 | 13200 |
| Sodium, Total | ug/L | 21500 | 131000 | 174000 | 162000 | 81800 |
| Sulfate | mg/L | 48.8 | 1080 | 1190 | NS | 53.6 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | <1.0 | NS | NS | NS | NS |
| Total Dissolved Solids | mg/L | 446 | 2060 | 2070 | NS | 588 |
| Total Organic Carbon | mg/L | <1.0 | 2.9 | 1.9 | 2.2 | 2.2 |
| Total Radium | pCi/L | 0.595 | 1.96 | 18.8 | 0.857 | 1.9 |
| pH at 25 Degrees C | Std. Units | 7.5 | 7.4 | 7.2 | NS | 7.6 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-103I | MW-103S | MW-104D | MW-104S | MW-105D |
|---|---|---|---|---|---|---|
| Sample Date | | 5/4/2022 | 5/4/2022 | 5/13/2022 | 5/13/2022 | 5/11/2022 |
| Pace Lab ID | | 50315733002 | 50315733001 | 50316511005 | 50316511004 | 50316233003 |
| | | | | | | |
| Static Water Elevation | ft MSL | 611.3283 | 665.92 | 589.205 | Dry to top of pump (<621.80) | 614.39 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 13.80 | 14.83 | 16.62 | 17.82 | 15.37 |
| Dissolved Oxygen, Field | mg/L | 1.10 | 0.51 | 2.89 | 4.59 | 0.04 |
| Conductivity, Field | uS/cm | 960.9 | 1797.7 | 1951.1 | 1161.5 | 934.3 |
| ORP, Field | mV | 49.8 | -44.2 | 40.4 | 19.8 | -102.0 |
| pH, Field | Std. Units | 7.17 | 6.75 | 6.60 | 6.57 | 6.89 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 252 | 626 | 370 | 377 | 272 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 252 | 626 | 370 | 377 | 272 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | <1.0 | 21.2 | 6.6 | <1.0 | 4.7 |
| Barium, Total | ug/L | 202 | 65.2 | 66.2 | 28.8 | 332 |
| Beryllium, Total | ug/L | NS | NS | NS | NS | NS |
| Boron, Total | ug/L | 280 | 887 | 2720 | 1270 | 1100 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 91800 | 291000 | 305000 | 302000 | 101000 |
| Chloride | mg/L | 135 | 68.4 | 116 | 58.2 | 115 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | 2.1 | 1.1 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.7 | 5.2 | 1.7 | 2.2 | 1.9 |
| Fluoride | mg/L | 0.22 | 0.27 | 0.14 | 0.22 | 0.22 |
| Iron, Total | ug/L | 1500 | 16300 | 6720 | <100 | 5700 |
| Iron, Ferrous | mg/L | <0.20 | 1.1 | <0.20 | <0.20 | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | <20.0 | 23 | 26.3 | <20.0 |
| Magnesium, Total | ug/L | 26100 | 80200 | 78400 | 79300 | 25000 |
| Manganese, Total | ug/L | 309 | 289 | 1220 | <10.0 | 115 |
| Manganese, Dissolved | ug/L | 300 | 292 | 425 | <10.0 | 121 |
| Mercury | ug/L | NS | NS | NS | NS | NS |
| Molybdenum, Total | ug/L | <10.0 | 22.4 | <10.0 | <10.0 | 17.4 |
| Molybdenum, Dissolved | ug/L | <10.0 | 23 | <10.0 | <10.0 | 17.1 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | 0.26 | 0.6 | 0.1 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | <0.15 | <0.15 | <0.15 | 0.26 |
| Potassium, Total | ug/L | 7500 | 2140 | 9540 | 6800 | 5420 |
| Radium-226 | pCi/L | 0.956 | <-0.304 | 0.409 | 0.469 | 1.73 |
| Radium-228 | pCi/L | 1.66 | 0.832 | <0.273 | 0.391 | 1.09 |
| Selenium, Total | ug/L | <1.0 | <1.0 | 1.5 | 3.9 | <1.0 |
| Silica, Total | ug/L | 10700 | 25100 | 11200 | 10700 | 12200 |
| Sodium, Total | ug/L | 62700 | 47000 | 90000 | 62100 | 71400 |
| Sulfate | mg/L | 40.2 | 435 | 738 | 748 | 120 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | NS | NS | NS | NS | NS |
| Total Dissolved Solids | mg/L | 535 | 1370 | 1630 | 1670 | 609 |
| Total Organic Carbon | mg/L | 2.7 | 5.6 | 1.2 | <1.0 | 1.6 |
| Total Radium | pCi/L | 2.62 | <0.832 | 0.682 | 0.86 | 2.82 |
| pH at 25 Degrees C | Std. Units | 7.5 | 7.9 | 7.0 | 7.0 | 7.5 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-105I | MW-105S | MW-106D | MW-106I | MW-106S |
|---|---|---|---|---|---|---|
| Sample Date | | 5/11/2022 | 5/11/2022 | 5/5/2022 | 5/12/2022 | 5/5/2022 |
| Pace Lab ID | | 50316233002 | 50316233001 | 50315836002 | 50316495002 | 50315836001 |
| | | | | | | |
| Static Water Elevation | ft MSL | 608.09 | 636.53 | 608.41 | 610.1 | 649.44 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 15.50 | 14.86 | 14.26 | 21.75 | 13.76 |
| Dissolved Oxygen, Field | mg/L | 0.06 | 0.38 | 2.08 | 0.15 | 0.50 |
| Conductivity, Field | uS/cm | 926.19 | 2323.5 | 2311.9 | 2139.7 | 1861.9 |
| ORP, Field | mV | -104.0 | -69.1 | -116.4 | -123.9 | -26.4 |
| pH, Field | Std. Units | 6.94 | 6.74 | 7.36 | 7.06 | 7.21 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 284 | 283 | 242 | 238 | 348 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 284 | 283 | 242 | 238 | 348 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | 487 | 541 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | <1.0 | 5.5 | 195 | 117 | 3.6 |
| Barium, Total | ug/L | 346 | 32.7 | 31.0 | 69.3 | 21.4 |
| Beryllium, Total | ug/L | NS | NS | NS | NS | NS |
| Boron, Total | ug/L | 393 | 22800 | 13300 | 12100 | 388 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 103000 | 335000 | 277000 | 240000 | 312000 |
| Chloride | mg/L | 118 | 118 | 264 | 263 | 12.4 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | 1.4 |
| Dissolved Organic Carbon | mg/L | 1.6 | 1.5 | 2.1 | <4.0 | <1.0 |
| Fluoride | mg/L | 0.13 | 0.28 | 0.28 | 0.2 | 0.28 |
| Iron, Total | ug/L | 4690 | 8870 | 4520 | 6500 | 4230 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | <0.20 | <0.20 | 0.9 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | <20.0 | 306 | 120 | 101 | 31.7 |
| Magnesium, Total | ug/L | 25100 | 85700 | 52500 | 47600 | 121000 |
| Manganese, Total | ug/L | 124 | 204 | 328 | 432 | 1030 |
| Manganese, Dissolved | ug/L | 126 | 208 | 324 | 432 | 1010 |
| Mercury | ug/L | NS | NS | NS | NS | NS |
| Molybdenum, Total | ug/L | <10.0 | 74 | 244 | 320 | 18.9 |
| Molybdenum, Dissolved | ug/L | <10.0 | 72.3 | 246 | 342 | 18.4 |
| Nitrogen, Nitrate | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | 0.11 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | <0.15 | <0.15 | 0.75 | 0.75 | <0.15 |
| Potassium, Total | ug/L | 5470 | 19200 | 15400 | 15800 | 7060 |
| Radium-226 | pCi/L | <-0.038 | 0.436 | 0.302 | 0.999 | <0.0541 |
| Radium-228 | pCi/L | 0.668 | 0.945 | 0.694 | 0.731 | 0.68 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | 1 |
| Silica, Total | ug/L | 12100 | 15300 | 14900 | 14800 | 9660 |
| Sodium, Total | ug/L | 68400 | 132000 | 199000 | 183000 | 21200 |
| Sulfate | mg/L | 87.4 | 1230 | 702 | 710 | 1120 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | NS | NS | NS | NS | NS |
| Total Dissolved Solids | mg/L | 585 | 2090 | 1660 | 1730 | 1780 |
| Total Organic Carbon | mg/L | 1.6 | 1.3 | 1.7 | <4 | <1.0 |
| Total Radium | pCi/L | <0.668 | 1.38 | 0.996 | 1.73 | 0.734 |
| pH at 25 Degrees C | Std. Units | 7.2 | 7.0 | 7.7 | 7.4 | 7.7 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-107D | MW-107I | MW-107S | MW-108D | MW-108S |
|---|---|---|---|---|---|---|
| Sample Date | | 5/5/2022 | 5/5/2022 | 5/5/2022 | 5/10/2022 | 5/10/2022 |
| Pace Lab ID | | 50315836005 | 50315836004 | 50315836003 | 50316220002 | 50316220001 |
| | | | | | | |
| Static Water Elevation | ft MSL | 622.63 | 623.81 | 652.75 | 595.92 | 609.41 |
| | | | | | | |
| **Field Parameters** | **Units** | | | | | |
| Temperature | °C | 13.83 | 13.80 | 11.54 | 23.09 | 16.93 |
| Dissolved Oxygen, Field | mg/L | 2.29 | 1.13 | 0.11 | 0.00 | 0.13 |
| Conductivity, Field | uS/cm | 2192.5 | 1581.6 | 1545.0 | 306.55 | 2429.7 |
| ORP, Field | mV | -85.2 | -100.9 | -39.4 | -103.4 | -65.1 |
| pH, Field | Std. Units | 7.28 | 7.21 | 7.31 | 7.98 | 6.89 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 221 | 286 | 231 | 258 | 337 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 221 | 286 | 231 | 258 | 337 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | 3 | 2.5 | <1.0 | <1.0 | <1.0 |
| Barium, Total | ug/L | 136 | 241 | 17.0 | 43.1 | 38.7 |
| Beryllium, Total | ug/L | NS | NS | NS | NS | NS |
| Boron, Total | ug/L | 7500 | 3270 | 6250 | 5800 | 2300 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 213000 | 221000 | 238000 | 226000 | 288000 |
| Chloride | mg/L | 242 | 176 | 266 | 217 | 181 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.1 | 3.3 | 1.8 | 1.9 | 1.6 |
| Fluoride | mg/L | 0.34 | 0.28 | 0.68 | 0.41 | 0.65 |
| Iron, Total | ug/L | 6560 | 8120 | 2050 | 5800 | 4850 |
| Iron, Ferrous | mg/L | <0.20 | 0.23 | 0.36 | <0.20 | <0.20 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 68.2 | <20.0 | 84 | 81 | 79.3 |
| Magnesium, Total | ug/L | 54600 | 63100 | 79900 | 61800 | 100000 |
| Manganese, Total | ug/L | 362 | 241 | 420 | 393 | 556 |
| Manganese, Dissolved | ug/L | 353 | 238 | 414 | 384 | 536 |
| Mercury | ug/L | NS | NS | NS | NS | NS |
| Molybdenum, Total | ug/L | 124 | 17.8 | 64.3 | 150 | 108 |
| Molybdenum, Dissolved | ug/L | 124 | 17.7 | 63.2 | 153 | 107 |
| Nitrogen, Nitrate | mg/L | 0.11 | <0.10 | <0.10 | 0.25 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.6 | 0.79 | 0.18 | 0.25 | 0.15 |
| Potassium, Total | ug/L | 18700 | 3530 | 11800 | 13100 | 13700 |
| Radium-226 | pCi/L | 0.526 | 0.429 | 0.691 | 0.385 | 0.296 |
| Radium-228 | pCi/L | 0.467 | 0.638 | <0.168 | 1.08 | <0.364 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 13900 | 20400 | 11800 | 14100 | 14200 |
| Sodium, Total | ug/L | 224000 | 83800 | 236000 | 192000 | 182000 |
| Sulfate | mg/L | 708 | 485 | 732 | 712 | 959 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | NS | NS | NS | NS | NS |
| Total Dissolved Solids | mg/L | 1540 | 1200 | 1720 | 1610 | 1960 |
| Total Organic Carbon | mg/L | 1.8 | 2.9 | 1.2 | 1.5 | 1.3 |
| Total Radium | pCi/L | 0.993 | 1.07 | 0.859 | 1.47 | <0.66 |
| pH at 25 Degrees C | Std. Units | 7.4 | 7.4 | 7.5 | 7.4 | 7.1 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 4**
Summary of Monitoring Results - May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | PZ-100D | PZ-100S | PZ-101S | PZ-101D |
|---|---|---|---|---|---|
| Sample Date | | 5/13/2022 | 5/13/2022 | 5/4/2022 | 5/4/2022 |
| Pace Lab ID | | 50316511002 | 50316511001 | 50315733004 | 50315733007 |
| | | | | | |
| Static Water Elevation | ft MSL | 634.91 | 651.71 | 645.24 | 604.02 |
| | | | | | |
| **Field Parameters** | **Units** | | | | |
| Temperature | °C | 17.96 | 17.43 | 15.86 | 15.54 |
| Dissolved Oxygen, Field | mg/L | 0.25 | 0.52 | 2.63 | 0.22 |
| Conductivity, Field | uS/cm | 1758.2 | 590.97 | 1573.6 | 1707.9 |
| ORP, Field | mV | -141.8 | -17.3 | -73.1 | -90.8 |
| pH, Field | Std. Units | 7.33 | 6.77 | 7.21 | 7.07 |
| | | | | | |
| **Analytical Data** | | | | | |
| Alkalinity, Total as CaCO3 | mg/L | 260 | 335 | 290 | 266 |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 260 | 335 | 290 | 266 |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2.0 | <2.0 | <2.0 | <2.0 |
| Aluminum, Total | ug/L | <200 | <200 | <200 | <200 |
| Antimony, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 |
| Arsenic, Total | ug/L | 81.3 | 2.6 | 15.6 | 4.7 |
| Barium, Total | ug/L | 59.5 | 34.4 | 168 | 84.1 |
| Beryllium, Total | ug/L | NS | NS | NS | NS |
| Boron, Total | ug/L | 6770 | 2160 | 7690 | 7380 |
| Cadmium, Total | ug/L | <2.0 | <2.0 | <2.0 | <2.0 |
| Calcium, Total | ug/L | 232000 | 176000 | 233000 | 223000 |
| Chloride | mg/L | 211 | 267 | 112 | 142 |
| Chromium, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 |
| Cobalt, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 |
| Dissolved Organic Carbon | mg/L | 2.0 | <4.0 | 1.3 | 1.5 |
| Fluoride | mg/L | 0.6 | 2.0 | 0.22 | 0.24 |
| Iron, Total | ug/L | 3270 | 1800 | 5870 | 3590 |
| Iron, Ferrous | mg/L | <0.20 | <0.20 | 0.71 | 0.25 |
| Lead, Total | ug/L | <10.0 | <10.0 | <10.0 | <10.0 |
| Lithium, Total | ug/L | 81.1 | 61.2 | 101 | 112 |
| Magnesium, Total | ug/L | 58600 | 59900 | 50300 | 44400 |
| Manganese, Total | ug/L | 230 | 359 | 783 | 416 |
| Manganese, Dissolved | ug/L | 232 | 373 | 770 | 420 |
| Mercury | ug/L | NS | NS | NS | NS |
| Molybdenum, Total | ug/L | 152 | 113 | 117 | 183 |
| Molybdenum, Dissolved | ug/L | 150 | 115 | 120 | 190 |
| Nitrogen, Nitrate | mg/L | <0.10 | 0.13 | <0.10 | <0.10 |
| Nitrogen, Nitrite | mg/L | <0.10 | <0.10 | <0.10 | <0.10 |
| Phosphate as P04 | mg/L | 0.59 | <0.15 | <0.15 | <0.15 |
| Potassium, Total | ug/L | 11900 | 10700 | 10900 | 14100 |
| Radium-226 | pCi/L | 0.655 | 0.81 | 0.947 | <0.0783 |
| Radium-228 | pCi/L | 0.587 | 0.451 | 0.895 | 1.31 |
| Selenium, Total | ug/L | <1.0 | <1.0 | <1.0 | <1.0 |
| Silica, Total | ug/L | 12800 | 15300 | 12700 | 12000 |
| Sodium, Total | ug/L | 156000 | 230000 | 105000 | 123000 |
| Sulfate | mg/L | 579 | 455 | 567 | 648 |
| Sulfide | mg/L | <0.10 | <0.10 | <0.10 | <0.10 |
| Thallium, Total | ug/L | NS | NS | NS | NS |
| Total Dissolved Solids | mg/L | 1490 | 1530 | 1260 | 1270 |
| Total Organic Carbon | mg/L | 1.6 | <4.0 | 1.5 | 1.1 |
| Total Radium | pCi/L | 1.24 | 1.26 | 1.84 | 1.39 |
| pH at 25 Degrees C | Std. Units | 7.4 | 7.5 | 7.3 | 7.4 |

Notes:
ft MSL: Elevation, feet mean sea level
°C: Degrees celcius
uS/cm: microsiemen per centimeter
umhos/cm: micromhos per centimeter
NA: Not analyzed
NS: Not Sampled
mV: millivolt
DTP: Dry to pump
Std. Units: standard units
mg/L: milligram per liter
ug/L: microgram per liter
pCi/L: picoCurie per liter
1 - Suspect reading; field sensor not operating properly

Static water elevation listed for a well may have been collected on a date different than date of well sampling.

**Table 5**
Summary of Soil Results - 2022 Monitoring Well Locations
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-109D (82-84) | MW-109I (54-56) | MW-109S (31-33) | MW-110D (96-98) | MW-110I (68-70) | MW-110S (52-54) | MW-12D1 (78-80) | MW-2D1 (77-79) | MW-45R (34-36) |
|---|---|---|---|---|---|---|---|---|---|---|
| Sample Date | | 11/8/2022 | 11/8/2022 | 11/8/2022 | 11/8/2022 | 11/8/2022 | 11/8/2022 | 11/23/2022 | 12/8/2022 | 12/8/2022 |
| Pace Lab ID | | 50330483003 | 50330483002 | 50330483001 | 50330483006 | 50330483005 | 50330483004 | 50332045002 | 50332961001 | 50332961002 |
| | | | | | | | | | | |
| **Analytical Data** | | | | | | | | | | |
| Arsenic, Total | mg/kg | 6.1 | 3.6 | 3.4 | 4.1 | 2.3 | 3.8 | 3.3 | 6.2 | 2.4 |
| Iron, Total | mg/kg | 8420 | 5320 | 6090 | 6310 | 5500 | 7780 | 4660 | 8960 | 5610 |
| Lithium, Total | mg/kg | <4.6 | <5.5 | <4.5 | <5.5 | <5 | <5.9 | <6.1 | 7.7 | 5.6 |
| Manganese, Total | mg/kg | 286 | 216 | 212 | 325 | 101 | 287 | 36.6 | 73.2 | 165 |
| Mean Total Organic Carbon | mg/kg | 33900 | 9000 | 14800 | 8320 | 5320 | 13600 | 38800 | 13000 | 35400 |
| Molybdenum, Total | mg/kg | 2.5 | 1.5 | 1.0 | 1.6 | <1 | 1.7 | <1.2 | 2.4 | <1 |
| Percent Moisture | % | 4.7 | 12.1 | 2.8 | 10.3 | 3.4 | 15.3 | 23.3 | 12.8 | 6.7 |
| RSD% | % | 17.3 | 21 | 22.8 | 12.7 | 5.8 | 12.7 | 7 | 34.9 | 4.4 |
| Total Organic Carbon | mg/kg | 41900 | 11100 | 14100 | 8980 | 5550 | 13000 | 40200 | 19300 | 36000 |
| Total Organic Carbon | mg/kg | 33800 | 6480 | 19100 | 7670 | 5520 | 15800 | 36200 | 13300 | 37100 |
| Total Organic Carbon | mg/kg | 28100 | 9130 | 15200 | 7200 | 4880 | 11700 | 36800 | 9360 | 35400 |
| Total Organic Carbon | mg/kg | 31600 | 9320 | 11000 | 9420 | 5330 | 14100 | 41800.0 | 10100 | 33400 |
| pH at 25 Degrees C | Std. Units | 8 | 7.7 | 7.9 | 7.9 | 8 | 8 | 6.4 | 7.8 | 8.2 |

Notes:
NA: Not analyzed
Std. Units: standard units
mg/kg: milligram per kilogram

**Table 5**
Summary of Soil Results - 2022 Monitoring Well Locations
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Well ID | | MW-4D (78-80) | MW-4I (60-62) | MW-5D (74-76) | MW-6I (62-64) | MW-8D0 (34-36) |
|---|---|---|---|---|---|---|
| Sample Date | | 11/8/2022 | 11/8/2022 | 12/8/2022 | 11/23/2022 | 12/8/2022 |
| Pace Lab ID | | 50330483008 | 50330483007 | 50332961003 | 50332045001 | 50332961004 |
| | | | | | | |
| **Analytical Data** | | | | | | |
| Arsenic, Total | mg/kg | 4.9 | 5.3 | 1.9 | 7.7 | 12.8 |
| Iron, Total | mg/kg | 6610 | 6980 | 10100 | 12800 | 14200 |
| Lithium, Total | mg/kg | <5.5 | <5.1 | <5.5 | 14.8 | 7.8 |
| Manganese, Total | mg/kg | 216 | 231 | 56.8 | 342 | 346 |
| Mean Total Organic Carbon | mg/kg | 6050 | 26000 | <721 | 29100 | 939 |
| Molybdenum, Total | mg/kg | 3.3 | 2.4 | 1.5 | 4.3 | 2.6 |
| Percent Moisture | % | 12.5 | 9 | 16.3 | 14 | 14.2 |
| RSD% | % | 40.2 | 27.8 | 11.9 | 8.4 | 4.6 |
| Total Organic Carbon | mg/kg | 8140 | 21300 | <723 | 30700 | 988 |
| Total Organic Carbon | mg/kg | 3500 | 25000 | <718 | 27500 | 888 |
| Total Organic Carbon | mg/kg | 8130 | 36500 | <722 | 31600 | 959 |
| Total Organic Carbon | mg/kg | 4440 | | <719 | 26500 | 922 |
| pH at 25 Degrees C | Std. Units | 7.4 | 7.6 | 7.7 | 7.1 | 7.7 |

Notes:
NA: Not analyzed
Std. Units: standard units
mg/kg: milligram per kilogram

**Table 6**
Groundwater Protection Standards -
November 2021 and May 2022
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| Parameter | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Units | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| Shallow Zone GWPS | 6 | 10 | 2000 | 4 | 5 | 100 | 6 | 4 | 15 | 40 | 2 | 100 | 50 | 2 | 5 |
| Deep Zone GWPS | 6 | 10 | 2000 | 4 | 5 | 100 | 6 | 4 | 15 | 40 | 2 | 100 | 50 | 2 | 5 |

Notes:
ug/L = micrograms per liter (ppb)
mg/L = milligrams per liter (ppm)
pCi/L = picoCuries per liter
GWPS = Groundwater Protection Standard

ATTACHMENT A

**OCTOBER 2021**

**Table A-1**
Gauging Summary
October 29, 2021
AES Indiana
Harding Street Generating Station
ATC Project No. 170LF01115

| Well | Date | Time | DTW, from top of Reference Point | Reference Point Elevation (TOC) | | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| **Existing CCR Well Network** | | | | | | | |
| MW-1S | 10/29/2021 | 10:02 | 10.58 | 675.33 | | 664.75 | |
| MW-1D | 10/29/2021 | 9:59 | 10.31 | 675.17 | | 664.86 | |
| MW-2S | 10/29/2021 | 11:24 | 17.77 | 684.99 | | 667.22 | |
| MW-2D | 10/29/2021 | 11:20 | 17.93 | 685.20 | | 667.27 | |
| MW-3S | 10/29/2021 | 11:19 | 24.85 | 688.98 | | 664.13 | |
| MW-3D | 10/29/2021 | 11:21 | 24.80 | 688.82 | | 664.02 | |
| MW-4S | 10/29/2021 | 10:53 | 33.00 | 689.29 | | 656.29 | |
| MW-5S | 10/29/2021 | 10:24 | 31.01 | 689.43 | | 658.42 | |
| MW-6S | 10/29/2021 | 9:48 | 33.20 | 695.67 | | 662.47 | |
| MW-7S | 10/29/2021 | 10:25 | 38.12 | 696.76 | | 658.64 | |
| MW-7D | 10/29/2021 | 10:30 | 37.70 | 696.29 | | 658.59 | |
| MW-8S | 10/29/2021 | 8:40 | 11.86 | 672.78 | | 660.92 | |
| MW-9S | 10/29/2021 | 10:40 | dry to pump (34.2) | 689.02 | | <654.82 | |
| MW-9I | 10/29/2021 | 10:36 | 35.83 | 689.11 | | 653.28 | |
| MW-9D | 10/29/2021 | 10:38 | 36.08 | 689.27 | | 653.19 | |
| MW-10S | 10/29/2021 | 9:48 | 26.72 | 691.10 | | 664.38 | |
| MW-10D | 10/29/2021 | 9:46 | 26.92 | 691.28 | | 664.36 | |
| MW-11S | 10/29/2021 | 8:53 | 28.42 | 686.17 | | 657.75 | |
| MW-11D | 10/29/2021 | 8:55 | 26.38 | 686.17 | | 659.79 | |
| MW-12S | 10/29/2021 | 10:28 | dry to pump (35.3) | 688.82 | | <653.52 | |
| MW-12D | 10/29/2021 | 10:26 | 35.81 | 688.73 | | 652.92 | |
| MW-13S | 10/29/2021 | 10:00 | 36.12 | 696.08 | | 659.96 | |
| MW-13D | 10/29/2021 | 9:58 | 36.83 | 696.78 | | 659.95 | |
| MW-14D | 10/29/2021 | 8:59 | 38.94 | 697.88 | | 658.94 | |
| MW-15S | 10/29/2021 | 12:25 | 16.07 | 685.46 | | 669.39 | |
| MW-15I | 10/29/2021 | 12:30 | 16.09 | 685.59 | | 669.50 | |
| MW-15D | 10/29/2021 | 12:35 | 15.82 | 685.20 | | 669.38 | |
| **Nature & Extent Wells/Piezometers** | | | | | | | |
| M-4 | 10/29/2021 | 10:09 | 35.04 | 693.25 | | 658.21 | |
| PZ-100S | 10/29/2021 | 10:45 | 28.49 | 681.79 | | 653.30 | |
| PZ-100D | 10/29/2021 | 10:47 | 46.10 | 681.84 | | 635.74 | |
| PZ-101S | 10/29/2021 | 10:38 | 43.56 | 689.36 | | 645.80 | |
| PZ-101D | 10/29/2021 | 10:40 | 83.96 | 689.40 | | 605.44 | |
| MW-102S | 10/29/2021 | 11:48 | 56.02 | 677.10 | | 621.08 | |
| MW-102D | 10/29/2021 | 12:00 | 60.10 | 677.48 | | 617.38 | |
| MW-103S | 10/29/2021 | 11:13 | 35.71 | 701.27 | | 665.56 | |
| MW-103I | 10/29/2021 | 11:15 | 86.92 | 701.26 | | 614.34 | |
| MW-103D | 10/29/2021 | 11:17 | 90.01 | 701.54 | | 611.53 | |
| MW-104S | 10/29/2021 | 12:15 | 56.88 | 676.60 | | 619.72 | |
| MW-104D | 10/29/2021 | 12:17 | 86.82 | 677.01 | | 590.19 | |
| MW-105S | 10/29/2021 | 11:25 | 25.87 | 661.47 | | 635.60 | |
| MW-105I | 10/29/2021 | 11:27 | 53.12 | 661.37 | | 608.25 | |
| MW-105D | 10/29/2021 | 11:29 | 59.75 | 661.04 | | 601.29 | |
| MW-106S | 10/29/2021 | 11:37 | 33.13 | 671.05 | | 637.92 | |
| MW-106I | 10/29/2021 | 11:35 | 61.02 | 671.05 | | 610.03 | |
| MW-106D | 10/29/2021 | 11:33 | 62.6 | 671.00 | | 608.40 | |
| MW-107S | 10/29/2021 | 10:56 | 4.65 | 658.23 | | 653.58 | |
| MW-107I | 10/29/2021 | 10:58 | 34.00 | 658.47 | | 624.47 | |
| MW-107D | 10/29/2021 | 11:00 | 35.91 | 658.55 | | 622.64 | |
| MW-108S | 10/29/2021 | 12:05 | 32.45 | 642.22 | | 609.77 | |
| MW-108D | 10/29/2021 | 12:07 | 45.65 | 642.03 | | 596.38 | |
| **Historic Piezometers/Wells** | | | | | | | |
| M-3 | 10/29/2021 | 10:12 | 9.23 | 693.58 | | 684.35 | |
| M-6 | 10/29/2021 | 10:10 | 7.71 | 676.52 | | 668.81 | |
| P-2 | 10/29/2021 | 11:02 | 9.47 | 675.73 | | 666.26 | |
| P-3 | 10/29/2021 | 12:17 | 16.44 | 685.67 | | - | |
| P-4 | 10/29/2021 | 12:11 | 15.95 | 684.53 | | 668.58 | |
| P-5 | 10/29/2021 | 12:05 | 15.12 | 683.75 | | 668.63 | |
| P-6 | 10/29/2021 | 11:45 | 9.74 | 677.49 | | 667.75 | |
| PZ-1 | 10/29/2021 | 8:39 | DRY | 714.54 | | DRY | |
| PZ-2 | 10/29/2021 | 8:43 | DRY | 714.91 | | DRY | |
| PZ-3 | 10/29/2021 | 9:16 | 45.25 | 713.81 | | 668.56 | |
| PZ-5 | 10/29/2021 | 8:30 | 40.63 | 714.52 | | 673.89 | |
| PZ-6 | 10/29/2021 | 11:13 | 18.13 | 688.21 | | 670.08 | |
| PZ-7 | 10/29/2021 | 11:25 | 15.13 | 684.73 | | 669.60 | |
| PZ-8 | 10/29/2021 | Not Gauged | | 683.96 | | - | |

**Table A-1**
Gauging Summary
October 29, 2021
AES Indiana
Harding Street Generating Station
ATC Project No. 170LF01115

| Well | Date | Time | DTW, from top of Reference Point | Reference Point Elevation (TOC) | | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| PZ-9 | 10/29/2021 | 10:57 | 26.83 | 683.86 | | 657.03 | |
| PZ-10 | 10/29/2021 | Not Gauged | | 683.91 | | - | |
| PZ-11 | 10/29/2021 | Not Gauged | | 685.12 | | - | |
| PZ-12 | 10/29/2021 | 9:22 | 33.27 | 709.68 | | 676.41 | |
| PZ-13 | 10/29/2021 | 10:15 | 19.10 | 698.01 | | 678.91 | |
| PZ-14 | | Not gauged - riser has bercome detached ~ 4 ft below grade | | 708.67 | | 708.67 | |
| **Ash Pond Piezometers** | | | | | | | |
| P1 PZ-1S | 10/29/2021 | 11:06 | 10.67 | 687.30 | | 676.63 | |
| P1 PZ-1D | 10/29/2021 | 11:09 | 21.31 | 687.25 | | 665.94 | |
| P2 PZ-1S | 10/29/2021 | 8:31 | 51.77 | 717.16 | | 665.39 | |
| P2 PZ-1D | 10/29/2021 | 8:33 | 54.07 | 716.33 | | 662.26 | |
| P2 PZ-2S | 10/29/2021 | 9:32 | 39.75 | 707.15 | | 667.40 | |
| P2 PZ-2D | 10/29/2021 | 9:35 | 47.90 | 706.92 | | 659.02 | |
| P2 PZ-3S | 10/29/2021 | 9:09 | 53.53 | 718.21 | | 664.68 | |
| P2 PZ-3D | 10/29/2021 | 9:12 | 58.29 | 718.19 | | 659.90 | |
| P2 A/B PZ-1S | 10/29/2021 | 10:56 | 25.70 | 691.55 | | 665.85 | |
| P2 A/B PZ-1D | 10/29/2021 | 10:59 | 26.06 | 691.19 | | 665.13 | |
| P2 A/B PZ-2S | 10/29/2021 | 10:49 | 24.41 | 689.49 | | 665.08 | |
| P2 A/B PZ-2D | 10/29/2021 | 10:52 | 26.83 | 689.06 | | 662.23 | |
| P3 PZ-1S | 10/29/2021 | 11:46 | 9.62 | 680.52 | | 670.90 | |
| P3 PZ-1D | 10/29/2021 | 11:41 | 14.46 | 681.15 | | 666.69 | |
| **Drive Point Piezometers** | | | | | | | |
| HA PZ-1 | 10/29/2021 | 11:27 | 4.34 | 670.80 | | 666.46 | |
| HA PZ-2 | 10/29/2021 | 9:45 | 7.37 | 670.56 | | 663.19 | |
| HA PZ-3 | 10/29/2021 | 9:34 | 9.45 | 671.08 | | 661.63 | |
| HA PZ-4 | 10/29/2021 | 9:26 | 3.74 | 663.67 | | 659.93 | |
| HA PZ-5 | 10/29/2021 | 9:18 | 8.35 | 667.91 | | 659.56 | |

| Well | Date | Time | Water Gauge Level (ft) | Reference Point Elevation (top of gage placard) | Staff Total Height (ft)* | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| Survey Shot SG-2 | - | - | - | - | - | | Not measured |
| Survey Shot SG-3 | - | - | - | - | - | | Not measured |
| Survey Shot SG-4 | - | - | - | - | - | | Not measured |
| Survey Shot SG-5 | - | - | - | - | - | | Not measured |

**USGS 03353611 - White River at Harding Street Generating Station (upstream of lowhead dam)**

| | Date | Time | Gage Height Above Datum (ft) | Datum Height | | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| River Gage | 10/29/2021 | 8:00 | 5.44 | 662.73 | | 668.17 | |

**Flow Rate Calculations - October 2021**
AES Indiana Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| HSS SHALLOW ZONE<br>FIGURE 1 | | **HSS** | | **HANSON** | |
|---|---|---|---|---|---|
| 10/29/2021 | Flow Rate Line | FR1 | FR2 | FR3 | FR4 |
| $v = Q/n_eA^1 = KI/n_e$ | | | | | |
| $\Delta H$ (ft) | Potentiometric Surface Hydraulic Head Change | 10 | 15 | 35 | 50 |
| $\Delta L$ (ft) | Flow Line Length | 1850 | 1765 | 530 | 1505 |
| K (hydraulic conductivity (ft/day)) | (2016 C/PC Plan) | 308 | 308 | 308 | 308 |
| I ($\Delta H/\Delta L$) | | 0.0054 | 0.0085 | 0.066 | 0.033 |
| $n_e$ (effective porosity, dimensionless) | (2016 C/PC Plan) | 0.35 | 0.35 | 0.35 | 0.35 |
| v (ft/day) | | 4.8 | 7.5 | 58 | 29 |
| | | | | | |
| HSS DEEP ZONE<br>FIGURE 2 | | **HSS** | | **HANSON** | |
| 10/29/2021 | Flow Rate Line | FR1 | FR2 | FR3 | FR4 |
| $v = Q/n_eA^1 = KI/n_e$ | | | | | |
| $\Delta H$ (ft) | Potentiometric Surface Hydraulic Head Change | 5 | 5 | 50 | 65 |
| $\Delta L$ (ft) | Flow Line Length | 1160 | 850 | 350 | 1805 |
| K (hydraulic conductivity (ft/day)) | (2016 C/PC Plan) | 308 | 308 | 308 | 308 |
| I ($\Delta H/\Delta L$) | | 0.0043 | 0.0059 | 0.14 | 0.036 |
| $n_e$ (effective porosity, dimensionless) | (2016 C/PC Plan) | 0.35 | 0.35 | 0.35 | 0.35 |
| v (ft/day) | | 3.8 | 5.2 | 120 | 32 |

Notes

1 - Average linear velocity equation from Fetter, C.W., 1980, Applied Hydrogeology: Merrill Publishing Company, 592 p.

Flow line paths are plotted to be consistent between Nov 2021 and May 2022 events.

**MAY 2022**

**Table A-2**
Gauging Summary
May 2, 2022
AES Indiana
Harding Street Generating Station
ATC Project No. 170LF01277

| Well | Date | Time | DTW, from top of Reference Point | Reference Point Elevation (TOC) | | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| **Existing CCR Well Network** | | | | | | | |
| MW-1S | 5/2/2022 | 10:04 | 12.01 | 675.33 | | 663.32 | |
| MW-1D | 5/2/2022 | 10:02 | 11.74 | 675.17 | | 663.43 | |
| MW-2S | 5/2/2022 | 11:33 | 19.32 | 684.99 | | 665.67 | |
| MW-2D | 5/2/2022 | 11:44 | 18.55 | 685.20 | | 666.65 | |
| MW-3S | 5/2/2022 | 11:19 | 26.02 | 688.98 | | 662.96 | |
| MW-3D | 5/2/2022 | 11:19 | 26.07 | 688.82 | | 662.75 | |
| MW-4S | 5/2/2022 | 11:03 | DRY | 689.29 | | DRY | |
| MW-5S | 5/2/2022 | 11:53 | 32.32 | 689.43 | | 657.11 | |
| MW-6S | 5/2/2022 | 11:27 | 33.76 | 695.67 | | 661.91 | |
| MW-7S | 5/2/2022 | 11:13 | 38.63 | 696.76 | | 658.13 | |
| MW-7D | 5/2/2022 | 11:15 | 38.21 | 696.29 | | 658.08 | |
| MW-8S | 5/2/2022 | 10:14 | 14.49 | 672.78 | | 658.29 | |
| MW-9S | 5/2/2022 | 10:59 | DRY | 689.02 | | DRY | |
| MW-9I | 5/2/2022 | 11:01 | 36.25 | 689.11 | | 652.86 | |
| MW-9D | 5/2/2022 | 10:59 | 36.48 | 689.27 | | 652.79 | |
| MW-10S | 5/2/2022 | 14:07 | 27.45 | 691.10 | | 663.65 | |
| MW-10D | 5/2/2022 | 14:08 | 27.68 | 691.28 | | 663.60 | |
| MW-11S | 5/2/2022 | 12:20 | 30.74 | 686.17 | | 655.43 | |
| MW-11D | 5/2/2022 | 12:25 | 29.13 | 686.17 | | 657.04 | |
| MW-12S | 5/2/2022 | 11:56 | DRY | 688.82 | | DRY | |
| MW-12D | 5/2/2022 | 11:56 | 37.05 | 688.73 | | 651.68 | |
| MW-13S | 5/2/2022 | 11:26 | 36.37 | 696.08 | | 659.71 | |
| MW-13D | 5/2/2022 | 11:23 | 37.12 | 696.78 | | 659.66 | |
| MW-14D | 5/2/2022 | 12:31 | 40.62 | 697.88 | | 657.26 | |
| MW-15S | 5/2/2022 | 12:15 | 17.00 | 685.46 | | 668.46 | |
| MW-15I | 5/2/2022 | 12:16 | 16.40 | 685.59 | | 669.19 | |
| MW-15D | 5/2/2022 | 12:17 | 16.43 | 685.20 | | 668.77 | |
| **Nature & Extent Wells/Piezometers** | | | | | | | |
| M-4 | 5/2/2022 | 10:48 | 35.85 | 693.25 | | 657.40 | |
| PZ-100S | 5/2/2022 | 11:05 | 30.08 | 681.79 | | 651.71 | |
| PZ-100D | 5/2/2022 | 11:06 | 46.93 | 681.84 | | 634.91 | |
| PZ-101S | 5/2/2022 | 10:59 | 44.12 | 689.36 | | 645.24 | |
| PZ-101D | 5/2/2022 | 10:58 | 85.38 | 689.40 | | 604.02 | |
| MW-102S | 5/2/2022 | 10:40 | 56.97 | 677.10 | | 620.13 | |
| MW-102D | 5/2/2022 | 10:42 | 59.90 | 677.48 | | 617.58 | |
| MW-103S | 5/2/2022 | 10:25 | 35.35 | 701.27 | | 665.92 | |
| MW-103I | 5/2/2022 | 10:26 | 89.93 | 701.26 | | 611.33 | |
| MW-103D | 5/2/2022 | 10:27 | 91.90 | 701.54 | | 609.64 | |
| MW-104S | 5/2/2022 | 10:35 | DRY | 676.60 | | DRY | |
| MW-104D | 5/2/2022 | 10:38 | 87.80 | 677.01 | | 589.21 | |
| MW-105S | 5/2/2022 | 10:15 | 24.94 | 661.47 | | 636.53 | |
| MW-105I | 5/2/2022 | 10:16 | 53.28 | 661.37 | | 608.09 | |
| MW-105D | 5/2/2022 | 10:17 | 46.65 | 661.04 | | 614.39 | |
| MW-106S | 5/2/2022 | 10:10 | 21.61 | 671.05 | | 649.44 | |
| MW-106I | 5/2/2022 | 10:11 | 60.95 | 671.05 | | 610.10 | |
| MW-106D | 5/2/2022 | 10:12 | 62.59 | 671.00 | | 608.41 | |
| MW-107S | 5/2/2022 | 9:56 | 5.48 | 658.23 | | 652.75 | |
| MW-107I | 5/2/2022 | 9:55 | 34.66 | 658.47 | | 623.81 | |
| MW-107D | 5/2/2022 | 9:54 | 35.92 | 658.55 | | 622.63 | |
| MW-108S | 5/2/2022 | 10:50 | 32.81 | 642.22 | | 609.41 | |
| MW-108D | 5/2/2022 | 10:52 | 46.11 | 642.03 | | 595.92 | |
| **Historic Piezometers/Wells** | | | | | | | |
| M-3 | 5/2/2022 | 10:45 | 9.34 | 693.58 | | 684.24 | |
| M-6 | 5/2/2022 | 10:25 | 7.67 | 676.52 | | 668.85 | |
| P-2 | 5/2/2022 | 11:14 | 10.66 | 675.73 | | 665.07 | |
| P-3 | 5/2/2022 | 12:20 | 17.30 | 685.67 | | - | |
| P-4 | 5/2/2022 | 12:30 | 17.03 | 684.53 | | 667.50 | |
| P-5 | 5/2/2022 | 12:25 | 15.40 | 683.75 | | 668.35 | |
| P-6 | 5/2/2022 | 12:40 | 10.05 | 677.49 | | 667.44 | |
| PZ-1 | 5/2/2022 | 12:00 | dry (45.0 ft) | 714.54 | | <669.54 | |
| PZ-2 | 5/2/2022 | 12:03 | 45.97 | 714.91 | | 668.94 | |
| PZ-3 | 5/2/2022 | 11:00 | 43.42 | 713.81 | | 670.39 | |
| PZ-5 | 5/2/2022 | 11:42 | 41.35 | 714.52 | | 673.17 | |
| PZ-6 | 5/2/2022 | 11:29 | 17.84 | 688.21 | | 670.37 | |
| PZ-7 | 5/2/2022 | 12:24 | 14.38 | 684.73 | | 670.35 | |
| PZ-8 | 5/2/2022 | 11:18 | dry | 683.96 | | #VALUE! | |
| PZ-9 | 5/2/2022 | 11:06 | 28.04 | 683.86 | | 655.82 | |
| PZ-10 | 5/2/2022 | 11:09 | 33.01 | 683.91 | | 650.90 | |

**Table A-2**
Gauging Summary
May 2, 2022
AES Indiana
Harding Street Generating Station
ATC Project No. 170LF01277

| Well | Date | Time | DTW, from top of Reference Point | Reference Point Elevation (TOC) | | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| PZ-11 | 5/2/2022 | 14:00 | 23.58 | 685.12 | | 661.54 | |
| PZ-12 | 5/2/2022 | 10:57 | 30.81 | 709.68 | | 678.87 | |
| PZ-13 | 5/2/2022 | 10:55 | 17.42 | 698.01 | | 680.59 | |
| PZ-14 | 5/2/2022 | Not gauged - riser has bercome detached ~ 4 ft below grade | | 708.67 | | 708.67 | |
| **Ash Pond Piezometers** | | | | | | | |
| P1 PZ-1S | 5/2/2022 | 11:49 | 13.40 | 687.30 | | 673.90 | |
| P1 PZ-1D | 5/2/2022 | 11:49 | 22.15 | 687.25 | | 665.10 | |
| P2 PZ-1S | 5/2/2022 | 11:55 | 50.37 | 717.16 | | 666.79 | |
| P2 PZ-1D | 5/2/2022 | 11:51 | 55.44 | 716.33 | | 660.89 | |
| P2 PZ-2S | 5/2/2022 | 12:40 | 37.05 | 707.15 | | 670.10 | |
| P2 PZ-2D | 5/2/2022 | 12:42 | 48.53 | 706.92 | | 658.39 | |
| P2 PZ-3S | 5/2/2022 | 12:49 | 52.87 | 718.21 | | 665.34 | |
| P2 PZ-3D | 5/2/2022 | 12:51 | 60.54 | 718.19 | | 657.65 | |
| P2 A/B PZ-1S | 5/2/2022 | 13:45 | 26.11 | 691.55 | | 665.44 | |
| P2 A/B PZ-1D | 5/2/2022 | 13:46 | 26.53 | 691.19 | | 664.66 | |
| P2 A/B PZ-2S | 5/2/2022 | 13:50 | 24.76 | 689.49 | | 664.73 | |
| P2 A/B PZ-2D | 5/2/2022 | 13:52 | 25.87 | 689.06 | | 663.19 | |
| P3 PZ-1S | 5/2/2022 | 11:26 | 9.98 | 680.52 | | 670.54 | |
| P3 PZ-1D | 5/2/2022 | 11:26 | 15.25 | 681.15 | | 665.90 | |
| **Drive Point Piezometers** | | | | | | | |
| HA PZ-1 | | 11:45 | 4.35 | 670.80 | | 666.45 | |
| HA PZ-2 | 5/2/2022 | 9:37 | 9.34 | 670.56 | | 661.22 | |
| HA PZ-3 | 5/2/2022 | 9:26 | 11.57 | 671.08 | | 659.51 | |
| HA PZ-4 | 5/2/2022 | 9:17 | 2.33 | 663.67 | | 661.34 | |
| HA PZ-5 | 5/2/2022 | 9:10 | 7.71 | 667.91 | | 660.20 | |

| Well | Date | Time | Water Gauge Level (ft) | Reference Point Elevation (top of gage placard) | Staff Total Height (ft)* | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| Survey Shot SG-2 | 5/2/2022 | 8:43 | - | - | - | 662.65 | AES surveyor surveyed water level in front of piezometer |
| Survey Shot SG-3 | 5/2/2022 | 8:52 | - | - | - | 662.35 | AES surveyor surveyed water level in front of piezometer |
| Survey Shot SG-4 | 5/2/2022 | 9:01 | - | - | - | 661.89 | AES surveyor surveyed water level in front of piezometer |
| Survey Shot SG-5 | 5/2/2022 | 9:10 | - | - | - | 661.96 | AES surveyor surveyed water level in front of piezometer |

**USGS 03353611 - White River at Harding Street Generating Station (upstream of lowhead dam)**

| | Date | Time | Gage Height Above Datum (ft) | Datum Height | | SWE, ft MSL | Notes |
|---|---|---|---|---|---|---|---|
| River Gage | 5/2/2022 | 9:00 | 6.87 | 662.73 | | 669.6 | river peaked at 630am 5/2/2022 and was starting to decline |

**Flow Rate Calculations - May 2022**
AES Indiana Harding Street Generating Station
Indianapolis, Indiana
ATC Project No. 170LF01277

| HSS SHALLOW ZONE<br>FIGURE 5 | | **HSS** | | **HANSON** | |
|---|---|---|---|---|---|
| 5/2/2022 | Flow Rate Line | FR1 | FR2 | FR3 | FR4 |
| $v = Q/n_eA^1 = KI/n_e$ | | | | | |
| $\Delta H$ (ft) | Potentiometric Surface Hydraulic Head Change | 10 | 15 | 40 | 50 |
| $\Delta L$ (ft) | Flow Line Length | 1910 | 1705 | 530 | 1520 |
| K (hydraulic conductivity (ft/day)) | (2016 C/PC Plan) | 308 | 308 | 308 | 308 |
| I ($\Delta H/\Delta L$) | | 0.0052 | 0.0088 | 0.075 | 0.033 |
| $n_e$ (effective porosity, dimensionless) | (2016 C/PC Plan) | 0.35 | 0.35 | 0.35 | 0.35 |
| v (ft/day) | | 4.6 | 7.7 | 66 | 29 |
| | | | | | |
| HSS DEEP ZONE<br>FIGURE 6 | | **HSS** | | **HANSON** | |
| 5/2/2022 | Flow Rate Line | FR1 | FR2 | FR3 | FR4 |
| $v = Q/n_eA^1 = KI/n_e$ | | | | | |
| $\Delta H$ (ft) | Potentiometric Surface Hydraulic Head Change | 5 | 5 | 40 | 65 |
| $\Delta L$ (ft) | Flow Line Length | 1210 | 850 | 260 | 1765 |
| K (hydraulic conductivity (ft/day)) | (2016 C/PC Plan) | 308 | 308 | 308 | 308 |
| I ($\Delta H/\Delta L$) | | 0.0041 | 0.0059 | 0.15 | 0.037 |
| $n_e$ (effective porosity, dimensionless) | (2016 C/PC Plan) | 0.35 | 0.35 | 0.35 | 0.35 |
| v (ft/day) | | 3.6 | 5.2 | 130 | 33 |

Notes

1 - Average linear velocity equation from Fetter, C.W., 1980, Applied Hydrogeology: Merrill Publishing Company, 592 p.

Flow line paths are plotted to be consistent between Nov 2021 and May 2022 events.

ATTACHMENT B

**NOVEMBER 2021**

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 14, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 02, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Guam Certification
Florida: Cert E871149 SEKS WET
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50301756001** | **MW-2S** | Water | 11/01/21 10:35 | 11/02/21 14:30 |
| **50301756002** | **MW-2D** | Water | 11/01/21 12:00 | 11/02/21 14:30 |
| **50301756003** | **MW-3S** | Water | 11/01/21 15:10 | 11/02/21 14:30 |
| **50301756004** | **MW-3D** | Water | 11/01/21 15:22 | 11/02/21 14:30 |
| **50301756005** | **MW-3D RAD MS** | Water | 11/01/21 15:22 | 11/02/21 14:30 |
| **50301756006** | **MW-3D RAD MSD** | Water | 11/01/21 15:22 | 11/02/21 14:30 |
| **50301756007** | **MW-4S** | Water | 11/01/21 14:16 | 11/02/21 14:30 |
| **50301756008** | **MW-5S** | Water | 11/01/21 10:18 | 11/02/21 14:30 |
| **50301756009** | **MW-6S** | Water | 11/01/21 14:25 | 11/02/21 14:30 |
| **50301756010** | **MW-11D** | Water | 11/01/21 10:15 | 11/02/21 14:30 |
| **50301756011** | **MW-12S** | Water | 11/01/21 12:48 | 11/02/21 14:30 |
| **50301756012** | **MW-11S** | Water | 11/01/21 11:20 | 11/02/21 14:30 |
| **50301756013** | **MW-12D** | Water | 11/01/21 11:40 | 11/02/21 14:30 |
| **50301756014** | **MW-13D** | Water | 11/01/21 16:10 | 11/02/21 14:30 |
| **50301756015** | **MW-14D** | Water | 11/01/21 12:55 | 11/02/21 14:30 |
| **50301756016** | **DUP-1** | Water | 11/01/21 08:00 | 11/02/21 14:30 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50301756001** | **MW-2S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756002** | **MW-2D** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756003** | **MW-3S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756004** | **MW-3D** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756005** | **MW-3D RAD MS** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| **50301756006** | **MW-3D RAD MSD** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| **50301756007** | **MW-4S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756008** | **MW-5S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756009** | **MW-6S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756010** | **MW-11D** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756011** | **MW-12S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756012** | **MW-11S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756013** | **MW-12D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756014** | **MW-13D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756015** | **MW-14D** | EPA 9056 | RMR | 3 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301756016** | **DUP-1** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | RAM | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756001** | **MW-2S** | | | | | |
| EPA 9056 | Chloride | 206 | mg/L | 25.0 | 11/05/21 08:22 | |
| EPA 9056 | Fluoride | 0.50 | mg/L | 0.10 | 11/05/21 08:03 | P8 |
| EPA 9056 | Sulfate | 167 | mg/L | 25.0 | 11/05/21 08:22 | |
| EPA 6010 | Barium | 103 | ug/L | 10.0 | 11/13/21 10:46 | |
| EPA 6010 | Boron | 413 | ug/L | 100 | 11/13/21 10:46 | |
| EPA 6010 | Calcium | 83100 | ug/L | 1000 | 11/13/21 10:46 | |
| EPA 6010 | Iron | 3800 | ug/L | 100 | 11/13/21 10:46 | |
| EPA 6010 | Magnesium | 21000 | ug/L | 1000 | 11/13/21 10:46 | |
| EPA 6010 | Manganese | 373 | ug/L | 10.0 | 11/13/21 10:46 | |
| EPA 6010 | Molybdenum | 38.4 | ug/L | 10.0 | 11/13/21 10:46 | |
| EPA 6010 | Potassium | 7140 | ug/L | 1000 | 11/13/21 10:46 | |
| EPA 6010 | Silica | 11400 | ug/L | 450 | 11/13/21 10:46 | N2 |
| EPA 6010 | Sodium | 186000 | ug/L | 1000 | 11/13/21 10:46 | |
| EPA 6010 | Manganese, Dissolved | 356 | ug/L | 10.0 | 11/11/21 11:55 | |
| EPA 6010 | Molybdenum, Dissolved | 38.7 | ug/L | 10.0 | 11/11/21 11:55 | |
| EPA 6020 | Arsenic | 28.9 | ug/L | 1.0 | 11/05/21 03:58 | |
| EPA 903.1 | Radium-226 | 1.11 ± 0.505 (0.513) C:NA T:93% | pCi/L | | 12/09/21 14:18 | |
| EPA 904.0 | Radium-228 | 1.12 ± 0.434 (0.628) C:66% T:88% | pCi/L | | 12/09/21 11:43 | |
| Total Radium Calculation | Total Radium | 2.23 ± 0.939 (1.14) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 200 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 200 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 870 | mg/L | 20.0 | 11/03/21 09:59 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/21 10:36 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.93 | mg/L | 0.15 | 11/11/21 18:40 | |
| SM 5310C | Total Organic Carbon | 2.8 | mg/L | 1.0 | 11/09/21 18:53 | |
| SM 5310C | Dissolved Organic Carbon | 2.7 | mg/L | 1.0 | 11/15/21 19:21 | |
| **50301756002** | **MW-2D** | | | | | |
| EPA 9056 | Chloride | 291 | mg/L | 25.0 | 11/05/21 08:58 | |
| EPA 9056 | Fluoride | 0.86 | mg/L | 0.10 | 11/05/21 08:40 | P8 |
| EPA 9056 | Sulfate | 453 | mg/L | 25.0 | 11/05/21 08:58 | |
| EPA 6010 | Barium | 57.4 | ug/L | 10.0 | 11/13/21 10:48 | |
| EPA 6010 | Boron | 2020 | ug/L | 100 | 11/13/21 10:48 | |
| EPA 6010 | Calcium | 223000 | ug/L | 2000 | 11/13/21 12:02 | |
| EPA 6010 | Iron | 2300 | ug/L | 100 | 11/13/21 10:48 | |
| EPA 6010 | Lithium | 56.1 | ug/L | 20.0 | 11/13/21 10:48 | |
| EPA 6010 | Magnesium | 54300 | ug/L | 1000 | 11/13/21 10:48 | |
| EPA 6010 | Manganese | 494 | ug/L | 10.0 | 11/13/21 10:48 | |
| EPA 6010 | Molybdenum | 56.4 | ug/L | 10.0 | 11/13/21 10:48 | |
| EPA 6010 | Potassium | 14700 | ug/L | 1000 | 11/13/21 10:48 | |
| EPA 6010 | Silica | 16100 | ug/L | 450 | 11/13/21 10:48 | N2 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756002** | **MW-2D** | | | | | |
| EPA 6010 | Sodium | 190000 | ug/L | 1000 | 11/13/21 10:48 | |
| EPA 6010 | Manganese, Dissolved | 517 | ug/L | 10.0 | 11/11/21 11:57 | |
| EPA 6010 | Molybdenum, Dissolved | 56.8 | ug/L | 10.0 | 11/11/21 11:57 | |
| EPA 6020 | Arsenic | 3.8 | ug/L | 1.0 | 11/05/21 04:02 | |
| EPA 903.1 | Radium-226 | 0.189 ± 0.355 (0.628) C:NA T:102% | pCi/L | | 12/09/21 14:18 | |
| EPA 904.0 | Radium-228 | 1.39 ± 0.516 (0.770) C:60% T:99% | pCi/L | | 12/09/21 11:43 | |
| Total Radium Calculation | Total Radium | 1.58 ± 0.871 (1.40) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 309 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 309 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1470 | mg/L | 20.0 | 11/03/21 10:14 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.1 | Std. Units | 0.10 | 11/09/21 10:40 | H3 |
| SM 5310C | Total Organic Carbon | 2.2 | mg/L | 1.0 | 11/09/21 19:06 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 1.0 | 11/15/21 19:42 | |
| **50301756003** | **MW-3S** | | | | | |
| EPA 9056 | Chloride | 122 | mg/L | 25.0 | 11/09/21 06:31 | |
| EPA 9056 | Fluoride | 0.14 | mg/L | 0.10 | 11/09/21 06:20 | |
| EPA 9056 | Sulfate | 98.5 | mg/L | 2.5 | 11/05/21 09:35 | |
| EPA 6010 | Barium | 55.4 | ug/L | 10.0 | 11/13/21 10:50 | |
| EPA 6010 | Boron | 194 | ug/L | 100 | 11/13/21 10:50 | |
| EPA 6010 | Calcium | 99000 | ug/L | 1000 | 11/13/21 10:50 | |
| EPA 6010 | Magnesium | 20800 | ug/L | 1000 | 11/13/21 10:50 | |
| EPA 6010 | Manganese | 1110 | ug/L | 10.0 | 11/13/21 10:50 | |
| EPA 6010 | Molybdenum | 46.7 | ug/L | 10.0 | 11/13/21 10:50 | |
| EPA 6010 | Potassium | 2200 | ug/L | 1000 | 11/13/21 10:50 | |
| EPA 6010 | Silica | 9140 | ug/L | 450 | 11/13/21 10:50 | N2 |
| EPA 6010 | Sodium | 76200 | ug/L | 1000 | 11/13/21 10:50 | |
| EPA 6010 | Molybdenum, Dissolved | 34.5 | ug/L | 10.0 | 11/11/21 11:59 | |
| EPA 6020 | Antimony | 7.3 | ug/L | 1.0 | 11/04/21 10:05 | |
| EPA 6020 | Arsenic | 1.6 | ug/L | 1.0 | 11/05/21 04:06 | |
| EPA 6020 | Selenium | 3.6 | ug/L | 1.0 | 11/05/21 04:06 | |
| EPA 903.1 | Radium-226 | -0.325 ± 0.320 (0.764) C:NA T:99% | pCi/L | | 12/09/21 14:18 | |
| EPA 904.0 | Radium-228 | 0.591 ± 0.386 (0.732) C:63% T:95% | pCi/L | | 12/09/21 11:43 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756003** | **MW-3S** | | | | | |
| Total Radium Calculation | Total Radium | 0.591 ± 0.706 (1.50) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 279 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 279 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 548 | mg/L | 10.0 | 11/03/21 10:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 11/09/21 10:47 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 2.8 | mg/L | 0.10 | 11/02/21 18:09 | |
| **50301756004** | **MW-3D** | | | | | |
| EPA 9056 | Chloride | 178 | mg/L | 25.0 | 11/09/21 06:57 | |
| EPA 9056 | Fluoride | 0.15 | mg/L | 0.10 | 11/09/21 06:45 | |
| EPA 9056 | Sulfate | 76.4 | mg/L | 2.5 | 11/05/21 10:50 | |
| EPA 6010 | Barium | 66.9 | ug/L | 10.0 | 11/13/21 10:52 | |
| EPA 6010 | Boron | 393 | ug/L | 100 | 11/13/21 10:52 | |
| EPA 6010 | Calcium | 107000 | ug/L | 1000 | 11/13/21 10:52 | |
| EPA 6010 | Iron | 1650 | ug/L | 100 | 11/13/21 10:52 | |
| EPA 6010 | Magnesium | 26100 | ug/L | 1000 | 11/13/21 10:52 | |
| EPA 6010 | Manganese | 241 | ug/L | 10.0 | 11/13/21 10:52 | |
| EPA 6010 | Potassium | 3850 | ug/L | 1000 | 11/13/21 10:52 | |
| EPA 6010 | Silica | 10200 | ug/L | 450 | 11/13/21 10:52 | N2 |
| EPA 6010 | Sodium | 77600 | ug/L | 1000 | 11/13/21 10:52 | |
| EPA 6010 | Manganese, Dissolved | 233 | ug/L | 10.0 | 11/11/21 12:02 | |
| EPA 6020 | Arsenic | 3.4 | ug/L | 1.0 | 11/05/21 04:19 | |
| EPA 903.1 | Radium-226 | 0.342 ± 0.352 (0.564) C:NA T:100% | pCi/L | | 12/09/21 14:18 | |
| EPA 904.0 | Radium-228 | 1.14 ± 0.495 (0.820) C:66% T:88% | pCi/L | | 12/09/21 11:45 | |
| Total Radium Calculation | Total Radium | 1.48 ± 0.847 (1.38) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 216 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 216 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 615 | mg/L | 10.0 | 11/03/21 10:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 10:49 | H3 |
| SM 5310C | Total Organic Carbon | 1.1 | mg/L | 1.0 | 11/09/21 19:54 | |
| SM 5310C | Dissolved Organic Carbon | 1.2 | mg/L | 1.0 | 11/15/21 20:21 | |
| **50301756005** | **MW-3D RAD MS** | | | | | |
| EPA 903.1 | Radium-226 | 84.37 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 12/09/21 14:18 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756005** | **MW-3D RAD MS** | | | | | |
| EPA 904.0 | Radium-228 | 110.32 %REC ± NA (NA) C:NA T:NA | pCi/L | | 12/09/21 11:45 | |
| **50301756006** | **MW-3D RAD MSD** | | | | | |
| EPA 903.1 | Radium-226 | 90.15 %REC 6.62 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 12/09/21 14:18 | |
| EPA 904.0 | Radium-228 | 105.13 %REC 4.81 RPD ± NA (NA) C:NA T:NA | pCi/L | | 12/09/21 11:45 | |
| **50301756007** | **MW-4S** | | | | | |
| EPA 9056 | Chloride | 27.6 | mg/L | 25.0 | 11/05/21 12:40 | |
| EPA 9056 | Fluoride | 0.10 | mg/L | 0.10 | 11/09/21 06:09 | |
| EPA 9056 | Sulfate | 98.7 | mg/L | 25.0 | 11/05/21 12:40 | |
| EPA 6010 | Barium | 80.8 | ug/L | 10.0 | 11/13/21 11:06 | |
| EPA 6010 | Boron | 3160 | ug/L | 100 | 11/13/21 11:06 | |
| EPA 6010 | Calcium | 155000 | ug/L | 1000 | 11/13/21 11:06 | |
| EPA 6010 | Lithium | 23.4 | ug/L | 20.0 | 11/13/21 11:06 | |
| EPA 6010 | Magnesium | 31500 | ug/L | 1000 | 11/13/21 11:06 | |
| EPA 6010 | Potassium | 2100 | ug/L | 1000 | 11/13/21 11:06 | |
| EPA 6010 | Silica | 11800 | ug/L | 450 | 11/13/21 11:06 | N2 |
| EPA 6010 | Sodium | 22100 | ug/L | 1000 | 11/13/21 11:06 | |
| EPA 6020 | Selenium | 20.3 | ug/L | 1.0 | 11/05/21 04:48 | |
| EPA 903.1 | Radium-226 | 0.120 ± 0.394 (0.728) C:NA T:96% | pCi/L | | 12/09/21 14:18 | |
| EPA 904.0 | Radium-228 | -0.0640 ± 0.400 (0.931) C:66% T:94% | pCi/L | | 12/09/21 11:45 | |
| Total Radium Calculation | Total Radium | 0.120 ± 0.794 (1.66) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 406 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 406 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 616 | mg/L | 10.0 | 11/03/21 10:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 11/09/21 10:44 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 3.4 | mg/L | 0.10 | 11/02/21 18:17 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 11/15/21 21:21 | |
| **50301756008** | **MW-5S** | | | | | |
| EPA 9056 | Chloride | 205 | mg/L | 25.0 | 11/05/21 13:17 | |
| EPA 9056 | Fluoride | 1.9 | mg/L | 0.10 | 11/05/21 12:59 | P8 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756008** | **MW-5S** | | | | | |
| EPA 9056 | Sulfate | 301 | mg/L | 25.0 | 11/05/21 13:17 | |
| EPA 6010 | Barium | 24.3 | ug/L | 10.0 | 11/13/21 11:08 | |
| EPA 6010 | Boron | 2370 | ug/L | 100 | 11/13/21 11:08 | |
| EPA 6010 | Calcium | 145000 | ug/L | 1000 | 11/13/21 11:08 | |
| EPA 6010 | Lithium | 46.2 | ug/L | 20.0 | 11/13/21 11:08 | |
| EPA 6010 | Magnesium | 41200 | ug/L | 1000 | 11/13/21 11:08 | |
| EPA 6010 | Manganese | 744 | ug/L | 10.0 | 11/13/21 11:08 | |
| EPA 6010 | Molybdenum | 152 | ug/L | 10.0 | 11/13/21 11:08 | |
| EPA 6010 | Potassium | 7620 | ug/L | 1000 | 11/13/21 11:08 | |
| EPA 6010 | Silica | 13900 | ug/L | 450 | 11/13/21 11:08 | N2 |
| EPA 6010 | Sodium | 174000 | ug/L | 1000 | 11/13/21 11:08 | |
| EPA 6010 | Manganese, Dissolved | 727 | ug/L | 10.0 | 11/11/21 12:10 | |
| EPA 6010 | Molybdenum, Dissolved | 147 | ug/L | 10.0 | 11/11/21 12:10 | |
| EPA 903.1 | Radium-226 | 0.0401 ± 0.342 (0.667) C:NA T:97% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 0.979 ± 0.441 (0.751) C:69% T:92% | pCi/L | | 12/09/21 11:45 | |
| Total Radium Calculation | Total Radium | 1.02 ± 0.783 (1.42) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 291 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 291 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1140 | mg/L | 20.0 | 11/03/21 10:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 11/09/21 10:32 | H3 |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/09/21 20:43 | |
| SM 5310C | Dissolved Organic Carbon | 1.7 | mg/L | 1.0 | 11/15/21 21:41 | |
| **50301756009** | **MW-6S** | | | | | |
| EPA 9056 | Chloride | 202 | mg/L | 25.0 | 11/05/21 14:31 | |
| EPA 9056 | Fluoride | 1.2 | mg/L | 0.10 | 11/05/21 14:13 | |
| EPA 9056 | Sulfate | 485 | mg/L | 25.0 | 11/05/21 14:31 | |
| EPA 6010 | Barium | 117 | ug/L | 10.0 | 11/13/21 11:10 | |
| EPA 6010 | Boron | 6210 | ug/L | 100 | 11/13/21 11:10 | |
| EPA 6010 | Calcium | 233000 | ug/L | 2000 | 11/13/21 12:08 | |
| EPA 6010 | Iron | 5810 | ug/L | 100 | 11/13/21 11:10 | |
| EPA 6010 | Lithium | 73.0 | ug/L | 20.0 | 11/13/21 11:10 | |
| EPA 6010 | Magnesium | 62900 | ug/L | 1000 | 11/13/21 11:10 | |
| EPA 6010 | Manganese | 1690 | ug/L | 10.0 | 11/13/21 11:10 | |
| EPA 6010 | Molybdenum | 186 | ug/L | 10.0 | 11/13/21 11:10 | |
| EPA 6010 | Potassium | 11500 | ug/L | 1000 | 11/13/21 11:10 | |
| EPA 6010 | Silica | 13100 | ug/L | 450 | 11/13/21 11:10 | N2 |
| EPA 6010 | Sodium | 171000 | ug/L | 1000 | 11/13/21 11:10 | |
| EPA 6010 | Manganese, Dissolved | 1460 | ug/L | 10.0 | 11/11/21 12:12 | |
| EPA 6010 | Molybdenum, Dissolved | 150 | ug/L | 10.0 | 11/11/21 12:12 | |
| EPA 6020 | Arsenic | 11.8 | ug/L | 1.0 | 11/05/21 04:56 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756009** | **MW-6S** | | | | | |
| EPA 6020 | Cobalt | 1.6 | ug/L | 1.0 | 11/05/21 04:56 | |
| EPA 6020 | Selenium | 6.0 | ug/L | 1.0 | 11/05/21 04:56 | |
| EPA 903.1 | Radium-226 | -0.234 ± 0.401 (0.882) C:NA T:88% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 0.392 ± 0.375 (0.770) C:67% T:89% | pCi/L | | 12/09/21 11:45 | |
| Total Radium Calculation | Total Radium | 0.392 ± 0.776 (1.65) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 426 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 426 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1440 | mg/L | 20.0 | 11/03/21 10:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 11/09/21 10:46 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.77 | mg/L | 0.10 | 11/02/21 18:21 | |
| EPA 365.1 | Phosphate as P04 | 0.62 | mg/L | 0.15 | 11/11/21 18:46 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/09/21 18:36 | |
| SM 5310C | Dissolved Organic Carbon | 1.8 | mg/L | 1.0 | 11/15/21 22:01 | |
| **50301756010** | **MW-11D** | | | | | |
| EPA 9056 | Chloride | 67.3 | mg/L | 25.0 | 11/05/21 15:08 | |
| EPA 9056 | Fluoride | 0.36 | mg/L | 0.10 | 11/05/21 14:50 | |
| EPA 9056 | Sulfate | 530 | mg/L | 25.0 | 11/05/21 15:08 | |
| EPA 6010 | Barium | 23.6 | ug/L | 10.0 | 11/13/21 11:12 | |
| EPA 6010 | Boron | 10900 | ug/L | 100 | 11/13/21 11:12 | |
| EPA 6010 | Calcium | 213000 | ug/L | 2000 | 11/13/21 12:10 | |
| EPA 6010 | Iron | 5300 | ug/L | 100 | 11/13/21 11:12 | |
| EPA 6010 | Lithium | 150 | ug/L | 20.0 | 11/13/21 11:12 | |
| EPA 6010 | Magnesium | 49900 | ug/L | 1000 | 11/13/21 11:12 | |
| EPA 6010 | Manganese | 39.5 | ug/L | 10.0 | 11/13/21 11:12 | |
| EPA 6010 | Potassium | 3010 | ug/L | 1000 | 11/13/21 11:12 | |
| EPA 6010 | Silica | 16500 | ug/L | 450 | 11/13/21 11:12 | N2 |
| EPA 6010 | Sodium | 74200 | ug/L | 1000 | 11/13/21 11:12 | |
| EPA 6010 | Manganese, Dissolved | 35.6 | ug/L | 10.0 | 11/11/21 12:19 | |
| EPA 6020 | Arsenic | 14.8 | ug/L | 1.0 | 11/05/21 05:00 | |
| EPA 903.1 | Radium-226 | 0.0864 ± 0.268 (0.519) C:NA T:96% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 1.00 ± 0.443 (0.740) C:68% T:95% | pCi/L | | 12/09/21 11:46 | |
| Total Radium Calculation | Total Radium | 1.09 ± 0.711 (1.26) | pCi/L | | 12/14/21 13:39 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756010** | **MW-11D** | | | | | |
| SM 2320B | Alkalinity, Total as CaCO3 | 249 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 249 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1160 | mg/L | 20.0 | 11/03/21 10:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.1 | Std. Units | 0.10 | 11/09/21 10:31 | H3 |
| SM 5310C | Dissolved Organic Carbon | 1.3 | mg/L | 1.0 | 11/15/21 22:20 | |
| **50301756011** | **MW-12S** | | | | | |
| EPA 9056 | Chloride | 177 | mg/L | 25.0 | 11/05/21 15:45 | |
| EPA 9056 | Fluoride | 1.8 | mg/L | 0.10 | 11/05/21 15:27 | |
| EPA 9056 | Sulfate | 486 | mg/L | 25.0 | 11/05/21 15:45 | |
| EPA 6010 | Barium | 31.6 | ug/L | 10.0 | 11/13/21 11:15 | |
| EPA 6010 | Boron | 5870 | ug/L | 100 | 11/13/21 11:15 | |
| EPA 6010 | Calcium | 198000 | ug/L | 1000 | 11/13/21 11:15 | |
| EPA 6010 | Lithium | 73.2 | ug/L | 20.0 | 11/13/21 11:15 | |
| EPA 6010 | Magnesium | 57000 | ug/L | 1000 | 11/13/21 11:15 | |
| EPA 6010 | Manganese | 393 | ug/L | 10.0 | 11/13/21 11:15 | |
| EPA 6010 | Molybdenum | 144 | ug/L | 10.0 | 11/13/21 11:15 | |
| EPA 6010 | Potassium | 9480 | ug/L | 1000 | 11/13/21 11:15 | |
| EPA 6010 | Silica | 15600 | ug/L | 450 | 11/13/21 11:15 | N2 |
| EPA 6010 | Sodium | 157000 | ug/L | 1000 | 11/13/21 11:15 | |
| EPA 6010 | Manganese, Dissolved | 404 | ug/L | 10.0 | 11/11/21 12:21 | |
| EPA 6010 | Molybdenum, Dissolved | 137 | ug/L | 10.0 | 11/11/21 12:21 | |
| EPA 6020 | Antimony | 2.8 | ug/L | 1.0 | 11/04/21 10:34 | |
| EPA 6020 | Arsenic | 43.4 | ug/L | 1.0 | 11/05/21 05:12 | |
| EPA 6020 | Selenium | 10.7 | ug/L | 1.0 | 11/05/21 05:12 | |
| EPA 903.1 | Radium-226 | 0.000 ± 0.357 (0.703) C:NA T:102% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 0.912 ± 0.481 (0.874) C:64% T:91% | pCi/L | | 12/09/21 11:46 | |
| Total Radium Calculation | Total Radium | 0.912 ± 0.838 (1.58) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 315 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 315 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1350 | mg/L | 20.0 | 11/03/21 10:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 10:41 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.24 | mg/L | 0.10 | 11/02/21 18:28 | |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 11/09/21 19:21 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 1.0 | 11/15/21 23:19 | |
| **50301756012** | **MW-11S** | | | | | |
| EPA 9056 | Chloride | 25.1 | mg/L | 2.5 | 11/05/21 16:22 | |
| EPA 9056 | Fluoride | 1.4 | mg/L | 0.10 | 11/05/21 16:03 | |
| EPA 9056 | Sulfate | 103 | mg/L | 2.5 | 11/05/21 16:22 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756012** | **MW-11S** | | | | | |
| EPA 6010 | Barium | 74.3 | ug/L | 10.0 | 11/13/21 11:17 | |
| EPA 6010 | Boron | 617 | ug/L | 100 | 11/13/21 11:17 | |
| EPA 6010 | Calcium | 50300 | ug/L | 1000 | 11/13/21 11:17 | |
| EPA 6010 | Iron | 194 | ug/L | 100 | 11/13/21 11:17 | |
| EPA 6010 | Magnesium | 29600 | ug/L | 1000 | 11/13/21 11:17 | |
| EPA 6010 | Molybdenum | 76.1 | ug/L | 10.0 | 11/13/21 11:17 | |
| EPA 6010 | Potassium | 2000 | ug/L | 1000 | 11/13/21 11:17 | |
| EPA 6010 | Silica | 13600 | ug/L | 450 | 11/13/21 11:17 | N2 |
| EPA 6010 | Sodium | 20800 | ug/L | 1000 | 11/13/21 11:17 | |
| EPA 6010 | Molybdenum, Dissolved | 70.8 | ug/L | 10.0 | 11/11/21 12:24 | |
| EPA 6020 | Arsenic | 2.2 | ug/L | 1.0 | 11/05/21 05:17 | |
| EPA 903.1 | Radium-226 | 0.497 ± 0.368 (0.498) C:NA T:101% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 0.571 ± 0.438 (0.869) C:63% T:89% | pCi/L | | 12/09/21 11:46 | |
| Total Radium Calculation | Total Radium | 1.07 ± 0.806 (1.37) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 195 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 195 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 421 | mg/L | 10.0 | 11/03/21 10:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/09/21 10:38 | H3 |
| **50301756013** | **MW-12D** | | | | | |
| EPA 9056 | Chloride | 168 | mg/L | 25.0 | 11/03/21 20:27 | |
| EPA 9056 | Fluoride | 1.3 | mg/L | 0.10 | 11/03/21 19:54 | |
| EPA 9056 | Sulfate | 614 | mg/L | 25.0 | 11/03/21 20:27 | |
| EPA 6010 | Barium | 26.8 | ug/L | 10.0 | 11/13/21 11:19 | |
| EPA 6010 | Boron | 7730 | ug/L | 100 | 11/13/21 11:19 | |
| EPA 6010 | Calcium | 218000 | ug/L | 2000 | 11/13/21 12:12 | |
| EPA 6010 | Iron | 2340 | ug/L | 100 | 11/13/21 11:19 | |
| EPA 6010 | Lithium | 95.5 | ug/L | 20.0 | 11/13/21 11:19 | |
| EPA 6010 | Magnesium | 51400 | ug/L | 1000 | 11/13/21 11:19 | |
| EPA 6010 | Manganese | 316 | ug/L | 10.0 | 11/13/21 11:19 | |
| EPA 6010 | Molybdenum | 176 | ug/L | 10.0 | 11/13/21 11:19 | |
| EPA 6010 | Potassium | 13400 | ug/L | 1000 | 11/13/21 11:19 | |
| EPA 6010 | Silica | 13700 | ug/L | 450 | 11/13/21 11:19 | N2 |
| EPA 6010 | Sodium | 166000 | ug/L | 1000 | 11/13/21 11:19 | |
| EPA 6010 | Manganese, Dissolved | 343 | ug/L | 10.0 | 11/11/21 12:26 | |
| EPA 6010 | Molybdenum, Dissolved | 171 | ug/L | 10.0 | 11/11/21 12:26 | |
| EPA 6020 | Arsenic | 428 | ug/L | 5.0 | 11/05/21 05:45 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756013** | **MW-12D** | | | | | |
| EPA 903.1 | Radium-226 | 0.205 ± 0.349 (0.616) C:NA T:87% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 0.755 ± 0.411 (0.745) C:70% T:88% | pCi/L | | 12/09/21 11:46 | |
| Total Radium Calculation | Total Radium | 0.960 ± 0.760 (1.36) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 254 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 254 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1450 | mg/L | 20.0 | 11/03/21 10:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 10:39 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.57 | mg/L | 0.15 | 11/17/21 07:35 | |
| SM 5310C | Total Organic Carbon | 1.1 | mg/L | 1.0 | 11/09/21 20:12 | |
| SM 5310C | Dissolved Organic Carbon | 1.3 | mg/L | 1.0 | 11/16/21 00:04 | |
| **50301756014** | **MW-13D** | | | | | |
| EPA 9056 | Chloride | 299 | mg/L | 25.0 | 11/03/21 21:18 | |
| EPA 9056 | Fluoride | 0.55 | mg/L | 0.10 | 11/03/21 20:44 | |
| EPA 9056 | Sulfate | 484 | mg/L | 25.0 | 11/03/21 21:18 | |
| EPA 6010 | Barium | 30.7 | ug/L | 10.0 | 11/13/21 11:21 | |
| EPA 6010 | Boron | 11400 | ug/L | 100 | 11/13/21 11:21 | |
| EPA 6010 | Calcium | 191000 | ug/L | 1000 | 11/13/21 11:21 | |
| EPA 6010 | Iron | 1940 | ug/L | 100 | 11/13/21 11:21 | |
| EPA 6010 | Lithium | 84.7 | ug/L | 20.0 | 11/13/21 11:21 | |
| EPA 6010 | Magnesium | 53200 | ug/L | 1000 | 11/13/21 11:21 | |
| EPA 6010 | Manganese | 196 | ug/L | 10.0 | 11/13/21 11:21 | |
| EPA 6010 | Molybdenum | 599 | ug/L | 10.0 | 11/13/21 11:21 | |
| EPA 6010 | Potassium | 15800 | ug/L | 1000 | 11/13/21 11:21 | |
| EPA 6010 | Silica | 13300 | ug/L | 450 | 11/13/21 11:21 | N2 |
| EPA 6010 | Sodium | 180000 | ug/L | 1000 | 11/13/21 11:21 | |
| EPA 6010 | Manganese, Dissolved | 182 | ug/L | 10.0 | 11/11/21 12:28 | |
| EPA 6010 | Molybdenum, Dissolved | 554 | ug/L | 10.0 | 11/11/21 12:28 | |
| EPA 6020 | Arsenic | 231 | ug/L | 2.0 | 11/05/21 05:50 | |
| EPA 903.1 | Radium-226 | 0.370 ± 0.294 (0.382) C:NA T:93% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 1.09 ± 0.446 (0.699) C:67% T:92% | pCi/L | | 12/09/21 11:46 | |
| Total Radium Calculation | Total Radium | 1.46 ± 0.740 (1.08) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 182 | mg/L | 2.0 | 11/04/21 16:03 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756014** | **MW-13D** | | | | | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 182 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1430 | mg/L | 20.0 | 11/03/21 10:17 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/09/21 10:51 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.34 | mg/L | 0.15 | 11/17/21 07:36 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/09/21 20:32 | |
| SM 5310C | Dissolved Organic Carbon | 2.2 | mg/L | 1.0 | 11/16/21 00:24 | |
| **50301756015** | **MW-14D** | | | | | |
| EPA 9056 | Chloride | 283 | mg/L | 25.0 | 11/03/21 22:42 | |
| EPA 9056 | Fluoride | 0.20 | mg/L | 0.10 | 11/03/21 21:35 | |
| EPA 9056 | Sulfate | 1830 | mg/L | 25.0 | 11/03/21 22:42 | |
| EPA 6010 | Aluminum | 328 | ug/L | 200 | 11/13/21 11:23 | |
| EPA 6010 | Barium | 51.5 | ug/L | 10.0 | 11/13/21 11:23 | |
| EPA 6010 | Boron | 42400 | ug/L | 100 | 11/13/21 11:23 | |
| EPA 6010 | Calcium | 504000 | ug/L | 5000 | 11/13/21 12:14 | |
| EPA 6010 | Iron | 2460 | ug/L | 100 | 11/13/21 11:23 | |
| EPA 6010 | Lithium | 751 | ug/L | 20.0 | 11/13/21 11:23 | |
| EPA 6010 | Magnesium | 123000 | ug/L | 1000 | 11/13/21 11:23 | |
| EPA 6010 | Manganese | 293 | ug/L | 10.0 | 11/13/21 11:23 | |
| EPA 6010 | Molybdenum | 257 | ug/L | 10.0 | 11/13/21 11:23 | |
| EPA 6010 | Potassium | 55200 | ug/L | 1000 | 11/13/21 11:23 | |
| EPA 6010 | Silica | 11000 | ug/L | 450 | 11/13/21 11:23 | N2 |
| EPA 6010 | Sodium | 290000 | ug/L | 5000 | 11/13/21 12:14 | |
| EPA 6010 | Manganese, Dissolved | 288 | ug/L | 10.0 | 11/11/21 12:30 | |
| EPA 6010 | Molybdenum, Dissolved | 242 | ug/L | 10.0 | 11/11/21 12:30 | |
| EPA 6020 | Arsenic | 113 | ug/L | 1.0 | 11/05/21 05:37 | |
| EPA 903.1 | Radium-226 | 0.117 ± 0.398 (0.735) C:NA T:99% | pCi/L | | 12/09/21 14:31 | |
| EPA 904.0 | Radium-228 | 1.37 ± 0.632 (1.11) C:66% T:78% | pCi/L | | 12/09/21 11:35 | |
| Total Radium Calculation | Total Radium | 1.49 ± 1.03 (1.85) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 133 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 133 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 3380 | mg/L | 40.0 | 11/03/21 10:17 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 10:42 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.52 | mg/L | 0.15 | 11/17/21 07:38 | |
| SM 5310C | Total Organic Carbon | 1.9 | mg/L | 1.0 | 11/09/21 20:53 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 11/16/21 00:45 | |
| **50301756016** | **DUP-1** | | | | | |
| EPA 9056 | Chloride | 192 | mg/L | 25.0 | 11/03/21 23:32 | |
| EPA 9056 | Fluoride | 1.1 | mg/L | 0.10 | 11/03/21 22:59 | |
| EPA 9056 | Sulfate | 477 | mg/L | 25.0 | 11/03/21 23:32 | |
| EPA 6010 | Barium | 117 | ug/L | 10.0 | 11/13/21 11:47 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301756016** | **DUP-1** | | | | | |
| EPA 6010 | Boron | 6090 | ug/L | 100 | 11/13/21 11:47 | |
| EPA 6010 | Calcium | 234000 | ug/L | 2000 | 11/13/21 12:17 | |
| EPA 6010 | Iron | 5940 | ug/L | 100 | 11/13/21 11:47 | |
| EPA 6010 | Lithium | 69.6 | ug/L | 20.0 | 11/13/21 11:47 | |
| EPA 6010 | Magnesium | 62300 | ug/L | 1000 | 11/13/21 11:47 | |
| EPA 6010 | Manganese | 1680 | ug/L | 10.0 | 11/13/21 11:47 | |
| EPA 6010 | Molybdenum | 181 | ug/L | 10.0 | 11/13/21 11:47 | |
| EPA 6010 | Potassium | 11200 | ug/L | 1000 | 11/13/21 11:47 | |
| EPA 6010 | Silica | 12900 | ug/L | 450 | 11/13/21 11:47 | N2 |
| EPA 6010 | Sodium | 166000 | ug/L | 1000 | 11/13/21 11:47 | |
| EPA 6010 | Manganese, Dissolved | 1530 | ug/L | 10.0 | 11/11/21 12:33 | |
| EPA 6010 | Molybdenum, Dissolved | 154 | ug/L | 10.0 | 11/11/21 12:33 | |
| EPA 6020 | Arsenic | 12.4 | ug/L | 1.0 | 11/05/21 05:41 | |
| EPA 6020 | Cobalt | 1.6 | ug/L | 1.0 | 11/04/21 11:03 | |
| EPA 6020 | Selenium | 6.4 | ug/L | 1.0 | 11/05/21 05:41 | |
| EPA 903.1 | Radium-226 | 0.401 ± 0.354 (0.525) C:NA T:94% | pCi/L | | 12/09/21 14:50 | |
| EPA 904.0 | Radium-228 | 0.563 ± 0.504 (1.04) C:66% T:87% | pCi/L | | 12/09/21 11:35 | |
| Total Radium Calculation | Total Radium | 0.964 ± 0.858 (1.57) | pCi/L | | 12/14/21 13:38 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 440 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 440 | mg/L | 2.0 | 11/04/21 16:03 | |
| SM 2540C | Total Dissolved Solids | 1380 | mg/L | 20.0 | 11/03/21 10:17 | |
| SM 4500-H+B | pH at 25 Degrees C | 6.9 | Std. Units | 0.10 | 11/09/21 10:30 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.67 | mg/L | 0.10 | 11/02/21 18:37 | |
| EPA 365.1 | Phosphate as P04 | 0.62 | mg/L | 0.15 | 11/17/21 07:39 | |
| SM 5310C | Total Organic Carbon | 2.0 | mg/L | 1.0 | 11/09/21 21:25 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 11/16/21 01:05 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-2S** **Lab ID: 50301756001** Collected: 11/01/21 10:35 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **206** | mg/L | 25.0 | 100 | | 11/05/21 08:22 | 16887-00-6 | |
| Fluoride | **0.50** | mg/L | 0.10 | 1 | | 11/05/21 08:03 | 16984-48-8 | P8 |
| Sulfate | **167** | mg/L | 25.0 | 100 | | 11/05/21 08:22 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7429-90-5 | |
| Barium | **103** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-39-3 | |
| Boron | **413** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-43-9 | |
| Calcium | **83100** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-47-3 | |
| Iron | **3800** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7439-93-2 | |
| Magnesium | **21000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7439-95-4 | |
| Manganese | **373** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7439-96-5 | |
| Molybdenum | **38.4** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7439-98-7 | |
| Potassium | **7140** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-09-7 | |
| Silica | **11400** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7631-86-9 | N2 |
| Sodium | **186000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:46 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **356** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 11:55 | 7439-96-5 | |
| Molybdenum, Dissolved | **38.7** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 11:55 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 09:57 | 7440-36-0 | |
| Arsenic | **28.9** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 03:58 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 03:58 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 03:58 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **200** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **200** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **870** | mg/L | 20.0 | 1 | | 11/03/21 09:59 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-2S** **Lab ID: 50301756001** Collected: 11/01/21 10:35 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/09/21 10:36 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:06 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:06 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.93** | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:40 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.8** | mg/L | 1.0 | 1 | | 11/09/21 18:53 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.7** | mg/L | 1.0 | 1 | | 11/15/21 19:21 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-2D** **Lab ID: 50301756002** Collected: 11/01/21 12:00 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **291** | mg/L | 25.0 | 100 | | 11/05/21 08:58 | 16887-00-6 | |
| Fluoride | **0.86** | mg/L | 0.10 | 1 | | 11/05/21 08:40 | 16984-48-8 | P8 |
| Sulfate | **453** | mg/L | 25.0 | 100 | | 11/05/21 08:58 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7429-90-5 | |
| Barium | **57.4** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7440-39-3 | |
| Boron | **2020** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7440-43-9 | |
| Calcium | **223000** | ug/L | 2000 | 2 | 11/11/21 07:00 | 11/13/21 12:02 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7440-47-3 | |
| Iron | **2300** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7439-92-1 | |
| Lithium | **56.1** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7439-93-2 | |
| Magnesium | **54300** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7439-95-4 | |
| Manganese | **494** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7439-96-5 | |
| Molybdenum | **56.4** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7439-98-7 | |
| Potassium | **14700** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7440-09-7 | |
| Silica | **16100** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7631-86-9 | N2 |
| Sodium | **190000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:48 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **517** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 11:57 | 7439-96-5 | |
| Molybdenum, Dissolved | **56.8** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 11:57 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:01 | 7440-36-0 | |
| Arsenic | **3.8** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:02 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:02 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:02 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **309** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **309** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1470** | mg/L | 20.0 | 1 | | 11/03/21 10:14 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-2D** **Lab ID: 50301756002** Collected: 11/01/21 12:00 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.1** | Std. Units | 0.10 | 1 | | 11/09/21 10:40 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:08 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:08 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:40 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 11/09/21 19:06 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 11/15/21 19:42 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3S** **Lab ID: 50301756003** Collected: 11/01/21 15:10 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **122** | mg/L | 25.0 | 100 | | 11/09/21 06:31 | 16887-00-6 | |
| Fluoride | **0.14** | mg/L | 0.10 | 1 | | 11/09/21 06:20 | 16984-48-8 | |
| Sulfate | **98.5** | mg/L | 2.5 | 10 | | 11/05/21 09:35 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7429-90-5 | |
| Barium | **55.4** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-39-3 | |
| Boron | **194** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-43-9 | |
| Calcium | **99000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7439-93-2 | |
| Magnesium | **20800** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7439-95-4 | |
| Manganese | **1110** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7439-96-5 | |
| Molybdenum | **46.7** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7439-98-7 | |
| Potassium | **2200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-09-7 | |
| Silica | **9140** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7631-86-9 | N2 |
| Sodium | **76200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:50 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 11:59 | 7439-96-5 | |
| Molybdenum, Dissolved | **34.5** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 11:59 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | **7.3** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:05 | 7440-36-0 | |
| Arsenic | **1.6** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:06 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:06 | 7440-48-4 | |
| Selenium | **3.6** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:06 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **279** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **279** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **548** | mg/L | 10.0 | 1 | | 11/03/21 10:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3S** **Lab ID: 50301756003** Collected: 11/01/21 15:10 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 11/09/21 10:47 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **2.8** | mg/L | 0.10 | 1 | | 11/02/21 18:09 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:09 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/09/21 19:42 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/15/21 20:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3D** **Lab ID: 50301756004** Collected: 11/01/21 15:22 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **178** | mg/L | 25.0 | 100 | | 11/09/21 06:57 | 16887-00-6 | |
| Fluoride | **0.15** | mg/L | 0.10 | 1 | | 11/09/21 06:45 | 16984-48-8 | |
| Sulfate | **76.4** | mg/L | 2.5 | 10 | | 11/05/21 10:50 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7429-90-5 | |
| Barium | **66.9** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-39-3 | |
| Boron | **393** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-43-9 | |
| Calcium | **107000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-47-3 | |
| Iron | **1650** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7439-93-2 | |
| Magnesium | **26100** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7439-95-4 | |
| Manganese | **241** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7439-98-7 | |
| Potassium | **3850** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-09-7 | |
| Silica | **10200** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7631-86-9 | N2 |
| Sodium | **77600** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 10:52 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **233** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:02 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:02 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 09:24 | 7440-36-0 | |
| Arsenic | **3.4** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:19 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:19 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:19 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **216** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **216** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **615** | mg/L | 10.0 | 1 | | 11/03/21 10:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3D** **Lab ID: 50301756004** Collected: 11/01/21 15:22 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 10:49 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:11 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:11 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 11/09/21 19:54 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.2** | mg/L | 1.0 | 1 | | 11/15/21 20:21 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-4S** **Lab ID: 50301756007** Collected: 11/01/21 14:16 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **27.6** | mg/L | 25.0 | 100 | | 11/05/21 12:40 | 16887-00-6 | |
| Fluoride | **0.10** | mg/L | 0.10 | 1 | | 11/09/21 06:09 | 16984-48-8 | |
| Sulfate | **98.7** | mg/L | 25.0 | 100 | | 11/05/21 12:40 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7429-90-5 | |
| Barium | **80.8** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-39-3 | |
| Boron | **3160** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-43-9 | |
| Calcium | **155000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7439-92-1 | |
| Lithium | **23.4** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7439-93-2 | |
| Magnesium | **31500** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7439-98-7 | |
| Potassium | **2100** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-09-7 | |
| Silica | **11800** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7631-86-9 | N2 |
| Sodium | **22100** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:06 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:08 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:08 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:17 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:48 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:48 | 7440-48-4 | |
| Selenium | **20.3** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:48 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **406** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **406** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **616** | mg/L | 10.0 | 1 | | 11/03/21 10:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-4S** **Lab ID: 50301756007** Collected: 11/01/21 14:16 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 11/09/21 10:44 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **3.4** | mg/L | 0.10 | 1 | | 11/02/21 18:17 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:17 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:45 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/09/21 20:26 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 11/15/21 21:21 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-5S** **Lab ID: 50301756008** Collected: 11/01/21 10:18 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **205** | mg/L | 25.0 | 100 | | 11/05/21 13:17 | 16887-00-6 | |
| Fluoride | **1.9** | mg/L | 0.10 | 1 | | 11/05/21 12:59 | 16984-48-8 | P8 |
| Sulfate | **301** | mg/L | 25.0 | 100 | | 11/05/21 13:17 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7429-90-5 | |
| Barium | **24.3** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-39-3 | |
| Boron | **2370** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-43-9 | |
| Calcium | **145000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7439-92-1 | |
| Lithium | **46.2** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7439-93-2 | |
| Magnesium | **41200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7439-95-4 | |
| Manganese | **744** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7439-96-5 | |
| Molybdenum | **152** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7439-98-7 | |
| Potassium | **7620** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-09-7 | |
| Silica | **13900** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7631-86-9 | N2 |
| Sodium | **174000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:08 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **727** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:10 | 7439-96-5 | |
| Molybdenum, Dissolved | **147** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:10 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:22 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:52 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:52 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:52 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **291** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **291** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1140** | mg/L | 20.0 | 1 | | 11/03/21 10:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-5S** **Lab ID: 50301756008** Collected: 11/01/21 10:18 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 11/09/21 10:32 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:19 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:19 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:45 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/09/21 20:43 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 11/15/21 21:41 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-6S** **Lab ID: 50301756009** Collected: 11/01/21 14:25 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **202** | mg/L | 25.0 | 100 | | 11/05/21 14:31 | 16887-00-6 | |
| Fluoride | **1.2** | mg/L | 0.10 | 1 | | 11/05/21 14:13 | 16984-48-8 | |
| Sulfate | **485** | mg/L | 25.0 | 100 | | 11/05/21 14:31 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7429-90-5 | |
| Barium | **117** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7440-39-3 | |
| Boron | **6210** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7440-43-9 | |
| Calcium | **233000** | ug/L | 2000 | 2 | 11/11/21 07:00 | 11/13/21 12:08 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7440-47-3 | |
| Iron | **5810** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7439-92-1 | |
| Lithium | **73.0** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7439-93-2 | |
| Magnesium | **62900** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7439-95-4 | |
| Manganese | **1690** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7439-96-5 | |
| Molybdenum | **186** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7439-98-7 | |
| Potassium | **11500** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7440-09-7 | |
| Silica | **13100** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7631-86-9 | N2 |
| Sodium | **171000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:10 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **1460** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:12 | 7439-96-5 | |
| Molybdenum, Dissolved | **150** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:12 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:26 | 7440-36-0 | |
| Arsenic | **11.8** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:56 | 7440-38-2 | |
| Cobalt | **1.6** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:56 | 7440-48-4 | |
| Selenium | **6.0** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 04:56 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **426** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **426** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1440** | mg/L | 20.0 | 1 | | 11/03/21 10:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-6S** **Lab ID: 50301756009** Collected: 11/01/21 14:25 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 11/09/21 10:46 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.77** | mg/L | 0.10 | 1 | | 11/02/21 18:21 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:21 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.62** | mg/L | 0.15 | 1 | 11/11/21 10:30 | 11/11/21 18:46 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/09/21 18:36 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/15/21 22:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-11D** **Lab ID: 50301756010** Collected: 11/01/21 10:15 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **67.3** | mg/L | 25.0 | 100 | | 11/05/21 15:08 | 16887-00-6 | |
| Fluoride | **0.36** | mg/L | 0.10 | 1 | | 11/05/21 14:50 | 16984-48-8 | |
| Sulfate | **530** | mg/L | 25.0 | 100 | | 11/05/21 15:08 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7429-90-5 | |
| Barium | **23.6** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7440-39-3 | |
| Boron | **10900** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7440-43-9 | |
| Calcium | **213000** | ug/L | 2000 | 2 | 11/11/21 07:00 | 11/13/21 12:10 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7440-47-3 | |
| Iron | **5300** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7439-92-1 | |
| Lithium | **150** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7439-93-2 | |
| Magnesium | **49900** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7439-95-4 | |
| Manganese | **39.5** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7439-98-7 | |
| Potassium | **3010** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7440-09-7 | |
| Silica | **16500** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7631-86-9 | N2 |
| Sodium | **74200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:12 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **35.6** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:19 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:19 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:30 | 7440-36-0 | |
| Arsenic | **14.8** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:00 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:00 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:00 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **249** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **249** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1160** | mg/L | 20.0 | 1 | | 11/03/21 10:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-11D** **Lab ID: 50301756010** Collected: 11/01/21 10:15 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.1** | Std. Units | 0.10 | 1 | | 11/09/21 10:31 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:22 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:22 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:32 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/09/21 18:55 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 11/15/21 22:20 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-12S** **Lab ID: 50301756011** Collected: 11/01/21 12:48 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **177** | mg/L | 25.0 | 100 | | 11/05/21 15:45 | 16887-00-6 | |
| Fluoride | **1.8** | mg/L | 0.10 | 1 | | 11/05/21 15:27 | 16984-48-8 | |
| Sulfate | **486** | mg/L | 25.0 | 100 | | 11/05/21 15:45 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7429-90-5 | |
| Barium | **31.6** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-39-3 | |
| Boron | **5870** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-43-9 | |
| Calcium | **198000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7439-92-1 | |
| Lithium | **73.2** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7439-93-2 | |
| Magnesium | **57000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7439-95-4 | |
| Manganese | **393** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7439-96-5 | |
| Molybdenum | **144** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7439-98-7 | |
| Potassium | **9480** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-09-7 | |
| Silica | **15600** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7631-86-9 | N2 |
| Sodium | **157000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:15 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **404** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:21 | 7439-96-5 | |
| Molybdenum, Dissolved | **137** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:21 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | **2.8** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:34 | 7440-36-0 | |
| Arsenic | **43.4** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:12 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:12 | 7440-48-4 | |
| Selenium | **10.7** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:12 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **315** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **315** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1350** | mg/L | 20.0 | 1 | | 11/03/21 10:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-12S** **Lab ID: 50301756011** Collected: 11/01/21 12:48 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 10:41 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.24** | mg/L | 0.10 | 1 | | 11/02/21 18:28 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:28 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:33 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 11/09/21 19:21 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 11/15/21 23:19 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-11S** **Lab ID: 50301756012** Collected: 11/01/21 11:20 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **25.1** | mg/L | 2.5 | 10 | | 11/05/21 16:22 | 16887-00-6 | |
| Fluoride | **1.4** | mg/L | 0.10 | 1 | | 11/05/21 16:03 | 16984-48-8 | |
| Sulfate | **103** | mg/L | 2.5 | 10 | | 11/05/21 16:22 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7429-90-5 | |
| Barium | **74.3** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-39-3 | |
| Boron | **617** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-43-9 | |
| Calcium | **50300** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-47-3 | |
| Iron | **194** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7439-93-2 | |
| Magnesium | **29600** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7439-96-5 | |
| Molybdenum | **76.1** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7439-98-7 | |
| Potassium | **2000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-09-7 | |
| Silica | **13600** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7631-86-9 | N2 |
| Sodium | **20800** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:17 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:24 | 7439-96-5 | |
| Molybdenum, Dissolved | **70.8** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:24 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:46 | 7440-36-0 | |
| Arsenic | **2.2** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:17 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:46 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:17 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **195** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **195** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **421** | mg/L | 10.0 | 1 | | 11/03/21 10:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-11S** **Lab ID: 50301756012** Collected: 11/01/21 11:20 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/09/21 10:38 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:30 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:30 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:33 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/09/21 19:46 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/15/21 23:44 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-12D** **Lab ID: 50301756013** Collected: 11/01/21 11:40 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **168** | mg/L | 25.0 | 100 | | 11/03/21 20:27 | 16887-00-6 | |
| Fluoride | **1.3** | mg/L | 0.10 | 1 | | 11/03/21 19:54 | 16984-48-8 | |
| Sulfate | **614** | mg/L | 25.0 | 100 | | 11/03/21 20:27 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7429-90-5 | |
| Barium | **26.8** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7440-39-3 | |
| Boron | **7730** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7440-43-9 | |
| Calcium | **218000** | ug/L | 2000 | 2 | 11/11/21 07:00 | 11/13/21 12:12 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7440-47-3 | |
| Iron | **2340** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7439-92-1 | |
| Lithium | **95.5** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7439-93-2 | |
| Magnesium | **51400** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7439-95-4 | |
| Manganese | **316** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7439-96-5 | |
| Molybdenum | **176** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7439-98-7 | |
| Potassium | **13400** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7440-09-7 | |
| Silica | **13700** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7631-86-9 | N2 |
| Sodium | **166000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:19 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **343** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:26 | 7439-96-5 | |
| Molybdenum, Dissolved | **171** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:26 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:51 | 7440-36-0 | |
| Arsenic | **428** | ug/L | 5.0 | 5 | 11/03/21 18:25 | 11/05/21 05:45 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:51 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:21 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **254** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **254** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1450** | mg/L | 20.0 | 1 | | 11/03/21 10:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-12D** **Lab ID: 50301756013** Collected: 11/01/21 11:40 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 10:39 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:32 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:32 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.57** | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:35 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 11/09/21 20:12 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 11/16/21 00:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-13D** **Lab ID: 50301756014** Collected: 11/01/21 16:10 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **299** | mg/L | 25.0 | 100 | | 11/03/21 21:18 | 16887-00-6 | |
| Fluoride | **0.55** | mg/L | 0.10 | 1 | | 11/03/21 20:44 | 16984-48-8 | |
| Sulfate | **484** | mg/L | 25.0 | 100 | | 11/03/21 21:18 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7429-90-5 | |
| Barium | **30.7** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-39-3 | |
| Boron | **11400** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-43-9 | |
| Calcium | **191000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-47-3 | |
| Iron | **1940** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7439-92-1 | |
| Lithium | **84.7** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7439-93-2 | |
| Magnesium | **53200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7439-95-4 | |
| Manganese | **196** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7439-96-5 | |
| Molybdenum | **599** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7439-98-7 | |
| Potassium | **15800** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-09-7 | |
| Silica | **13300** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7631-86-9 | N2 |
| Sodium | **180000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:21 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **182** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:28 | 7439-96-5 | |
| Molybdenum, Dissolved | **554** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:28 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:55 | 7440-36-0 | |
| Arsenic | **231** | ug/L | 2.0 | 2 | 11/03/21 18:25 | 11/05/21 05:50 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:55 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:25 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **182** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **182** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1430** | mg/L | 20.0 | 1 | | 11/03/21 10:17 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-13D** **Lab ID: 50301756014** Collected: 11/01/21 16:10 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/09/21 10:51 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:34 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:34 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.34** | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:36 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/09/21 20:32 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 11/16/21 00:24 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-14D** **Lab ID: 50301756015** Collected: 11/01/21 12:55 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **283** | mg/L | 25.0 | 100 | | 11/03/21 22:42 | 16887-00-6 | |
| Fluoride | **0.20** | mg/L | 0.10 | 1 | | 11/03/21 21:35 | 16984-48-8 | |
| Sulfate | **1830** | mg/L | 25.0 | 100 | | 11/03/21 22:42 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **328** | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7429-90-5 | |
| Barium | **51.5** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7440-39-3 | |
| Boron | **42400** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7440-43-9 | |
| Calcium | **504000** | ug/L | 5000 | 5 | 11/11/21 07:00 | 11/13/21 12:14 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7440-47-3 | |
| Iron | **2460** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7439-92-1 | |
| Lithium | **751** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7439-93-2 | |
| Magnesium | **123000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7439-95-4 | |
| Manganese | **293** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7439-96-5 | |
| Molybdenum | **257** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7439-98-7 | |
| Potassium | **55200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7440-09-7 | |
| Silica | **11000** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:23 | 7631-86-9 | N2 |
| Sodium | **290000** | ug/L | 5000 | 5 | 11/11/21 07:00 | 11/13/21 12:14 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **288** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:30 | 7439-96-5 | |
| Molybdenum, Dissolved | **242** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:30 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:59 | 7440-36-0 | |
| Arsenic | **113** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:37 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 10:59 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:37 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **133** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **133** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **3380** | mg/L | 40.0 | 1 | | 11/03/21 10:17 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-14D** **Lab ID: 50301756015** Collected: 11/01/21 12:55 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 10:42 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/02/21 18:35 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:35 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.52** | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:38 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 11/09/21 20:53 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 11/16/21 00:45 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: DUP-1** **Lab ID: 50301756016** Collected: 11/01/21 08:00 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **192** | mg/L | 25.0 | 100 | | 11/03/21 23:32 | 16887-00-6 | |
| Fluoride | **1.1** | mg/L | 0.10 | 1 | | 11/03/21 22:59 | 16984-48-8 | |
| Sulfate | **477** | mg/L | 25.0 | 100 | | 11/03/21 23:32 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7429-90-5 | |
| Barium | **117** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7440-39-3 | |
| Boron | **6090** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7440-43-9 | |
| Calcium | **234000** | ug/L | 2000 | 2 | 11/11/21 07:00 | 11/13/21 12:17 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7440-47-3 | |
| Iron | **5940** | ug/L | 100 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7439-92-1 | |
| Lithium | **69.6** | ug/L | 20.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7439-93-2 | |
| Magnesium | **62300** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7439-95-4 | |
| Manganese | **1680** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7439-96-5 | |
| Molybdenum | **181** | ug/L | 10.0 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7439-98-7 | |
| Potassium | **11200** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7440-09-7 | |
| Silica | **12900** | ug/L | 450 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7631-86-9 | N2 |
| Sodium | **166000** | ug/L | 1000 | 1 | 11/11/21 07:00 | 11/13/21 11:47 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **1530** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:33 | 7439-96-5 | |
| Molybdenum, Dissolved | **154** | ug/L | 10.0 | 1 | 11/09/21 13:57 | 11/11/21 12:33 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 11:03 | 7440-36-0 | |
| Arsenic | **12.4** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:41 | 7440-38-2 | |
| Cobalt | **1.6** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/04/21 11:03 | 7440-48-4 | |
| Selenium | **6.4** | ug/L | 1.0 | 1 | 11/03/21 18:25 | 11/05/21 05:41 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **440** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Bicarbonate (CaCO3) | **440** | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/04/21 16:03 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1380** | mg/L | 20.0 | 1 | | 11/03/21 10:17 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: DUP-1** **Lab ID: 50301756016** Collected: 11/01/21 08:00 Received: 11/02/21 14:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **6.9** | Std. Units | 0.10 | 1 | | 11/09/21 10:30 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/03/21 17:05 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.67** | mg/L | 0.10 | 1 | | 11/02/21 18:37 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/02/21 18:37 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.62** | mg/L | 0.15 | 1 | 11/11/21 12:00 | 11/17/21 07:39 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 11/09/21 21:25 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 11/16/21 01:05 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648336
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012

METHOD BLANK: 2987050 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/04/21 20:41 | |
| Fluoride | mg/L | ND | 0.10 | 11/04/21 20:41 | |
| Sulfate | mg/L | ND | 0.25 | 11/04/21 20:41 | |

LABORATORY CONTROL SAMPLE: 2987051

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 93 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.47 | 95 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 95 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987052 2987053

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 178 | 125 | 125 | 305 | 305 | 101 | 102 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.15 | 0.5 | 0.5 | 0.52 | 0.53 | 74 | 75 | 80-120 | 1 | 15 | M0 |
| Sulfate | mg/L | 76.4 | 25 | 25 | 100 | 101 | 96 | 98 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648381
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2987254 Matrix: Water
Associated Lab Samples: 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/03/21 19:20 | |
| Fluoride | mg/L | ND | 0.10 | 11/03/21 19:20 | |
| Sulfate | mg/L | ND | 0.25 | 11/03/21 19:20 | |

LABORATORY CONTROL SAMPLE: 2987255

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 94 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 95 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 97 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987256 2987257

| Parameter | Units | 50301690012 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 2.6 | 1.2 | 1.2 | 3.7 | 3.7 | 91 | 92 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | <0.10 | 0.5 | 0.5 | 0.48 | 0.48 | 87 | 87 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | <1.0 | 2.5 | 2.5 | 2.8 | 2.7 | 92 | 92 | 80-120 | 0 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987258 2987259

| Parameter | Units | 50301690013 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 11.4 | 1.2 | 1.2 | 12.4 | 12.4 | 77 | 78 | 80-120 | 0 | 15 | E |
| Fluoride | mg/L | <0.10 | 0.5 | 0.5 | 0.45 | 0.46 | 82 | 84 | 80-120 | 3 | 15 | |
| Sulfate | mg/L | 4.5 | 2.5 | 2.5 | 7.0 | 7.0 | 97 | 97 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648524
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2988162 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/13/21 10:39 | |
| Barium | ug/L | ND | 10.0 | 11/13/21 10:39 | |
| Boron | ug/L | ND | 100 | 11/13/21 10:39 | |
| Cadmium | ug/L | ND | 2.0 | 11/13/21 10:39 | |
| Calcium | ug/L | ND | 1000 | 11/13/21 10:39 | |
| Chromium | ug/L | ND | 10.0 | 11/13/21 10:39 | |
| Iron | ug/L | ND | 100 | 11/13/21 10:39 | |
| Lead | ug/L | ND | 10.0 | 11/13/21 10:39 | |
| Lithium | ug/L | ND | 20.0 | 11/13/21 10:39 | |
| Magnesium | ug/L | ND | 1000 | 11/13/21 10:39 | |
| Manganese | ug/L | ND | 10.0 | 11/13/21 10:39 | |
| Molybdenum | ug/L | ND | 10.0 | 11/13/21 10:39 | |
| Potassium | ug/L | ND | 1000 | 11/13/21 10:39 | |
| Silica | ug/L | ND | 450 | 11/13/21 10:39 | N2 |
| Sodium | ug/L | ND | 1000 | 11/13/21 10:39 | |

LABORATORY CONTROL SAMPLE: 2988163

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4730 | 95 | 80-120 | |
| Barium | ug/L | 1000 | 950 | 95 | 80-120 | |
| Boron | ug/L | 1000 | 941 | 94 | 80-120 | |
| Cadmium | ug/L | 1000 | 907 | 91 | 80-120 | |
| Calcium | ug/L | 5000 | 4820 | 96 | 80-120 | |
| Chromium | ug/L | 1000 | 952 | 95 | 80-120 | |
| Iron | ug/L | 2500 | 2390 | 96 | 80-120 | |
| Lead | ug/L | 1000 | 899 | 90 | 80-120 | |
| Lithium | ug/L | 1000 | 1010 | 101 | 80-120 | |
| Magnesium | ug/L | 5000 | 4620 | 92 | 80-120 | |
| Manganese | ug/L | 1000 | 927 | 93 | 80-120 | |
| Molybdenum | ug/L | 1000 | 945 | 94 | 80-120 | |
| Potassium | ug/L | 5000 | 4700 | 94 | 80-120 | |
| Silica | ug/L | 5350 | 5030 | 94 | | N2 |
| Sodium | ug/L | 5000 | 4720 | 94 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988164 2988165

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4630 | 4510 | 92 | 90 | 75-125 | 2 | 20 | |
| Barium | ug/L | 66.9 | 1000 | 1000 | 1030 | 1000 | 96 | 93 | 75-125 | 3 | 20 | |
| Boron | ug/L | 393 | 1000 | 1000 | 1370 | 1340 | 97 | 95 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 932 | 915 | 93 | 92 | 75-125 | 2 | 20 | |
| Calcium | ug/L | 107000 | 5000 | 5000 | 111000 | 111000 | 78 | 70 | 75-125 | 0 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 966 | 937 | 97 | 94 | 75-125 | 3 | 20 | |
| Iron | ug/L | 1650 | 2500 | 2500 | 4000 | 3960 | 94 | 92 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 880 | 859 | 88 | 86 | 75-125 | 2 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1090 | 1060 | 107 | 105 | 75-125 | 3 | 20 | |
| Magnesium | ug/L | 26100 | 5000 | 5000 | 30300 | 30200 | 83 | 83 | 75-125 | 0 | 20 | |
| Manganese | ug/L | 241 | 1000 | 1000 | 1160 | 1140 | 92 | 90 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 984 | 963 | 98 | 96 | 75-125 | 2 | 20 | |
| Potassium | ug/L | 3850 | 5000 | 5000 | 8960 | 8860 | 102 | 100 | 75-125 | 1 | 20 | |
| Silica | ug/L | 10200 | 5350 | 5350 | 15300 | 15200 | 94 | 92 | | 1 | | N2 |
| Sodium | ug/L | 77600 | 5000 | 5000 | 82600 | 81700 | 101 | 82 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648486
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2987927 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/11/21 11:26 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/11/21 11:26 | |

LABORATORY CONTROL SAMPLE: 2987928

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 956 | 96 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 986 | 99 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987929 2987930

| Parameter | Units | 50301711003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 2250 | 1000 | 1000 | 3170 | 3160 | 92 | 91 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1010 | 1000 | 100 | 99 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987931 2987932

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 233 | 1000 | 1000 | 1180 | 1120 | 94 | 89 | 75-125 | 5 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 981 | 943 | 97 | 94 | 75-125 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648378
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2987188 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/04/21 03:36 | |
| Arsenic | ug/L | ND | 1.0 | 11/04/21 03:36 | |
| Cobalt | ug/L | ND | 1.0 | 11/04/21 03:36 | |
| Selenium | ug/L | ND | 1.0 | 11/04/21 03:36 | |

LABORATORY CONTROL SAMPLE: 2987189

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 40.0 | 100 | 80-120 | |
| Arsenic | ug/L | 40 | 37.6 | 94 | 80-120 | |
| Cobalt | ug/L | 40 | 38.0 | 95 | 80-120 | |
| Selenium | ug/L | 40 | 36.0 | 90 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987190 2987191

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 41.1 | 41.4 | 103 | 103 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | 3.4 | 40 | 40 | 40.4 | 40.7 | 92 | 93 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 36.0 | 36.3 | 90 | 90 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.7 | 39.1 | 96 | 97 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648601 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2988459 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/04/21 16:03 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/04/21 16:03 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/04/21 16:03 | |

LABORATORY CONTROL SAMPLE: 2988460

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 48.7 | 97 | 90-110 | |

SAMPLE DUPLICATE: 2988461

| Parameter | Units | 50301756004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 216 | 218 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 216 | 218 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2988462

| Parameter | Units | 50301767002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 378 | 349 | 8 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 378 | 348 | 8 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648289
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001

METHOD BLANK: 2986822 Matrix: Water
Associated Lab Samples: 50301756001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/03/21 09:56 | |

LABORATORY CONTROL SAMPLE: 2986823

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 304 | 101 | 80-120 | |

SAMPLE DUPLICATE: 2986825

| Parameter | Units | 50301711003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2530 | 2570 | 1 | 10 | |

SAMPLE DUPLICATE: 2986912

| Parameter | Units | 50301712003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2530 | 2570 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648290 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2986830 Matrix: Water
Associated Lab Samples: 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/03/21 10:14 | |

LABORATORY CONTROL SAMPLE: 2986831

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 291 | 97 | 80-120 | |

SAMPLE DUPLICATE: 2986832

| Parameter | Units | 50301756004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 615 | 626 | 2 | 10 | |

SAMPLE DUPLICATE: 2986833

| Parameter | Units | 50301767002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 439 | 443 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 649296
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

SAMPLE DUPLICATE: 2991788

| Parameter | Units | 50301756004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.3 | 7.3 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 2991789

| Parameter | Units | 50301767002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.8 | 7.9 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648329 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2987019 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/03/21 17:05 | |

LABORATORY CONTROL SAMPLE: 2987020

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.50 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987021 2987022

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.37 | 0.39 | 74 | 78 | 90-110 | 5 | 20 | M3 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2987023 2987024

| Parameter | Units | 50301767002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.35 | 0.35 | 71 | 70 | 90-110 | 1 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 648160
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2986375 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/02/21 14:27 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/02/21 14:27 | |

LABORATORY CONTROL SAMPLE: 2986376

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 109 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2986377 2986378

| Parameter | Units | 50301711003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 102 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 111 | 111 | 90-110 | 0 | 20 | M3 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2986572 2986573

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 109 | 109 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 649655 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009

METHOD BLANK: 2993568 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/11/21 18:38 | |

LABORATORY CONTROL SAMPLE: 2993569

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993570 2993571

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.6 | ND | | | | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993572 2993573

| Parameter | Units | 50301690012 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | <0.15 | | | 1.7 | 1.7 | | | | 1 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 649656 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2993578 Matrix: Water
Associated Lab Samples: 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 07:31 | |

LABORATORY CONTROL SAMPLE: 2993579

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE SAMPLE: 2993580

| Parameter | Units | 50301756010 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993581 2993582

| Parameter | Units | 50301690013 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | <0.15 | | | 1.5 | 1.5 | | | | 1 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 649369 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008

METHOD BLANK: 2992155 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/09/21 15:26 | |

LABORATORY CONTROL SAMPLE: 2992156

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992157 2992158

| Parameter | Units | 50301711003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.3 | 10 | 10 | 12.6 | 12.8 | 102 | 105 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992159 2992160

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.1 | 10 | 10 | 11.4 | 11.3 | 103 | 102 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 649371 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2992165 Matrix: Water
Associated Lab Samples: 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/09/21 17:50 | |

LABORATORY CONTROL SAMPLE: 2992166

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.7 | 97 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992167 2992168

| Parameter | Units | 50301758007 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.1 | 10 | 10 | 10.8 | 10.9 | 97 | 98 | 80-120 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 2992169

| Parameter | Units | 50301763002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 5880 ug/L | 10 | 15.7 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 650220
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2997030 Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/15/21 15:04 | |

LABORATORY CONTROL SAMPLE: 2997031

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.6 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997032 2997033

| Parameter | Units | 50301711003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.3 | 10 | 10 | 11.8 | 12.3 | 95 | 100 | 80-120 | 4 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997034 2997035

| Parameter | Units | 50301756004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.2 | 10 | 10 | 10.9 | 10.9 | 97 | 98 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-2S** **Lab ID: 50301756001** Collected: 11/01/21 10:35 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.11 ± 0.505 (0.513) C:NA T:93%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.12 ± 0.434 (0.628) C:66% T:88%** | pCi/L | 12/09/21 11:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.23 ± 0.939 (1.14)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-2D** **Lab ID: 50301756002** Collected: 11/01/21 12:00 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.189 ± 0.355 (0.628) C:NA T:102%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.39 ± 0.516 (0.770) C:60% T:99%** | pCi/L | 12/09/21 11:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.58 ± 0.871 (1.40)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3S** **Lab ID: 50301756003** Collected: 11/01/21 15:10 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.325 ± 0.320 (0.764) C:NA T:99%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.591 ± 0.386 (0.732) C:63% T:95%** | pCi/L | 12/09/21 11:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.591 ± 0.706 (1.50)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3D** **Lab ID: 50301756004** Collected: 11/01/21 15:22 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.342 ± 0.352 (0.564) C:NA T:100%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.14 ± 0.495 (0.820) C:66% T:88%** | pCi/L | 12/09/21 11:45 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.48 ± 0.847 (1.38)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3D RAD MS** **Lab ID: 50301756005** Collected: 11/01/21 15:22 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-226 | EPA 903.1 | **84.37 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-228 | EPA 904.0 | **110.32 %REC ± NA (NA) C:NA T:NA** | pCi/L | 12/09/21 11:45 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-3D RAD MSD** **Lab ID: 50301756006** Collected: 11/01/21 15:22 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **90.15 %REC 6.62 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **105.13 %REC 4.81 RPD ± NA (NA) C:NA T:NA** | pCi/L | 12/09/21 11:45 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-4S** **Lab ID: 50301756007** Collected: 11/01/21 14:16 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.120 ± 0.394 (0.728) C:NA T:96%** | pCi/L | 12/09/21 14:18 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **-0.0640 ± 0.400 (0.931) C:66% T:94%** | pCi/L | 12/09/21 11:45 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.120 ± 0.794 (1.66)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-5S** **Lab ID: 50301756008** Collected: 11/01/21 10:18 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0401 ± 0.342 (0.667) C:NA T:97%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.979 ± 0.441 (0.751) C:69% T:92%** | pCi/L | 12/09/21 11:45 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.02 ± 0.783 (1.42)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-6S** **Lab ID: 50301756009** Collected: 11/01/21 14:25 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.234 ± 0.401 (0.882) C:NA T:88%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.392 ± 0.375 (0.770) C:67% T:89%** | pCi/L | 12/09/21 11:45 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.392 ± 0.776 (1.65)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-11D** **Lab ID: 50301756010** Collected: 11/01/21 10:15 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0864 ± 0.268 (0.519) C:NA T:96%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.00 ± 0.443 (0.740) C:68% T:95%** | pCi/L | 12/09/21 11:46 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.09 ± 0.711 (1.26)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-12S** **Lab ID: 50301756011** Collected: 11/01/21 12:48 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.000 ± 0.357 (0.703) C:NA T:102%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.912 ± 0.481 (0.874) C:64% T:91%** | pCi/L | 12/09/21 11:46 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.912 ± 0.838 (1.58)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-11S** **Lab ID: 50301756012** Collected: 11/01/21 11:20 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.497 ± 0.368 (0.498) C:NA T:101%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.571 ± 0.438 (0.869) C:63% T:89%** | pCi/L | 12/09/21 11:46 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.07 ± 0.806 (1.37)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-12D** **Lab ID: 50301756013** Collected: 11/01/21 11:40 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.205 ± 0.349 (0.616) C:NA T:87%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.755 ± 0.411 (0.745) C:70% T:88%** | pCi/L | 12/09/21 11:46 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.960 ± 0.760 (1.36)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-13D** **Lab ID: 50301756014** Collected: 11/01/21 16:10 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.370 ± 0.294 (0.382) C:NA T:93%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.09 ± 0.446 (0.699) C:67% T:92%** | pCi/L | 12/09/21 11:46 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.46 ± 0.740 (1.08)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: MW-14D** **Lab ID: 50301756015** Collected: 11/01/21 12:55 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.117 ± 0.398 (0.735) C:NA T:99%** | pCi/L | 12/09/21 14:31 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.37 ± 0.632 (1.11) C:66% T:78%** | pCi/L | 12/09/21 11:35 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.49 ± 1.03 (1.85)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

**Sample: DUP-1** **Lab ID: 50301756016** Collected: 11/01/21 08:00 Received: 11/02/21 14:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.401 ± 0.354 (0.525) C:NA T:94%** | pCi/L | 12/09/21 14:50 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.563 ± 0.504 (1.04) C:66% T:87%** | pCi/L | 12/09/21 11:35 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.964 ± 0.858 (1.57)** | pCi/L | 12/14/21 13:38 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 472460
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756005, 50301756006, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2280947
Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756005, 50301756006, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.662 ± 0.378 (0.680) C:66% T:89% | pCi/L | 12/09/21 11:47 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

QC Batch: 472459
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756005, 50301756006, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

METHOD BLANK: 2280946
Matrix: Water
Associated Lab Samples: 50301756001, 50301756002, 50301756003, 50301756004, 50301756005, 50301756006, 50301756007, 50301756008, 50301756009, 50301756010, 50301756011, 50301756012, 50301756013, 50301756014, 50301756015, 50301756016

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0920 ± 0.301 (0.556) C:NA T:97% | pCi/L | 12/09/21 14:18 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| E | Analyte concentration exceeded the calibration range. The reported result is estimated. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| P8 | Analyte was detected in the method blank. All associated samples had concentrations of at least ten times greater than the blank or were below the reporting limit. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50301756001 | MW-2S | EPA 9056 | 648336 | | |
| 50301756002 | MW-2D | EPA 9056 | 648336 | | |
| 50301756003 | MW-3S | EPA 9056 | 648336 | | |
| 50301756004 | MW-3D | EPA 9056 | 648336 | | |
| 50301756007 | MW-4S | EPA 9056 | 648336 | | |
| 50301756008 | MW-5S | EPA 9056 | 648336 | | |
| 50301756009 | MW-6S | EPA 9056 | 648336 | | |
| 50301756010 | MW-11D | EPA 9056 | 648336 | | |
| 50301756011 | MW-12S | EPA 9056 | 648336 | | |
| 50301756012 | MW-11S | EPA 9056 | 648336 | | |
| 50301756013 | MW-12D | EPA 9056 | 648381 | | |
| 50301756014 | MW-13D | EPA 9056 | 648381 | | |
| 50301756015 | MW-14D | EPA 9056 | 648381 | | |
| 50301756016 | DUP-1 | EPA 9056 | 648381 | | |
| 50301756001 | MW-2S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756002 | MW-2D | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756003 | MW-3S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756004 | MW-3D | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756007 | MW-4S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756008 | MW-5S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756009 | MW-6S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756010 | MW-11D | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756011 | MW-12S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756012 | MW-11S | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756013 | MW-12D | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756014 | MW-13D | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756015 | MW-14D | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756016 | DUP-1 | EPA 3010 | 648524 | EPA 6010 | 650290 |
| 50301756001 | MW-2S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756002 | MW-2D | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756003 | MW-3S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756004 | MW-3D | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756007 | MW-4S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756008 | MW-5S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756009 | MW-6S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756010 | MW-11D | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756011 | MW-12S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756012 | MW-11S | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756013 | MW-12D | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756014 | MW-13D | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756015 | MW-14D | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756016 | DUP-1 | EPA 3010 | 648486 | EPA 6010 | 649840 |
| 50301756001 | MW-2S | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| 50301756002 | MW-2D | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| 50301756003 | MW-3S | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| 50301756004 | MW-3D | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| 50301756007 | MW-4S | EPA 200.2 | 648378 | EPA 6020 | 648530 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50301756008** | **MW-5S** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756009** | **MW-6S** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756010** | **MW-11D** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756011** | **MW-12S** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756012** | **MW-11S** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756013** | **MW-12D** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756014** | **MW-13D** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756015** | **MW-14D** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756016** | **DUP-1** | EPA 200.2 | 648378 | EPA 6020 | 648530 |
| **50301756001** | **MW-2S** | EPA 903.1 | 472459 | | |
| **50301756002** | **MW-2D** | EPA 903.1 | 472459 | | |
| **50301756003** | **MW-3S** | EPA 903.1 | 472459 | | |
| **50301756004** | **MW-3D** | EPA 903.1 | 472459 | | |
| **50301756005** | **MW-3D RAD MS** | EPA 903.1 | 472459 | | |
| **50301756006** | **MW-3D RAD MSD** | EPA 903.1 | 472459 | | |
| **50301756007** | **MW-4S** | EPA 903.1 | 472459 | | |
| **50301756008** | **MW-5S** | EPA 903.1 | 472459 | | |
| **50301756009** | **MW-6S** | EPA 903.1 | 472459 | | |
| **50301756010** | **MW-11D** | EPA 903.1 | 472459 | | |
| **50301756011** | **MW-12S** | EPA 903.1 | 472459 | | |
| **50301756012** | **MW-11S** | EPA 903.1 | 472459 | | |
| **50301756013** | **MW-12D** | EPA 903.1 | 472459 | | |
| **50301756014** | **MW-13D** | EPA 903.1 | 472459 | | |
| **50301756015** | **MW-14D** | EPA 903.1 | 472459 | | |
| **50301756016** | **DUP-1** | EPA 903.1 | 472459 | | |
| **50301756001** | **MW-2S** | EPA 904.0 | 472460 | | |
| **50301756002** | **MW-2D** | EPA 904.0 | 472460 | | |
| **50301756003** | **MW-3S** | EPA 904.0 | 472460 | | |
| **50301756004** | **MW-3D** | EPA 904.0 | 472460 | | |
| **50301756005** | **MW-3D RAD MS** | EPA 904.0 | 472460 | | |
| **50301756006** | **MW-3D RAD MSD** | EPA 904.0 | 472460 | | |
| **50301756007** | **MW-4S** | EPA 904.0 | 472460 | | |
| **50301756008** | **MW-5S** | EPA 904.0 | 472460 | | |
| **50301756009** | **MW-6S** | EPA 904.0 | 472460 | | |
| **50301756010** | **MW-11D** | EPA 904.0 | 472460 | | |
| **50301756011** | **MW-12S** | EPA 904.0 | 472460 | | |
| **50301756012** | **MW-11S** | EPA 904.0 | 472460 | | |
| **50301756013** | **MW-12D** | EPA 904.0 | 472460 | | |
| **50301756014** | **MW-13D** | EPA 904.0 | 472460 | | |
| **50301756015** | **MW-14D** | EPA 904.0 | 472460 | | |
| **50301756016** | **DUP-1** | EPA 904.0 | 472460 | | |
| **50301756001** | **MW-2S** | Total Radium Calculation | 476249 | | |
| **50301756002** | **MW-2D** | Total Radium Calculation | 476249 | | |
| **50301756003** | **MW-3S** | Total Radium Calculation | 476249 | | |
| **50301756004** | **MW-3D** | Total Radium Calculation | 476249 | | |
| **50301756007** | **MW-4S** | Total Radium Calculation | 476249 | | |
| **50301756008** | **MW-5S** | Total Radium Calculation | 476249 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50301756009 | MW-6S | Total Radium Calculation | 476249 | | |
| 50301756010 | MW-11D | Total Radium Calculation | 476249 | | |
| 50301756011 | MW-12S | Total Radium Calculation | 476249 | | |
| 50301756012 | MW-11S | Total Radium Calculation | 476249 | | |
| 50301756013 | MW-12D | Total Radium Calculation | 476249 | | |
| 50301756014 | MW-13D | Total Radium Calculation | 476249 | | |
| 50301756015 | MW-14D | Total Radium Calculation | 476249 | | |
| 50301756016 | DUP-1 | Total Radium Calculation | 476246 | | |
| 50301756001 | MW-2S | SM 2320B | 648601 | | |
| 50301756002 | MW-2D | SM 2320B | 648601 | | |
| 50301756003 | MW-3S | SM 2320B | 648601 | | |
| 50301756004 | MW-3D | SM 2320B | 648601 | | |
| 50301756007 | MW-4S | SM 2320B | 648601 | | |
| 50301756008 | MW-5S | SM 2320B | 648601 | | |
| 50301756009 | MW-6S | SM 2320B | 648601 | | |
| 50301756010 | MW-11D | SM 2320B | 648601 | | |
| 50301756011 | MW-12S | SM 2320B | 648601 | | |
| 50301756012 | MW-11S | SM 2320B | 648601 | | |
| 50301756013 | MW-12D | SM 2320B | 648601 | | |
| 50301756014 | MW-13D | SM 2320B | 648601 | | |
| 50301756015 | MW-14D | SM 2320B | 648601 | | |
| 50301756016 | DUP-1 | SM 2320B | 648601 | | |
| 50301756001 | MW-2S | SM 2540C | 648289 | | |
| 50301756002 | MW-2D | SM 2540C | 648290 | | |
| 50301756003 | MW-3S | SM 2540C | 648290 | | |
| 50301756004 | MW-3D | SM 2540C | 648290 | | |
| 50301756007 | MW-4S | SM 2540C | 648290 | | |
| 50301756008 | MW-5S | SM 2540C | 648290 | | |
| 50301756009 | MW-6S | SM 2540C | 648290 | | |
| 50301756010 | MW-11D | SM 2540C | 648290 | | |
| 50301756011 | MW-12S | SM 2540C | 648290 | | |
| 50301756012 | MW-11S | SM 2540C | 648290 | | |
| 50301756013 | MW-12D | SM 2540C | 648290 | | |
| 50301756014 | MW-13D | SM 2540C | 648290 | | |
| 50301756015 | MW-14D | SM 2540C | 648290 | | |
| 50301756016 | DUP-1 | SM 2540C | 648290 | | |
| 50301756001 | MW-2S | SM 4500-H+B | 649296 | | |
| 50301756002 | MW-2D | SM 4500-H+B | 649296 | | |
| 50301756003 | MW-3S | SM 4500-H+B | 649296 | | |
| 50301756004 | MW-3D | SM 4500-H+B | 649296 | | |
| 50301756007 | MW-4S | SM 4500-H+B | 649296 | | |
| 50301756008 | MW-5S | SM 4500-H+B | 649296 | | |
| 50301756009 | MW-6S | SM 4500-H+B | 649296 | | |
| 50301756010 | MW-11D | SM 4500-H+B | 649296 | | |
| 50301756011 | MW-12S | SM 4500-H+B | 649296 | | |
| 50301756012 | MW-11S | SM 4500-H+B | 649296 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50301756013 | MW-12D | SM 4500-H+B | 649296 | | |
| 50301756014 | MW-13D | SM 4500-H+B | 649296 | | |
| 50301756015 | MW-14D | SM 4500-H+B | 649296 | | |
| 50301756016 | DUP-1 | SM 4500-H+B | 649296 | | |
| 50301756001 | MW-2S | SM 4500-S2-D | 648329 | | |
| 50301756002 | MW-2D | SM 4500-S2-D | 648329 | | |
| 50301756003 | MW-3S | SM 4500-S2-D | 648329 | | |
| 50301756004 | MW-3D | SM 4500-S2-D | 648329 | | |
| 50301756007 | MW-4S | SM 4500-S2-D | 648329 | | |
| 50301756008 | MW-5S | SM 4500-S2-D | 648329 | | |
| 50301756009 | MW-6S | SM 4500-S2-D | 648329 | | |
| 50301756010 | MW-11D | SM 4500-S2-D | 648329 | | |
| 50301756011 | MW-12S | SM 4500-S2-D | 648329 | | |
| 50301756012 | MW-11S | SM 4500-S2-D | 648329 | | |
| 50301756013 | MW-12D | SM 4500-S2-D | 648329 | | |
| 50301756014 | MW-13D | SM 4500-S2-D | 648329 | | |
| 50301756015 | MW-14D | SM 4500-S2-D | 648329 | | |
| 50301756016 | DUP-1 | SM 4500-S2-D | 648329 | | |
| 50301756001 | MW-2S | EPA 353.2 | 648160 | | |
| 50301756002 | MW-2D | EPA 353.2 | 648160 | | |
| 50301756003 | MW-3S | EPA 353.2 | 648160 | | |
| 50301756004 | MW-3D | EPA 353.2 | 648160 | | |
| 50301756007 | MW-4S | EPA 353.2 | 648160 | | |
| 50301756008 | MW-5S | EPA 353.2 | 648160 | | |
| 50301756009 | MW-6S | EPA 353.2 | 648160 | | |
| 50301756010 | MW-11D | EPA 353.2 | 648160 | | |
| 50301756011 | MW-12S | EPA 353.2 | 648160 | | |
| 50301756012 | MW-11S | EPA 353.2 | 648160 | | |
| 50301756013 | MW-12D | EPA 353.2 | 648160 | | |
| 50301756014 | MW-13D | EPA 353.2 | 648160 | | |
| 50301756015 | MW-14D | EPA 353.2 | 648160 | | |
| 50301756016 | DUP-1 | EPA 353.2 | 648160 | | |
| 50301756001 | MW-2S | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756002 | MW-2D | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756003 | MW-3S | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756004 | MW-3D | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756007 | MW-4S | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756008 | MW-5S | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756009 | MW-6S | EPA 365.1 | 649655 | EPA 365.1 | 649958 |
| 50301756010 | MW-11D | EPA 365.1 | 649656 | EPA 365.1 | 650202 |
| 50301756011 | MW-12S | EPA 365.1 | 649656 | EPA 365.1 | 650202 |
| 50301756012 | MW-11S | EPA 365.1 | 649656 | EPA 365.1 | 650202 |
| 50301756013 | MW-12D | EPA 365.1 | 649656 | EPA 365.1 | 650202 |
| 50301756014 | MW-13D | EPA 365.1 | 649656 | EPA 365.1 | 650202 |
| 50301756015 | MW-14D | EPA 365.1 | 649656 | EPA 365.1 | 650202 |
| 50301756016 | DUP-1 | EPA 365.1 | 649656 | EPA 365.1 | 650202 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Hadring St Profile 1 Report 1
Pace Project No.: 50301756

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50301756001** | **MW-2S** | SM 5310C | 649369 | | |
| **50301756002** | **MW-2D** | SM 5310C | 649369 | | |
| **50301756003** | **MW-3S** | SM 5310C | 649369 | | |
| **50301756004** | **MW-3D** | SM 5310C | 649369 | | |
| **50301756007** | **MW-4S** | SM 5310C | 649369 | | |
| **50301756008** | **MW-5S** | SM 5310C | 649369 | | |
| **50301756009** | **MW-6S** | SM 5310C | 649371 | | |
| **50301756010** | **MW-11D** | SM 5310C | 649371 | | |
| **50301756011** | **MW-12S** | SM 5310C | 649371 | | |
| **50301756012** | **MW-11S** | SM 5310C | 649371 | | |
| **50301756013** | **MW-12D** | SM 5310C | 649371 | | |
| **50301756014** | **MW-13D** | SM 5310C | 649371 | | |
| **50301756015** | **MW-14D** | SM 5310C | 649371 | | |
| **50301756016** | **DUP-1** | SM 5310C | 649371 | | |
| **50301756001** | **MW-2S** | SM 5310C | 650220 | | |
| **50301756002** | **MW-2D** | SM 5310C | 650220 | | |
| **50301756003** | **MW-3S** | SM 5310C | 650220 | | |
| **50301756004** | **MW-3D** | SM 5310C | 650220 | | |
| **50301756007** | **MW-4S** | SM 5310C | 650220 | | |
| **50301756008** | **MW-5S** | SM 5310C | 650220 | | |
| **50301756009** | **MW-6S** | SM 5310C | 650220 | | |
| **50301756010** | **MW-11D** | SM 5310C | 650220 | | |
| **50301756011** | **MW-12S** | SM 5310C | 650220 | | |
| **50301756012** | **MW-11S** | SM 5310C | 650220 | | |
| **50301756013** | **MW-12D** | SM 5310C | 650220 | | |
| **50301756014** | **MW-13D** | SM 5310C | 650220 | | |
| **50301756015** | **MW-14D** | SM 5310C | 650220 | | |
| **50301756016** | **DUP-1** | SM 5310C | 650220 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50301756

50301756

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

master copy #1



Section C
Invoice Information:

| Required Project Information: | | | |
|---|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: | |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: | |
| Indianapolis, IN 46256 | | Address: | |
| Email: mark.breting@atcassociates.com | Purchase Order #: | Pace Quote: | |
| Phone: NONE Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt | |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 | |

Regulatory Agency

State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test: TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | Y/N | | | | | | | | | | | | | Y | | | | | | Y | | | |
| 1 | MW-1S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 2 | MW-1D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 3 | MW-2S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 4 | MW-2D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 5 | MW-3S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 6 | MW-3D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-4S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 8 | MW-5S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 9 | MW-6S | WT | | | | 11-1-21 | 14:25 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 10 | MW-7S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 11 | MW-7D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 12 | MW-8S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |

MATRIX CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jozkowiak | 11-2-21 | 7:40 | [illegible] | 11/2/21 | 1405 | | | | |
| 6020 (Co, As, Se, Sb) | [illegible] | 11/2/21 | 1430 | BC | 11/2/21 | 1430 | Sol SW | Y | N | Y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | |
|---|---|---|---|
| PRINT Name of SAMPLER: | Andy Jozkowiak | | |
| SIGNATURE of SAMPLER: | [signature] | DATE Signed: | 11-2-21 |

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

(2) #1

Page : 1 Of 1

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| Indianapolis, IN 46256 | | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

Regulatory Agency

State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | |
| 1 | ~~MW-1S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 2 | ~~MW-1D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 3 | MW-2S | WT | | 11-1 | 1035 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 4 | MW-2D | WT | | 11-1 | 1200 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 5 | MW-3S | WT | | 11-1 | 1510 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 6 | MW-3D MS/MSD -1 | WT | | 11-1 | 1522 | | | | 33 | 9 | 9 | 12 | | 3 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 7 | ~~MW-4S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 8 | ~~MW-5S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 9 | ~~MW-6S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 10 | ~~MW-7S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 11 | ~~MW-7D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 12 | ~~MW-8S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | P. Greg Hopper | | | | | | |
| 6020 (Co, As, Se, Sb) | | 11.2.21 | 0705 | | | | See #1 |
| ** Dissolved FF 6010 (Mo, Mn) | | 11/2/21 | 1430 | BC | 11/2/21 | 1430 | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: P. Greg Hopper

SIGNATURE of SAMPLER: [signature] DATE Signed: 11.1.21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

3 #1

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page : 1 Of 3

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

Regulatory Agency

State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | |
| 1 | MW-1S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 2 | MW-1D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 3 | MW-2S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 4 | MW-2D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 5 | MW-3S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 6 | MW-3D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 7 | MW-4S | WT | | | | 11/1/21 | 1416 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 8 | MW-5S | WT | | | | 11/1/21 | 1018 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 9 | MW-6S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 10 | MW-7S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 11 | MW-7D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 12 | MW-8S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | MARK BRETING / ATLAS | 11/2/21 | 0700 | Pace | 11/2/21 | 1405 | |
| 6020 (Co, As, Se, Sb) | Pace | 11/2/21 | 1430 | BL | 11/2/21 | 1430 | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: MARK BRETING

SIGNATURE of SAMPLER: Mark Breting DATE Signed: 11/1/21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

#2



| Section A Required Client Information: | | Section B Required Project Information: | Section C Invoice Information: | |
|---|---|---|---|---|
| Company: ATC Group Services | | Report To: Mark Breting | Attention: | |
| Address: 7988 Centerpoint Drive | | Copy To: | Company Name: | Regulatory Agency |
| Indianapolis, IN 46256 | | | Address: | |
| Email: mark.breting@atcassociates.com | | Purchase Order #: | Pace Quote: | |
| Phone: NONE | Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt | State / Location |
| Requested Due Date: | | Project #: | Pace Profile #: 6246 Line 30 | IN |

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | | | | |
| 13 | MW-9S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 14 | MW-9I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 15 | MW-9D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 16 | MW-10S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 17 | MW-10D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 18 | MW-11D | WT | | | | 11-1-21 | 10:15 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 19 | MW-12S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 20 | MW-11S | WT | | | | 11-1-21 | 11:20 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 21 | MW-12D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 22 | MW-13S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 23 | MW-13D | WT | | | | 11-1-21 | 16:10 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 24 | MW-14D | WT | | | | 11-1-21 | 12:55 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jastromski | 11-2-21 | 7:40 | Pace | 11/2/21 | 1405 | |
| 6020 (Co, As, Se, Sb) | Pace | 11/2/21 | 1430 | BC | 11/2/21 | 1430 | See mastercopy page 1 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | | | | |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: Andy Jastromski | | | | | | |
| SIGNATURE of SAMPLER: | DATE Signed: 11-2-21 | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

(3) #2



| Section A Required Client Information: | Section B Required Project Information: | Section C Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcassociates.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

| Regulatory Agency | State / Location |
|---|---|
| | IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | | |
| 13 | MW-9S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 14 | MW-9I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 15 | MW-9D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 16 | MW-10S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 17 | MW-10D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 18 | MW-11D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 19 | MW-12S | WT | | | | 11/1/21 | 1248 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 20 | MW-11S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 21 | MW-12D | WT | | | | 11/1/21 | 1140 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 22 | MW-13S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 23 | MW-13D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 24 | MW-14D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / ATC | 11/2/21 | 0700 | [signature] Pace | 11/2/21 | 1405 | |
| 6020 (Co, As, Se, Sb) | [signature] Pace | 11/2/21 | 1430 | BC | 11/2/21 | 1430 | #1 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|
| PRINT Name of SAMPLER: Mark Breting | | | | | |
| SIGNATURE of SAMPLER: Mark Breting | DATE Signed: 11/1/21 | | | | |

#3

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | | Section B Required Project Information: | Section C Invoice Information: | |
|---|---|---|---|---|
| Company: ATC Group Services | | Report To: Mark Breting | Attention: | |
| Address: 7988 Centerpoint Drive | | Copy To: | Company Name: | Regulatory Agency |
| Indianapolis, IN 46256 | | | Address: | |
| Email: mark.breting@atcassociates.com | | Purchase Order #: | Pace Quote: | |
| Phone: NONE | Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt | State / Location |
| Requested Due Date: | | Project #: | Pace Profile #: 6246 Line 30 | IN |

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Y/N | Analyses Test: TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | |
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 28 | DUP 1 | WT | | | | 11-1-21 | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 30 | Field Blank 1 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | X | |
| 31 | MS1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 32 | MSD1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 33 | MS2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 34 | MSD2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jaskowiak | 11-2-21 | 1740 | Zak Jaskowiak Pace | 11/2/21 | 1405 | |
| 6020 (Co, As, Se, Sb) | Zak Jaskowiak Pace | 11/2/21 | 1430 | BC | 11/2/21 | 1430 | Ice #1 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: Andy Jaskowiak

SIGNATURE of SAMPLER: [signature] DATE Signed: 11-2-21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** BC 1500 11/02/21

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☒ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☒ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 (A) B C D E F

4. **Cooler Temperature:** ①2.1/2.1 ②1.6/1.6 ③1.9/1.9 ④1.7/1.7 ⑤2.3/2.3 ⑥2.1/2.1 ⑦0.9/0.9 ⑧1.3/1.3

Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☒ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☒ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)? Analysis:** NO2, NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1520 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

**COC PAGE** 1 **of** 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 4 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 5 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | | | | |
| 6 | | | | | | | | | | | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | | | | |
| 7 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | | | |
| 8 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | | | | |
| 9 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE** 2 **of** 3

## Sample Container Count

SBS / DI / MeOH (only) / BK / Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 7 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | ( | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 12 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | ( | ) | | 1 | | | | | ↓ | ✓ | ✓ | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 3 of 3

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | SBS / DI / MeOH (only) / BK / Kit R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 15, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 03, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50301920001** | **PZ-100S** | Water | 11/02/21 10:42 | 11/03/21 15:20 |
| **50301920002** | **PZ-100D** | Water | 11/02/21 09:36 | 11/03/21 15:20 |
| **50301920003** | **PZ-101S** | Water | 11/02/21 12:33 | 11/03/21 15:20 |
| **50301920004** | **PZ-101D** | Water | 11/02/21 13:34 | 11/03/21 15:20 |
| **50301920005** | **MW-104D** | Water | 11/02/21 14:56 | 11/03/21 15:20 |
| **50301920006** | **MW-105S** | Water | 11/02/21 14:17 | 11/03/21 15:20 |
| **50301920007** | **MW-105I** | Water | 11/02/21 16:15 | 11/03/21 15:20 |
| **50301920008** | **MW-108S** | Water | 11/02/21 10:15 | 11/03/21 15:20 |
| **50301920009** | **MW-108D** | Water | 11/02/21 11:50 | 11/03/21 15:20 |
| **50301920010** | **DUP 3** | Water | 11/02/21 08:00 | 11/03/21 15:20 |
| **50301920011** | **DUP 4** | Water | 11/02/21 00:00 | 11/03/21 15:20 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50301920001** | **PZ-100S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920002** | **PZ-100D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920003** | **PZ-101S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920004** | **PZ-101D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920005** | **MW-104D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920006** | **MW-105S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920007** | **MW-105I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920008** | **MW-108S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920009** | **MW-108D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920010** | **DUP 3** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301920011** | **DUP 4** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920001** | **PZ-100S** | | | | | |
| EPA 9056 | Chloride | 314 | mg/L | 25.0 | 11/07/21 01:57 | |
| EPA 9056 | Fluoride | 1.6 | mg/L | 0.10 | 11/07/21 01:41 | |
| EPA 9056 | Sulfate | 397 | mg/L | 25.0 | 11/07/21 01:57 | |
| EPA 6010 | Barium | 32.6 | ug/L | 10.0 | 11/15/21 08:46 | |
| EPA 6010 | Boron | 2290 | ug/L | 100 | 11/15/21 08:46 | |
| EPA 6010 | Calcium | 161000 | ug/L | 1000 | 11/15/21 08:46 | |
| EPA 6010 | Iron | 1750 | ug/L | 100 | 11/15/21 08:46 | |
| EPA 6010 | Lithium | 63.2 | ug/L | 20.0 | 11/15/21 08:46 | |
| EPA 6010 | Magnesium | 56300 | ug/L | 1000 | 11/15/21 08:46 | |
| EPA 6010 | Manganese | 353 | ug/L | 10.0 | 11/15/21 08:46 | |
| EPA 6010 | Molybdenum | 133 | ug/L | 10.0 | 11/15/21 08:46 | |
| EPA 6010 | Potassium | 10700 | ug/L | 1000 | 11/15/21 08:46 | |
| EPA 6010 | Silica | 14600 | ug/L | 450 | 11/15/21 08:46 | N2 |
| EPA 6010 | Sodium | 240000 | ug/L | 2000 | 11/15/21 09:42 | |
| EPA 6010 | Manganese, Dissolved | 326 | ug/L | 10.0 | 11/13/21 01:10 | |
| EPA 6010 | Molybdenum, Dissolved | 132 | ug/L | 10.0 | 11/13/21 01:10 | |
| EPA 6020 | Arsenic | 2.3 | ug/L | 1.0 | 11/08/21 19:55 | |
| EPA 903.1 | Radium-226 | 0.124 ± 0.514 (0.980) C:NA T:93% | pCi/L | | 12/09/21 12:10 | |
| EPA 904.0 | Radium-228 | 2.29 ± 0.691 (0.863) C:68% T:83% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 2.41 ± 1.21 (1.84) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 312 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 312 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1300 | mg/L | 20.0 | 11/05/21 09:13 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.8 | Std. Units | 0.10 | 11/09/21 13:38 | H3 |
| SM 5310C | Total Organic Carbon | 2.5 | mg/L | 1.0 | 11/13/21 12:52 | |
| SM 5310C | Dissolved Organic Carbon | 2.9 | mg/L | 1.0 | 11/15/21 10:51 | |
| **50301920002** | **PZ-100D** | | | | | |
| EPA 9056 | Chloride | 204 | mg/L | 25.0 | 11/07/21 01:28 | |
| EPA 9056 | Fluoride | 0.37 | mg/L | 0.10 | 11/07/21 01:12 | |
| EPA 9056 | Sulfate | 547 | mg/L | 25.0 | 11/07/21 01:28 | |
| EPA 6010 | Barium | 54.5 | ug/L | 10.0 | 11/15/21 08:48 | |
| EPA 6010 | Boron | 7500 | ug/L | 100 | 11/15/21 08:48 | |
| EPA 6010 | Calcium | 211000 | ug/L | 2000 | 11/15/21 09:44 | |
| EPA 6010 | Iron | 3110 | ug/L | 100 | 11/15/21 08:48 | |
| EPA 6010 | Lithium | 76.9 | ug/L | 20.0 | 11/15/21 08:48 | |
| EPA 6010 | Magnesium | 52200 | ug/L | 1000 | 11/15/21 08:48 | |
| EPA 6010 | Manganese | 228 | ug/L | 10.0 | 11/15/21 08:48 | |
| EPA 6010 | Molybdenum | 164 | ug/L | 10.0 | 11/15/21 08:48 | |
| EPA 6010 | Potassium | 11100 | ug/L | 1000 | 11/15/21 08:48 | |
| EPA 6010 | Silica | 11700 | ug/L | 450 | 11/15/21 08:48 | N2 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920002** | **PZ-100D** | | | | | |
| EPA 6010 | Sodium | 152000 | ug/L | 1000 | 11/15/21 08:48 | |
| EPA 6010 | Manganese, Dissolved | 214 | ug/L | 10.0 | 11/13/21 01:12 | |
| EPA 6010 | Molybdenum, Dissolved | 161 | ug/L | 10.0 | 11/13/21 01:12 | |
| EPA 6020 | Arsenic | 59.7 | ug/L | 1.0 | 11/09/21 14:55 | |
| EPA 903.1 | Radium-226 | 0.711 ± 0.597 (0.854) C:NA T:86% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 0.919 ± 0.427 (0.724) C:75% T:92% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 1.63 ± 1.02 (1.58) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 222 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 222 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1370 | mg/L | 20.0 | 11/05/21 09:13 | |
| SM 4500-H+B | pH at 25 Degrees C | 8.0 | Std. Units | 0.10 | 11/09/21 13:36 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.42 | mg/L | 0.15 | 11/17/21 07:28 | |
| SM 5310C | Total Organic Carbon | 1.6 | mg/L | 1.0 | 11/13/21 13:03 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 11/15/21 11:11 | |
| **50301920003** | **PZ-101S** | | | | | |
| EPA 9056 | Chloride | 97.9 | mg/L | 25.0 | 11/07/21 02:00 | |
| EPA 9056 | Fluoride | 0.19 | mg/L | 0.10 | 11/07/21 01:44 | |
| EPA 9056 | Sulfate | 288 | mg/L | 25.0 | 11/07/21 02:00 | |
| EPA 6010 | Barium | 118 | ug/L | 10.0 | 11/15/21 08:50 | |
| EPA 6010 | Boron | 5350 | ug/L | 100 | 11/15/21 08:50 | |
| EPA 6010 | Calcium | 147000 | ug/L | 1000 | 11/15/21 08:50 | |
| EPA 6010 | Iron | 4890 | ug/L | 100 | 11/15/21 08:50 | |
| EPA 6010 | Lithium | 69.4 | ug/L | 20.0 | 11/15/21 08:50 | |
| EPA 6010 | Magnesium | 41000 | ug/L | 1000 | 11/15/21 08:50 | |
| EPA 6010 | Manganese | 698 | ug/L | 10.0 | 11/15/21 08:50 | |
| EPA 6010 | Molybdenum | 116 | ug/L | 10.0 | 11/15/21 08:50 | |
| EPA 6010 | Potassium | 5810 | ug/L | 1000 | 11/15/21 08:50 | |
| EPA 6010 | Silica | 12400 | ug/L | 450 | 11/15/21 08:50 | N2 |
| EPA 6010 | Sodium | 80600 | ug/L | 1000 | 11/15/21 08:50 | |
| EPA 6010 | Manganese, Dissolved | 665 | ug/L | 10.0 | 11/13/21 01:14 | |
| EPA 6010 | Molybdenum, Dissolved | 120 | ug/L | 10.0 | 11/13/21 01:14 | |
| EPA 6020 | Arsenic | 18.1 | ug/L | 1.0 | 11/09/21 15:00 | |
| EPA 903.1 | Radium-226 | 0.434 ± 0.532 (0.874) C:NA T:90% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 0.762 ± 0.520 (1.02) C:73% T:85% | pCi/L | | 12/09/21 14:51 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920003** | **PZ-101S** | | | | | |
| Total Radium Calculation | Total Radium | 1.20 ± 1.05 (1.89) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 289 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 289 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 836 | mg/L | 20.0 | 11/05/21 11:07 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.9 | Std. Units | 0.10 | 11/09/21 13:42 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.27 | mg/L | 0.15 | 11/17/21 07:29 | |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 11/13/21 13:14 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 1.0 | 11/15/21 11:31 | |
| **50301920004** | **PZ-101D** | | | | | |
| EPA 9056 | Chloride | 108 | mg/L | 25.0 | 11/07/21 02:31 | |
| EPA 9056 | Fluoride | 0.20 | mg/L | 0.10 | 11/07/21 02:15 | |
| EPA 9056 | Sulfate | 230 | mg/L | 25.0 | 11/07/21 02:31 | |
| EPA 6010 | Barium | 51.5 | ug/L | 10.0 | 11/15/21 09:04 | |
| EPA 6010 | Boron | 5240 | ug/L | 100 | 11/15/21 09:04 | |
| EPA 6010 | Calcium | 124000 | ug/L | 1000 | 11/15/21 09:04 | |
| EPA 6010 | Iron | 2070 | ug/L | 100 | 11/15/21 09:04 | |
| EPA 6010 | Lithium | 93.6 | ug/L | 20.0 | 11/15/21 09:04 | |
| EPA 6010 | Magnesium | 29800 | ug/L | 1000 | 11/15/21 09:04 | |
| EPA 6010 | Manganese | 268 | ug/L | 10.0 | 11/15/21 09:04 | |
| EPA 6010 | Molybdenum | 229 | ug/L | 10.0 | 11/15/21 09:04 | |
| EPA 6010 | Potassium | 10200 | ug/L | 1000 | 11/15/21 09:04 | |
| EPA 6010 | Silica | 9820 | ug/L | 450 | 11/15/21 09:04 | N2 |
| EPA 6010 | Sodium | 84300 | ug/L | 1000 | 11/15/21 09:04 | |
| EPA 6010 | Manganese, Dissolved | 253 | ug/L | 10.0 | 11/13/21 01:28 | |
| EPA 6010 | Molybdenum, Dissolved | 228 | ug/L | 10.0 | 11/13/21 01:28 | |
| EPA 6020 | Arsenic | 4.0 | ug/L | 1.0 | 11/09/21 15:04 | |
| EPA 903.1 | Radium-226 | 0.185 ± 0.364 (0.665) C:NA T:92% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 0.872 ± 0.439 (0.781) C:73% T:93% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 1.06 ± 0.803 (1.45) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 256 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 256 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 762 | mg/L | 20.0 | 11/05/21 11:08 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.9 | Std. Units | 0.10 | 11/09/21 13:44 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.12 | mg/L | 0.10 | 11/04/21 10:02 | |
| SM 5310C | Dissolved Organic Carbon | 1.5 | mg/L | 1.0 | 11/15/21 11:50 | |
| **50301920005** | **MW-104D** | | | | | |
| EPA 9056 | Chloride | 115 | mg/L | 25.0 | 11/07/21 03:34 | |
| EPA 9056 | Fluoride | 0.12 | mg/L | 0.10 | 11/07/21 03:18 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920005** | **MW-104D** | | | | | |
| EPA 9056 | Sulfate | 455 | mg/L | 25.0 | 11/07/21 03:34 | |
| EPA 6010 | Barium | 52.1 | ug/L | 10.0 | 11/15/21 09:06 | |
| EPA 6010 | Boron | 3460 | ug/L | 100 | 11/15/21 09:06 | |
| EPA 6010 | Calcium | 224000 | ug/L | 2000 | 11/15/21 09:50 | |
| EPA 6010 | Iron | 305 | ug/L | 100 | 11/15/21 09:06 | |
| EPA 6010 | Lithium | 24.2 | ug/L | 20.0 | 11/15/21 09:06 | |
| EPA 6010 | Magnesium | 60000 | ug/L | 1000 | 11/15/21 09:06 | |
| EPA 6010 | Manganese | 405 | ug/L | 10.0 | 11/15/21 09:06 | |
| EPA 6010 | Potassium | 7460 | ug/L | 1000 | 11/15/21 09:06 | |
| EPA 6010 | Silica | 9260 | ug/L | 450 | 11/15/21 09:06 | N2 |
| EPA 6010 | Sodium | 84200 | ug/L | 1000 | 11/15/21 09:06 | |
| EPA 6010 | Manganese, Dissolved | 336 | ug/L | 10.0 | 11/13/21 01:30 | |
| EPA 903.1 | Radium-226 | 0.213 ± 0.369 (0.660) C:NA T:89% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | -0.0312 ± 0.330 (0.775) C:75% T:85% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 0.213 ± 0.699 (1.44) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 348 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 348 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1160 | mg/L | 20.0 | 11/05/21 11:09 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 13:50 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.13 | mg/L | 0.10 | 11/04/21 10:07 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 11/15/21 12:10 | |
| **50301920006** | **MW-105S** | | | | | |
| EPA 9056 | Chloride | 113 | mg/L | 25.0 | 11/07/21 04:06 | |
| EPA 9056 | Fluoride | 0.30 | mg/L | 0.10 | 11/07/21 03:50 | |
| EPA 9056 | Sulfate | 1020 | mg/L | 25.0 | 11/07/21 04:06 | |
| EPA 6010 | Barium | 31.6 | ug/L | 10.0 | 11/15/21 09:08 | |
| EPA 6010 | Boron | 21000 | ug/L | 100 | 11/15/21 09:08 | |
| EPA 6010 | Calcium | 333000 | ug/L | 2000 | 11/15/21 09:52 | |
| EPA 6010 | Iron | 8330 | ug/L | 100 | 11/15/21 09:08 | |
| EPA 6010 | Lithium | 300 | ug/L | 20.0 | 11/15/21 09:08 | |
| EPA 6010 | Magnesium | 81300 | ug/L | 1000 | 11/15/21 09:08 | |
| EPA 6010 | Manganese | 192 | ug/L | 10.0 | 11/15/21 09:08 | |
| EPA 6010 | Molybdenum | 64.2 | ug/L | 10.0 | 11/15/21 09:08 | |
| EPA 6010 | Potassium | 17000 | ug/L | 1000 | 11/15/21 09:08 | |
| EPA 6010 | Silica | 16600 | ug/L | 450 | 11/15/21 09:08 | N2 |
| EPA 6010 | Sodium | 126000 | ug/L | 1000 | 11/15/21 09:08 | |
| EPA 6010 | Manganese, Dissolved | 176 | ug/L | 10.0 | 11/13/21 01:32 | |
| EPA 6010 | Molybdenum, Dissolved | 61.2 | ug/L | 10.0 | 11/13/21 01:32 | |
| EPA 6020 | Arsenic | 5.8 | ug/L | 1.0 | 11/09/21 15:24 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920006** | **MW-105S** | | | | | |
| EPA 903.1 | Radium-226 | 0.648 ± 0.544 (0.779) C:NA T:87% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 1.22 ± 0.486 (0.767) C:76% T:90% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 1.87 ± 1.03 (1.55) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 267 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 267 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1890 | mg/L | 20.0 | 11/05/21 11:10 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 13:47 | H3 |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 11/13/21 13:45 | |
| SM 5310C | Dissolved Organic Carbon | 2.1 | mg/L | 1.0 | 11/15/21 12:35 | |
| **50301920007** | **MW-105I** | | | | | |
| EPA 9056 | Chloride | 97.3 | mg/L | 2.5 | 11/07/21 04:37 | |
| EPA 9056 | Fluoride | 0.14 | mg/L | 0.10 | 11/07/21 04:22 | |
| EPA 9056 | Sulfate | 74.0 | mg/L | 2.5 | 11/07/21 04:37 | |
| EPA 6010 | Aluminum | 1500 | ug/L | 200 | 11/15/21 09:10 | |
| EPA 6010 | Barium | 336 | ug/L | 10.0 | 11/15/21 09:10 | |
| EPA 6010 | Boron | 587 | ug/L | 100 | 11/15/21 09:10 | |
| EPA 6010 | Calcium | 127000 | ug/L | 1000 | 11/15/21 09:10 | |
| EPA 6010 | Iron | 7490 | ug/L | 100 | 11/15/21 09:10 | |
| EPA 6010 | Magnesium | 29900 | ug/L | 1000 | 11/15/21 09:10 | |
| EPA 6010 | Manganese | 190 | ug/L | 10.0 | 11/15/21 09:10 | |
| EPA 6010 | Potassium | 6140 | ug/L | 1000 | 11/15/21 09:10 | |
| EPA 6010 | Silica | 17500 | ug/L | 450 | 11/15/21 09:10 | N2 |
| EPA 6010 | Sodium | 65200 | ug/L | 1000 | 11/15/21 09:10 | |
| EPA 6010 | Manganese, Dissolved | 117 | ug/L | 10.0 | 11/13/21 01:34 | |
| EPA 6020 | Arsenic | 2.4 | ug/L | 1.0 | 11/09/21 15:28 | |
| EPA 6020 | Cobalt | 1.2 | ug/L | 1.0 | 11/09/21 15:28 | |
| EPA 903.1 | Radium-226 | 1.02 ± 0.701 (0.957) C:NA T:84% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 1.18 ± 0.529 (0.903) C:75% T:85% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 2.20 ± 1.23 (1.86) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 319 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 319 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 594 | mg/L | 10.0 | 11/05/21 11:11 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 13:52 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.30 | mg/L | 0.15 | 11/17/21 09:45 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920007** | **MW-105I** | | | | | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/13/21 13:56 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 1.0 | 11/15/21 13:14 | |
| **50301920008** | **MW-108S** | | | | | |
| EPA 9056 | Chloride | 275 | mg/L | 25.0 | 11/07/21 05:09 | |
| EPA 9056 | Fluoride | 0.54 | mg/L | 0.10 | 11/07/21 04:53 | |
| EPA 9056 | Sulfate | 784 | mg/L | 25.0 | 11/07/21 05:09 | |
| EPA 6010 | Barium | 39.2 | ug/L | 10.0 | 11/15/21 09:13 | |
| EPA 6010 | Boron | 2450 | ug/L | 100 | 11/15/21 09:13 | |
| EPA 6010 | Calcium | 261000 | ug/L | 2000 | 11/15/21 09:54 | |
| EPA 6010 | Iron | 3940 | ug/L | 100 | 11/15/21 09:13 | |
| EPA 6010 | Lithium | 87.4 | ug/L | 20.0 | 11/15/21 09:13 | |
| EPA 6010 | Magnesium | 84200 | ug/L | 1000 | 11/15/21 09:13 | |
| EPA 6010 | Manganese | 480 | ug/L | 10.0 | 11/15/21 09:13 | |
| EPA 6010 | Molybdenum | 116 | ug/L | 10.0 | 11/15/21 09:13 | |
| EPA 6010 | Potassium | 14800 | ug/L | 1000 | 11/15/21 09:13 | |
| EPA 6010 | Silica | 13700 | ug/L | 450 | 11/15/21 09:13 | N2 |
| EPA 6010 | Sodium | 208000 | ug/L | 2000 | 11/15/21 09:54 | |
| EPA 6010 | Manganese, Dissolved | 462 | ug/L | 10.0 | 11/13/21 01:36 | |
| EPA 6010 | Molybdenum, Dissolved | 118 | ug/L | 10.0 | 11/13/21 01:36 | |
| EPA 903.1 | Radium-226 | 0.0646 ± 0.420 (0.847) C:NA T:92% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 0.636 ± 0.451 (0.880) C:69% T:86% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 0.701 ± 0.871 (1.73) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 304 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 304 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1880 | mg/L | 40.0 | 11/05/21 11:11 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 13:37 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.16 | mg/L | 0.15 | 11/17/21 09:46 | |
| SM 5310C | Total Organic Carbon | 1.7 | mg/L | 1.0 | 11/13/21 14:51 | |
| SM 5310C | Dissolved Organic Carbon | 1.8 | mg/L | 1.0 | 11/15/21 13:34 | |
| **50301920009** | **MW-108D** | | | | | |
| EPA 9056 | Chloride | 285 | mg/L | 25.0 | 11/10/21 10:29 | |
| EPA 9056 | Fluoride | 0.35 | mg/L | 0.10 | 11/07/21 05:25 | |
| EPA 9056 | Sulfate | 639 | mg/L | 25.0 | 11/10/21 10:29 | |
| EPA 6010 | Barium | 46.3 | ug/L | 10.0 | 11/15/21 09:15 | |
| EPA 6010 | Boron | 4440 | ug/L | 100 | 11/15/21 09:15 | |
| EPA 6010 | Calcium | 230000 | ug/L | 2000 | 11/15/21 09:57 | |
| EPA 6010 | Iron | 5530 | ug/L | 100 | 11/15/21 09:15 | |
| EPA 6010 | Lithium | 95.2 | ug/L | 20.0 | 11/15/21 09:15 | |
| EPA 6010 | Magnesium | 61200 | ug/L | 1000 | 11/15/21 09:15 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920009** | **MW-108D** | | | | | |
| EPA 6010 | Manganese | 384 | ug/L | 10.0 | 11/15/21 09:15 | |
| EPA 6010 | Molybdenum | 149 | ug/L | 10.0 | 11/15/21 09:15 | |
| EPA 6010 | Potassium | 14400 | ug/L | 1000 | 11/15/21 09:15 | |
| EPA 6010 | Silica | 13100 | ug/L | 450 | 11/15/21 09:15 | N2 |
| EPA 6010 | Sodium | 219000 | ug/L | 2000 | 11/15/21 09:57 | |
| EPA 6010 | Manganese, Dissolved | 366 | ug/L | 10.0 | 11/13/21 01:38 | |
| EPA 6010 | Molybdenum, Dissolved | 148 | ug/L | 10.0 | 11/13/21 01:38 | |
| EPA 903.1 | Radium-226 | 0.321 ± 0.520 (0.905) C:NA T:92% | pCi/L | | 12/09/21 12:24 | |
| EPA 904.0 | Radium-228 | 0.291 ± 0.412 (0.884) C:70% T:82% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 0.612 ± 0.932 (1.79) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 257 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 257 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1660 | mg/L | 40.0 | 11/05/21 11:12 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 13:40 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.29 | mg/L | 0.15 | 11/17/21 09:46 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/13/21 15:04 | |
| SM 5310C | Dissolved Organic Carbon | 1.8 | mg/L | 1.0 | 11/15/21 13:55 | |
| **50301920010** | **DUP 3** | | | | | |
| EPA 9056 | Chloride | 297 | mg/L | 25.0 | 11/10/21 11:01 | |
| EPA 9056 | Fluoride | 0.32 | mg/L | 0.10 | 11/10/21 10:45 | |
| EPA 9056 | Sulfate | 659 | mg/L | 25.0 | 11/10/21 11:01 | |
| EPA 6010 | Barium | 47.4 | ug/L | 10.0 | 11/15/21 09:17 | |
| EPA 6010 | Boron | 4540 | ug/L | 100 | 11/15/21 09:17 | |
| EPA 6010 | Calcium | 236000 | ug/L | 2000 | 11/15/21 09:59 | |
| EPA 6010 | Iron | 5630 | ug/L | 100 | 11/15/21 09:17 | |
| EPA 6010 | Lithium | 95.5 | ug/L | 20.0 | 11/15/21 09:17 | |
| EPA 6010 | Magnesium | 62300 | ug/L | 1000 | 11/15/21 09:17 | |
| EPA 6010 | Manganese | 390 | ug/L | 10.0 | 11/15/21 09:17 | |
| EPA 6010 | Molybdenum | 152 | ug/L | 10.0 | 11/15/21 09:17 | |
| EPA 6010 | Potassium | 14800 | ug/L | 1000 | 11/15/21 09:17 | |
| EPA 6010 | Silica | 13400 | ug/L | 450 | 11/15/21 09:17 | N2 |
| EPA 6010 | Sodium | 226000 | ug/L | 2000 | 11/15/21 09:59 | |
| EPA 6010 | Manganese, Dissolved | 362 | ug/L | 10.0 | 11/13/21 01:45 | |
| EPA 6010 | Molybdenum, Dissolved | 147 | ug/L | 10.0 | 11/13/21 01:45 | |
| EPA 903.1 | Radium-226 | 0.441 ± 0.413 (0.585) C:NA T:89% | pCi/L | | 12/09/21 12:40 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920010** | **DUP 3** | | | | | |
| EPA 904.0 | Radium-228 | 0.839 ± 0.400 (0.677) C:75% T:89% | pCi/L | | 12/09/21 14:52 | |
| Total Radium Calculation | Total Radium | 1.28 ± 0.813 (1.26) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 252 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 252 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1690 | mg/L | 20.0 | 11/05/21 11:12 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 13:34 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.31 | mg/L | 0.15 | 11/17/21 09:47 | |
| SM 5310C | Total Organic Carbon | 1.7 | mg/L | 1.0 | 11/13/21 15:16 | |
| SM 5310C | Dissolved Organic Carbon | 1.8 | mg/L | 1.0 | 11/16/21 13:23 | |
| **50301920011** | **DUP 4** | | | | | |
| EPA 9056 | Chloride | 295 | mg/L | 25.0 | 11/10/21 11:32 | |
| EPA 9056 | Fluoride | 1.6 | mg/L | 0.10 | 11/10/21 11:17 | |
| EPA 9056 | Sulfate | 373 | mg/L | 25.0 | 11/10/21 11:32 | |
| EPA 6010 | Barium | 31.7 | ug/L | 10.0 | 11/15/21 09:19 | |
| EPA 6010 | Boron | 2300 | ug/L | 100 | 11/15/21 09:19 | |
| EPA 6010 | Calcium | 159000 | ug/L | 1000 | 11/15/21 09:19 | |
| EPA 6010 | Iron | 1700 | ug/L | 100 | 11/15/21 09:19 | |
| EPA 6010 | Lithium | 63.1 | ug/L | 20.0 | 11/15/21 09:19 | |
| EPA 6010 | Magnesium | 55400 | ug/L | 1000 | 11/15/21 09:19 | |
| EPA 6010 | Manganese | 348 | ug/L | 10.0 | 11/15/21 09:19 | |
| EPA 6010 | Molybdenum | 130 | ug/L | 10.0 | 11/15/21 09:19 | |
| EPA 6010 | Potassium | 10600 | ug/L | 1000 | 11/15/21 09:19 | |
| EPA 6010 | Silica | 14300 | ug/L | 450 | 11/15/21 09:19 | N2 |
| EPA 6010 | Sodium | 232000 | ug/L | 2000 | 11/15/21 10:01 | |
| EPA 6010 | Manganese, Dissolved | 328 | ug/L | 10.0 | 11/13/21 01:47 | |
| EPA 6010 | Molybdenum, Dissolved | 132 | ug/L | 10.0 | 11/13/21 01:47 | |
| EPA 6020 | Arsenic | 2.2 | ug/L | 1.0 | 11/09/21 15:57 | |
| EPA 903.1 | Radium-226 | 0.195 ± 0.337 (0.603) C:NA T:94% | pCi/L | | 12/09/21 12:40 | |
| EPA 904.0 | Radium-228 | 0.906 ± 0.493 (0.919) C:77% T:88% | pCi/L | | 12/09/21 14:46 | |
| Total Radium Calculation | Total Radium | 1.10 ± 0.830 (1.52) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 323 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 323 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1410 | mg/L | 20.0 | 11/05/21 11:12 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/09/21 13:31 | H3 |
| SM 5310C | Total Organic Carbon | 2.4 | mg/L | 1.0 | 11/13/21 15:29 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301920011** | **DUP 4** | | | | | |
| SM 5310C | Dissolved Organic Carbon | 2.5 | mg/L | 1.0 | 11/16/21 13:43 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-100S** **Lab ID: 50301920001** Collected: 11/02/21 10:42 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **314** | mg/L | 25.0 | 100 | | 11/07/21 01:57 | 16887-00-6 | |
| Fluoride | **1.6** | mg/L | 0.10 | 1 | | 11/07/21 01:41 | 16984-48-8 | |
| Sulfate | **397** | mg/L | 25.0 | 100 | | 11/07/21 01:57 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7429-90-5 | |
| Barium | **32.6** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7440-39-3 | |
| Boron | **2290** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7440-43-9 | |
| Calcium | **161000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7440-47-3 | |
| Iron | **1750** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7439-92-1 | |
| Lithium | **63.2** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7439-93-2 | |
| Magnesium | **56300** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7439-95-4 | |
| Manganese | **353** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7439-96-5 | |
| Molybdenum | **133** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7439-98-7 | |
| Potassium | **10700** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7440-09-7 | |
| Silica | **14600** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 08:46 | 7631-86-9 | N2 |
| Sodium | **240000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:42 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **326** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:10 | 7439-96-5 | |
| Molybdenum, Dissolved | **132** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:10 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 19:55 | 7440-36-0 | |
| Arsenic | **2.3** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 19:55 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 19:55 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 19:55 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **312** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **312** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1300** | mg/L | 20.0 | 1 | | 11/05/21 09:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-100S** **Lab ID: 50301920001** Collected: 11/02/21 10:42 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.8** | Std. Units | 0.10 | 1 | | 11/09/21 13:38 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:49 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:49 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/12/21 09:00 | 11/17/21 07:26 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.5** | mg/L | 1.0 | 1 | | 11/13/21 12:52 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.9** | mg/L | 1.0 | 1 | | 11/15/21 10:51 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-100D** **Lab ID: 50301920002** Collected: 11/02/21 09:36 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **204** | mg/L | 25.0 | 100 | | 11/07/21 01:28 | 16887-00-6 | |
| Fluoride | **0.37** | mg/L | 0.10 | 1 | | 11/07/21 01:12 | 16984-48-8 | |
| Sulfate | **547** | mg/L | 25.0 | 100 | | 11/07/21 01:28 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7429-90-5 | |
| Barium | **54.5** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7440-39-3 | |
| Boron | **7500** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7440-43-9 | |
| Calcium | **211000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:44 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7440-47-3 | |
| Iron | **3110** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7439-92-1 | |
| Lithium | **76.9** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7439-93-2 | |
| Magnesium | **52200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7439-95-4 | |
| Manganese | **228** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7439-96-5 | |
| Molybdenum | **164** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7439-98-7 | |
| Potassium | **11100** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7440-09-7 | |
| Silica | **11700** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7631-86-9 | N2 |
| Sodium | **152000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:48 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **214** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:12 | 7439-96-5 | |
| Molybdenum, Dissolved | **161** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:12 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 14:55 | 7440-36-0 | |
| Arsenic | **59.7** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 14:55 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 14:55 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 14:55 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **222** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **222** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1370** | mg/L | 20.0 | 1 | | 11/05/21 09:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-100D** **Lab ID: 50301920002** Collected: 11/02/21 09:36 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **8.0** | Std. Units | 0.10 | 1 | | 11/09/21 13:36 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:34 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:34 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.42** | mg/L | 0.15 | 1 | 11/12/21 09:00 | 11/17/21 07:28 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 11/13/21 13:03 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 11/15/21 11:11 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-101S** **Lab ID: 50301920003** Collected: 11/02/21 12:33 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **97.9** | mg/L | 25.0 | 100 | | 11/07/21 02:00 | 16887-00-6 | |
| Fluoride | **0.19** | mg/L | 0.10 | 1 | | 11/07/21 01:44 | 16984-48-8 | |
| Sulfate | **288** | mg/L | 25.0 | 100 | | 11/07/21 02:00 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7429-90-5 | |
| Barium | **118** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-39-3 | |
| Boron | **5350** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-43-9 | |
| Calcium | **147000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-47-3 | |
| Iron | **4890** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7439-92-1 | |
| Lithium | **69.4** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7439-93-2 | |
| Magnesium | **41000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7439-95-4 | |
| Manganese | **698** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7439-96-5 | |
| Molybdenum | **116** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7439-98-7 | |
| Potassium | **5810** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-09-7 | |
| Silica | **12400** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7631-86-9 | N2 |
| Sodium | **80600** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 08:50 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **665** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:14 | 7439-96-5 | |
| Molybdenum, Dissolved | **120** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:14 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:00 | 7440-36-0 | |
| Arsenic | **18.1** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:00 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:00 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:00 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **289** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **289** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **836** | mg/L | 20.0 | 1 | | 11/05/21 11:07 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-101S** **Lab ID: 50301920003** Collected: 11/02/21 12:33 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.9** | Std. Units | 0.10 | 1 | | 11/09/21 13:42 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 10:00 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:00 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.27** | mg/L | 0.15 | 1 | 11/12/21 09:00 | 11/17/21 07:29 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 11/13/21 13:14 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 11/15/21 11:31 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-101D** **Lab ID: 50301920004** Collected: 11/02/21 13:34 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **108** | mg/L | 25.0 | 100 | | 11/07/21 02:31 | 16887-00-6 | |
| Fluoride | **0.20** | mg/L | 0.10 | 1 | | 11/07/21 02:15 | 16984-48-8 | |
| Sulfate | **230** | mg/L | 25.0 | 100 | | 11/07/21 02:31 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7429-90-5 | |
| Barium | **51.5** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-39-3 | |
| Boron | **5240** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-43-9 | |
| Calcium | **124000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-47-3 | |
| Iron | **2070** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7439-92-1 | |
| Lithium | **93.6** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7439-93-2 | |
| Magnesium | **29800** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7439-95-4 | |
| Manganese | **268** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7439-96-5 | |
| Molybdenum | **229** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7439-98-7 | |
| Potassium | **10200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-09-7 | |
| Silica | **9820** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7631-86-9 | N2 |
| Sodium | **84300** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:04 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **253** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:28 | 7439-96-5 | |
| Molybdenum, Dissolved | **228** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:28 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:04 | 7440-36-0 | |
| Arsenic | **4.0** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:04 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:04 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:04 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **256** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **256** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **762** | mg/L | 20.0 | 1 | | 11/05/21 11:08 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-101D** **Lab ID: 50301920004** Collected: 11/02/21 13:34 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.9** | Std. Units | 0.10 | 1 | | 11/09/21 13:44 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.12** | mg/L | 0.10 | 1 | | 11/04/21 10:02 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:02 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/12/21 09:00 | 11/17/21 07:29 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/13/21 13:24 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.5** | mg/L | 1.0 | 1 | | 11/15/21 11:50 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-104D** **Lab ID: 50301920005** Collected: 11/02/21 14:56 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **115** | mg/L | 25.0 | 100 | | 11/07/21 03:34 | 16887-00-6 | |
| Fluoride | **0.12** | mg/L | 0.10 | 1 | | 11/07/21 03:18 | 16984-48-8 | |
| Sulfate | **455** | mg/L | 25.0 | 100 | | 11/07/21 03:34 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7429-90-5 | |
| Barium | **52.1** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7440-39-3 | |
| Boron | **3460** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7440-43-9 | |
| Calcium | **224000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:50 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7440-47-3 | |
| Iron | **305** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7439-92-1 | |
| Lithium | **24.2** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7439-93-2 | |
| Magnesium | **60000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7439-95-4 | |
| Manganese | **405** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7439-98-7 | |
| Potassium | **7460** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7440-09-7 | |
| Silica | **9260** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7631-86-9 | N2 |
| Sodium | **84200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:06 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **336** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:30 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:30 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:09 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:09 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:09 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:09 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **348** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **348** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1160** | mg/L | 20.0 | 1 | | 11/05/21 11:09 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-104D** **Lab ID: 50301920005** Collected: 11/02/21 14:56 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 13:50 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.13** | mg/L | 0.10 | 1 | | 11/04/21 10:07 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:07 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:16 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/13/21 13:35 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 11/15/21 12:10 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-105S** **Lab ID: 50301920006** Collected: 11/02/21 14:17 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **113** | mg/L | 25.0 | 100 | | 11/07/21 04:06 | 16887-00-6 | |
| Fluoride | **0.30** | mg/L | 0.10 | 1 | | 11/07/21 03:50 | 16984-48-8 | |
| Sulfate | **1020** | mg/L | 25.0 | 100 | | 11/07/21 04:06 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7429-90-5 | |
| Barium | **31.6** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7440-39-3 | |
| Boron | **21000** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7440-43-9 | |
| Calcium | **333000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:52 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7440-47-3 | |
| Iron | **8330** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7439-92-1 | |
| Lithium | **300** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7439-93-2 | |
| Magnesium | **81300** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7439-95-4 | |
| Manganese | **192** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7439-96-5 | |
| Molybdenum | **64.2** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7439-98-7 | |
| Potassium | **17000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7440-09-7 | |
| Silica | **16600** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7631-86-9 | N2 |
| Sodium | **126000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:08 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **176** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:32 | 7439-96-5 | |
| Molybdenum, Dissolved | **61.2** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:32 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:24 | 7440-36-0 | |
| Arsenic | **5.8** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:24 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:24 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:24 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **267** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **267** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1890** | mg/L | 20.0 | 1 | | 11/05/21 11:10 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-105S** **Lab ID: 50301920006** Collected: 11/02/21 14:17 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 13:47 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 10:06 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:06 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:44 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 11/13/21 13:45 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 11/15/21 12:35 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-105I** **Lab ID: 50301920007** Collected: 11/02/21 16:15 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **97.3** | mg/L | 2.5 | 10 | | 11/07/21 04:37 | 16887-00-6 | |
| Fluoride | **0.14** | mg/L | 0.10 | 1 | | 11/07/21 04:22 | 16984-48-8 | |
| Sulfate | **74.0** | mg/L | 2.5 | 10 | | 11/07/21 04:37 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **1500** | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7429-90-5 | |
| Barium | **336** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-39-3 | |
| Boron | **587** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-43-9 | |
| Calcium | **127000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-47-3 | |
| Iron | **7490** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7439-93-2 | |
| Magnesium | **29900** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7439-95-4 | |
| Manganese | **190** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7439-98-7 | |
| Potassium | **6140** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-09-7 | |
| Silica | **17500** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7631-86-9 | N2 |
| Sodium | **65200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:10 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **117** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:34 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:34 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:28 | 7440-36-0 | |
| Arsenic | **2.4** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:28 | 7440-38-2 | |
| Cobalt | **1.2** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:28 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:28 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **319** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **319** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **594** | mg/L | 10.0 | 1 | | 11/05/21 11:11 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-105I** **Lab ID: 50301920007** Collected: 11/02/21 16:15 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 13:52 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 10:19 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:19 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.30** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:45 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/13/21 13:56 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 11/15/21 13:14 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-108S** **Lab ID: 50301920008** Collected: 11/02/21 10:15 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **275** | mg/L | 25.0 | 100 | | 11/07/21 05:09 | 16887-00-6 | |
| Fluoride | **0.54** | mg/L | 0.10 | 1 | | 11/07/21 04:53 | 16984-48-8 | |
| Sulfate | **784** | mg/L | 25.0 | 100 | | 11/07/21 05:09 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7429-90-5 | |
| Barium | **39.2** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7440-39-3 | |
| Boron | **2450** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7440-43-9 | |
| Calcium | **261000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:54 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7440-47-3 | |
| Iron | **3940** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7439-92-1 | |
| Lithium | **87.4** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7439-93-2 | |
| Magnesium | **84200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7439-95-4 | |
| Manganese | **480** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7439-96-5 | |
| Molybdenum | **116** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7439-98-7 | |
| Potassium | **14800** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7440-09-7 | |
| Silica | **13700** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:13 | 7631-86-9 | N2 |
| Sodium | **208000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:54 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **462** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:36 | 7439-96-5 | |
| Molybdenum, Dissolved | **118** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:36 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:33 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:33 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:33 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:33 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **304** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **304** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1880** | mg/L | 40.0 | 1 | | 11/05/21 11:11 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-108S** **Lab ID: 50301920008** Collected: 11/02/21 10:15 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 13:37 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:47 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:47 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.16** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:46 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 11/13/21 14:51 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/15/21 13:34 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-108D** **Lab ID: 50301920009** Collected: 11/02/21 11:50 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **285** | mg/L | 25.0 | 100 | | 11/10/21 10:29 | 16887-00-6 | |
| Fluoride | **0.35** | mg/L | 0.10 | 1 | | 11/07/21 05:25 | 16984-48-8 | |
| Sulfate | **639** | mg/L | 25.0 | 100 | | 11/10/21 10:29 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7429-90-5 | |
| Barium | **46.3** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7440-39-3 | |
| Boron | **4440** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7440-43-9 | |
| Calcium | **230000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:57 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7440-47-3 | |
| Iron | **5530** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7439-92-1 | |
| Lithium | **95.2** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7439-93-2 | |
| Magnesium | **61200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7439-95-4 | |
| Manganese | **384** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7439-96-5 | |
| Molybdenum | **149** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7439-98-7 | |
| Potassium | **14400** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7440-09-7 | |
| Silica | **13100** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:15 | 7631-86-9 | N2 |
| Sodium | **219000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:57 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **366** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:38 | 7439-96-5 | |
| Molybdenum, Dissolved | **148** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:38 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:48 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:48 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:48 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:48 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **257** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **257** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1660** | mg/L | 40.0 | 1 | | 11/05/21 11:12 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-108D** **Lab ID: 50301920009** Collected: 11/02/21 11:50 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 13:40 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:56 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:56 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.29** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:46 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/13/21 15:04 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/15/21 13:55 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: DUP 3** **Lab ID: 50301920010** Collected: 11/02/21 08:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **297** | mg/L | 25.0 | 100 | | 11/10/21 11:01 | 16887-00-6 | |
| Fluoride | **0.32** | mg/L | 0.10 | 1 | | 11/10/21 10:45 | 16984-48-8 | |
| Sulfate | **659** | mg/L | 25.0 | 100 | | 11/10/21 11:01 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7429-90-5 | |
| Barium | **47.4** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7440-39-3 | |
| Boron | **4540** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7440-43-9 | |
| Calcium | **236000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:59 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7440-47-3 | |
| Iron | **5630** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7439-92-1 | |
| Lithium | **95.5** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7439-93-2 | |
| Magnesium | **62300** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7439-95-4 | |
| Manganese | **390** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7439-96-5 | |
| Molybdenum | **152** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7439-98-7 | |
| Potassium | **14800** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7440-09-7 | |
| Silica | **13400** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:17 | 7631-86-9 | N2 |
| Sodium | **226000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 09:59 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **362** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:45 | 7439-96-5 | |
| Molybdenum, Dissolved | **147** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:45 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:52 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:52 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:52 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:52 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **252** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **252** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1690** | mg/L | 20.0 | 1 | | 11/05/21 11:12 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: DUP 3** **Lab ID: 50301920010** Collected: 11/02/21 08:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 13:34 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:41 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:41 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.31** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:47 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 11/13/21 15:16 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/16/21 13:23 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: DUP 4** **Lab ID: 50301920011** Collected: 11/02/21 00:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **295** | mg/L | 25.0 | 100 | | 11/10/21 11:32 | 16887-00-6 | |
| Fluoride | **1.6** | mg/L | 0.10 | 1 | | 11/10/21 11:17 | 16984-48-8 | |
| Sulfate | **373** | mg/L | 25.0 | 100 | | 11/10/21 11:32 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7429-90-5 | |
| Barium | **31.7** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7440-39-3 | |
| Boron | **2300** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7440-43-9 | |
| Calcium | **159000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7440-47-3 | |
| Iron | **1700** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7439-92-1 | |
| Lithium | **63.1** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7439-93-2 | |
| Magnesium | **55400** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7439-95-4 | |
| Manganese | **348** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7439-96-5 | |
| Molybdenum | **130** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7439-98-7 | |
| Potassium | **10600** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7440-09-7 | |
| Silica | **14300** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:19 | 7631-86-9 | N2 |
| Sodium | **232000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:01 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **328** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:47 | 7439-96-5 | |
| Molybdenum, Dissolved | **132** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:47 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:57 | 7440-36-0 | |
| Arsenic | **2.2** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:57 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:57 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/09/21 15:57 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **323** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **323** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1410** | mg/L | 20.0 | 1 | | 11/05/21 11:12 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: DUP 4** **Lab ID: 50301920011** Collected: 11/02/21 00:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/09/21 13:31 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:40 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:40 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:48 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.4** | mg/L | 1.0 | 1 | | 11/13/21 15:29 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.5** | mg/L | 1.0 | 1 | | 11/16/21 13:43 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648602
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2988463 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/06/21 19:04 | |
| Fluoride | mg/L | ND | 0.10 | 11/06/21 19:04 | |
| Sulfate | mg/L | ND | 0.25 | 11/06/21 19:04 | |

LABORATORY CONTROL SAMPLE: 2988464

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 93 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.44 | 88 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 94 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988465 2988466

| Parameter | Units | 50301888002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 59.1 | 12.5 | 12.5 | 70.2 | 70.2 | 89 | 88 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.40 | 0.5 | 0.5 | 0.83 | 0.82 | 85 | 84 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 1190 | 250 | 250 | 1410 | 1410 | 88 | 89 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648877
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2990119
Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/15/21 08:42 | |
| Barium | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Boron | ug/L | ND | 100 | 11/15/21 08:42 | |
| Cadmium | ug/L | ND | 2.0 | 11/15/21 08:42 | |
| Calcium | ug/L | ND | 1000 | 11/15/21 08:42 | |
| Chromium | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Iron | ug/L | ND | 100 | 11/15/21 08:42 | |
| Lead | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Lithium | ug/L | ND | 20.0 | 11/15/21 08:42 | |
| Magnesium | ug/L | ND | 1000 | 11/15/21 08:42 | |
| Manganese | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Molybdenum | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Potassium | ug/L | ND | 1000 | 11/15/21 08:42 | |
| Silica | ug/L | ND | 450 | 11/15/21 08:42 | N2 |
| Sodium | ug/L | ND | 1000 | 11/15/21 08:42 | |

LABORATORY CONTROL SAMPLE: 2990120

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4900 | 98 | 80-120 | |
| Barium | ug/L | 1000 | 963 | 96 | 80-120 | |
| Boron | ug/L | 1000 | 956 | 96 | 80-120 | |
| Cadmium | ug/L | 1000 | 934 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 4950 | 99 | 80-120 | |
| Chromium | ug/L | 1000 | 972 | 97 | 80-120 | |
| Iron | ug/L | 2500 | 2430 | 97 | 80-120 | |
| Lead | ug/L | 1000 | 923 | 92 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4710 | 94 | 80-120 | |
| Manganese | ug/L | 1000 | 952 | 95 | 80-120 | |
| Molybdenum | ug/L | 1000 | 950 | 95 | 80-120 | |
| Potassium | ug/L | 5000 | 4830 | 97 | 80-120 | |
| Silica | ug/L | 5350 | 5090 | 95 | | N2 |
| Sodium | ug/L | 5000 | 4720 | 94 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990121 2990122

| Parameter | Units | 50301920003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4980 | 4960 | 97 | 97 | 75-125 | 0 | 20 | |
| Barium | ug/L | 118 | 1000 | 1000 | 1090 | 1090 | 97 | 97 | 75-125 | 0 | 20 | |
| Boron | ug/L | 5350 | 1000 | 1000 | 6300 | 6300 | 96 | 96 | 75-125 | 0 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 951 | 950 | 95 | 95 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 147000 | 5000 | 5000 | 155000 | 153000 | 160 | 126 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 981 | 981 | 98 | 98 | 75-125 | 0 | 20 | |
| Iron | ug/L | 4890 | 2500 | 2500 | 7310 | 7260 | 97 | 95 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 891 | 887 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | 69.4 | 1000 | 1000 | 1140 | 1140 | 107 | 107 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 41000 | 5000 | 5000 | 45500 | 45300 | 89 | 86 | 75-125 | 0 | 20 | |
| Manganese | ug/L | 698 | 1000 | 1000 | 1650 | 1640 | 95 | 95 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 116 | 1000 | 1000 | 1090 | 1090 | 97 | 97 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 5810 | 5000 | 5000 | 11000 | 11100 | 105 | 106 | 75-125 | 0 | 20 | |
| Silica | ug/L | 12400 | 5350 | 5350 | 17400 | 17400 | 93 | 94 | | 0 | | N2 |
| Sodium | ug/L | 80600 | 5000 | 5000 | 86800 | 86800 | 124 | 123 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648526
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2988170 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/13/21 01:06 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/13/21 01:06 | |

LABORATORY CONTROL SAMPLE: 2988171

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 904 | 90 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 944 | 94 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988172 2988173

| Parameter | Units | 50301920003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 665 | 1000 | 1000 | 1520 | 1530 | 85 | 87 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | 120 | 1000 | 1000 | 1060 | 1080 | 94 | 96 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648844
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2989855 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/08/21 19:45 | |
| Arsenic | ug/L | ND | 1.0 | 11/08/21 19:45 | |
| Cobalt | ug/L | ND | 1.0 | 11/08/21 19:45 | |
| Selenium | ug/L | ND | 1.0 | 11/08/21 19:45 | |

LABORATORY CONTROL SAMPLE: 2989856

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 42.1 | 105 | 80-120 | |
| Arsenic | ug/L | 40 | 37.1 | 93 | 80-120 | |
| Cobalt | ug/L | 40 | 39.8 | 99 | 80-120 | |
| Selenium | ug/L | 40 | 38.5 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989857 2989858

| Parameter | Units | 50301920001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.5 | 41.8 | 108 | 104 | 75-125 | 4 | 20 | |
| Arsenic | ug/L | 2.3 | 40 | 40 | 38.9 | 38.3 | 91 | 90 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 37.6 | 36.1 | 93 | 89 | 75-125 | 4 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 37.9 | 37.1 | 94 | 92 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 649249
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2991616 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/09/21 11:15 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/09/21 11:15 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/09/21 11:15 | |

LABORATORY CONTROL SAMPLE: 2991617

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.1 | 98 | 90-110 | |

SAMPLE DUPLICATE: 2991618

| Parameter | Units | 50301920001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 312 | 312 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 312 | 312 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2991619

| Parameter | Units | 50301927001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 234 | 248 | 6 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 234 | 248 | 6 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648795
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002

METHOD BLANK: 2989631 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/05/21 09:09 | |

LABORATORY CONTROL SAMPLE: 2989632

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 296 | 99 | 80-120 | |

SAMPLE DUPLICATE: 2989633

| Parameter | Units | 50301885004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 420 | 427 | 2 | 10 | |

SAMPLE DUPLICATE: 2989634

| Parameter | Units | 50301885005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 377 | 365 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648797 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2989635 Matrix: Water
Associated Lab Samples: 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/05/21 11:06 | |

LABORATORY CONTROL SAMPLE: 2989636

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 302 | 101 | 80-120 | |

SAMPLE DUPLICATE: 2989637

| Parameter | Units | 50301920003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 836 | 832 | 0 | 10 | |

SAMPLE DUPLICATE: 2989638

| Parameter | Units | 50301920004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 762 | 762 | 0 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 649358
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

SAMPLE DUPLICATE: 2992126

| Parameter | Units | 50301920011 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.6 | 7.6 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 2992127

| Parameter | Units | 50301937002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.1 | 7.1 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648870 Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2990073 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 15:06 | |

LABORATORY CONTROL SAMPLE: 2990074

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990075 2990076

| Parameter | Units | 50301920001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.17 | 0.17 | 34 | 34 | 90-110 | 2 | 20 | M3 |

MATRIX SPIKE SAMPLE: 2990077

| Parameter | Units | 50301927001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.20 | 38 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 648555
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2988308 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/04/21 09:36 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/04/21 09:36 | |

LABORATORY CONTROL SAMPLE: 2988309

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 110 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988314 2988315

| Parameter | Units | 50301927003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 102 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 111 | 112 | 90-110 | 1 | 20 | M3 |

MATRIX SPIKE SAMPLE: 2988316

| Parameter | Units | 50301920007 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1.1 | 112 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 649944
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004

METHOD BLANK: 2995301 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 07:21 | |

LABORATORY CONTROL SAMPLE: 2995302

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2995303 2995304

| Parameter | Units | 50301897015 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.37 | | | 1.8 | 1.9 | | | | 5 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 649946
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2995306 Matrix: Water
Associated Lab Samples: 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 09:42 | |

LABORATORY CONTROL SAMPLE: 2995307

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2995308 2995309

| Parameter | Units | 50301920006 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.5 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 650186
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920005

METHOD BLANK: 2996933 Matrix: Water
Associated Lab Samples: 50301920005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 13:15 | |

LABORATORY CONTROL SAMPLE: 2996934

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996935 2996936

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.39 | | | 1.8 | 1.8 | | | | 3 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996937 2996938

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.6 | 1.5 | | | | 4 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 650224 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2997050 — Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/13/21 12:29 | |

LABORATORY CONTROL SAMPLE: 2997051

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997052 2997053

| Parameter | Units | 50301920007 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.8 | 10 | 10 | 11.9 | 12.2 | 101 | 103 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 2997054

| Parameter | Units | 50301927003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.3 | 10 | 12.8 | 105 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 650223
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009

METHOD BLANK: 2997044 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/16/21 01:24 | |

LABORATORY CONTROL SAMPLE: 2997045

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.7 | 97 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997046 2997047

| Parameter | Units | 50301767002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 0.46J | 10 | 10 | 10.3 | 10.5 | 99 | 100 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997048 2997049

| Parameter | Units | 50301769006 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 17.3 | 10 | 10 | 26.3 | 27.0 | 89 | 96 | 80-120 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 650521
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301920010, 50301920011

METHOD BLANK: 2998289 Matrix: Water
Associated Lab Samples: 50301920010, 50301920011

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/16/21 12:43 | |

LABORATORY CONTROL SAMPLE: 2998290

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.7 | 97 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998291 2998292

| Parameter | Units | 50301937002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.6 | 10 | 10 | 11.3 | 10.8 | 97 | 92 | 80-120 | 4 | 20 | |

MATRIX SPIKE SAMPLE: 2998293

| Parameter | Units | 50302003002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.3 | 10 | 11.1 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-100S** **Lab ID: 50301920001** Collected: 11/02/21 10:42 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.124 ± 0.514 (0.980) C:NA T:93%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **2.29 ± 0.691 (0.863) C:68% T:83%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.41 ± 1.21 (1.84)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-100D** **Lab ID: 50301920002** Collected: 11/02/21 09:36 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.711 ± 0.597 (0.854) C:NA T:86%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.919 ± 0.427 (0.724) C:75% T:92%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.63 ± 1.02 (1.58)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-101S** **Lab ID: 50301920003** Collected: 11/02/21 12:33 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.434 ± 0.532 (0.874) C:NA T:90%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.762 ± 0.520 (1.02) C:73% T:85%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.20 ± 1.05 (1.89)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: PZ-101D** **Lab ID: 50301920004** Collected: 11/02/21 13:34 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.185 ± 0.364 (0.665) C:NA T:92%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.872 ± 0.439 (0.781) C:73% T:93%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.06 ± 0.803 (1.45)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-104D** **Lab ID: 50301920005** Collected: 11/02/21 14:56 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.213 ± 0.369 (0.660) C:NA T:89%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **-0.0312 ± 0.330 (0.775) C:75% T:85%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.213 ± 0.699 (1.44)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-105S** **Lab ID: 50301920006** Collected: 11/02/21 14:17 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.648 ± 0.544 (0.779) C:NA T:87%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.22 ± 0.486 (0.767) C:76% T:90%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.87 ± 1.03 (1.55)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-105I** **Lab ID: 50301920007** Collected: 11/02/21 16:15 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.02 ± 0.701 (0.957) C:NA T:84%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.18 ± 0.529 (0.903) C:75% T:85%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.20 ± 1.23 (1.86)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-108S** **Lab ID: 50301920008** Collected: 11/02/21 10:15 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0646 ± 0.420 (0.847) C:NA T:92%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.636 ± 0.451 (0.880) C:69% T:86%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.701 ± 0.871 (1.73)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: MW-108D** **Lab ID: 50301920009** Collected: 11/02/21 11:50 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.321 ± 0.520 (0.905) C:NA T:92%** | pCi/L | 12/09/21 12:24 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.291 ± 0.412 (0.884) C:70% T:82%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.612 ± 0.932 (1.79)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: DUP 3** **Lab ID: 50301920010** Collected: 11/02/21 08:00 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.441 ± 0.413 (0.585) C:NA T:89%** | pCi/L | 12/09/21 12:40 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.839 ± 0.400 (0.677) C:75% T:89%** | pCi/L | 12/09/21 14:52 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.28 ± 0.813 (1.26)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

**Sample: DUP 4** **Lab ID: 50301920011** Collected: 11/02/21 00:00 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.195 ± 0.337 (0.603) C:NA T:94%** | pCi/L | 12/09/21 12:40 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.906 ± 0.493 (0.919) C:77% T:88%** | pCi/L | 12/09/21 14:46 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.10 ± 0.830 (1.52)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 473880 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2289233 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0520 ± 0.338 (0.682) C:NA T:89% | pCi/L | 12/09/21 12:10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

QC Batch: 473881
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

METHOD BLANK: 2289234 Matrix: Water
Associated Lab Samples: 50301920001, 50301920002, 50301920003, 50301920004, 50301920005, 50301920006, 50301920007, 50301920008, 50301920009, 50301920010, 50301920011

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.597 ± 0.344 (0.619) C:69% T:87% | pCi/L | 12/09/21 11:47 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50301920001 | PZ-100S | EPA 9056 | 648602 | | |
| 50301920002 | PZ-100D | EPA 9056 | 648602 | | |
| 50301920003 | PZ-101S | EPA 9056 | 648602 | | |
| 50301920004 | PZ-101D | EPA 9056 | 648602 | | |
| 50301920005 | MW-104D | EPA 9056 | 648602 | | |
| 50301920006 | MW-105S | EPA 9056 | 648602 | | |
| 50301920007 | MW-105I | EPA 9056 | 648602 | | |
| 50301920008 | MW-108S | EPA 9056 | 648602 | | |
| 50301920009 | MW-108D | EPA 9056 | 648602 | | |
| 50301920010 | DUP 3 | EPA 9056 | 648602 | | |
| 50301920011 | DUP 4 | EPA 9056 | 648602 | | |
| 50301920001 | PZ-100S | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920002 | PZ-100D | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920003 | PZ-101S | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920004 | PZ-101D | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920005 | MW-104D | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920006 | MW-105S | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920007 | MW-105I | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920008 | MW-108S | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920009 | MW-108D | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920010 | DUP 3 | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920011 | DUP 4 | EPA 3010 | 648877 | EPA 6010 | 650421 |
| 50301920001 | PZ-100S | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920002 | PZ-100D | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920003 | PZ-101S | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920004 | PZ-101D | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920005 | MW-104D | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920006 | MW-105S | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920007 | MW-105I | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920008 | MW-108S | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920009 | MW-108D | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920010 | DUP 3 | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920011 | DUP 4 | EPA 3010 | 648526 | EPA 6010 | 650253 |
| 50301920001 | PZ-100S | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920002 | PZ-100D | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920003 | PZ-101S | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920004 | PZ-101D | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920005 | MW-104D | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920006 | MW-105S | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920007 | MW-105I | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920008 | MW-108S | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920009 | MW-108D | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920010 | DUP 3 | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920011 | DUP 4 | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| 50301920001 | PZ-100S | EPA 903.1 | 473880 | | |
| 50301920002 | PZ-100D | EPA 903.1 | 473880 | | |
| 50301920003 | PZ-101S | EPA 903.1 | 473880 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50301920004 | PZ-101D | EPA 903.1 | 473880 | | |
| 50301920005 | MW-104D | EPA 903.1 | 473880 | | |
| 50301920006 | MW-105S | EPA 903.1 | 473880 | | |
| 50301920007 | MW-105I | EPA 903.1 | 473880 | | |
| 50301920008 | MW-108S | EPA 903.1 | 473880 | | |
| 50301920009 | MW-108D | EPA 903.1 | 473880 | | |
| 50301920010 | DUP 3 | EPA 903.1 | 473880 | | |
| 50301920011 | DUP 4 | EPA 903.1 | 473880 | | |
| 50301920001 | PZ-100S | EPA 904.0 | 473881 | | |
| 50301920002 | PZ-100D | EPA 904.0 | 473881 | | |
| 50301920003 | PZ-101S | EPA 904.0 | 473881 | | |
| 50301920004 | PZ-101D | EPA 904.0 | 473881 | | |
| 50301920005 | MW-104D | EPA 904.0 | 473881 | | |
| 50301920006 | MW-105S | EPA 904.0 | 473881 | | |
| 50301920007 | MW-105I | EPA 904.0 | 473881 | | |
| 50301920008 | MW-108S | EPA 904.0 | 473881 | | |
| 50301920009 | MW-108D | EPA 904.0 | 473881 | | |
| 50301920010 | DUP 3 | EPA 904.0 | 473881 | | |
| 50301920011 | DUP 4 | EPA 904.0 | 473881 | | |
| 50301920001 | PZ-100S | Total Radium Calculation | 476250 | | |
| 50301920002 | PZ-100D | Total Radium Calculation | 476250 | | |
| 50301920003 | PZ-101S | Total Radium Calculation | 476250 | | |
| 50301920004 | PZ-101D | Total Radium Calculation | 476250 | | |
| 50301920005 | MW-104D | Total Radium Calculation | 476250 | | |
| 50301920006 | MW-105S | Total Radium Calculation | 476250 | | |
| 50301920007 | MW-105I | Total Radium Calculation | 476250 | | |
| 50301920008 | MW-108S | Total Radium Calculation | 476250 | | |
| 50301920009 | MW-108D | Total Radium Calculation | 476250 | | |
| 50301920010 | DUP 3 | Total Radium Calculation | 476250 | | |
| 50301920011 | DUP 4 | Total Radium Calculation | 476250 | | |
| 50301920001 | PZ-100S | SM 2320B | 649249 | | |
| 50301920002 | PZ-100D | SM 2320B | 649249 | | |
| 50301920003 | PZ-101S | SM 2320B | 649249 | | |
| 50301920004 | PZ-101D | SM 2320B | 649249 | | |
| 50301920005 | MW-104D | SM 2320B | 649249 | | |
| 50301920006 | MW-105S | SM 2320B | 649249 | | |
| 50301920007 | MW-105I | SM 2320B | 649249 | | |
| 50301920008 | MW-108S | SM 2320B | 649249 | | |
| 50301920009 | MW-108D | SM 2320B | 649249 | | |
| 50301920010 | DUP 3 | SM 2320B | 649249 | | |
| 50301920011 | DUP 4 | SM 2320B | 649249 | | |
| 50301920001 | PZ-100S | SM 2540C | 648795 | | |
| 50301920002 | PZ-100D | SM 2540C | 648795 | | |
| 50301920003 | PZ-101S | SM 2540C | 648797 | | |
| 50301920004 | PZ-101D | SM 2540C | 648797 | | |
| 50301920005 | MW-104D | SM 2540C | 648797 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50301920006 | MW-105S | SM 2540C | 648797 | | |
| 50301920007 | MW-105I | SM 2540C | 648797 | | |
| 50301920008 | MW-108S | SM 2540C | 648797 | | |
| 50301920009 | MW-108D | SM 2540C | 648797 | | |
| 50301920010 | DUP 3 | SM 2540C | 648797 | | |
| 50301920011 | DUP 4 | SM 2540C | 648797 | | |
| 50301920001 | PZ-100S | SM 4500-H+B | 649358 | | |
| 50301920002 | PZ-100D | SM 4500-H+B | 649358 | | |
| 50301920003 | PZ-101S | SM 4500-H+B | 649358 | | |
| 50301920004 | PZ-101D | SM 4500-H+B | 649358 | | |
| 50301920005 | MW-104D | SM 4500-H+B | 649358 | | |
| 50301920006 | MW-105S | SM 4500-H+B | 649358 | | |
| 50301920007 | MW-105I | SM 4500-H+B | 649358 | | |
| 50301920008 | MW-108S | SM 4500-H+B | 649358 | | |
| 50301920009 | MW-108D | SM 4500-H+B | 649358 | | |
| 50301920010 | DUP 3 | SM 4500-H+B | 649358 | | |
| 50301920011 | DUP 4 | SM 4500-H+B | 649358 | | |
| 50301920001 | PZ-100S | SM 4500-S2-D | 648870 | | |
| 50301920002 | PZ-100D | SM 4500-S2-D | 648870 | | |
| 50301920003 | PZ-101S | SM 4500-S2-D | 648870 | | |
| 50301920004 | PZ-101D | SM 4500-S2-D | 648870 | | |
| 50301920005 | MW-104D | SM 4500-S2-D | 648870 | | |
| 50301920006 | MW-105S | SM 4500-S2-D | 648870 | | |
| 50301920007 | MW-105I | SM 4500-S2-D | 648870 | | |
| 50301920008 | MW-108S | SM 4500-S2-D | 648870 | | |
| 50301920009 | MW-108D | SM 4500-S2-D | 648870 | | |
| 50301920010 | DUP 3 | SM 4500-S2-D | 648870 | | |
| 50301920011 | DUP 4 | SM 4500-S2-D | 648870 | | |
| 50301920001 | PZ-100S | EPA 353.2 | 648555 | | |
| 50301920002 | PZ-100D | EPA 353.2 | 648555 | | |
| 50301920003 | PZ-101S | EPA 353.2 | 648555 | | |
| 50301920004 | PZ-101D | EPA 353.2 | 648555 | | |
| 50301920005 | MW-104D | EPA 353.2 | 648555 | | |
| 50301920006 | MW-105S | EPA 353.2 | 648555 | | |
| 50301920007 | MW-105I | EPA 353.2 | 648555 | | |
| 50301920008 | MW-108S | EPA 353.2 | 648555 | | |
| 50301920009 | MW-108D | EPA 353.2 | 648555 | | |
| 50301920010 | DUP 3 | EPA 353.2 | 648555 | | |
| 50301920011 | DUP 4 | EPA 353.2 | 648555 | | |
| 50301920001 | PZ-100S | EPA 365.1 | 649944 | EPA 365.1 | 650200 |
| 50301920002 | PZ-100D | EPA 365.1 | 649944 | EPA 365.1 | 650200 |
| 50301920003 | PZ-101S | EPA 365.1 | 649944 | EPA 365.1 | 650200 |
| 50301920004 | PZ-101D | EPA 365.1 | 649944 | EPA 365.1 | 650200 |
| 50301920005 | MW-104D | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| 50301920006 | MW-105S | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| 50301920007 | MW-105I | EPA 365.1 | 649946 | EPA 365.1 | 650211 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50301920

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50301920008** | **MW-108S** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301920009** | **MW-108D** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301920010** | **DUP 3** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301920011** | **DUP 4** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301920001** | **PZ-100S** | SM 5310C | 650224 | | |
| **50301920002** | **PZ-100D** | SM 5310C | 650224 | | |
| **50301920003** | **PZ-101S** | SM 5310C | 650224 | | |
| **50301920004** | **PZ-101D** | SM 5310C | 650224 | | |
| **50301920005** | **MW-104D** | SM 5310C | 650224 | | |
| **50301920006** | **MW-105S** | SM 5310C | 650224 | | |
| **50301920007** | **MW-105I** | SM 5310C | 650224 | | |
| **50301920008** | **MW-108S** | SM 5310C | 650224 | | |
| **50301920009** | **MW-108D** | SM 5310C | 650224 | | |
| **50301920010** | **DUP 3** | SM 5310C | 650224 | | |
| **50301920011** | **DUP 4** | SM 5310C | 650224 | | |
| **50301920001** | **PZ-100S** | SM 5310C | 650223 | | |
| **50301920002** | **PZ-100D** | SM 5310C | 650223 | | |
| **50301920003** | **PZ-101S** | SM 5310C | 650223 | | |
| **50301920004** | **PZ-101D** | SM 5310C | 650223 | | |
| **50301920005** | **MW-104D** | SM 5310C | 650223 | | |
| **50301920006** | **MW-105S** | SM 5310C | 650223 | | |
| **50301920007** | **MW-105I** | SM 5310C | 650223 | | |
| **50301920008** | **MW-108S** | SM 5310C | 650223 | | |
| **50301920009** | **MW-108D** | SM 5310C | 650223 | | |
| **50301920010** | **DUP 3** | SM 5310C | 650521 | | |
| **50301920011** | **DUP 4** | SM 5310C | 650521 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

(2)

WO# : 50301920

50301920

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request D

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields m

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pac

| Section A<br>Required Client Information: | Section B<br>Required Project Information: | Section C<br>Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcgs.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding Street Profile 1 Report 2 | Pace Project Manager: hayden.putt@pacelabs.com, |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

Regulatory Agency: State / Location: IN

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID<br>One Character per box. (A-Z, 0-9 / , -)<br>Sample Ids must be unique<br>MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** Y | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C Y | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | M-4 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 2 | PZ-100S | WT | | | | 11/2/21 | 1042 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | 001 |
| 3 | PZ-100D | WT | | | | 11/2/21 | 0936 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | 002 |
| 4 | PZ-101S | WT | | | | 11/2/21 | 1233 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | 003 |
| 5 | PZ-101D | WT | | | | 11/2/21 | 1334 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | 004 |
| 6 | MW-102S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-102D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 8 | MW-103S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 9 | MW-103I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 10 | MW-103D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 11 | MW-104S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 12 | MW-104D | WT | | | | 11/2/21 | 1456 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | 005 |

| | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting/ATCGS | 11/3/21 | 0650 | | 11/3 | 1420 | | | | |
| 6020 (Co, As, Se, Sb) | | 11/3/21 | 1520 | JC | 11/3/21 | 1520 | | see | scur | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: MARK BRETING

SIGNATURE of SAMPLER: Mark Breting DATE Signed: 11/2/21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

(3)

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@atcgs.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding Street Profile 1 Report 2 | Pace Project Manager: | hayden.putt@pacelabs.com, |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

Regulatory Agency: | State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analysis Test Y/N | Requested Analysis Filtered (Y/N): TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | | | | |
| 13 | MW-105S | WT | | 11-2 | 1417 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 006 |
| 14 | MW-105I | WT | | 11-2 | 1615 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 007 |
| 15 | ~~MW-105D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 16 | ~~MW-106S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 17 | ~~MW-106I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 18 | ~~MW-106D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 19 | ~~MW-107S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 20 | ~~MW-107I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 21 | ~~MW-107D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 22 | MW-108S | WT | | 11-2 | 1015 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 008 |
| 23 | MW-108D | WT | | 11-2 | 1150 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 009 |
| 24 | DUP 3 | WT | | 11-2 | ~ | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 010 |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 11-3-21 | 0700 | pac | 11/3/21 | 1420 | |
| 6020 (Co, As, Se, Sb) | | 11/3/21 | 1520 | JC | 11/3/21 | 1520 | See scan |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: P. Greg Hopper

SIGNATURE of SAMPLER: [signature] DATE Signed: 11-3-21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

(2)

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A Required Client Information: | Section B Required Project Information: | Section C Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcgs.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding Street Profile 1 Report 2 | Pace Project Manager: hayden.putt@pacelabs.com, |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipes | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analysis Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | Y | | | | | | | | Y | | | | |
| 25 | DUP 4 | WT | | | | 11/2/21 | 0000 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 011 |
| 26 | Field Blank 2 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | X | | |
| 27 | MS3 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 28 | MSD3 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 29 | MS4 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 30 | MSD4 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | MARK BRETING/ATLAS | 11/3/21 | 0650 | | 11/3 | 1420 | |
| 6020 (Co, As, Se, Sb) | | 11/3/21 | 1520 | | 11/3/21 | 1520 | See SCUR |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: MARK BRETING

SIGNATURE of SAMPLER: Mark Breting DATE Signed: 11/2/21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** JC 11/3/21 1810

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature:** #1(2.8/2.9), #2(2.2/1.4), #3(1.9/1.1), #4(3.5/2.7), #5(2.7/1.9), #6(3.6/2.8), #7(2.0/1.2), #8(4.8/4.0), #9(1.7/0.9)
Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3, NO2 | ✓ | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** 11/4/21 | Time: 11/3/21 DMP 1900 | |
| **Rush TAT Requested (4 days or less):** | | ✓ |
| Custody Signatures Present? | ✓ | |
| Containers Intact?: | ✓ | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | DMP | ✓ |
| Extra labels on Terracore Vials? (soils only) | 11/3/21 | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any ~~non-conformance~~ to pH recommendations ~~will be noted~~ on the container count form | ✓ | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Headspace Wisconsin Sulfide? | | | ✓ |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | ✓ |
| Trip Blank Present? | | ✓ | |
| Trip Blank Custody Seals?: | | | ✓ |

COMMENTS: All containers except the BP3F, and AG3SF received for "MW-105I" labeled as "MW-105D" with dates/times matching MW-105I, BP3F and AG3SF received unmarked, assumed to be with MW-105I.

**COC PAGE** 1 of 3

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | SBS / DI / MeOH (only) / BK / Kit: R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | 2 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | 2 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |

1 DUP 11/3/21

DUP 11/3/21

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE** 2 **of** 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 2 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | 2 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | 2 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 11 | | | | | | | | | | | | 1 | 1 | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 12 | | | | | | | | | | | | 1 | ✓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |

BMP 10/3/21

Container Codes

## Glass

| | | | |
|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass |
| GN | General | AG3C | 250mL NaOH amber glass |

## Plastic / Misc.

| | |
|---|---|
| BP1B | 1L NaOH plastic |
| BP1N | 1L HNO3 plastic |
| BP1S | 1L H2SO4 plastic |
| BP1U | 1L unpreserved plastic |
| BP1Z | 1L NaOH, Zn, Ac |
| BP2N | 500mL HNO3 plastic |
| BP2C | 500mL NaOH plastic |
| BP2S | 500mL H2SO4 plastic |
| BP2U | 500mL unpreserved plastic |
| BP2Z | 500mL NaOH, Zn Ac |
| BP3B | 250mL NaOH plastic |
| BP3N | 250mL HNO3 plastic |
| BP3F | 250mL HNO3 plastic-field filtered |
| BP3U | 250mL unpreserved plastic |
| BP3S | 250mL H2SO4 plastic |
| BP3Z | 250mL NaOH, ZnAc plastic |
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 3 of 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 2 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | SL | ✓ | ✓ | |
| 2 | | | | | | | | | | | | DMP 11/3/21 | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 14, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 03, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Guam Certification
Florida: Cert E871149 SEKS WET
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50301927001** | **MW-7S** | Water | 11/02/21 10:00 | 11/03/21 15:20 |
| **50301927002** | **MW-7D** | Water | 11/02/21 10:55 | 11/03/21 15:20 |
| **50301927003** | **MW-10S** | Water | 11/02/21 15:20 | 11/03/21 15:20 |
| **50301927004** | **MW-10D** | Water | 11/02/21 13:40 | 11/03/21 15:20 |
| **50301927005** | **MW-13S** | Water | 11/02/21 12:30 | 11/03/21 15:20 |
| **50301927006** | **DUP 2** | Water | 11/02/21 08:00 | 11/03/21 15:20 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50301927001** | **MW-7S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301927002** | **MW-7D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301927003** | **MW-10S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301927004** | **MW-10D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301927005** | **MW-13S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 5310C | GWA | 1 | PASI-I |
| **50301927006** | **DUP 2** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | JDG | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301927001** | **MW-7S** | | | | | |
| EPA 9056 | Chloride | 220 | mg/L | 25.0 | 11/08/21 07:22 | |
| EPA 9056 | Fluoride | 0.50 | mg/L | 0.10 | 11/08/21 05:47 | |
| EPA 9056 | Sulfate | 500 | mg/L | 25.0 | 11/08/21 07:22 | |
| EPA 6010 | Aluminum | 209 | ug/L | 200 | 11/15/21 09:25 | |
| EPA 6010 | Barium | 41.8 | ug/L | 10.0 | 11/15/21 09:25 | |
| EPA 6010 | Boron | 12200 | ug/L | 100 | 11/15/21 09:25 | |
| EPA 6010 | Calcium | 195000 | ug/L | 1000 | 11/15/21 09:25 | |
| EPA 6010 | Iron | 3640 | ug/L | 100 | 11/15/21 09:25 | |
| EPA 6010 | Lithium | 85.8 | ug/L | 20.0 | 11/15/21 09:25 | |
| EPA 6010 | Magnesium | 45800 | ug/L | 1000 | 11/15/21 09:25 | |
| EPA 6010 | Manganese | 426 | ug/L | 10.0 | 11/15/21 09:25 | |
| EPA 6010 | Molybdenum | 625 | ug/L | 10.0 | 11/15/21 09:25 | |
| EPA 6010 | Potassium | 15100 | ug/L | 1000 | 11/15/21 09:25 | |
| EPA 6010 | Silica | 14000 | ug/L | 450 | 11/15/21 09:25 | N2 |
| EPA 6010 | Sodium | 178000 | ug/L | 1000 | 11/15/21 09:25 | |
| EPA 6010 | Manganese, Dissolved | 393 | ug/L | 10.0 | 11/13/21 01:49 | |
| EPA 6010 | Molybdenum, Dissolved | 623 | ug/L | 10.0 | 11/13/21 01:49 | |
| EPA 6020 | Arsenic | 376 | ug/L | 5.0 | 11/08/21 21:40 | |
| EPA 903.1 | Radium-226 | 0.209 ± 0.530 (0.983) C:NA T:88% | pCi/L | | 12/09/21 12:10 | |
| EPA 904.0 | Radium-228 | 0.467 ± 0.533 (1.13) C:68% T:87% | pCi/L | | 12/09/21 11:35 | |
| Total Radium Calculation | Total Radium | 0.676 ± 1.06 (2.11) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 234 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 234 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1360 | mg/L | 20.0 | 11/05/21 11:13 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 11/09/21 12:38 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.82 | mg/L | 0.15 | 11/17/21 09:50 | |
| SM 5310C | Total Organic Carbon | 2.2 | mg/L | 1.0 | 11/13/21 15:41 | |
| SM 5310C | Dissolved Organic Carbon | 2.3 | mg/L | 1.0 | 11/16/21 14:04 | |
| **50301927002** | **MW-7D** | | | | | |
| EPA 9056 | Chloride | 187 | mg/L | 25.0 | 11/08/21 08:57 | |
| EPA 9056 | Fluoride | 0.38 | mg/L | 0.10 | 11/08/21 08:41 | |
| EPA 9056 | Sulfate | 528 | mg/L | 25.0 | 11/08/21 08:57 | |
| EPA 6010 | Aluminum | 3380 | ug/L | 200 | 11/15/21 09:27 | |
| EPA 6010 | Barium | 53.9 | ug/L | 10.0 | 11/15/21 09:27 | |
| EPA 6010 | Boron | 13900 | ug/L | 100 | 11/15/21 09:27 | |
| EPA 6010 | Calcium | 190000 | ug/L | 1000 | 11/15/21 09:27 | |
| EPA 6010 | Iron | 7440 | ug/L | 100 | 11/15/21 09:27 | |
| EPA 6010 | Lithium | 103 | ug/L | 20.0 | 11/15/21 09:27 | |
| EPA 6010 | Magnesium | 41200 | ug/L | 1000 | 11/15/21 09:27 | |
| EPA 6010 | Manganese | 486 | ug/L | 10.0 | 11/15/21 09:27 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301927002** | **MW-7D** | | | | | |
| EPA 6010 | Molybdenum | 688 | ug/L | 10.0 | 11/15/21 09:27 | |
| EPA 6010 | Potassium | 16000 | ug/L | 1000 | 11/15/21 09:27 | |
| EPA 6010 | Silica | 24300 | ug/L | 450 | 11/15/21 09:27 | N2 |
| EPA 6010 | Sodium | 171000 | ug/L | 1000 | 11/15/21 09:27 | |
| EPA 6010 | Manganese, Dissolved | 393 | ug/L | 10.0 | 11/13/21 01:51 | |
| EPA 6010 | Molybdenum, Dissolved | 684 | ug/L | 10.0 | 11/13/21 01:51 | |
| EPA 6020 | Arsenic | 457 | ug/L | 5.0 | 11/08/21 21:44 | |
| EPA 6020 | Cobalt | 1.8 | ug/L | 1.0 | 11/08/21 23:16 | |
| EPA 903.1 | Radium-226 | 0.417 ± 0.390 (0.553) C:NA T:97% | pCi/L | | 12/09/21 12:10 | |
| EPA 904.0 | Radium-228 | 0.675 ± 0.616 (1.26) C:66% T:88% | pCi/L | | 12/09/21 14:50 | |
| Total Radium Calculation | Total Radium | 1.09 ± 1.01 (1.81) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 221 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 221 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1300 | mg/L | 20.0 | 11/05/21 11:13 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 12:40 | H3 |
| EPA 365.1 | Phosphate as P04 | 1.0 | mg/L | 0.15 | 11/17/21 09:50 | |
| SM 5310C | Total Organic Carbon | 1.9 | mg/L | 1.0 | 11/13/21 15:53 | |
| SM 5310C | Dissolved Organic Carbon | 2.2 | mg/L | 1.0 | 11/16/21 14:24 | |
| **50301927003** | **MW-10S** | | | | | |
| EPA 9056 | Chloride | 348 | mg/L | 25.0 | 11/08/21 09:28 | |
| EPA 9056 | Fluoride | 2.5 | mg/L | 0.10 | 11/08/21 09:12 | |
| EPA 9056 | Sulfate | 483 | mg/L | 25.0 | 11/08/21 09:28 | |
| EPA 6010 | Barium | 73.3 | ug/L | 10.0 | 11/15/21 09:29 | |
| EPA 6010 | Boron | 1540 | ug/L | 100 | 11/15/21 09:29 | |
| EPA 6010 | Calcium | 201000 | ug/L | 2000 | 11/15/21 10:07 | |
| EPA 6010 | Iron | 1190 | ug/L | 100 | 11/15/21 09:29 | |
| EPA 6010 | Lithium | 53.3 | ug/L | 20.0 | 11/15/21 09:29 | |
| EPA 6010 | Magnesium | 44600 | ug/L | 1000 | 11/15/21 09:29 | |
| EPA 6010 | Manganese | 385 | ug/L | 10.0 | 11/15/21 09:29 | |
| EPA 6010 | Molybdenum | 71.2 | ug/L | 10.0 | 11/15/21 09:29 | |
| EPA 6010 | Potassium | 9900 | ug/L | 1000 | 11/15/21 09:29 | |
| EPA 6010 | Silica | 13200 | ug/L | 450 | 11/15/21 09:29 | N2 |
| EPA 6010 | Sodium | 257000 | ug/L | 2000 | 11/15/21 10:07 | |
| EPA 6010 | Manganese, Dissolved | 359 | ug/L | 10.0 | 11/13/21 01:53 | |
| EPA 6010 | Molybdenum, Dissolved | 69.0 | ug/L | 10.0 | 11/13/21 01:53 | |
| EPA 6020 | Arsenic | 429 | ug/L | 5.0 | 11/08/21 21:49 | |
| EPA 903.1 | Radium-226 | 0.179 ± 0.352 (0.643) C:NA T:92% | pCi/L | | 12/09/21 12:10 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301927003** | **MW-10S** | | | | | |
| EPA 904.0 | Radium-228 | 0.985 ± 0.665 (1.29) C:66% T:84% | pCi/L | | 12/09/21 14:50 | |
| Total Radium Calculation | Total Radium | 1.16 ± 1.02 (1.93) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 264 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 264 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1580 | mg/L | 20.0 | 11/05/21 11:14 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/09/21 12:54 | H3 |
| EPA 365.1 | Phosphate as P04 | 1.4 | mg/L | 0.15 | 11/17/21 09:51 | |
| SM 5310C | Total Organic Carbon | 2.3 | mg/L | 1.0 | 11/13/21 16:06 | |
| SM 5310C | Dissolved Organic Carbon | 2.4 | mg/L | 1.0 | 11/16/21 14:44 | |
| **50301927004** | **MW-10D** | | | | | |
| EPA 9056 | Chloride | 413 | mg/L | 25.0 | 11/08/21 10:00 | |
| EPA 9056 | Fluoride | 2.0 | mg/L | 0.10 | 11/08/21 09:44 | |
| EPA 9056 | Sulfate | 546 | mg/L | 25.0 | 11/08/21 10:00 | |
| EPA 6010 | Barium | 33.3 | ug/L | 10.0 | 11/15/21 09:31 | |
| EPA 6010 | Boron | 3670 | ug/L | 100 | 11/15/21 09:31 | |
| EPA 6010 | Calcium | 205000 | ug/L | 2000 | 11/15/21 10:09 | |
| EPA 6010 | Iron | 1840 | ug/L | 100 | 11/15/21 09:31 | |
| EPA 6010 | Lithium | 67.4 | ug/L | 20.0 | 11/15/21 09:31 | |
| EPA 6010 | Magnesium | 73400 | ug/L | 1000 | 11/15/21 09:31 | |
| EPA 6010 | Manganese | 184 | ug/L | 10.0 | 11/15/21 09:31 | |
| EPA 6010 | Molybdenum | 84.1 | ug/L | 10.0 | 11/15/21 09:31 | |
| EPA 6010 | Potassium | 12900 | ug/L | 1000 | 11/15/21 09:31 | |
| EPA 6010 | Silica | 14200 | ug/L | 450 | 11/15/21 09:31 | N2 |
| EPA 6010 | Sodium | 244000 | ug/L | 2000 | 11/15/21 10:09 | |
| EPA 6010 | Manganese, Dissolved | 178 | ug/L | 10.0 | 11/13/21 01:56 | |
| EPA 6010 | Molybdenum, Dissolved | 83.2 | ug/L | 10.0 | 11/13/21 01:56 | |
| EPA 6020 | Arsenic | 173 | ug/L | 1.0 | 11/08/21 23:35 | |
| EPA 903.1 | Radium-226 | 0.524 ± 0.517 (0.787) C:NA T:91% | pCi/L | | 12/09/21 12:10 | |
| EPA 904.0 | Radium-228 | 0.673 ± 0.534 (1.06) C:75% T:84% | pCi/L | | 12/09/21 14:50 | |
| Total Radium Calculation | Total Radium | 1.20 ± 1.05 (1.85) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 267 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 267 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1700 | mg/L | 40.0 | 11/05/21 11:14 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/21 12:49 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.29 | mg/L | 0.15 | 11/17/21 09:51 | |
| SM 5310C | Total Organic Carbon | 2.2 | mg/L | 1.0 | 11/13/21 16:33 | |
| SM 5310C | Dissolved Organic Carbon | 2.2 | mg/L | 1.0 | 11/16/21 15:05 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301927005** | **MW-13S** | | | | | |
| EPA 9056 | Chloride | 282 | mg/L | 25.0 | 11/08/21 10:31 | |
| EPA 9056 | Fluoride | 0.83 | mg/L | 0.10 | 11/08/21 10:16 | |
| EPA 9056 | Sulfate | 434 | mg/L | 25.0 | 11/08/21 10:31 | |
| EPA 6010 | Barium | 44.2 | ug/L | 10.0 | 11/15/21 09:33 | |
| EPA 6010 | Boron | 8620 | ug/L | 100 | 11/15/21 09:33 | |
| EPA 6010 | Calcium | 179000 | ug/L | 1000 | 11/15/21 09:33 | |
| EPA 6010 | Iron | 1970 | ug/L | 100 | 11/15/21 09:33 | |
| EPA 6010 | Lithium | 73.3 | ug/L | 20.0 | 11/15/21 09:33 | |
| EPA 6010 | Magnesium | 51900 | ug/L | 1000 | 11/15/21 09:33 | |
| EPA 6010 | Manganese | 434 | ug/L | 10.0 | 11/15/21 09:33 | |
| EPA 6010 | Molybdenum | 553 | ug/L | 10.0 | 11/15/21 09:33 | |
| EPA 6010 | Potassium | 13200 | ug/L | 1000 | 11/15/21 09:33 | |
| EPA 6010 | Silica | 14000 | ug/L | 450 | 11/15/21 09:33 | N2 |
| EPA 6010 | Sodium | 185000 | ug/L | 1000 | 11/15/21 09:33 | |
| EPA 6010 | Manganese, Dissolved | 385 | ug/L | 10.0 | 11/13/21 01:58 | |
| EPA 6010 | Molybdenum, Dissolved | 562 | ug/L | 10.0 | 11/13/21 01:58 | |
| EPA 6020 | Arsenic | 368 | ug/L | 5.0 | 11/08/21 22:08 | |
| EPA 903.1 | Radium-226 | 0.0749 ± 0.487 (0.981) C:NA T:82% | pCi/L | | 12/09/21 12:10 | |
| EPA 904.0 | Radium-228 | 1.93 ± 0.771 (1.24) C:72% T:83% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 2.00 ± 1.26 (2.22) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 264 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 264 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1340 | mg/L | 20.0 | 11/05/21 11:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/21 12:48 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.45 | mg/L | 0.15 | 11/17/21 09:57 | |
| SM 5310C | Total Organic Carbon | 3.2 | mg/L | 1.0 | 11/13/21 17:13 | |
| SM 5310C | Dissolved Organic Carbon | 4.0 | mg/L | 1.0 | 11/16/21 15:26 | |
| **50301927006** | **DUP 2** | | | | | |
| EPA 9056 | Chloride | 410 | mg/L | 25.0 | 11/08/21 11:35 | |
| EPA 9056 | Fluoride | 2.0 | mg/L | 0.10 | 11/08/21 11:19 | |
| EPA 9056 | Sulfate | 540 | mg/L | 25.0 | 11/08/21 11:35 | |
| EPA 6010 | Barium | 32.7 | ug/L | 10.0 | 11/15/21 09:36 | |
| EPA 6010 | Boron | 3490 | ug/L | 100 | 11/15/21 09:36 | |
| EPA 6010 | Calcium | 198000 | ug/L | 2000 | 11/15/21 10:12 | |
| EPA 6010 | Iron | 1770 | ug/L | 100 | 11/15/21 09:36 | |
| EPA 6010 | Lithium | 69.2 | ug/L | 20.0 | 11/15/21 09:36 | |
| EPA 6010 | Magnesium | 71100 | ug/L | 1000 | 11/15/21 09:36 | |
| EPA 6010 | Manganese | 174 | ug/L | 10.0 | 11/15/21 09:36 | |
| EPA 6010 | Molybdenum | 82.1 | ug/L | 10.0 | 11/15/21 09:36 | |
| EPA 6010 | Potassium | 12500 | ug/L | 1000 | 11/15/21 09:36 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50301927006** | **DUP 2** | | | | | |
| EPA 6010 | Silica | 13900 | ug/L | 450 | 11/15/21 09:36 | N2 |
| EPA 6010 | Sodium | 240000 | ug/L | 2000 | 11/15/21 10:12 | |
| EPA 6010 | Manganese, Dissolved | 173 | ug/L | 10.0 | 11/13/21 02:00 | |
| EPA 6010 | Molybdenum, Dissolved | 81.9 | ug/L | 10.0 | 11/13/21 02:00 | |
| EPA 6020 | Arsenic | 180 | ug/L | 1.0 | 11/08/21 23:44 | |
| EPA 903.1 | Radium-226 | 0.386 ± 0.360 (0.474) C:NA T:92% | pCi/L | | 12/09/21 12:10 | |
| EPA 904.0 | Radium-228 | 2.09 ± 0.656 (0.865) C:70% T:86% | pCi/L | | 12/09/21 14:51 | |
| Total Radium Calculation | Total Radium | 2.48 ± 1.02 (1.34) | pCi/L | | 12/14/21 13:39 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 264 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 264 | mg/L | 2.0 | 11/09/21 11:15 | |
| SM 2540C | Total Dissolved Solids | 1750 | mg/L | 40.0 | 11/05/21 11:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 11/09/21 12:22 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.23 | mg/L | 0.15 | 11/17/21 09:57 | |
| SM 5310C | Total Organic Carbon | 2.1 | mg/L | 1.0 | 11/13/21 17:27 | |
| SM 5310C | Dissolved Organic Carbon | 2.5 | mg/L | 1.0 | 11/16/21 15:47 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-7S** **Lab ID: 50301927001** Collected: 11/02/21 10:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **220** | mg/L | 25.0 | 100 | | 11/08/21 07:22 | 16887-00-6 | |
| Fluoride | **0.50** | mg/L | 0.10 | 1 | | 11/08/21 05:47 | 16984-48-8 | |
| Sulfate | **500** | mg/L | 25.0 | 100 | | 11/08/21 07:22 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **209** | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7429-90-5 | |
| Barium | **41.8** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-39-3 | |
| Boron | **12200** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-43-9 | |
| Calcium | **195000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-47-3 | |
| Iron | **3640** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7439-92-1 | |
| Lithium | **85.8** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7439-93-2 | |
| Magnesium | **45800** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7439-95-4 | |
| Manganese | **426** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7439-96-5 | |
| Molybdenum | **625** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7439-98-7 | |
| Potassium | **15100** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-09-7 | |
| Silica | **14000** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7631-86-9 | N2 |
| Sodium | **178000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:25 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **393** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:49 | 7439-96-5 | |
| Molybdenum, Dissolved | **623** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:49 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:11 | 7440-36-0 | |
| Arsenic | **376** | ug/L | 5.0 | 5 | 11/07/21 16:20 | 11/08/21 21:40 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:11 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:11 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **234** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **234** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1360** | mg/L | 20.0 | 1 | | 11/05/21 11:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-7S** **Lab ID: 50301927001** Collected: 11/02/21 10:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 11/09/21 12:38 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:45 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:45 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.82** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:50 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 11/13/21 15:41 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 11/16/21 14:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-7D** **Lab ID: 50301927002** Collected: 11/02/21 10:55 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **187** | mg/L | 25.0 | 100 | | 11/08/21 08:57 | 16887-00-6 | |
| Fluoride | **0.38** | mg/L | 0.10 | 1 | | 11/08/21 08:41 | 16984-48-8 | |
| Sulfate | **528** | mg/L | 25.0 | 100 | | 11/08/21 08:57 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **3380** | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7429-90-5 | |
| Barium | **53.9** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-39-3 | |
| Boron | **13900** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-43-9 | |
| Calcium | **190000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-47-3 | |
| Iron | **7440** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7439-92-1 | |
| Lithium | **103** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7439-93-2 | |
| Magnesium | **41200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7439-95-4 | |
| Manganese | **486** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7439-96-5 | |
| Molybdenum | **688** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7439-98-7 | |
| Potassium | **16000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-09-7 | |
| Silica | **24300** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7631-86-9 | N2 |
| Sodium | **171000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:27 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **393** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:51 | 7439-96-5 | |
| Molybdenum, Dissolved | **684** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:51 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:16 | 7440-36-0 | |
| Arsenic | **457** | ug/L | 5.0 | 5 | 11/07/21 16:20 | 11/08/21 21:44 | 7440-38-2 | |
| Cobalt | **1.8** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:16 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:16 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **221** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **221** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1300** | mg/L | 20.0 | 1 | | 11/05/21 11:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-7D** **Lab ID: 50301927002** Collected: 11/02/21 10:55 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 12:40 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:51 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:51 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **1.0** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:50 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 11/13/21 15:53 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 11/16/21 14:24 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-10S** **Lab ID: 50301927003** Collected: 11/02/21 15:20 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **348** | mg/L | 25.0 | 100 | | 11/08/21 09:28 | 16887-00-6 | |
| Fluoride | **2.5** | mg/L | 0.10 | 1 | | 11/08/21 09:12 | 16984-48-8 | |
| Sulfate | **483** | mg/L | 25.0 | 100 | | 11/08/21 09:28 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7429-90-5 | |
| Barium | **73.3** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7440-39-3 | |
| Boron | **1540** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7440-43-9 | |
| Calcium | **201000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:07 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7440-47-3 | |
| Iron | **1190** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7439-92-1 | |
| Lithium | **53.3** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7439-93-2 | |
| Magnesium | **44600** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7439-95-4 | |
| Manganese | **385** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7439-96-5 | |
| Molybdenum | **71.2** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7439-98-7 | |
| Potassium | **9900** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7440-09-7 | |
| Silica | **13200** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:29 | 7631-86-9 | N2 |
| Sodium | **257000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:07 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **359** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:53 | 7439-96-5 | |
| Molybdenum, Dissolved | **69.0** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:53 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:20 | 7440-36-0 | |
| Arsenic | **429** | ug/L | 5.0 | 5 | 11/07/21 16:20 | 11/08/21 21:49 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:20 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:20 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **264** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **264** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1580** | mg/L | 20.0 | 1 | | 11/05/21 11:14 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-10S** **Lab ID: 50301927003** Collected: 11/02/21 15:20 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/09/21 12:54 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 10:09 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:09 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **1.4** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:51 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 11/13/21 16:06 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.4** | mg/L | 1.0 | 1 | | 11/16/21 14:44 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-10D** **Lab ID: 50301927004** Collected: 11/02/21 13:40 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **413** | mg/L | 25.0 | 100 | | 11/08/21 10:00 | 16887-00-6 | |
| Fluoride | **2.0** | mg/L | 0.10 | 1 | | 11/08/21 09:44 | 16984-48-8 | |
| Sulfate | **546** | mg/L | 25.0 | 100 | | 11/08/21 10:00 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7429-90-5 | |
| Barium | **33.3** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7440-39-3 | |
| Boron | **3670** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7440-43-9 | |
| Calcium | **205000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:09 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7440-47-3 | |
| Iron | **1840** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7439-92-1 | |
| Lithium | **67.4** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7439-93-2 | |
| Magnesium | **73400** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7439-95-4 | |
| Manganese | **184** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7439-96-5 | |
| Molybdenum | **84.1** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7439-98-7 | |
| Potassium | **12900** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7440-09-7 | |
| Silica | **14200** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:31 | 7631-86-9 | N2 |
| Sodium | **244000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:09 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **178** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:56 | 7439-96-5 | |
| Molybdenum, Dissolved | **83.2** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:56 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:35 | 7440-36-0 | |
| Arsenic | **173** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:35 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:35 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:35 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **267** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **267** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1700** | mg/L | 40.0 | 1 | | 11/05/21 11:14 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-10D** **Lab ID: 50301927004** Collected: 11/02/21 13:40 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/09/21 12:49 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 10:04 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 10:04 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.29** | mg/L | 0.15 | 1 | 11/12/21 10:30 | 11/17/21 09:51 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 11/13/21 16:33 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 11/16/21 15:05 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-13S** **Lab ID: 50301927005** Collected: 11/02/21 12:30 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **282** | mg/L | 25.0 | 100 | | 11/08/21 10:31 | 16887-00-6 | |
| Fluoride | **0.83** | mg/L | 0.10 | 1 | | 11/08/21 10:16 | 16984-48-8 | |
| Sulfate | **434** | mg/L | 25.0 | 100 | | 11/08/21 10:31 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7429-90-5 | |
| Barium | **44.2** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-39-3 | |
| Boron | **8620** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-43-9 | |
| Calcium | **179000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-47-3 | |
| Iron | **1970** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7439-92-1 | |
| Lithium | **73.3** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7439-93-2 | |
| Magnesium | **51900** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7439-95-4 | |
| Manganese | **434** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7439-96-5 | |
| Molybdenum | **553** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7439-98-7 | |
| Potassium | **13200** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-09-7 | |
| Silica | **14000** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7631-86-9 | N2 |
| Sodium | **185000** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:33 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **385** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:58 | 7439-96-5 | |
| Molybdenum, Dissolved | **562** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 01:58 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:39 | 7440-36-0 | |
| Arsenic | **368** | ug/L | 5.0 | 5 | 11/07/21 16:20 | 11/08/21 22:08 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:39 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:39 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **264** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **264** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1340** | mg/L | 20.0 | 1 | | 11/05/21 11:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-13S** **Lab ID: 50301927005** Collected: 11/02/21 12:30 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/09/21 12:48 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:58 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:58 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.45** | mg/L | 0.15 | 1 | 11/12/21 12:30 | 11/17/21 09:57 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **3.2** | mg/L | 1.0 | 1 | | 11/13/21 17:13 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **4.0** | mg/L | 1.0 | 1 | | 11/16/21 15:26 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: DUP 2** **Lab ID: 50301927006** Collected: 11/02/21 08:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **410** | mg/L | 25.0 | 100 | | 11/08/21 11:35 | 16887-00-6 | |
| Fluoride | **2.0** | mg/L | 0.10 | 1 | | 11/08/21 11:19 | 16984-48-8 | |
| Sulfate | **540** | mg/L | 25.0 | 100 | | 11/08/21 11:35 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7429-90-5 | |
| Barium | **32.7** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7440-39-3 | |
| Boron | **3490** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7440-43-9 | |
| Calcium | **198000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:12 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7440-47-3 | |
| Iron | **1770** | ug/L | 100 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7439-92-1 | |
| Lithium | **69.2** | ug/L | 20.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7439-93-2 | |
| Magnesium | **71100** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7439-95-4 | |
| Manganese | **174** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7439-96-5 | |
| Molybdenum | **82.1** | ug/L | 10.0 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7439-98-7 | |
| Potassium | **12500** | ug/L | 1000 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7440-09-7 | |
| Silica | **13900** | ug/L | 450 | 1 | 11/12/21 13:51 | 11/15/21 09:36 | 7631-86-9 | N2 |
| Sodium | **240000** | ug/L | 2000 | 2 | 11/12/21 13:51 | 11/15/21 10:12 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **173** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 02:00 | 7439-96-5 | |
| Molybdenum, Dissolved | **81.9** | ug/L | 10.0 | 1 | 11/12/21 13:35 | 11/13/21 02:00 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:44 | 7440-36-0 | |
| Arsenic | **180** | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:44 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:44 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/07/21 16:20 | 11/08/21 23:44 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **264** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Bicarbonate (CaCO3) | **264** | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/09/21 11:15 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1750** | mg/L | 40.0 | 1 | | 11/05/21 11:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: DUP 2** **Lab ID: 50301927006** Collected: 11/02/21 08:00 Received: 11/03/21 15:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 11/09/21 12:22 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 15:06 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 09:43 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 09:43 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.23** | mg/L | 0.15 | 1 | 11/12/21 12:30 | 11/17/21 09:57 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 11/13/21 17:27 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.5** | mg/L | 1.0 | 1 | | 11/16/21 15:47 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648603 | Analysis Method: EPA 9056
QC Batch Method: EPA 9056 | Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2988468 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/08/21 05:16 | |
| Fluoride | mg/L | ND | 0.10 | 11/08/21 05:16 | |
| Sulfate | mg/L | ND | 0.25 | 11/08/21 05:16 | |

LABORATORY CONTROL SAMPLE: 2988469

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 92 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.43 | 85 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 92 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988470 2988471

| Parameter | Units | 50301927001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 220 | 125 | 125 | 341 | 341 | 97 | 96 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.50 | 0.5 | 0.5 | 0.94 | 0.94 | 88 | 88 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 500 | 250 | 250 | 746 | 750 | 99 | 100 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648877
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2990119 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/15/21 08:42 | |
| Barium | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Boron | ug/L | ND | 100 | 11/15/21 08:42 | |
| Cadmium | ug/L | ND | 2.0 | 11/15/21 08:42 | |
| Calcium | ug/L | ND | 1000 | 11/15/21 08:42 | |
| Chromium | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Iron | ug/L | ND | 100 | 11/15/21 08:42 | |
| Lead | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Lithium | ug/L | ND | 20.0 | 11/15/21 08:42 | |
| Magnesium | ug/L | ND | 1000 | 11/15/21 08:42 | |
| Manganese | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Molybdenum | ug/L | ND | 10.0 | 11/15/21 08:42 | |
| Potassium | ug/L | ND | 1000 | 11/15/21 08:42 | |
| Silica | ug/L | ND | 450 | 11/15/21 08:42 | N2 |
| Sodium | ug/L | ND | 1000 | 11/15/21 08:42 | |

LABORATORY CONTROL SAMPLE: 2990120

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4900 | 98 | 80-120 | |
| Barium | ug/L | 1000 | 963 | 96 | 80-120 | |
| Boron | ug/L | 1000 | 956 | 96 | 80-120 | |
| Cadmium | ug/L | 1000 | 934 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 4950 | 99 | 80-120 | |
| Chromium | ug/L | 1000 | 972 | 97 | 80-120 | |
| Iron | ug/L | 2500 | 2430 | 97 | 80-120 | |
| Lead | ug/L | 1000 | 923 | 92 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4710 | 94 | 80-120 | |
| Manganese | ug/L | 1000 | 952 | 95 | 80-120 | |
| Molybdenum | ug/L | 1000 | 950 | 95 | 80-120 | |
| Potassium | ug/L | 5000 | 4830 | 97 | 80-120 | |
| Silica | ug/L | 5350 | 5090 | 95 | | N2 |
| Sodium | ug/L | 5000 | 4720 | 94 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990121 2990122

| Parameter | Units | 50301920003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4980 | 4960 | 97 | 97 | 75-125 | 0 | 20 | |
| Barium | ug/L | 118 | 1000 | 1000 | 1090 | 1090 | 97 | 97 | 75-125 | 0 | 20 | |
| Boron | ug/L | 5350 | 1000 | 1000 | 6300 | 6300 | 96 | 96 | 75-125 | 0 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 951 | 950 | 95 | 95 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 147000 | 5000 | 5000 | 155000 | 153000 | 160 | 126 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 981 | 981 | 98 | 98 | 75-125 | 0 | 20 | |
| Iron | ug/L | 4890 | 2500 | 2500 | 7310 | 7260 | 97 | 95 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 891 | 887 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | 69.4 | 1000 | 1000 | 1140 | 1140 | 107 | 107 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 41000 | 5000 | 5000 | 45500 | 45300 | 89 | 86 | 75-125 | 0 | 20 | |
| Manganese | ug/L | 698 | 1000 | 1000 | 1650 | 1640 | 95 | 95 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 116 | 1000 | 1000 | 1090 | 1090 | 97 | 97 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 5810 | 5000 | 5000 | 11000 | 11100 | 105 | 106 | 75-125 | 0 | 20 | |
| Silica | ug/L | 12400 | 5350 | 5350 | 17400 | 17400 | 93 | 94 | | 0 | | N2 |
| Sodium | ug/L | 80600 | 5000 | 5000 | 86800 | 86800 | 124 | 123 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648526
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2988170 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/13/21 01:06 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/13/21 01:06 | |

LABORATORY CONTROL SAMPLE: 2988171

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 904 | 90 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 944 | 94 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988172 2988173

| Parameter | Units | 50301920003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 665 | 1000 | 1000 | 1520 | 1530 | 85 | 87 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | 120 | 1000 | 1000 | 1060 | 1080 | 94 | 96 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648844
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2989855 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/08/21 19:45 | |
| Arsenic | ug/L | ND | 1.0 | 11/08/21 19:45 | |
| Cobalt | ug/L | ND | 1.0 | 11/08/21 19:45 | |
| Selenium | ug/L | ND | 1.0 | 11/08/21 19:45 | |

LABORATORY CONTROL SAMPLE: 2989856

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 42.1 | 105 | 80-120 | |
| Arsenic | ug/L | 40 | 37.1 | 93 | 80-120 | |
| Cobalt | ug/L | 40 | 39.8 | 99 | 80-120 | |
| Selenium | ug/L | 40 | 38.5 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989857 2989858

| Parameter | Units | 50301920001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.5 | 41.8 | 108 | 104 | 75-125 | 4 | 20 | |
| Arsenic | ug/L | 2.3 | 40 | 40 | 38.9 | 38.3 | 91 | 90 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 37.6 | 36.1 | 93 | 89 | 75-125 | 4 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 37.9 | 37.1 | 94 | 92 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 649249 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2991616 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/09/21 11:15 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/09/21 11:15 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/09/21 11:15 | |

LABORATORY CONTROL SAMPLE: 2991617

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.1 | 98 | 90-110 | |

SAMPLE DUPLICATE: 2991618

| Parameter | Units | 50301920001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 312 | 312 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 312 | 312 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2991619

| Parameter | Units | 50301927001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 234 | 248 | 6 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 234 | 248 | 6 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648797 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2989635 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/05/21 11:06 | |

LABORATORY CONTROL SAMPLE: 2989636

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 302 | 101 | 80-120 | |

SAMPLE DUPLICATE: 2989637

| Parameter | Units | 50301920003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 836 | 832 | 0 | 10 | |

SAMPLE DUPLICATE: 2989638

| Parameter | Units | 50301920004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 762 | 762 | 0 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 649339
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

SAMPLE DUPLICATE: 2991994

| Parameter | Units | 50301769001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 5.6 | 5.6 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 2991995

| Parameter | Units | 50301769006 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.9 | 7.0 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648870 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2990073 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 15:06 | |

LABORATORY CONTROL SAMPLE: 2990074

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990075 2990076

| Parameter | Units | 50301920001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.17 | 0.17 | 34 | 34 | 90-110 | 2 | 20 | M3 |

MATRIX SPIKE SAMPLE: 2990077

| Parameter | Units | 50301927001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.20 | 38 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 648555 | Analysis Method: EPA 353.2
QC Batch Method: EPA 353.2 | Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2988308 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/04/21 09:36 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/04/21 09:36 | |

LABORATORY CONTROL SAMPLE: 2988309

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 110 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2988314 2988315

| Parameter | Units | 50301927003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 102 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 111 | 112 | 90-110 | 1 | 20 | M3 |

MATRIX SPIKE SAMPLE: 2988316

| Parameter | Units | 50301920007 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1.1 | 112 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 649946
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004

METHOD BLANK: 2995306 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 09:42 | |

LABORATORY CONTROL SAMPLE: 2995307

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2995308 2995309

| Parameter | Units | 50301920006 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.5 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 649949
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927005, 50301927006

METHOD BLANK: 2995317 Matrix: Water
Associated Lab Samples: 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 09:52 | |

LABORATORY CONTROL SAMPLE: 2995318

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE SAMPLE: 2995319

| Parameter | Units | 5282022001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.89 | | 2.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2995320 2995321

| Parameter | Units | 50301937002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.26 | | | 1.6 | 1.7 | | | | 6 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 650224 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2997050 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/13/21 12:29 | |

LABORATORY CONTROL SAMPLE: 2997051

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997052 2997053

| Parameter | Units | 50301920007 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.8 | 10 | 10 | 11.9 | 12.2 | 101 | 103 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 2997054

| Parameter | Units | 50301927003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.3 | 10 | 12.8 | 105 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 650521 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2998289 — Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/16/21 12:43 | |

LABORATORY CONTROL SAMPLE: 2998290

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.7 | 97 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998291 2998292

| Parameter | Units | 50301937002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.6 | 10 | 10 | 11.3 | 10.8 | 97 | 92 | 80-120 | 4 | 20 | |

MATRIX SPIKE SAMPLE: 2998293

| Parameter | Units | 50302003002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.3 | 10 | 11.1 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-7S** **Lab ID: 50301927001** Collected: 11/02/21 10:00 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.209 ± 0.530 (0.983) C:NA T:88%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.467 ± 0.533 (1.13) C:68% T:87%** | pCi/L | 12/09/21 11:35 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.676 ± 1.06 (2.11)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-7D** **Lab ID: 50301927002** Collected: 11/02/21 10:55 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.417 ± 0.390 (0.553) C:NA T:97%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.675 ± 0.616 (1.26) C:66% T:88%** | pCi/L | 12/09/21 14:50 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.09 ± 1.01 (1.81)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-10S** **Lab ID: 50301927003** Collected: 11/02/21 15:20 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.179 ± 0.352 (0.643) C:NA T:92%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.985 ± 0.665 (1.29) C:66% T:84%** | pCi/L | 12/09/21 14:50 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.16 ± 1.02 (1.93)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-10D** **Lab ID: 50301927004** Collected: 11/02/21 13:40 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.524 ± 0.517 (0.787) C:NA T:91%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.673 ± 0.534 (1.06) C:75% T:84%** | pCi/L | 12/09/21 14:50 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.20 ± 1.05 (1.85)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: MW-13S** **Lab ID: 50301927005** Collected: 11/02/21 12:30 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0749 ± 0.487 (0.981) C:NA T:82%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.93 ± 0.771 (1.24) C:72% T:83%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.00 ± 1.26 (2.22)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

**Sample: DUP 2** **Lab ID: 50301927006** Collected: 11/02/21 08:00 Received: 11/03/21 15:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.386 ± 0.360 (0.474) C:NA T:92%** | pCi/L | 12/09/21 12:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **2.09 ± 0.656 (0.865) C:70% T:86%** | pCi/L | 12/09/21 14:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.48 ± 1.02 (1.34)** | pCi/L | 12/14/21 13:39 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 473880
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2289233 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0520 ± 0.338 (0.682) C:NA T:89% | pCi/L | 12/09/21 12:10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

QC Batch: 473881
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

METHOD BLANK: 2289234 Matrix: Water
Associated Lab Samples: 50301927001, 50301927002, 50301927003, 50301927004, 50301927005, 50301927006

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.597 ± 0.344 (0.619) C:69% T:87% | pCi/L | 12/09/21 11:47 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50301927001** | **MW-7S** | EPA 9056 | 648603 | | |
| **50301927002** | **MW-7D** | EPA 9056 | 648603 | | |
| **50301927003** | **MW-10S** | EPA 9056 | 648603 | | |
| **50301927004** | **MW-10D** | EPA 9056 | 648603 | | |
| **50301927005** | **MW-13S** | EPA 9056 | 648603 | | |
| **50301927006** | **DUP 2** | EPA 9056 | 648603 | | |
| **50301927001** | **MW-7S** | EPA 3010 | 648877 | EPA 6010 | 650421 |
| **50301927002** | **MW-7D** | EPA 3010 | 648877 | EPA 6010 | 650421 |
| **50301927003** | **MW-10S** | EPA 3010 | 648877 | EPA 6010 | 650421 |
| **50301927004** | **MW-10D** | EPA 3010 | 648877 | EPA 6010 | 650421 |
| **50301927005** | **MW-13S** | EPA 3010 | 648877 | EPA 6010 | 650421 |
| **50301927006** | **DUP 2** | EPA 3010 | 648877 | EPA 6010 | 650421 |
| **50301927001** | **MW-7S** | EPA 3010 | 648526 | EPA 6010 | 650253 |
| **50301927002** | **MW-7D** | EPA 3010 | 648526 | EPA 6010 | 650253 |
| **50301927003** | **MW-10S** | EPA 3010 | 648526 | EPA 6010 | 650253 |
| **50301927004** | **MW-10D** | EPA 3010 | 648526 | EPA 6010 | 650253 |
| **50301927005** | **MW-13S** | EPA 3010 | 648526 | EPA 6010 | 650253 |
| **50301927006** | **DUP 2** | EPA 3010 | 648526 | EPA 6010 | 650253 |
| **50301927001** | **MW-7S** | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| **50301927002** | **MW-7D** | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| **50301927003** | **MW-10S** | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| **50301927004** | **MW-10D** | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| **50301927005** | **MW-13S** | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| **50301927006** | **DUP 2** | EPA 200.2 | 648844 | EPA 6020 | 649020 |
| **50301927001** | **MW-7S** | EPA 903.1 | 473880 | | |
| **50301927002** | **MW-7D** | EPA 903.1 | 473880 | | |
| **50301927003** | **MW-10S** | EPA 903.1 | 473880 | | |
| **50301927004** | **MW-10D** | EPA 903.1 | 473880 | | |
| **50301927005** | **MW-13S** | EPA 903.1 | 473880 | | |
| **50301927006** | **DUP 2** | EPA 903.1 | 473880 | | |
| **50301927001** | **MW-7S** | EPA 904.0 | 473881 | | |
| **50301927002** | **MW-7D** | EPA 904.0 | 473881 | | |
| **50301927003** | **MW-10S** | EPA 904.0 | 473881 | | |
| **50301927004** | **MW-10D** | EPA 904.0 | 473881 | | |
| **50301927005** | **MW-13S** | EPA 904.0 | 473881 | | |
| **50301927006** | **DUP 2** | EPA 904.0 | 473881 | | |
| **50301927001** | **MW-7S** | Total Radium Calculation | 476249 | | |
| **50301927002** | **MW-7D** | Total Radium Calculation | 476249 | | |
| **50301927003** | **MW-10S** | Total Radium Calculation | 476249 | | |
| **50301927004** | **MW-10D** | Total Radium Calculation | 476249 | | |
| **50301927005** | **MW-13S** | Total Radium Calculation | 476249 | | |
| **50301927006** | **DUP 2** | Total Radium Calculation | 476249 | | |
| **50301927001** | **MW-7S** | SM 2320B | 649249 | | |
| **50301927002** | **MW-7D** | SM 2320B | 649249 | | |
| **50301927003** | **MW-10S** | SM 2320B | 649249 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50301927004** | **MW-10D** | SM 2320B | 649249 | | |
| **50301927005** | **MW-13S** | SM 2320B | 649249 | | |
| **50301927006** | **DUP 2** | SM 2320B | 649249 | | |
| **50301927001** | **MW-7S** | SM 2540C | 648797 | | |
| **50301927002** | **MW-7D** | SM 2540C | 648797 | | |
| **50301927003** | **MW-10S** | SM 2540C | 648797 | | |
| **50301927004** | **MW-10D** | SM 2540C | 648797 | | |
| **50301927005** | **MW-13S** | SM 2540C | 648797 | | |
| **50301927006** | **DUP 2** | SM 2540C | 648797 | | |
| **50301927001** | **MW-7S** | SM 4500-H+B | 649339 | | |
| **50301927002** | **MW-7D** | SM 4500-H+B | 649339 | | |
| **50301927003** | **MW-10S** | SM 4500-H+B | 649339 | | |
| **50301927004** | **MW-10D** | SM 4500-H+B | 649339 | | |
| **50301927005** | **MW-13S** | SM 4500-H+B | 649339 | | |
| **50301927006** | **DUP 2** | SM 4500-H+B | 649339 | | |
| **50301927001** | **MW-7S** | SM 4500-S2-D | 648870 | | |
| **50301927002** | **MW-7D** | SM 4500-S2-D | 648870 | | |
| **50301927003** | **MW-10S** | SM 4500-S2-D | 648870 | | |
| **50301927004** | **MW-10D** | SM 4500-S2-D | 648870 | | |
| **50301927005** | **MW-13S** | SM 4500-S2-D | 648870 | | |
| **50301927006** | **DUP 2** | SM 4500-S2-D | 648870 | | |
| **50301927001** | **MW-7S** | EPA 353.2 | 648555 | | |
| **50301927002** | **MW-7D** | EPA 353.2 | 648555 | | |
| **50301927003** | **MW-10S** | EPA 353.2 | 648555 | | |
| **50301927004** | **MW-10D** | EPA 353.2 | 648555 | | |
| **50301927005** | **MW-13S** | EPA 353.2 | 648555 | | |
| **50301927006** | **DUP 2** | EPA 353.2 | 648555 | | |
| **50301927001** | **MW-7S** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301927002** | **MW-7D** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301927003** | **MW-10S** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301927004** | **MW-10D** | EPA 365.1 | 649946 | EPA 365.1 | 650211 |
| **50301927005** | **MW-13S** | EPA 365.1 | 649949 | EPA 365.1 | 650212 |
| **50301927006** | **DUP 2** | EPA 365.1 | 649949 | EPA 365.1 | 650212 |
| **50301927001** | **MW-7S** | SM 5310C | 650224 | | |
| **50301927002** | **MW-7D** | SM 5310C | 650224 | | |
| **50301927003** | **MW-10S** | SM 5310C | 650224 | | |
| **50301927004** | **MW-10D** | SM 5310C | 650224 | | |
| **50301927005** | **MW-13S** | SM 5310C | 650224 | | |
| **50301927006** | **DUP 2** | SM 5310C | 650224 | | |
| **50301927001** | **MW-7S** | SM 5310C | 650521 | | |
| **50301927002** | **MW-7D** | SM 5310C | 650521 | | |
| **50301927003** | **MW-10S** | SM 5310C | 650521 | | |
| **50301927004** | **MW-10D** | SM 5310C | 650521 | | |
| **50301927005** | **MW-13S** | SM 5310C | 650521 | | |
| **50301927006** | **DUP 2** | SM 5310C | 650521 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50301927

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Docume

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be com

(1)

WO# : 50301927

50301927

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | |
| 1 | MW-1S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 2 | MW-1D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 3 | MW-2S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 4 | MW-2D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 5 | MW-3S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | MW-3D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-4S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 8 | MW-5S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 9 | MW-6S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 10 | MW-7S | WT | | | | 11-2-21 | 10:00 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 11 | MW-7D | WT | | | | 11-2-21 | 10:55 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 12 | MW-8S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jashowiak | 11-3-21 | 7:35 | | 11/3/21 | 1420 | |
| 6020 (Co, As, Se, Sb) | | 11/3/21 | 1520 | JC | 11/3/21 | 1520 | See SCUR |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER: Andy Jashowiak DATE Signed: 11-3-21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

(1)



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

| Regulatory Agency | |
|---|---|
| | |
| State / Location | |
| | IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | | |
| 13 | MW-9S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 14 | MW-9I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 15 | MW-9D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 16 | MW-10S | WT | | | | 11-2-21 | 15:20 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 003 |
| 17 | MW-10D | WT | | | | 11-2-21 | 13:40 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 004 |
| 18 | MW-11D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 19 | MW-12S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 20 | MW-11S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 21 | MW-12D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 22 | MW-13S | WT | | | | 11-2-21 | 12:30 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 005 |
| 23 | MW-13D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 24 | MW-14D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jaskowiak | 11-3-21 | 7:35 | pace | 11/3 | 1420 | |
| 6020 (Co, As, Se, Sb) | pace | 11/3/21 | 1520 | JC | 11/3/21 | 1520 | See SCVR |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | Andrew Jaskowiak | | | | | |
| SIGNATURE of SAMPLER: | | DATE Signed: 11-3-21 | | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

(1)



| Section A Required Client Information: | Section B Required Project Information: | Section C Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcassociates.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

Regulatory Agency:

State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | Requested Analysis Filtered (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Y/N | | | | Y | | | | | Y | | | | |
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | | | | 11-2-21 | — | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 006 |
| 30 | Field Blank 1 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | | |
| 31 | MS1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 32 | MSD1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 33 | MS2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 34 | MSD2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jaskowiak Pace | 11-3-21 | 7:35 | Pace | 11/3/21 | 1420 | |
| 6020 (Co, As, Se, Sb) | Pace | 11/3/21 | 1520 | JC | 11/3/21 | 1520 | See SCVN |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Andy Jaskowiak

SIGNATURE of SAMPLER: Andy Jaskowiak DATE Signed: 11-3-21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** SC 11/3/21 1810

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 **A B C D E F**

4. **Cooler Temperature:** #1(2.8/2.9), #2(2.2/1.4) #3(1.9/1.1), #4(3.5/2.7), #5(2.7/1.9), #6(3.6/2.8), #7(2.0/1.2), #8(4.8/4.0) #9(1.7/0.9)
Temp should be above freezing to 6°C (Initial/Corrected)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3, NO2 | ✓ | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1900 | |
| **Rush TAT Requested (4 days or less):** | | ✓ |
| Custody Signatures Present? | ✓ | |
| Containers Intact?: | ✓ | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | |
| COMMENTS: | | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any ~~non-conformance~~ to pH recommendations will be noted on the container count form | ✓ | | |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | Present | Absent | N/A ✓ |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Headspace Wisconsin Sulfide? | | | ✓ |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Trip Blank Present? | | ✓ | |
| Trip Blank Custody Seals?: | | | ✓ |

**COC PAGE 1 of 3**

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | AMP 11/8/21 | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 11 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE** 2 **of** 3

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | SBS / DI / MeOH (only) / BK / Kit: R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | 2 | | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 5 | | | | | | | | | | | | 2 | | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | NT | ✓ | ✓ | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | 2 | | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | NT | ✓ | ✓ | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE 3 of 3**

## Sample Container Count

SBS / DI / MeOH (only) / BK / Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | 8 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 14, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Guam Certification
Florida: Cert E871149 SEKS WET
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50302027001** | **MW-1S** | Water | 11/03/21 10:05 | 11/04/21 14:50 |
| **50302027002** | **MW-1D** | Water | 11/03/21 11:05 | 11/04/21 14:50 |
| **50302027003** | **MW-15S** | Water | 11/03/21 15:25 | 11/04/21 14:50 |
| **50302027004** | **MW-15I** | Water | 11/03/21 14:25 | 11/04/21 14:50 |
| **50302027005** | **MW-15D** | Water | 11/03/21 12:55 | 11/04/21 14:50 |
| **50302027006** | **MW-15D MS** | Water | 11/03/21 12:55 | 11/04/21 14:50 |
| **50302027007** | **MW-15D MSD** | Water | 11/03/21 12:55 | 11/04/21 14:50 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50302027001** | **MW-1S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302027002** | **MW-1D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302027003** | **MW-15S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302027004** | **MW-15I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302027005** | **MW-15D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302027006** | **MW-15D MS** | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50302027007** | **MW-15D MSD** | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302027001** | **MW-1S** | | | | | |
| EPA 9056 | Chloride | 179 | mg/L | 25.0 | 11/09/21 17:00 | |
| EPA 9056 | Fluoride | 0.31 | mg/L | 0.10 | 11/09/21 16:44 | |
| EPA 9056 | Sulfate | 135 | mg/L | 25.0 | 11/09/21 17:00 | |
| EPA 6010 | Barium | 64.8 | ug/L | 10.0 | 11/16/21 12:15 | |
| EPA 6010 | Boron | 558 | ug/L | 100 | 11/16/21 12:15 | |
| EPA 6010 | Calcium | 101000 | ug/L | 1000 | 11/16/21 12:15 | |
| EPA 6010 | Iron | 1840 | ug/L | 100 | 11/16/21 12:15 | |
| EPA 6010 | Magnesium | 27100 | ug/L | 1000 | 11/16/21 12:15 | |
| EPA 6010 | Manganese | 304 | ug/L | 10.0 | 11/16/21 12:15 | |
| EPA 6010 | Molybdenum | 28.1 | ug/L | 10.0 | 11/16/21 12:15 | |
| EPA 6010 | Potassium | 5250 | ug/L | 1000 | 11/16/21 12:15 | |
| EPA 6010 | Silica | 10700 | ug/L | 450 | 11/16/21 12:15 | N2 |
| EPA 6010 | Sodium | 132000 | ug/L | 1000 | 11/16/21 12:15 | |
| EPA 6010 | Manganese, Dissolved | 293 | ug/L | 10.0 | 11/16/21 03:00 | |
| EPA 6010 | Molybdenum, Dissolved | 25.0 | ug/L | 10.0 | 11/16/21 03:00 | |
| EPA 6020 | Arsenic | 7.4 | ug/L | 1.0 | 11/09/21 13:13 | |
| EPA 903.1 | Radium-226 | 0.0676 ± 0.547 (1.07) C:NA T:86% | pCi/L | | 12/07/21 12:19 | |
| EPA 904.0 | Radium-228 | 1.04 ± 0.566 (1.04) C:69% T:74% | pCi/L | | 12/07/21 11:28 | |
| Total Radium Calculation | Total Radium | 1.11 ± 1.11 (2.11) | pCi/L | | 12/08/21 15:01 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 260 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 260 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 738 | mg/L | 20.0 | 11/09/21 09:29 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/09/21 15:05 | H3 |
| EPA 365.1 | Phosphate as P04 | 1.2 | mg/L | 0.15 | 11/17/21 13:25 | |
| SM 5310C | Total Organic Carbon | 2.6 | mg/L | 1.0 | 11/13/21 23:06 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 1.0 | 11/17/21 02:34 | |
| **50302027002** | **MW-1D** | | | | | |
| EPA 9056 | Chloride | 126 | mg/L | 25.0 | 11/09/21 17:31 | |
| EPA 9056 | Fluoride | 0.31 | mg/L | 0.10 | 11/09/21 17:16 | |
| EPA 9056 | Sulfate | 87.8 | mg/L | 25.0 | 11/09/21 17:31 | |
| EPA 6010 | Barium | 72.0 | ug/L | 10.0 | 11/16/21 12:17 | |
| EPA 6010 | Boron | 231 | ug/L | 100 | 11/16/21 12:17 | |
| EPA 6010 | Calcium | 95000 | ug/L | 1000 | 11/16/21 12:17 | |
| EPA 6010 | Iron | 2280 | ug/L | 100 | 11/16/21 12:17 | |
| EPA 6010 | Lithium | 23.4 | ug/L | 20.0 | 11/16/21 12:17 | |
| EPA 6010 | Magnesium | 21800 | ug/L | 1000 | 11/16/21 12:17 | |
| EPA 6010 | Manganese | 227 | ug/L | 10.0 | 11/16/21 12:17 | |
| EPA 6010 | Molybdenum | 33.6 | ug/L | 10.0 | 11/16/21 12:17 | |
| EPA 6010 | Potassium | 5690 | ug/L | 1000 | 11/16/21 12:17 | |
| EPA 6010 | Silica | 13300 | ug/L | 450 | 11/16/21 12:17 | N2 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302027002** | **MW-1D** | | | | | |
| EPA 6010 | Sodium | 93600 | ug/L | 1000 | 11/16/21 12:17 | |
| EPA 6010 | Manganese, Dissolved | 229 | ug/L | 10.0 | 11/16/21 03:03 | |
| EPA 6010 | Molybdenum, Dissolved | 33.7 | ug/L | 10.0 | 11/16/21 03:03 | |
| EPA 6020 | Arsenic | 3.4 | ug/L | 1.0 | 11/09/21 13:17 | |
| EPA 903.1 | Radium-226 | 0.264 ± 0.485 (0.865) C:NA T:85% | pCi/L | | 12/07/21 12:32 | |
| EPA 904.0 | Radium-228 | 0.769 ± 0.546 (1.06) C:61% T:75% | pCi/L | | 12/07/21 11:28 | |
| Total Radium Calculation | Total Radium | 1.03 ± 1.03 (1.93) | pCi/L | | 12/08/21 15:01 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 259 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 259 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 616 | mg/L | 10.0 | 11/09/21 09:29 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 15:22 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.28 | mg/L | 0.15 | 11/17/21 13:26 | |
| SM 5310C | Total Organic Carbon | 2.3 | mg/L | 1.0 | 11/13/21 23:17 | |
| SM 5310C | Dissolved Organic Carbon | 2.4 | mg/L | 1.0 | 11/17/21 02:54 | |
| **50302027003** | **MW-15S** | | | | | |
| EPA 9056 | Chloride | 53.0 | mg/L | 2.5 | 11/09/21 18:04 | |
| EPA 9056 | Sulfate | 55.7 | mg/L | 2.5 | 11/09/21 18:04 | |
| EPA 6010 | Barium | 61.2 | ug/L | 10.0 | 11/16/21 12:19 | |
| EPA 6010 | Boron | 111 | ug/L | 100 | 11/16/21 12:19 | |
| EPA 6010 | Calcium | 117000 | ug/L | 1000 | 11/16/21 12:19 | |
| EPA 6010 | Magnesium | 30000 | ug/L | 1000 | 11/16/21 12:19 | |
| EPA 6010 | Potassium | 2130 | ug/L | 1000 | 11/16/21 12:19 | |
| EPA 6010 | Silica | 12700 | ug/L | 450 | 11/16/21 12:19 | N2 |
| EPA 6010 | Sodium | 42800 | ug/L | 1000 | 11/16/21 12:19 | |
| EPA 903.1 | Radium-226 | 0.488 ± 0.533 (0.838) C:NA T:83% | pCi/L | | 12/07/21 12:32 | |
| EPA 904.0 | Radium-228 | 0.0506 ± 0.514 (1.18) C:69% T:58% | pCi/L | | 12/07/21 11:28 | |
| Total Radium Calculation | Total Radium | 0.539 ± 1.05 (2.02) | pCi/L | | 12/08/21 15:01 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 349 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 349 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 542 | mg/L | 10.0 | 11/09/21 09:29 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/21 15:41 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 2.8 | mg/L | 0.10 | 11/04/21 17:59 | |
| EPA 365.1 | Phosphate as P04 | 0.17 | mg/L | 0.15 | 11/17/21 13:26 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302027004** | **MW-15I** | | | | | |
| EPA 9056 | Chloride | 19.9 | mg/L | 2.5 | 11/09/21 18:36 | |
| EPA 9056 | Sulfate | 39.3 | mg/L | 2.5 | 11/09/21 18:36 | |
| EPA 6010 | Barium | 67.9 | ug/L | 10.0 | 11/16/21 12:21 | |
| EPA 6010 | Boron | 101 | ug/L | 100 | 11/16/21 12:21 | |
| EPA 6010 | Calcium | 116000 | ug/L | 1000 | 11/16/21 12:21 | |
| EPA 6010 | Magnesium | 29900 | ug/L | 1000 | 11/16/21 12:21 | |
| EPA 6010 | Manganese | 16.4 | ug/L | 10.0 | 11/16/21 12:21 | |
| EPA 6010 | Potassium | 1450 | ug/L | 1000 | 11/16/21 12:21 | |
| EPA 6010 | Silica | 13100 | ug/L | 450 | 11/16/21 12:21 | N2 |
| EPA 6010 | Sodium | 13500 | ug/L | 1000 | 11/16/21 12:21 | |
| EPA 6010 | Manganese, Dissolved | 16.0 | ug/L | 10.0 | 11/16/21 03:07 | |
| EPA 6020 | Selenium | 1.0 | ug/L | 1.0 | 11/09/21 13:26 | |
| EPA 903.1 | Radium-226 | 0.429 ± 0.446 (0.665) C:NA T:85% | pCi/L | | 12/07/21 12:32 | |
| EPA 904.0 | Radium-228 | 0.747 ± 0.452 (0.835) C:70% T:74% | pCi/L | | 12/07/21 11:28 | |
| Total Radium Calculation | Total Radium | 1.18 ± 0.898 (1.50) | pCi/L | | 12/08/21 15:01 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 318 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 318 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 456 | mg/L | 10.0 | 11/09/21 09:30 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/21 15:32 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 9.2 | mg/L | 0.40 | 11/04/21 18:15 | |
| SM 5310C | Dissolved Organic Carbon | 1.1 | mg/L | 1.0 | 11/17/21 03:39 | |
| **50302027005** | **MW-15D** | | | | | |
| EPA 9056 | Chloride | 27.0 | mg/L | 2.5 | 11/09/21 20:12 | |
| EPA 9056 | Sulfate | 61.5 | mg/L | 2.5 | 11/09/21 20:12 | |
| EPA 6010 | Barium | 69.2 | ug/L | 10.0 | 11/16/21 12:24 | |
| EPA 6010 | Boron | 127 | ug/L | 100 | 11/16/21 12:24 | |
| EPA 6010 | Calcium | 106000 | ug/L | 1000 | 11/16/21 12:24 | |
| EPA 6010 | Iron | 1230 | ug/L | 100 | 11/16/21 12:24 | |
| EPA 6010 | Magnesium | 30700 | ug/L | 1000 | 11/16/21 12:24 | |
| EPA 6010 | Manganese | 118 | ug/L | 10.0 | 11/16/21 12:24 | |
| EPA 6010 | Potassium | 2050 | ug/L | 1000 | 11/16/21 12:24 | |
| EPA 6010 | Silica | 12300 | ug/L | 450 | 11/16/21 12:24 | N2 |
| EPA 6010 | Sodium | 19500 | ug/L | 1000 | 11/16/21 12:24 | |
| EPA 6010 | Manganese, Dissolved | 112 | ug/L | 10.0 | 11/16/21 03:13 | |
| EPA 6020 | Arsenic | 1.2 | ug/L | 1.0 | 11/09/21 13:38 | |
| EPA 903.1 | Radium-226 | 0.373 ± 0.379 (0.574) C:NA T:88% | pCi/L | | 12/07/21 12:32 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302027005** | **MW-15D** | | | | | |
| EPA 904.0 | Radium-228 | 0.761 ± 0.509 (0.971) C:75% T:62% | pCi/L | | 12/07/21 11:39 | |
| Total Radium Calculation | Total Radium | 1.13 ± 0.888 (1.55) | pCi/L | | 12/08/21 15:01 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 325 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 325 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 451 | mg/L | 10.0 | 11/09/21 09:30 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/21 15:25 | H3 |
| **50302027006** | **MW-15D MS** | | | | | |
| EPA 903.1 | Radium-226 | 92.25 %REC ± NA (NA) C:NA T:NA | pCi/L | | 12/07/21 12:32 | |
| EPA 904.0 | Radium-228 | 99.03 %REC ± NA (NA) C:NA T:NA | pCi/L | | 12/07/21 11:26 | |
| **50302027007** | **MW-15D MSD** | | | | | |
| EPA 903.1 | Radium-226 | 94.75 %REC 2.67 RPD ± NA (NA) C:NA T:NA | pCi/L | | 12/07/21 12:32 | |
| EPA 904.0 | Radium-228 | 82.99 %REC 17.62 RPD ± NA (NA) C:NA T:NA | pCi/L | | 12/07/21 11:50 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-1S** **Lab ID: 50302027001** Collected: 11/03/21 10:05 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **179** | mg/L | 25.0 | 100 | | 11/09/21 17:00 | 16887-00-6 | |
| Fluoride | **0.31** | mg/L | 0.10 | 1 | | 11/09/21 16:44 | 16984-48-8 | |
| Sulfate | **135** | mg/L | 25.0 | 100 | | 11/09/21 17:00 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7429-90-5 | |
| Barium | **64.8** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-39-3 | |
| Boron | **558** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-43-9 | |
| Calcium | **101000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-47-3 | |
| Iron | **1840** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7439-93-2 | |
| Magnesium | **27100** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7439-95-4 | |
| Manganese | **304** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7439-96-5 | |
| Molybdenum | **28.1** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7439-98-7 | |
| Potassium | **5250** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-09-7 | |
| Silica | **10700** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7631-86-9 | N2 |
| Sodium | **132000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:15 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **293** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:00 | 7439-96-5 | |
| Molybdenum, Dissolved | **25.0** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:00 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:13 | 7440-36-0 | |
| Arsenic | **7.4** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:13 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:13 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:13 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **260** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **260** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **738** | mg/L | 20.0 | 1 | | 11/09/21 09:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-1S** **Lab ID: 50302027001** Collected: 11/03/21 10:05 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/09/21 15:05 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 17:18 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:18 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **1.2** | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:25 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 11/13/21 23:06 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 11/17/21 02:34 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-1D** **Lab ID: 50302027002** Collected: 11/03/21 11:05 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **126** | mg/L | 25.0 | 100 | | 11/09/21 17:31 | 16887-00-6 | |
| Fluoride | **0.31** | mg/L | 0.10 | 1 | | 11/09/21 17:16 | 16984-48-8 | |
| Sulfate | **87.8** | mg/L | 25.0 | 100 | | 11/09/21 17:31 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7429-90-5 | |
| Barium | **72.0** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-39-3 | |
| Boron | **231** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-43-9 | |
| Calcium | **95000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-47-3 | |
| Iron | **2280** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7439-92-1 | |
| Lithium | **23.4** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7439-93-2 | |
| Magnesium | **21800** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7439-95-4 | |
| Manganese | **227** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7439-96-5 | |
| Molybdenum | **33.6** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7439-98-7 | |
| Potassium | **5690** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-09-7 | |
| Silica | **13300** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7631-86-9 | N2 |
| Sodium | **93600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:17 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **229** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:03 | 7439-96-5 | |
| Molybdenum, Dissolved | **33.7** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:03 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:17 | 7440-36-0 | |
| Arsenic | **3.4** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:17 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:17 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:17 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **259** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **259** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **616** | mg/L | 10.0 | 1 | | 11/09/21 09:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-1D** **Lab ID: 50302027002** Collected: 11/03/21 11:05 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 15:22 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 17:35 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:35 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.28** | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:26 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 11/13/21 23:17 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.4** | mg/L | 1.0 | 1 | | 11/17/21 02:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15S** **Lab ID: 50302027003** Collected: 11/03/21 15:25 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **53.0** | mg/L | 2.5 | 10 | | 11/09/21 18:04 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 11/09/21 17:47 | 16984-48-8 | |
| Sulfate | **55.7** | mg/L | 2.5 | 10 | | 11/09/21 18:04 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7429-90-5 | |
| Barium | **61.2** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-39-3 | |
| Boron | **111** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-43-9 | |
| Calcium | **117000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7439-93-2 | |
| Magnesium | **30000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7439-98-7 | |
| Potassium | **2130** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-09-7 | |
| Silica | **12700** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7631-86-9 | N2 |
| Sodium | **42800** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:19 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:05 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:05 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:21 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:21 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:21 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:21 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **349** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **349** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **542** | mg/L | 10.0 | 1 | | 11/09/21 09:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15S** **Lab ID: 50302027003** Collected: 11/03/21 15:25 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/09/21 15:41 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **2.8** | mg/L | 0.10 | 1 | | 11/04/21 17:59 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:59 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.17** | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:26 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/13/21 23:27 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/17/21 03:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15I** **Lab ID: 50302027004** Collected: 11/03/21 14:25 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **19.9** | mg/L | 2.5 | 10 | | 11/09/21 18:36 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 11/09/21 18:20 | 16984-48-8 | |
| Sulfate | **39.3** | mg/L | 2.5 | 10 | | 11/09/21 18:36 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7429-90-5 | |
| Barium | **67.9** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-39-3 | |
| Boron | **101** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-43-9 | |
| Calcium | **116000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7439-93-2 | |
| Magnesium | **29900** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7439-95-4 | |
| Manganese | **16.4** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7439-98-7 | |
| Potassium | **1450** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-09-7 | |
| Silica | **13100** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7631-86-9 | N2 |
| Sodium | **13500** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:21 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **16.0** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:07 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:07 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:26 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:26 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:26 | 7440-48-4 | |
| Selenium | **1.0** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:26 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **318** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **318** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **456** | mg/L | 10.0 | 1 | | 11/09/21 09:30 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15I** **Lab ID: 50302027004** Collected: 11/03/21 14:25 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/09/21 15:32 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **9.2** | mg/L | 0.40 | 4 | | 11/04/21 18:15 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.40 | 4 | | 11/04/21 18:15 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:27 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/14/21 00:03 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 11/17/21 03:39 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15D** **Lab ID: 50302027005** Collected: 11/03/21 12:55 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **27.0** | mg/L | 2.5 | 10 | | 11/09/21 20:12 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 11/09/21 19:25 | 16984-48-8 | |
| Sulfate | **61.5** | mg/L | 2.5 | 10 | | 11/09/21 20:12 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7429-90-5 | |
| Barium | **69.2** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-39-3 | |
| Boron | **127** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-43-9 | |
| Calcium | **106000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-47-3 | |
| Iron | **1230** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7439-93-2 | |
| Magnesium | **30700** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7439-95-4 | |
| Manganese | **118** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7439-98-7 | |
| Potassium | **2050** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-09-7 | |
| Silica | **12300** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7631-86-9 | N2 |
| Sodium | **19500** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:24 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **112** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:13 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:13 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:38 | 7440-36-0 | |
| Arsenic | **1.2** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:38 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:38 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:38 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **325** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **325** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **451** | mg/L | 10.0 | 1 | | 11/09/21 09:30 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15D** **Lab ID: 50302027005** Collected: 11/03/21 12:55 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/09/21 15:25 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 17:40 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:40 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:27 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/15/21 14:33 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/17/21 03:58 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 649284
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2991727 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/10/21 16:37 | |
| Fluoride | mg/L | ND | 0.10 | 11/10/21 16:37 | |
| Sulfate | mg/L | ND | 0.25 | 11/10/21 16:37 | |

LABORATORY CONTROL SAMPLE: 2991728

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 91 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.44 | 88 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 93 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991729 2991730

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 27.0 | 12.5 | 12.5 | 38.4 | 38.3 | 91 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.52 | 84 | 85 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 61.5 | 25 | 25 | 86.3 | 86.0 | 99 | 98 | 80-120 | 0 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991731 2991732

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 147 | 125 | 125 | 260 | 261 | 90 | 91 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.18 | 0.5 | 0.5 | 0.60 | 0.61 | 86 | 86 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 25.0 | 25 | 25 | 47.0 | 47.7 | 88 | 91 | 80-120 | 1 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991733 2991734

| Parameter | Units | 50302077001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 33.7 | 12.5 | 12.5 | 45.1 | 45.0 | 91 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.50 | 0.5 | 0.5 | 0.94 | 0.94 | 87 | 87 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 25.8 | 25 | 25 | 49.7 | 50.2 | 95 | 98 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 649047
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2990952 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/16/21 12:10 | |
| Barium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Boron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Cadmium | ug/L | ND | 2.0 | 11/16/21 12:10 | |
| Calcium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Chromium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Iron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Lead | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Lithium | ug/L | ND | 20.0 | 11/16/21 12:10 | |
| Magnesium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Manganese | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Molybdenum | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Potassium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Silica | ug/L | ND | 450 | 11/16/21 12:10 | N2 |
| Sodium | ug/L | ND | 1000 | 11/16/21 12:10 | |

LABORATORY CONTROL SAMPLE: 2990953

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4590 | 92 | 80-120 | |
| Barium | ug/L | 1000 | 966 | 97 | 80-120 | |
| Boron | ug/L | 1000 | 980 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 935 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 5040 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 979 | 98 | 80-120 | |
| Iron | ug/L | 2500 | 2440 | 98 | 80-120 | |
| Lead | ug/L | 1000 | 931 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4800 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 985 | 98 | 80-120 | |
| Molybdenum | ug/L | 1000 | 965 | 97 | 80-120 | |
| Potassium | ug/L | 5000 | 5020 | 100 | 80-120 | |
| Silica | ug/L | 5350 | 5350 | 100 | | N2 |
| Sodium | ug/L | 5000 | 4900 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990954 2990955

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4640 | 4650 | 93 | 93 | 75-125 | 0 | 20 | |
| Barium | ug/L | 69.2 | 1000 | 1000 | 1010 | 1010 | 94 | 94 | 75-125 | 0 | 20 | |
| Boron | ug/L | 127 | 1000 | 1000 | 1120 | 1130 | 99 | 100 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 927 | 930 | 93 | 93 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 106000 | 5000 | 5000 | 108000 | 107000 | 46 | 18 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 947 | 954 | 95 | 95 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1230 | 2500 | 2500 | 3550 | 3550 | 93 | 93 | 75-125 | 0 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 886 | 893 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1010 | 1010 | 100 | 101 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 30700 | 5000 | 5000 | 34600 | 34200 | 78 | 71 | 75-125 | 1 | 20 | P6 |
| Manganese | ug/L | 118 | 1000 | 1000 | 1060 | 1070 | 95 | 96 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 955 | 962 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 2050 | 5000 | 5000 | 6940 | 7010 | 98 | 99 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12300 | 5350 | 5350 | 17200 | 17000 | 93 | 88 | | 2 | | N2 |
| Sodium | ug/L | 19500 | 5000 | 5000 | 23800 | 23500 | 85 | 79 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990956 2990957

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4620 | 4720 | 92 | 94 | 75-125 | 2 | 20 | |
| Barium | ug/L | 221 | 1000 | 1000 | 1150 | 1160 | 93 | 94 | 75-125 | 1 | 20 | |
| Boron | ug/L | 263 | 1000 | 1000 | 1260 | 1280 | 99 | 101 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 919 | 931 | 92 | 93 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 96600 | 5000 | 5000 | 100000 | 102000 | 77 | 113 | 75-125 | 2 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 946 | 958 | 94 | 96 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1670 | 2500 | 2500 | 3950 | 4000 | 91 | 93 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 871 | 881 | 87 | 88 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1000 | 1020 | 99 | 101 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 29300 | 5000 | 5000 | 33600 | 34200 | 86 | 97 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 303 | 1000 | 1000 | 1240 | 1260 | 93 | 96 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 948 | 960 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 7590 | 5000 | 5000 | 12400 | 12500 | 96 | 98 | 75-125 | 1 | 20 | |
| Silica | ug/L | 10900 | 5350 | 5350 | 15900 | 16100 | 94 | 98 | | 1 | | N2 |
| Sodium | ug/L | 73700 | 5000 | 5000 | 77300 | 78000 | 72 | 86 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 649216
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2991499 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |

LABORATORY CONTROL SAMPLE: 2991500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 821 | 82 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 827 | 83 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991501 2991502

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 112 | 1000 | 1000 | 1070 | 1080 | 96 | 96 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 998 | 1010 | 100 | 100 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991503 2991504

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1230 | 1250 | 93 | 95 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 986 | 992 | 98 | 99 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 648753
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2989459 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/09/21 12:03 | |
| Arsenic | ug/L | ND | 1.0 | 11/09/21 12:03 | |
| Cobalt | ug/L | ND | 1.0 | 11/09/21 12:03 | |
| Selenium | ug/L | ND | 1.0 | 11/09/21 12:03 | |

LABORATORY CONTROL SAMPLE: 2989460

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 40.8 | 102 | 80-120 | |
| Arsenic | ug/L | 40 | 38.0 | 95 | 80-120 | |
| Cobalt | ug/L | 40 | 40.0 | 100 | 80-120 | |
| Selenium | ug/L | 40 | 40.8 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989461 2989462

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.0 | 41.8 | 105 | 104 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | 4.3 | 40 | 40 | 41.4 | 41.5 | 93 | 93 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 35.5 | 35.8 | 88 | 89 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.0 | 37.5 | 95 | 94 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989463 2989464

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 41.7 | 41.1 | 104 | 103 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | 1.2 | 40 | 40 | 37.8 | 37.9 | 91 | 92 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 36.5 | 36.4 | 91 | 91 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 37.6 | 37.7 | 94 | 94 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989465 2989466

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 41.7 | 40.9 | 104 | 102 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 36.4 | 36.6 | 91 | 91 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 36.7 | 36.6 | 91 | 91 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 37.3 | 38.4 | 93 | 96 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 649592
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2993294 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/11/21 12:43 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 12:43 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 12:43 | |

LABORATORY CONTROL SAMPLE: 2993295

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.1 | 98 | 90-110 | |

SAMPLE DUPLICATE: 2993296

| Parameter | Units | 50302027005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 325 | 319 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 325 | 319 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2993297

| Parameter | Units | 50302028002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 281 | 291 | 4 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 281 | 291 | 4 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 649251 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2991624 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/09/21 09:28 | |

LABORATORY CONTROL SAMPLE: 2991625

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 280 | 93 | 80-120 | |

SAMPLE DUPLICATE: 2991626

| Parameter | Units | 50302024014 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 396 | 408 | 3 | 10 | |

SAMPLE DUPLICATE: 2991627

| Parameter | Units | 50302027005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 451 | 452 | 0 | 10 | |

SAMPLE DUPLICATE: 2991628

| Parameter | Units | 50302028002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 597 | 604 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 649381
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

SAMPLE DUPLICATE: 2992229

| Parameter | Units | 50302028002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.4 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 2992230

| Parameter | Units | 50302027005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.4 | 7.3 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 2992231

| Parameter | Units | 50302013001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.7 | 6.8 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 648874 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2990102 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 16:39 | |

LABORATORY CONTROL SAMPLE: 2990103

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990104 2990105

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.46 | 0.46 | 92 | 91 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990106 2990107

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.29 | 0.28 | 57 | 54 | 90-110 | 6 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 648707
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2989098 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/04/21 17:07 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/04/21 17:07 | |

LABORATORY CONTROL SAMPLE: 2989099

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 110 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989100 2989101

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.99 | 0.99 | 99 | 99 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 110 | 110 | 90-110 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989102 2989103

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 101 | 101 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 111 | 111 | 90-110 | 0 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 650186 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2996933 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 13:15 | |

LABORATORY CONTROL SAMPLE: 2996934

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996935 2996936

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.39 | | | 1.8 | 1.8 | | | | 3 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996937 2996938

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.6 | 1.5 | | | | 4 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 650225 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004

METHOD BLANK: 2997060 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/13/21 18:12 | |

LABORATORY CONTROL SAMPLE: 2997061

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.3 | 103 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997062 2997063

| Parameter | Units | 50301937002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.4 | 10 | 10 | 10.9 | 11.1 | 95 | 97 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2997065 2997066

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.1 | 10 | 10 | 12.0 | 12.4 | 99 | 103 | 80-120 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 650494
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027005

METHOD BLANK: 2998195 Matrix: Water
Associated Lab Samples: 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/15/21 14:13 | |

LABORATORY CONTROL SAMPLE: 2998196

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998197 2998198

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 10.4 | 10.4 | 100 | 100 | 80-120 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998199 2998200

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.5 | 10 | 10 | 13.6 | 14.0 | 102 | 105 | 80-120 | 3 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998201 2998202

| Parameter | Units | 50302077001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 0.90 | 10 | 10 | 11.2 | 11.0 | 103 | 101 | 80-120 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 650522 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

METHOD BLANK: 2998294 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/16/21 22:54 | |

LABORATORY CONTROL SAMPLE: 2998295

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.6 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998296 2998297

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.1 | 10 | 10 | 12.0 | 11.8 | 99 | 96 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998298 2998299

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 10 | 10.6 | 10.5 | 99 | 98 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998301 2998302

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 3.5 | 10 | 10 | 13.2 | 13.1 | 97 | 96 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-1S** **Lab ID: 50302027001** Collected: 11/03/21 10:05 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0676 ± 0.547 (1.07) C:NA T:86%** | pCi/L | 12/07/21 12:19 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.04 ± 0.566 (1.04) C:69% T:74%** | pCi/L | 12/07/21 11:28 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.11 ± 1.11 (2.11)** | pCi/L | 12/08/21 15:01 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-1D** **Lab ID: 50302027002** Collected: 11/03/21 11:05 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.264 ± 0.485 (0.865) C:NA T:85%** | pCi/L | 12/07/21 12:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.769 ± 0.546 (1.06) C:61% T:75%** | pCi/L | 12/07/21 11:28 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.03 ± 1.03 (1.93)** | pCi/L | 12/08/21 15:01 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15S** **Lab ID: 50302027003** Collected: 11/03/21 15:25 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.488 ± 0.533 (0.838) C:NA T:83%** | pCi/L | 12/07/21 12:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.0506 ± 0.514 (1.18) C:69% T:58%** | pCi/L | 12/07/21 11:28 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.539 ± 1.05 (2.02)** | pCi/L | 12/08/21 15:01 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15I** **Lab ID: 50302027004** Collected: 11/03/21 14:25 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.429 ± 0.446 (0.665) C:NA T:85%** | pCi/L | 12/07/21 12:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.747 ± 0.452 (0.835) C:70% T:74%** | pCi/L | 12/07/21 11:28 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.18 ± 0.898 (1.50)** | pCi/L | 12/08/21 15:01 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15D** **Lab ID: 50302027005** Collected: 11/03/21 12:55 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.373 ± 0.379 (0.574) C:NA T:88%** | pCi/L | 12/07/21 12:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.761 ± 0.509 (0.971) C:75% T:62%** | pCi/L | 12/07/21 11:39 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.13 ± 0.888 (1.55)** | pCi/L | 12/08/21 15:01 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15D MS** **Lab ID: 50302027006** Collected: 11/03/21 12:55 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **92.25 %REC ± NA (NA) C:NA T:NA** | pCi/L | 12/07/21 12:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **99.03 %REC ± NA (NA) C:NA T:NA** | pCi/L | 12/07/21 11:26 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

**Sample: MW-15D MSD** **Lab ID: 50302027007** Collected: 11/03/21 12:55 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **94.75 %REC 2.67 RPD ± NA (NA) C:NA T:NA** | pCi/L | 12/07/21 12:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **82.99 %REC 17.62 RPD ± NA (NA) C:NA T:NA** | pCi/L | 12/07/21 11:50 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 473860 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005, 50302027006, 50302027007

METHOD BLANK: 2289206 Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005, 50302027006, 50302027007

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0506 ± 0.262 (0.608) C:NA T:90% | pCi/L | 12/07/21 12:05 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

QC Batch: 473862
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005, 50302027006, 50302027007

METHOD BLANK: 2289207
Matrix: Water
Associated Lab Samples: 50302027001, 50302027002, 50302027003, 50302027004, 50302027005, 50302027006, 50302027007

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.124 ± 0.291 (0.649) C:66% T:91% | pCi/L | 12/07/21 11:25 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302027001** | **MW-1S** | EPA 9056 | 649284 | | |
| **50302027002** | **MW-1D** | EPA 9056 | 649284 | | |
| **50302027003** | **MW-15S** | EPA 9056 | 649284 | | |
| **50302027004** | **MW-15I** | EPA 9056 | 649284 | | |
| **50302027005** | **MW-15D** | EPA 9056 | 649284 | | |
| **50302027001** | **MW-1S** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302027002** | **MW-1D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302027003** | **MW-15S** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302027004** | **MW-15I** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302027005** | **MW-15D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302027001** | **MW-1S** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302027002** | **MW-1D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302027003** | **MW-15S** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302027004** | **MW-15I** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302027005** | **MW-15D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302027001** | **MW-1S** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302027002** | **MW-1D** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302027003** | **MW-15S** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302027004** | **MW-15I** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302027005** | **MW-15D** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302027001** | **MW-1S** | EPA 903.1 | 473860 | | |
| **50302027002** | **MW-1D** | EPA 903.1 | 473860 | | |
| **50302027003** | **MW-15S** | EPA 903.1 | 473860 | | |
| **50302027004** | **MW-15I** | EPA 903.1 | 473860 | | |
| **50302027005** | **MW-15D** | EPA 903.1 | 473860 | | |
| **50302027006** | **MW-15D MS** | EPA 903.1 | 473860 | | |
| **50302027007** | **MW-15D MSD** | EPA 903.1 | 473860 | | |
| **50302027001** | **MW-1S** | EPA 904.0 | 473862 | | |
| **50302027002** | **MW-1D** | EPA 904.0 | 473862 | | |
| **50302027003** | **MW-15S** | EPA 904.0 | 473862 | | |
| **50302027004** | **MW-15I** | EPA 904.0 | 473862 | | |
| **50302027005** | **MW-15D** | EPA 904.0 | 473862 | | |
| **50302027006** | **MW-15D MS** | EPA 904.0 | 473862 | | |
| **50302027007** | **MW-15D MSD** | EPA 904.0 | 473862 | | |
| **50302027001** | **MW-1S** | Total Radium Calculation | 475485 | | |
| **50302027002** | **MW-1D** | Total Radium Calculation | 475485 | | |
| **50302027003** | **MW-15S** | Total Radium Calculation | 475485 | | |
| **50302027004** | **MW-15I** | Total Radium Calculation | 475485 | | |
| **50302027005** | **MW-15D** | Total Radium Calculation | 475485 | | |
| **50302027001** | **MW-1S** | SM 2320B | 649592 | | |
| **50302027002** | **MW-1D** | SM 2320B | 649592 | | |
| **50302027003** | **MW-15S** | SM 2320B | 649592 | | |
| **50302027004** | **MW-15I** | SM 2320B | 649592 | | |
| **50302027005** | **MW-15D** | SM 2320B | 649592 | | |
| **50302027001** | **MW-1S** | SM 2540C | 649251 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302027

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302027002** | **MW-1D** | SM 2540C | 649251 | | |
| **50302027003** | **MW-15S** | SM 2540C | 649251 | | |
| **50302027004** | **MW-15I** | SM 2540C | 649251 | | |
| **50302027005** | **MW-15D** | SM 2540C | 649251 | | |
| **50302027001** | **MW-1S** | SM 4500-H+B | 649381 | | |
| **50302027002** | **MW-1D** | SM 4500-H+B | 649381 | | |
| **50302027003** | **MW-15S** | SM 4500-H+B | 649381 | | |
| **50302027004** | **MW-15I** | SM 4500-H+B | 649381 | | |
| **50302027005** | **MW-15D** | SM 4500-H+B | 649381 | | |
| **50302027001** | **MW-1S** | SM 4500-S2-D | 648874 | | |
| **50302027002** | **MW-1D** | SM 4500-S2-D | 648874 | | |
| **50302027003** | **MW-15S** | SM 4500-S2-D | 648874 | | |
| **50302027004** | **MW-15I** | SM 4500-S2-D | 648874 | | |
| **50302027005** | **MW-15D** | SM 4500-S2-D | 648874 | | |
| **50302027001** | **MW-1S** | EPA 353.2 | 648707 | | |
| **50302027002** | **MW-1D** | EPA 353.2 | 648707 | | |
| **50302027003** | **MW-15S** | EPA 353.2 | 648707 | | |
| **50302027004** | **MW-15I** | EPA 353.2 | 648707 | | |
| **50302027005** | **MW-15D** | EPA 353.2 | 648707 | | |
| **50302027001** | **MW-1S** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302027002** | **MW-1D** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302027003** | **MW-15S** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302027004** | **MW-15I** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302027005** | **MW-15D** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302027001** | **MW-1S** | SM 5310C | 650225 | | |
| **50302027002** | **MW-1D** | SM 5310C | 650225 | | |
| **50302027003** | **MW-15S** | SM 5310C | 650225 | | |
| **50302027004** | **MW-15I** | SM 5310C | 650225 | | |
| **50302027005** | **MW-15D** | SM 5310C | 650494 | | |
| **50302027001** | **MW-1S** | SM 5310C | 650522 | | |
| **50302027002** | **MW-1D** | SM 5310C | 650522 | | |
| **50302027003** | **MW-15S** | SM 5310C | 650522 | | |
| **50302027004** | **MW-15I** | SM 5310C | 650522 | | |
| **50302027005** | **MW-15D** | SM 5310C | 650522 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Do

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must

WO# : 50302027

50302027

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| Indianapolis, IN 46256 | | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: NONE | Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

| Regulatory Agency |
|---|
| |
| State / Location |
| IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | | | | |
| 1 | MW-1S | WT | | | | 11-3-21 | 10:05 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | UD1 |
| 2 | MW-1D | WT | | | | 11-3-21 | 11:05 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | UD2 |
| 3 | MW-2S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 4 | MW-2D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 5 | MW-3S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 6 | MW-3D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 7 | MW-4S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 8 | MW-5S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 9 | MW-6S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 10 | MW-7S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 11 | MW-7D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |
| 12 | MW-8S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jagkowiak | 11-4-21 | 7:50 | | 11/4/21 | 1425 | | | | |
| 6020 (Co, As, Se, Sb) | | 11/4/21 | 1450 | | 11/4/21 | 1450 | Sol | 4 | 4 | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | Sew | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | 3.1 | 6.4 | 6.7 | 6.6 |

| SAMPLER NAME AND SIGNATURE | | | |
|---|---|---|---|
| PRINT Name of SAMPLER: | Andy Jagkowiak | TEMP in C | 2.6 |
| SIGNATURE of SAMPLER: | | Received on Ice (Y/N) | |
| DATE Signed: | 11-4-21 | Custody Sealed Cooler (Y/N) | |
| | | Samples Intact (Y/N) | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| Indianapolis, IN 46256 | | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

| Regulatory Agency | |
|---|---|
| | |
| State / Location | |
| | IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | Y/N | | | | Y | | | | | Y | | | | |
| 25 | MW-15S | WT | | | | 11-3-21 | 15:25 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | 003 |
| 26 | MW-15I | WT | | | | 11-3-21 | 14:25 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | 004 |
| 27 | MW-15D | WT | | | | 11-3-21 | 12:55 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | 005, 006, 007 |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 30 | Field Blank 1 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | X | | |
| 31 | MS1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 32 | MSD1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 33 | MS2 | WT | | | | 11-3-21 | 12:55 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 34 | MSD2 | WT | | | | 11-3-21 | 12:55 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jashovich | 11-4-21 | 7:50 | [illegible] Pace | 11/4/21 | 1425 |
| 6020 (Co, As, Se, Sb) | [illegible] Pace | 11/4/21 | 1450 | Bailey [illegible] | 11/4/21 | 1450 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| Sol Sew | Y | Y | |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: Andy Jashovich

SIGNATURE of SAMPLER: [signature] DATE Signed: 11-4-21

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** WS 4/4/21 1530

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature:** 3.4/3.1, 1.2/0.4, 1.2/0.4, 0.8/0.0, 3.4/2.0

Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** ~~HNO3 (<2)~~ ~~H2SO4 (<2)~~ NaOH (>10) ~~NaOH/ZnAc (>9)~~ ~~Any non-conformance~~ to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** $NH_3/NO_3$ | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1615 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

**COC PAGE** 1 **of** 1

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE ____ of ____**

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 3 | | | | | | | | | | | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | ↓ | ↓ | ↓ | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

## Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

## Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 15, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50302028001** | **MW-103S** | Water | 11/03/21 09:45 | 11/04/21 14:50 |
| **50302028002** | **MW-103I** | Water | 11/03/21 11:00 | 11/04/21 14:50 |
| **50302028003** | **MW-103I MS** | Water | 11/03/21 11:00 | 11/04/21 14:50 |
| **50302028004** | **MW-103I MSD** | Water | 11/03/21 11:00 | 11/04/21 14:50 |
| **50302028005** | **MW-106S** | Water | 11/03/21 13:46 | 11/04/21 14:50 |
| **50302028006** | **MW-106I** | Water | 11/03/21 11:51 | 11/04/21 14:50 |
| **50302028007** | **MW-106D** | Water | 11/03/21 10:12 | 11/04/21 14:50 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50302028001** | **MW-103S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302028002** | **MW-103I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302028003** | **MW-103I MS** | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50302028004** | **MW-103I MSD** | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50302028005** | **MW-106S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302028006** | **MW-106I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302028007** | **MW-106D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302028001** | **MW-103S** | | | | | |
| EPA 9056 | Chloride | 65.2 | mg/L | 2.5 | 11/09/21 22:37 | |
| EPA 9056 | Fluoride | 0.17 | mg/L | 0.10 | 11/09/21 22:22 | |
| EPA 9056 | Sulfate | 356 | mg/L | 25.0 | 11/09/21 22:53 | |
| EPA 6010 | Barium | 63.7 | ug/L | 10.0 | 11/16/21 12:38 | |
| EPA 6010 | Boron | 845 | ug/L | 100 | 11/16/21 12:38 | |
| EPA 6010 | Calcium | 268000 | ug/L | 2000 | 11/16/21 14:09 | |
| EPA 6010 | Iron | 11800 | ug/L | 100 | 11/16/21 12:38 | |
| EPA 6010 | Magnesium | 77200 | ug/L | 1000 | 11/16/21 12:38 | |
| EPA 6010 | Manganese | 334 | ug/L | 10.0 | 11/16/21 12:38 | |
| EPA 6010 | Molybdenum | 17.3 | ug/L | 10.0 | 11/16/21 12:38 | |
| EPA 6010 | Potassium | 2520 | ug/L | 1000 | 11/16/21 12:38 | |
| EPA 6010 | Silica | 24100 | ug/L | 450 | 11/16/21 12:38 | N2 |
| EPA 6010 | Sodium | 49600 | ug/L | 1000 | 11/16/21 12:38 | |
| EPA 6010 | Manganese, Dissolved | 327 | ug/L | 10.0 | 11/16/21 03:23 | |
| EPA 6010 | Molybdenum, Dissolved | 17.3 | ug/L | 10.0 | 11/16/21 03:23 | |
| EPA 6020 | Arsenic | 14.5 | ug/L | 1.0 | 11/09/21 13:50 | |
| EPA 6020 | Cobalt | 2.7 | ug/L | 1.0 | 11/09/21 13:50 | |
| EPA 903.1 | Radium-226 | 0.0114 ± 0.367 (0.737) C:NA T:99% | pCi/L | | 12/06/21 15:55 | |
| EPA 904.0 | Radium-228 | 1.12 ± 0.546 (0.964) C:74% T:74% | pCi/L | | 12/06/21 11:43 | |
| Total Radium Calculation | Total Radium | 1.13 ± 0.913 (1.70) | pCi/L | | 12/08/21 13:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 605 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 605 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 1280 | mg/L | 20.0 | 11/09/21 09:30 | |
| SM 4500-H+B | pH at 25 Degrees C | 6.8 | Std. Units | 0.10 | 11/09/21 15:03 | H3 |
| SM 5310C | Total Organic Carbon | 5.3 | mg/L | 1.0 | 11/15/21 15:04 | |
| SM 5310C | Dissolved Organic Carbon | 5.6 | mg/L | 1.0 | 11/17/21 05:41 | |
| **50302028002** | **MW-103I** | | | | | |
| EPA 9056 | Chloride | 147 | mg/L | 25.0 | 11/09/21 23:42 | |
| EPA 9056 | Fluoride | 0.18 | mg/L | 0.10 | 11/09/21 23:09 | |
| EPA 9056 | Sulfate | 25.0 | mg/L | 2.5 | 11/09/21 23:26 | |
| EPA 6010 | Barium | 221 | ug/L | 10.0 | 11/16/21 12:41 | |
| EPA 6010 | Boron | 263 | ug/L | 100 | 11/16/21 12:41 | |
| EPA 6010 | Calcium | 96600 | ug/L | 1000 | 11/16/21 12:41 | |
| EPA 6010 | Iron | 1670 | ug/L | 100 | 11/16/21 12:41 | |
| EPA 6010 | Magnesium | 29300 | ug/L | 1000 | 11/16/21 12:41 | |
| EPA 6010 | Manganese | 303 | ug/L | 10.0 | 11/16/21 12:41 | |
| EPA 6010 | Potassium | 7590 | ug/L | 1000 | 11/16/21 12:41 | |
| EPA 6010 | Silica | 10900 | ug/L | 450 | 11/16/21 12:41 | N2 |
| EPA 6010 | Sodium | 73700 | ug/L | 1000 | 11/16/21 12:41 | |
| EPA 6010 | Manganese, Dissolved | 300 | ug/L | 10.0 | 11/16/21 03:25 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302028002** | **MW-103I** | | | | | |
| EPA 903.1 | Radium-226 | 1.20 ± 0.536 (0.547) C:NA T:93% | pCi/L | | 12/06/21 15:55 | |
| EPA 904.0 | Radium-228 | 0.935 ± 0.488 (0.874) C:73% T:76% | pCi/L | | 12/06/21 11:43 | |
| Total Radium Calculation | Total Radium | 2.14 ± 1.02 (1.42) | pCi/L | | 12/08/21 13:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 281 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 281 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 597 | mg/L | 10.0 | 11/09/21 09:30 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/09/21 15:16 | H3 |
| SM 5310C | Total Organic Carbon | 3.5 | mg/L | 1.0 | 11/15/21 15:15 | |
| SM 5310C | Dissolved Organic Carbon | 3.5 | mg/L | 1.0 | 11/17/21 06:01 | |
| **50302028003** | **MW-103I MS** | | | | | |
| EPA 903.1 | Radium-226 | 99.20 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 12/06/21 16:11 | |
| EPA 904.0 | Radium-228 | 118.12 %REC ± NA (NA) C:NA T:NA | pCi/L | | 12/06/21 11:43 | |
| **50302028004** | **MW-103I MSD** | | | | | |
| EPA 903.1 | Radium-226 | 76.26 %REC 26.15 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 12/06/21 16:11 | |
| EPA 904.0 | Radium-228 | 103.57 %REC 13.13 RPD ± NA (NA) C:NA T:NA | pCi/L | | 12/06/21 11:43 | |
| **50302028005** | **MW-106S** | | | | | |
| EPA 9056 | Chloride | 23.5 | mg/L | 2.5 | 11/10/21 00:14 | |
| EPA 9056 | Fluoride | 0.38 | mg/L | 0.10 | 11/09/21 23:58 | |
| EPA 9056 | Sulfate | 947 | mg/L | 25.0 | 11/10/21 00:29 | |
| EPA 6010 | Barium | 25.8 | ug/L | 10.0 | 11/16/21 12:47 | |
| EPA 6010 | Boron | 548 | ug/L | 100 | 11/16/21 12:47 | |
| EPA 6010 | Calcium | 289000 | ug/L | 2000 | 11/16/21 14:16 | |
| EPA 6010 | Iron | 1130 | ug/L | 100 | 11/16/21 12:47 | |
| EPA 6010 | Lithium | 33.2 | ug/L | 20.0 | 11/16/21 12:47 | |
| EPA 6010 | Magnesium | 111000 | ug/L | 1000 | 11/16/21 12:47 | |
| EPA 6010 | Manganese | 976 | ug/L | 10.0 | 11/16/21 12:47 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302028005** | **MW-106S** | | | | | |
| EPA 6010 | Molybdenum | 23.2 | ug/L | 10.0 | 11/16/21 12:47 | |
| EPA 6010 | Potassium | 7460 | ug/L | 1000 | 11/16/21 12:47 | |
| EPA 6010 | Silica | 9430 | ug/L | 450 | 11/16/21 12:47 | N2 |
| EPA 6010 | Sodium | 24700 | ug/L | 1000 | 11/16/21 12:47 | |
| EPA 6010 | Manganese, Dissolved | 935 | ug/L | 10.0 | 11/16/21 03:31 | |
| EPA 6010 | Molybdenum, Dissolved | 23.2 | ug/L | 10.0 | 11/16/21 03:31 | |
| EPA 6020 | Arsenic | 3.2 | ug/L | 1.0 | 11/09/21 14:15 | |
| EPA 6020 | Cobalt | 1.1 | ug/L | 1.0 | 11/09/21 14:15 | |
| EPA 903.1 | Radium-226 | 0.337 ± 0.301 (0.386) C:NA T:98% | pCi/L | | 12/06/21 16:11 | |
| EPA 904.0 | Radium-228 | 0.415 ± 0.488 (1.04) C:67% T:84% | pCi/L | | 12/06/21 11:37 | |
| Total Radium Calculation | Total Radium | 0.752 ± 0.789 (1.43) | pCi/L | | 12/08/21 13:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 204 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 204 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 1670 | mg/L | 20.0 | 11/09/21 09:31 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 15:30 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.57 | mg/L | 0.10 | 11/04/21 17:51 | |
| **50302028006** | **MW-106I** | | | | | |
| EPA 9056 | Chloride | 258 | mg/L | 25.0 | 11/10/21 01:34 | |
| EPA 9056 | Fluoride | 0.30 | mg/L | 0.10 | 11/10/21 01:18 | |
| EPA 9056 | Sulfate | 691 | mg/L | 25.0 | 11/10/21 01:34 | |
| EPA 6010 | Aluminum | 291 | ug/L | 200 | 11/16/21 12:49 | |
| EPA 6010 | Barium | 68.6 | ug/L | 10.0 | 11/16/21 12:49 | |
| EPA 6010 | Boron | 12900 | ug/L | 100 | 11/16/21 12:49 | |
| EPA 6010 | Calcium | 253000 | ug/L | 2000 | 11/16/21 14:18 | |
| EPA 6010 | Iron | 7240 | ug/L | 100 | 11/16/21 12:49 | |
| EPA 6010 | Lithium | 98.3 | ug/L | 20.0 | 11/16/21 12:49 | |
| EPA 6010 | Magnesium | 55100 | ug/L | 1000 | 11/16/21 12:49 | |
| EPA 6010 | Manganese | 500 | ug/L | 10.0 | 11/16/21 12:49 | |
| EPA 6010 | Molybdenum | 292 | ug/L | 10.0 | 11/16/21 12:49 | |
| EPA 6010 | Potassium | 15100 | ug/L | 1000 | 11/16/21 12:49 | |
| EPA 6010 | Silica | 15600 | ug/L | 450 | 11/16/21 12:49 | N2 |
| EPA 6010 | Sodium | 212000 | ug/L | 2000 | 11/16/21 14:18 | |
| EPA 6010 | Manganese, Dissolved | 484 | ug/L | 10.0 | 11/16/21 03:37 | |
| EPA 6010 | Molybdenum, Dissolved | 298 | ug/L | 10.0 | 11/16/21 03:37 | |
| EPA 6020 | Arsenic | 92.6 | ug/L | 1.0 | 11/09/21 14:19 | |
| EPA 903.1 | Radium-226 | 0.191 ± 0.370 (0.646) C:NA T:95% | pCi/L | | 12/06/21 16:11 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302028006** | **MW-106I** | | | | | |
| EPA 904.0 | Radium-228 | 0.890 ± 0.515 (0.979) C:75% T:83% | pCi/L | | 12/06/21 11:37 | |
| Total Radium Calculation | Total Radium | 1.08 ± 0.885 (1.63) | pCi/L | | 12/08/21 13:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 236 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 236 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 1680 | mg/L | 20.0 | 11/09/21 09:31 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 11/09/21 15:23 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.81 | mg/L | 0.15 | 11/17/21 13:32 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/15/21 16:31 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 11/17/21 07:20 | |
| **50302028007** | **MW-106D** | | | | | |
| EPA 9056 | Chloride | 283 | mg/L | 25.0 | 11/10/21 02:07 | |
| EPA 9056 | Fluoride | 0.24 | mg/L | 0.10 | 11/10/21 01:50 | |
| EPA 9056 | Sulfate | 723 | mg/L | 25.0 | 11/10/21 02:07 | |
| EPA 6010 | Barium | 32.5 | ug/L | 10.0 | 11/16/21 12:56 | |
| EPA 6010 | Boron | 14700 | ug/L | 100 | 11/16/21 12:56 | |
| EPA 6010 | Calcium | 271000 | ug/L | 2000 | 11/16/21 14:20 | |
| EPA 6010 | Iron | 3860 | ug/L | 100 | 11/16/21 12:56 | |
| EPA 6010 | Lithium | 121 | ug/L | 20.0 | 11/16/21 12:56 | |
| EPA 6010 | Magnesium | 54100 | ug/L | 1000 | 11/16/21 12:56 | |
| EPA 6010 | Manganese | 272 | ug/L | 10.0 | 11/16/21 12:56 | |
| EPA 6010 | Molybdenum | 262 | ug/L | 10.0 | 11/16/21 12:56 | |
| EPA 6010 | Potassium | 14800 | ug/L | 1000 | 11/16/21 12:56 | |
| EPA 6010 | Silica | 14600 | ug/L | 450 | 11/16/21 12:56 | N2 |
| EPA 6010 | Sodium | 218000 | ug/L | 2000 | 11/16/21 14:20 | |
| EPA 6010 | Manganese, Dissolved | 260 | ug/L | 10.0 | 11/16/21 03:39 | |
| EPA 6010 | Molybdenum, Dissolved | 270 | ug/L | 10.0 | 11/16/21 03:39 | |
| EPA 6020 | Arsenic | 227 | ug/L | 2.0 | 11/09/21 22:23 | |
| EPA 903.1 | Radium-226 | 1.02 ± 0.725 (0.997) C:NA T:96% | pCi/L | | 12/06/21 16:11 | |
| EPA 904.0 | Radium-228 | 0.227 ± 0.496 (1.09) C:69% T:90% | pCi/L | | 12/06/21 11:37 | |
| Total Radium Calculation | Total Radium | 1.25 ± 1.22 (2.09) | pCi/L | | 12/08/21 13:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 214 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 214 | mg/L | 2.0 | 11/11/21 12:43 | |
| SM 2540C | Total Dissolved Solids | 1790 | mg/L | 40.0 | 11/09/21 09:32 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 11/09/21 15:06 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.13 | mg/L | 0.10 | 11/04/21 17:20 | |
| EPA 365.1 | Phosphate as P04 | 0.78 | mg/L | 0.15 | 11/17/21 13:32 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302028007** | **MW-106D** | | | | | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/15/21 16:44 | |
| SM 5310C | Dissolved Organic Carbon | 2.8 | mg/L | 1.0 | 11/17/21 07:41 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103S** **Lab ID: 50302028001** Collected: 11/03/21 09:45 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **65.2** | mg/L | 2.5 | 10 | | 11/09/21 22:37 | 16887-00-6 | |
| Fluoride | **0.17** | mg/L | 0.10 | 1 | | 11/09/21 22:22 | 16984-48-8 | |
| Sulfate | **356** | mg/L | 25.0 | 100 | | 11/09/21 22:53 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7429-90-5 | |
| Barium | **63.7** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7440-39-3 | |
| Boron | **845** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7440-43-9 | |
| Calcium | **268000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:09 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7440-47-3 | |
| Iron | **11800** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7439-93-2 | |
| Magnesium | **77200** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7439-95-4 | |
| Manganese | **334** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7439-96-5 | |
| Molybdenum | **17.3** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7439-98-7 | |
| Potassium | **2520** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7440-09-7 | |
| Silica | **24100** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7631-86-9 | N2 |
| Sodium | **49600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:38 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **327** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:23 | 7439-96-5 | |
| Molybdenum, Dissolved | **17.3** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:23 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:50 | 7440-36-0 | |
| Arsenic | **14.5** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:50 | 7440-38-2 | |
| Cobalt | **2.7** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:50 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:50 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **605** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **605** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1280** | mg/L | 20.0 | 1 | | 11/09/21 09:30 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103S** **Lab ID: 50302028001** Collected: 11/03/21 09:45 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **6.8** | Std. Units | 0.10 | 1 | | 11/09/21 15:03 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 17:16 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:16 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:37 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **5.3** | mg/L | 1.0 | 1 | | 11/15/21 15:04 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **5.6** | mg/L | 1.0 | 1 | | 11/17/21 05:41 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103I** **Lab ID: 50302028002** Collected: 11/03/21 11:00 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **147** | mg/L | 25.0 | 100 | | 11/09/21 23:42 | 16887-00-6 | |
| Fluoride | **0.18** | mg/L | 0.10 | 1 | | 11/09/21 23:09 | 16984-48-8 | |
| Sulfate | **25.0** | mg/L | 2.5 | 10 | | 11/09/21 23:26 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7429-90-5 | |
| Barium | **221** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-39-3 | |
| Boron | **263** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-43-9 | |
| Calcium | **96600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-47-3 | |
| Iron | **1670** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7439-93-2 | |
| Magnesium | **29300** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7439-95-4 | |
| Manganese | **303** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7439-98-7 | |
| Potassium | **7590** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-09-7 | |
| Silica | **10900** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7631-86-9 | N2 |
| Sodium | **73700** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:41 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **300** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:25 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:25 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:54 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:54 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:54 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 13:54 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **281** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **281** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **597** | mg/L | 10.0 | 1 | | 11/09/21 09:30 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103I** **Lab ID: 50302028002** Collected: 11/03/21 11:00 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/09/21 15:16 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 17:29 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:29 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 14:02 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **3.5** | mg/L | 1.0 | 1 | | 11/15/21 15:15 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.5** | mg/L | 1.0 | 1 | | 11/17/21 06:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106S** **Lab ID: 50302028005** Collected: 11/03/21 13:46 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **23.5** | mg/L | 2.5 | 10 | | 11/10/21 00:14 | 16887-00-6 | |
| Fluoride | **0.38** | mg/L | 0.10 | 1 | | 11/09/21 23:58 | 16984-48-8 | |
| Sulfate | **947** | mg/L | 25.0 | 100 | | 11/10/21 00:29 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7429-90-5 | |
| Barium | **25.8** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7440-39-3 | |
| Boron | **548** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7440-43-9 | |
| Calcium | **289000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:16 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7440-47-3 | |
| Iron | **1130** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7439-92-1 | |
| Lithium | **33.2** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7439-93-2 | |
| Magnesium | **111000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7439-95-4 | |
| Manganese | **976** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7439-96-5 | |
| Molybdenum | **23.2** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7439-98-7 | |
| Potassium | **7460** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7440-09-7 | |
| Silica | **9430** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7631-86-9 | N2 |
| Sodium | **24700** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:47 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **935** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:31 | 7439-96-5 | |
| Molybdenum, Dissolved | **23.2** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:31 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:15 | 7440-36-0 | |
| Arsenic | **3.2** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:15 | 7440-38-2 | |
| Cobalt | **1.1** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:15 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:15 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **204** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **204** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1670** | mg/L | 20.0 | 1 | | 11/09/21 09:31 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106S** **Lab ID: 50302028005** Collected: 11/03/21 13:46 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 15:30 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.57** | mg/L | 0.10 | 1 | | 11/04/21 17:51 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:51 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:31 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/15/21 15:59 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/17/21 07:00 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106I** **Lab ID: 50302028006** Collected: 11/03/21 11:51 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **258** | mg/L | 25.0 | 100 | | 11/10/21 01:34 | 16887-00-6 | |
| Fluoride | **0.30** | mg/L | 0.10 | 1 | | 11/10/21 01:18 | 16984-48-8 | |
| Sulfate | **691** | mg/L | 25.0 | 100 | | 11/10/21 01:34 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **291** | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7429-90-5 | |
| Barium | **68.6** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7440-39-3 | |
| Boron | **12900** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7440-43-9 | |
| Calcium | **253000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:18 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7440-47-3 | |
| Iron | **7240** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7439-92-1 | |
| Lithium | **98.3** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7439-93-2 | |
| Magnesium | **55100** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7439-95-4 | |
| Manganese | **500** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7439-96-5 | |
| Molybdenum | **292** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7439-98-7 | |
| Potassium | **15100** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7440-09-7 | |
| Silica | **15600** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:49 | 7631-86-9 | N2 |
| Sodium | **212000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:18 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **484** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:37 | 7439-96-5 | |
| Molybdenum, Dissolved | **298** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:37 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:19 | 7440-36-0 | |
| Arsenic | **92.6** | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:19 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:19 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:19 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **236** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **236** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1680** | mg/L | 20.0 | 1 | | 11/09/21 09:31 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106I** **Lab ID: 50302028006** Collected: 11/03/21 11:51 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 11/09/21 15:23 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/04/21 17:36 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:36 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.81** | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:32 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/15/21 16:31 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 11/17/21 07:20 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106D** **Lab ID: 50302028007** Collected: 11/03/21 10:12 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **283** | mg/L | 25.0 | 100 | | 11/10/21 02:07 | 16887-00-6 | |
| Fluoride | **0.24** | mg/L | 0.10 | 1 | | 11/10/21 01:50 | 16984-48-8 | |
| Sulfate | **723** | mg/L | 25.0 | 100 | | 11/10/21 02:07 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7429-90-5 | |
| Barium | **32.5** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7440-39-3 | |
| Boron | **14700** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7440-43-9 | |
| Calcium | **271000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:20 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7440-47-3 | |
| Iron | **3860** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7439-92-1 | |
| Lithium | **121** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7439-93-2 | |
| Magnesium | **54100** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7439-95-4 | |
| Manganese | **272** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7439-96-5 | |
| Molybdenum | **262** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7439-98-7 | |
| Potassium | **14800** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7440-09-7 | |
| Silica | **14600** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:56 | 7631-86-9 | N2 |
| Sodium | **218000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:20 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **260** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:39 | 7439-96-5 | |
| Molybdenum, Dissolved | **270** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:39 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:23 | 7440-36-0 | |
| Arsenic | **227** | ug/L | 2.0 | 2 | 11/05/21 08:44 | 11/09/21 22:23 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:23 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/05/21 08:44 | 11/09/21 14:23 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **214** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Bicarbonate (CaCO3) | **214** | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 12:43 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1790** | mg/L | 40.0 | 1 | | 11/09/21 09:32 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106D** **Lab ID: 50302028007** Collected: 11/03/21 10:12 Received: 11/04/21 14:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 11/09/21 15:06 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 16:39 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.13** | mg/L | 0.10 | 1 | | 11/04/21 17:20 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/04/21 17:20 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.78** | mg/L | 0.15 | 1 | 11/13/21 05:00 | 11/17/21 13:32 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/15/21 16:44 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.8** | mg/L | 1.0 | 1 | | 11/17/21 07:41 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 649284
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2991727 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/10/21 16:37 | |
| Fluoride | mg/L | ND | 0.10 | 11/10/21 16:37 | |
| Sulfate | mg/L | ND | 0.25 | 11/10/21 16:37 | |

LABORATORY CONTROL SAMPLE: 2991728

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 91 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.44 | 88 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 93 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991729 2991730

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 27.0 | 12.5 | 12.5 | 38.4 | 38.3 | 91 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.52 | 84 | 85 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 61.5 | 25 | 25 | 86.3 | 86.0 | 99 | 98 | 80-120 | 0 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991731 2991732

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 147 | 125 | 125 | 260 | 261 | 90 | 91 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.18 | 0.5 | 0.5 | 0.60 | 0.61 | 86 | 86 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 25.0 | 25 | 25 | 47.0 | 47.7 | 88 | 91 | 80-120 | 1 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991733 2991734

| Parameter | Units | 50302077001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 33.7 | 12.5 | 12.5 | 45.1 | 45.0 | 91 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.50 | 0.5 | 0.5 | 0.94 | 0.94 | 87 | 87 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 25.8 | 25 | 25 | 49.7 | 50.2 | 95 | 98 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 649047
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2990952 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/16/21 12:10 | |
| Barium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Boron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Cadmium | ug/L | ND | 2.0 | 11/16/21 12:10 | |
| Calcium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Chromium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Iron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Lead | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Lithium | ug/L | ND | 20.0 | 11/16/21 12:10 | |
| Magnesium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Manganese | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Molybdenum | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Potassium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Silica | ug/L | ND | 450 | 11/16/21 12:10 | N2 |
| Sodium | ug/L | ND | 1000 | 11/16/21 12:10 | |

LABORATORY CONTROL SAMPLE: 2990953

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4590 | 92 | 80-120 | |
| Barium | ug/L | 1000 | 966 | 97 | 80-120 | |
| Boron | ug/L | 1000 | 980 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 935 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 5040 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 979 | 98 | 80-120 | |
| Iron | ug/L | 2500 | 2440 | 98 | 80-120 | |
| Lead | ug/L | 1000 | 931 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4800 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 985 | 98 | 80-120 | |
| Molybdenum | ug/L | 1000 | 965 | 97 | 80-120 | |
| Potassium | ug/L | 5000 | 5020 | 100 | 80-120 | |
| Silica | ug/L | 5350 | 5350 | 100 | | N2 |
| Sodium | ug/L | 5000 | 4900 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990954 2990955

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4640 | 4650 | 93 | 93 | 75-125 | 0 | 20 | |
| Barium | ug/L | 69.2 | 1000 | 1000 | 1010 | 1010 | 94 | 94 | 75-125 | 0 | 20 | |
| Boron | ug/L | 127 | 1000 | 1000 | 1120 | 1130 | 99 | 100 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 927 | 930 | 93 | 93 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 106000 | 5000 | 5000 | 108000 | 107000 | 46 | 18 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 947 | 954 | 95 | 95 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1230 | 2500 | 2500 | 3550 | 3550 | 93 | 93 | 75-125 | 0 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 886 | 893 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1010 | 1010 | 100 | 101 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 30700 | 5000 | 5000 | 34600 | 34200 | 78 | 71 | 75-125 | 1 | 20 | P6 |
| Manganese | ug/L | 118 | 1000 | 1000 | 1060 | 1070 | 95 | 96 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 955 | 962 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 2050 | 5000 | 5000 | 6940 | 7010 | 98 | 99 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12300 | 5350 | 5350 | 17200 | 17000 | 93 | 88 | | 2 | | N2 |
| Sodium | ug/L | 19500 | 5000 | 5000 | 23800 | 23500 | 85 | 79 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990956 2990957

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4620 | 4720 | 92 | 94 | 75-125 | 2 | 20 | |
| Barium | ug/L | 221 | 1000 | 1000 | 1150 | 1160 | 93 | 94 | 75-125 | 1 | 20 | |
| Boron | ug/L | 263 | 1000 | 1000 | 1260 | 1280 | 99 | 101 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 919 | 931 | 92 | 93 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 96600 | 5000 | 5000 | 100000 | 102000 | 77 | 113 | 75-125 | 2 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 946 | 958 | 94 | 96 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1670 | 2500 | 2500 | 3950 | 4000 | 91 | 93 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 871 | 881 | 87 | 88 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1000 | 1020 | 99 | 101 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 29300 | 5000 | 5000 | 33600 | 34200 | 86 | 97 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 303 | 1000 | 1000 | 1240 | 1260 | 93 | 96 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 948 | 960 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 7590 | 5000 | 5000 | 12400 | 12500 | 96 | 98 | 75-125 | 1 | 20 | |
| Silica | ug/L | 10900 | 5350 | 5350 | 15900 | 16100 | 94 | 98 | | 1 | | N2 |
| Sodium | ug/L | 73700 | 5000 | 5000 | 77300 | 78000 | 72 | 86 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 649216
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2991499 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |

LABORATORY CONTROL SAMPLE: 2991500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 821 | 82 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 827 | 83 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991501 2991502

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 112 | 1000 | 1000 | 1070 | 1080 | 96 | 96 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 998 | 1010 | 100 | 100 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991503 2991504

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1230 | 1250 | 93 | 95 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 986 | 992 | 98 | 99 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 648753
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2989459 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/09/21 12:03 | |
| Arsenic | ug/L | ND | 1.0 | 11/09/21 12:03 | |
| Cobalt | ug/L | ND | 1.0 | 11/09/21 12:03 | |
| Selenium | ug/L | ND | 1.0 | 11/09/21 12:03 | |

LABORATORY CONTROL SAMPLE: 2989460

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 40.8 | 102 | 80-120 | |
| Arsenic | ug/L | 40 | 38.0 | 95 | 80-120 | |
| Cobalt | ug/L | 40 | 40.0 | 100 | 80-120 | |
| Selenium | ug/L | 40 | 40.8 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989461 2989462

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.0 | 41.8 | 105 | 104 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | 4.3 | 40 | 40 | 41.4 | 41.5 | 93 | 93 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 35.5 | 35.8 | 88 | 89 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.0 | 37.5 | 95 | 94 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989463 2989464

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 41.7 | 41.1 | 104 | 103 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | 1.2 | 40 | 40 | 37.8 | 37.9 | 91 | 92 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 36.5 | 36.4 | 91 | 91 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 37.6 | 37.7 | 94 | 94 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989465 2989466

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 41.7 | 40.9 | 104 | 102 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 36.4 | 36.6 | 91 | 91 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 36.7 | 36.6 | 91 | 91 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 37.3 | 38.4 | 93 | 96 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 649592 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2993294 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/11/21 12:43 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 12:43 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 12:43 | |

LABORATORY CONTROL SAMPLE: 2993295

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.1 | 98 | 90-110 | |

SAMPLE DUPLICATE: 2993296

| Parameter | Units | 50302027005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 325 | 319 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 325 | 319 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2993297

| Parameter | Units | 50302028002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 281 | 291 | 4 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 281 | 291 | 4 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 649251 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2991624 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/09/21 09:28 | |

LABORATORY CONTROL SAMPLE: 2991625

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 280 | 93 | 80-120 | |

SAMPLE DUPLICATE: 2991626

| Parameter | Units | 50302024014 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 396 | 408 | 3 | 10 | |

SAMPLE DUPLICATE: 2991627

| Parameter | Units | 50302027005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 451 | 452 | 0 | 10 | |

SAMPLE DUPLICATE: 2991628

| Parameter | Units | 50302028002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 597 | 604 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 649381
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

SAMPLE DUPLICATE: 2992229

| Parameter | Units | 50302028002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.4 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 2992230

| Parameter | Units | 50302027005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.4 | 7.3 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 2992231

| Parameter | Units | 50302013001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.7 | 6.8 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 648874 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2990102 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 16:39 | |

LABORATORY CONTROL SAMPLE: 2990103

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990104 2990105

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.46 | 0.46 | 92 | 91 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990106 2990107

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.29 | 0.28 | 57 | 54 | 90-110 | 6 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 648707
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2989098 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/04/21 17:07 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/04/21 17:07 | |

LABORATORY CONTROL SAMPLE: 2989099

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 101 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 110 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989100 2989101

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.99 | 0.99 | 99 | 99 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 110 | 110 | 90-110 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2989102 2989103

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 101 | 101 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 111 | 111 | 90-110 | 0 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 650186
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2996933 Matrix: Water
Associated Lab Samples: 50302028001, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 13:15 | |

LABORATORY CONTROL SAMPLE: 2996934

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996935 2996936

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.39 | | | 1.8 | 1.8 | | | | 3 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996937 2996938

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.6 | 1.5 | | | | 4 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 650188
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028002

METHOD BLANK: 2996941 Matrix: Water
Associated Lab Samples: 50302028002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/17/21 14:00 | |

LABORATORY CONTROL SAMPLE: 2996942

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2996943 2996944

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.5 | | | | 3 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 650494 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2998195 — Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/15/21 14:13 | |

LABORATORY CONTROL SAMPLE: 2998196

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998197 2998198

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 10.4 | 10.4 | 100 | 100 | 80-120 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998199 2998200

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.5 | 10 | 10 | 13.6 | 14.0 | 102 | 105 | 80-120 | 3 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998201 2998202

| Parameter | Units | 50302077001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 0.90 | 10 | 10 | 11.2 | 11.0 | 103 | 101 | 80-120 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 650522 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2998294 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028005, 50302028006, 50302028007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/16/21 22:54 | |

LABORATORY CONTROL SAMPLE: 2998295

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.6 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998296 2998297

| Parameter | Units | 50302013001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.1 | 10 | 10 | 12.0 | 11.8 | 99 | 96 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998298 2998299

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 10 | 10.6 | 10.5 | 99 | 98 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2998301 2998302

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 3.5 | 10 | 10 | 13.2 | 13.1 | 97 | 96 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103S** **Lab ID: 50302028001** Collected: 11/03/21 09:45 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0114 ± 0.367 (0.737) C:NA T:99%** | pCi/L | 12/06/21 15:55 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.12 ± 0.546 (0.964) C:74% T:74%** | pCi/L | 12/06/21 11:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.13 ± 0.913 (1.70)** | pCi/L | 12/08/21 13:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103I** **Lab ID: 50302028002** Collected: 11/03/21 11:00 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.20 ± 0.536 (0.547) C:NA T:93%** | pCi/L | 12/06/21 15:55 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.935 ± 0.488 (0.874) C:73% T:76%** | pCi/L | 12/06/21 11:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.14 ± 1.02 (1.42)** | pCi/L | 12/08/21 13:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103I MS** **Lab ID: 50302028003** Collected: 11/03/21 11:00 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **99.20 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 12/06/21 16:11 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **118.12 %REC ± NA (NA) C:NA T:NA** | pCi/L | 12/06/21 11:43 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-103I MSD** **Lab ID: 50302028004** Collected: 11/03/21 11:00 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **76.26 %REC 26.15 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 12/06/21 16:11 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **103.57 %REC 13.13 RPD ± NA (NA) C:NA T:NA** | pCi/L | 12/06/21 11:43 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106S** **Lab ID: 50302028005** Collected: 11/03/21 13:46 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.337 ± 0.301 (0.386) C:NA T:98%** | pCi/L | 12/06/21 16:11 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.415 ± 0.488 (1.04) C:67% T:84%** | pCi/L | 12/06/21 11:37 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.752 ± 0.789 (1.43)** | pCi/L | 12/08/21 13:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106I** **Lab ID: 50302028006** Collected: 11/03/21 11:51 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.191 ± 0.370 (0.646) C:NA T:95%** | pCi/L | 12/06/21 16:11 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.890 ± 0.515 (0.979) C:75% T:83%** | pCi/L | 12/06/21 11:37 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.08 ± 0.885 (1.63)** | pCi/L | 12/08/21 13:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

**Sample: MW-106D** **Lab ID: 50302028007** Collected: 11/03/21 10:12 Received: 11/04/21 14:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.02 ± 0.725 (0.997) C:NA T:96%** | pCi/L | 12/06/21 16:11 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.227 ± 0.496 (1.09) C:69% T:90%** | pCi/L | 12/06/21 11:37 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.25 ± 1.22 (2.09)** | pCi/L | 12/08/21 13:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 473853 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302028001, 50302028002, 50302028003, 50302028004, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2289200 Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028003, 50302028004, 50302028005, 50302028006, 50302028007

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0875 ± 0.400 (0.738) C:NA T:97% | pCi/L | 12/06/21 15:36 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

QC Batch: 473855
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302028001, 50302028002, 50302028003, 50302028004, 50302028005, 50302028006, 50302028007

METHOD BLANK: 2289202
Matrix: Water
Associated Lab Samples: 50302028001, 50302028002, 50302028003, 50302028004, 50302028005, 50302028006, 50302028007

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.452 ± 0.295 (0.553) C:73% T:97% | pCi/L | 12/06/21 11:38 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302028001** | **MW-103S** | EPA 9056 | 649284 | | |
| **50302028002** | **MW-103I** | EPA 9056 | 649284 | | |
| **50302028005** | **MW-106S** | EPA 9056 | 649284 | | |
| **50302028006** | **MW-106I** | EPA 9056 | 649284 | | |
| **50302028007** | **MW-106D** | EPA 9056 | 649284 | | |
| **50302028001** | **MW-103S** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302028002** | **MW-103I** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302028005** | **MW-106S** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302028006** | **MW-106I** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302028007** | **MW-106D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302028001** | **MW-103S** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302028002** | **MW-103I** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302028005** | **MW-106S** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302028006** | **MW-106I** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302028007** | **MW-106D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302028001** | **MW-103S** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302028002** | **MW-103I** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302028005** | **MW-106S** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302028006** | **MW-106I** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302028007** | **MW-106D** | EPA 200.2 | 648753 | EPA 6020 | 648923 |
| **50302028001** | **MW-103S** | EPA 903.1 | 473853 | | |
| **50302028002** | **MW-103I** | EPA 903.1 | 473853 | | |
| **50302028003** | **MW-103I MS** | EPA 903.1 | 473853 | | |
| **50302028004** | **MW-103I MSD** | EPA 903.1 | 473853 | | |
| **50302028005** | **MW-106S** | EPA 903.1 | 473853 | | |
| **50302028006** | **MW-106I** | EPA 903.1 | 473853 | | |
| **50302028007** | **MW-106D** | EPA 903.1 | 473853 | | |
| **50302028001** | **MW-103S** | EPA 904.0 | 473855 | | |
| **50302028002** | **MW-103I** | EPA 904.0 | 473855 | | |
| **50302028003** | **MW-103I MS** | EPA 904.0 | 473855 | | |
| **50302028004** | **MW-103I MSD** | EPA 904.0 | 473855 | | |
| **50302028005** | **MW-106S** | EPA 904.0 | 473855 | | |
| **50302028006** | **MW-106I** | EPA 904.0 | 473855 | | |
| **50302028007** | **MW-106D** | EPA 904.0 | 473855 | | |
| **50302028001** | **MW-103S** | Total Radium Calculation | 475452 | | |
| **50302028002** | **MW-103I** | Total Radium Calculation | 475452 | | |
| **50302028005** | **MW-106S** | Total Radium Calculation | 475452 | | |
| **50302028006** | **MW-106I** | Total Radium Calculation | 475452 | | |
| **50302028007** | **MW-106D** | Total Radium Calculation | 475452 | | |
| **50302028001** | **MW-103S** | SM 2320B | 649592 | | |
| **50302028002** | **MW-103I** | SM 2320B | 649592 | | |
| **50302028005** | **MW-106S** | SM 2320B | 649592 | | |
| **50302028006** | **MW-106I** | SM 2320B | 649592 | | |
| **50302028007** | **MW-106D** | SM 2320B | 649592 | | |
| **50302028001** | **MW-103S** | SM 2540C | 649251 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302028

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302028002** | **MW-103I** | SM 2540C | 649251 | | |
| **50302028005** | **MW-106S** | SM 2540C | 649251 | | |
| **50302028006** | **MW-106I** | SM 2540C | 649251 | | |
| **50302028007** | **MW-106D** | SM 2540C | 649251 | | |
| **50302028001** | **MW-103S** | SM 4500-H+B | 649381 | | |
| **50302028002** | **MW-103I** | SM 4500-H+B | 649381 | | |
| **50302028005** | **MW-106S** | SM 4500-H+B | 649381 | | |
| **50302028006** | **MW-106I** | SM 4500-H+B | 649381 | | |
| **50302028007** | **MW-106D** | SM 4500-H+B | 649381 | | |
| **50302028001** | **MW-103S** | SM 4500-S2-D | 648874 | | |
| **50302028002** | **MW-103I** | SM 4500-S2-D | 648874 | | |
| **50302028005** | **MW-106S** | SM 4500-S2-D | 648874 | | |
| **50302028006** | **MW-106I** | SM 4500-S2-D | 648874 | | |
| **50302028007** | **MW-106D** | SM 4500-S2-D | 648874 | | |
| **50302028001** | **MW-103S** | EPA 353.2 | 648707 | | |
| **50302028002** | **MW-103I** | EPA 353.2 | 648707 | | |
| **50302028005** | **MW-106S** | EPA 353.2 | 648707 | | |
| **50302028006** | **MW-106I** | EPA 353.2 | 648707 | | |
| **50302028007** | **MW-106D** | EPA 353.2 | 648707 | | |
| **50302028001** | **MW-103S** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302028002** | **MW-103I** | EPA 365.1 | 650188 | EPA 365.1 | 651016 |
| **50302028005** | **MW-106S** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302028006** | **MW-106I** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302028007** | **MW-106D** | EPA 365.1 | 650186 | EPA 365.1 | 651015 |
| **50302028001** | **MW-103S** | SM 5310C | 650494 | | |
| **50302028002** | **MW-103I** | SM 5310C | 650494 | | |
| **50302028005** | **MW-106S** | SM 5310C | 650494 | | |
| **50302028006** | **MW-106I** | SM 5310C | 650494 | | |
| **50302028007** | **MW-106D** | SM 5310C | 650494 | | |
| **50302028001** | **MW-103S** | SM 5310C | 650522 | | |
| **50302028002** | **MW-103I** | SM 5310C | 650522 | | |
| **50302028005** | **MW-106S** | SM 5310C | 650522 | | |
| **50302028006** | **MW-106I** | SM 5310C | 650522 | | |
| **50302028007** | **MW-106D** | SM 5310C | 650522 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50302028

50302028

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

...t and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



**Section A** — **Required Client Information:**

| | |
|---|---|
| Company: | ATC Group Services |
| Address: | 7988 Centerpoint Drive |
| | Indianapolis, IN 46256 |
| Email: | mark.breting@atcgs.com |
| Phone: | NONE Fax: |
| Requested Due Date: | |

**Required Project Information:**

| | |
|---|---|
| Report To: | Mark Breting |
| Copy To: | |
| Purchase Order #: | |
| Project Name: | Harding Street Profile 1 Report 2 |
| Project #: | |

**Section C** — **Invoice Information:**

| | |
|---|---|
| Attention: | |
| Company Name: | |
| Address: | |
| Pace Quote: | |
| Pace Project Manager: | hayden.putt@pacelabs.com, |
| Pace Profile #: | 6246 Line 30 |

Regulation Criteria:

State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | Requested Analysis Filtered (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | | | | | Y | | | | Y | | | |
| 1 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 2 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 3 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 4 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 5 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 8 | MW-103S | WT | | 11-3 | 0945 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 9 | MW-103I | WT | | 11-3 | 1100 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002,003,004 |
| 10 | MS-3 (MW-103I) | WT | | | 1100 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | ~~005~~ |
| 11 | MSD-3 (MW-103I) | WT | | | 1100 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 12 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 11-3-21 | 1630 | | 11/4/21 | 1425 | |
| 6020 (Co, As, Se, Sb) | | 11/4/21 | 1450 | | 11/4/21 | 1450 | SCR SCW |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | 0.2 |

| SAMPLER NAME AND SIGNATURE | | | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | P. Greg Hopper | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| SIGNATURE of SAMPLER: | | DATE Signed: 11-3-21 | | Y | N | |

# CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical® WWW.PACELABS.COM

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A Required Client Information: | Section B Required Project Information: | Section C Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcgs.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding Street Profile 1 Report 2 | Pace Project Manager: hayden.putt@pacelabs.com, |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

Regulatory Agency:

State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** (Y) | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C (Y) | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 13 | MW-105S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 14 | MW-105I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 15 | MW-105D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 16 | MW-106S | WT | | | | 11/3/21 | 1346 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 17 | MW-106I | WT | | | | 11/3/21 | 1151 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 005 |
| 18 | MW-106D | WT | | | | 11/3/21 | 1012 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 006 |
| 19 | MW-107S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 007 |
| 20 | MW-107I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 21 | MW-107D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 22 | MW-108S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 23 | MW-108D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 24 | DUP 3 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | MARK BRETING / ATLAS | 11/4/21 | 0700 | [signature] | 11/4/21 | 1425 | | | | |
| 6020 (Co, As, Se, Sb) | [signature] | 11/4/21 | 1450 | [signature] | 11/4/21 | 1450 | See SCR | Y | N | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | | |
|---|---|---|---|---|
| PRINT Name of SAMPLER: MARK BRETING | | | | |
| SIGNATURE of SAMPLER: Mark Breting | DATE Signed: 11/3/21 | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| | | | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** WS 11-4-21 1540

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature:** 3.9/3.1, 1.4/0.6, 2.1/1.3, 1.0/0.2

Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle: HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)? Analysis:** $NO_2/NO_3$ | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1615 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

**COC PAGE** 1 **of** 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 9 | | | | | | | | | | | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | ✓ | ✓ | ✓ | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 2 of 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

## Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

## Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 14, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 05, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

Revised report replaces the original dated 12/9/21. M-4 taken off 50302158 and not reporting on 50309026-002. hrp 2/14/22

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Guam Certification
Florida: Cert E871149 SEKS WET
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50302158001** | **MW-8S** | Water | 11/04/21 13:00 | 11/05/21 13:25 |
| **50302158002** | **MW-9I** | Water | 11/04/21 11:05 | 11/05/21 13:25 |
| **50302158003** | **MW-9D** | Water | 11/04/21 09:55 | 11/05/21 13:25 |
| **50302158004** | **Field Blank 1** | Water | 11/04/21 13:20 | 11/05/21 13:25 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50302158001** | **MW-8S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302158002** | **MW-9I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302158003** | **MW-9D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302158004** | **Field Blank 1** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302158001** | **MW-8S** | | | | | |
| EPA 9056 | Chloride | 138 | mg/L | 25.0 | 11/10/21 18:53 | |
| EPA 9056 | Fluoride | 0.12 | mg/L | 0.10 | 11/10/21 18:34 | |
| EPA 9056 | Sulfate | 610 | mg/L | 25.0 | 11/10/21 18:53 | |
| EPA 6010 | Barium | 32.2 | ug/L | 10.0 | 11/16/21 12:58 | |
| EPA 6010 | Boron | 10500 | ug/L | 100 | 11/16/21 12:58 | |
| EPA 6010 | Calcium | 226000 | ug/L | 2000 | 11/16/21 14:22 | |
| EPA 6010 | Lithium | 137 | ug/L | 20.0 | 11/16/21 12:58 | |
| EPA 6010 | Magnesium | 84400 | ug/L | 1000 | 11/16/21 12:58 | |
| EPA 6010 | Manganese | 107 | ug/L | 10.0 | 11/16/21 12:58 | |
| EPA 6010 | Molybdenum | 270 | ug/L | 10.0 | 11/16/21 12:58 | |
| EPA 6010 | Potassium | 21600 | ug/L | 1000 | 11/16/21 12:58 | |
| EPA 6010 | Silica | 13800 | ug/L | 450 | 11/16/21 12:58 | N2 |
| EPA 6010 | Sodium | 140000 | ug/L | 1000 | 11/16/21 12:58 | |
| EPA 6010 | Manganese, Dissolved | 98.3 | ug/L | 10.0 | 11/16/21 04:02 | |
| EPA 6010 | Molybdenum, Dissolved | 274 | ug/L | 10.0 | 11/16/21 04:02 | |
| EPA 6020 | Selenium | 1.3 | ug/L | 1.0 | 11/17/21 06:17 | |
| EPA 903.1 | Radium-226 | 0.000 ± 0.374 (0.762) C:NA T:89% | pCi/L | | 12/07/21 14:05 | |
| EPA 904.0 | Radium-228 | 0.336 ± 0.589 (1.28) C:73% T:90% | pCi/L | | 12/07/21 14:32 | |
| Total Radium Calculation | Total Radium | 0.336 ± 0.963 (2.04) | pCi/L | | 12/08/21 14:55 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 345 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 345 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2540C | Total Dissolved Solids | 1520 | mg/L | 20.0 | 11/10/21 09:09 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 11/10/21 16:22 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.51 | mg/L | 0.10 | 11/05/21 17:40 | |
| SM 5310C | Total Organic Carbon | 1.7 | mg/L | 1.0 | 11/17/21 00:22 | |
| SM 5310C | Dissolved Organic Carbon | 2.7 | mg/L | 1.0 | 11/18/21 23:03 | |
| **50302158002** | **MW-9I** | | | | | |
| EPA 9056 | Chloride | 94.0 | mg/L | 25.0 | 11/10/21 19:32 | |
| EPA 9056 | Fluoride | 0.98 | mg/L | 0.10 | 11/10/21 19:12 | |
| EPA 9056 | Sulfate | 79.7 | mg/L | 25.0 | 11/10/21 19:32 | |
| EPA 6010 | Barium | 73.4 | ug/L | 10.0 | 11/16/21 13:01 | |
| EPA 6010 | Boron | 972 | ug/L | 100 | 11/16/21 13:01 | |
| EPA 6010 | Calcium | 103000 | ug/L | 1000 | 11/16/21 13:01 | |
| EPA 6010 | Iron | 1010 | ug/L | 100 | 11/16/21 13:01 | |
| EPA 6010 | Lithium | 28.5 | ug/L | 20.0 | 11/16/21 13:01 | |
| EPA 6010 | Magnesium | 24600 | ug/L | 1000 | 11/16/21 13:01 | |
| EPA 6010 | Manganese | 241 | ug/L | 10.0 | 11/16/21 13:01 | |
| EPA 6010 | Molybdenum | 123 | ug/L | 10.0 | 11/16/21 13:01 | |
| EPA 6010 | Potassium | 5280 | ug/L | 1000 | 11/16/21 13:01 | |
| EPA 6010 | Silica | 11500 | ug/L | 450 | 11/16/21 13:01 | N2 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302158002** | **MW-9I** | | | | | |
| EPA 6010 | Sodium | 77900 | ug/L | 1000 | 11/16/21 13:01 | |
| EPA 6010 | Manganese, Dissolved | 228 | ug/L | 10.0 | 11/16/21 03:43 | |
| EPA 6010 | Molybdenum, Dissolved | 122 | ug/L | 10.0 | 11/16/21 03:43 | |
| EPA 6020 | Arsenic | 5.2 | ug/L | 1.0 | 11/17/21 06:22 | |
| EPA 903.1 | Radium-226 | 1.16 ± 0.583 (0.196) C:NA T:91% | pCi/L | | 12/07/21 14:05 | |
| EPA 904.0 | Radium-228 | 0.637 ± 0.510 (1.03) C:74% T:83% | pCi/L | | 12/07/21 14:32 | |
| Total Radium Calculation | Total Radium | 1.80 ± 1.09 (1.23) | pCi/L | | 12/08/21 14:55 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 269 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 269 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2540C | Total Dissolved Solids | 562 | mg/L | 10.0 | 11/10/21 09:09 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/10/21 16:11 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.20 | mg/L | 0.10 | 11/05/21 17:45 | |
| **50302158003** | **MW-9D** | | | | | |
| EPA 9056 | Chloride | 86.1 | mg/L | 25.0 | 11/10/21 20:14 | |
| EPA 9056 | Fluoride | 0.36 | mg/L | 0.10 | 11/10/21 19:54 | |
| EPA 9056 | Sulfate | 129 | mg/L | 25.0 | 11/10/21 20:14 | |
| EPA 6010 | Barium | 46.3 | ug/L | 10.0 | 11/16/21 13:03 | |
| EPA 6010 | Boron | 1080 | ug/L | 100 | 11/16/21 13:03 | |
| EPA 6010 | Calcium | 110000 | ug/L | 1000 | 11/16/21 13:03 | |
| EPA 6010 | Iron | 1880 | ug/L | 100 | 11/16/21 13:03 | |
| EPA 6010 | Lithium | 23.0 | ug/L | 20.0 | 11/16/21 13:03 | |
| EPA 6010 | Magnesium | 31200 | ug/L | 1000 | 11/16/21 13:03 | |
| EPA 6010 | Manganese | 238 | ug/L | 10.0 | 11/16/21 13:03 | |
| EPA 6010 | Molybdenum | 41.3 | ug/L | 10.0 | 11/16/21 13:03 | |
| EPA 6010 | Potassium | 5820 | ug/L | 1000 | 11/16/21 13:03 | |
| EPA 6010 | Silica | 11600 | ug/L | 450 | 11/16/21 13:03 | N2 |
| EPA 6010 | Sodium | 73300 | ug/L | 1000 | 11/16/21 13:03 | |
| EPA 6010 | Manganese, Dissolved | 229 | ug/L | 10.0 | 11/16/21 03:46 | |
| EPA 6010 | Molybdenum, Dissolved | 42.2 | ug/L | 10.0 | 11/16/21 03:46 | |
| EPA 6020 | Arsenic | 9.0 | ug/L | 1.0 | 11/17/21 06:26 | |
| EPA 903.1 | Radium-226 | 0.650 ± 0.431 (0.196) C:NA T:94% | pCi/L | | 12/07/21 14:05 | |
| EPA 904.0 | Radium-228 | 0.772 ± 0.512 (1.00) C:73% T:88% | pCi/L | | 12/07/21 14:32 | |
| Total Radium Calculation | Total Radium | 1.42 ± 0.943 (1.20) | pCi/L | | 12/08/21 14:55 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302158003** | **MW-9D** | | | | | |
| SM 2320B | Alkalinity, Total as CaCO3 | 269 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 269 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2540C | Total Dissolved Solids | 629 | mg/L | 10.0 | 11/10/21 09:10 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/10/21 16:10 | H3 |
| SM 5310C | Total Organic Carbon | 1.1 | mg/L | 1.0 | 11/17/21 00:43 | |
| SM 5310C | Dissolved Organic Carbon | 1.1 | mg/L | 1.0 | 11/18/21 23:24 | |
| **50302158004** | **Field Blank 1** | | | | | |
| EPA 903.1 | Radium-226 | 0.000 ± 0.482 (1.02) C:NA T:96% | pCi/L | | 12/07/21 14:05 | |
| EPA 904.0 | Radium-228 | -0.0950 ± 0.515 (1.19) C:74% T:84% | pCi/L | | 12/07/21 14:32 | |
| Total Radium Calculation | Total Radium | 0.000 ± 0.997 (2.21) | pCi/L | | 12/08/21 14:55 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 2.2 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 2.2 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/10/21 16:23 | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-8S** **Lab ID: 50302158001** Collected: 11/04/21 13:00 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **138** | mg/L | 25.0 | 100 | | 11/10/21 18:53 | 16887-00-6 | |
| Fluoride | **0.12** | mg/L | 0.10 | 1 | | 11/10/21 18:34 | 16984-48-8 | |
| Sulfate | **610** | mg/L | 25.0 | 100 | | 11/10/21 18:53 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7429-90-5 | |
| Barium | **32.2** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7440-39-3 | |
| Boron | **10500** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7440-43-9 | |
| Calcium | **226000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:22 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7439-92-1 | |
| Lithium | **137** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7439-93-2 | |
| Magnesium | **84400** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7439-95-4 | |
| Manganese | **107** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7439-96-5 | |
| Molybdenum | **270** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7439-98-7 | |
| Potassium | **21600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7440-09-7 | |
| Silica | **13800** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7631-86-9 | N2 |
| Sodium | **140000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 12:58 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **98.3** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 04:02 | 7439-96-5 | |
| Molybdenum, Dissolved | **274** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 04:02 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:17 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:17 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:17 | 7440-48-4 | |
| Selenium | **1.3** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:17 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **345** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **345** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1520** | mg/L | 20.0 | 1 | | 11/10/21 09:09 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-8S** **Lab ID: 50302158001** Collected: 11/04/21 13:00 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 11/10/21 16:22 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.51** | mg/L | 0.10 | 1 | | 11/05/21 17:40 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:40 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:27 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 11/17/21 00:22 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.7** | mg/L | 1.0 | 1 | | 11/18/21 23:03 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-9I** **Lab ID: 50302158002** Collected: 11/04/21 11:05 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **94.0** | mg/L | 25.0 | 100 | | 11/10/21 19:32 | 16887-00-6 | |
| Fluoride | **0.98** | mg/L | 0.10 | 1 | | 11/10/21 19:12 | 16984-48-8 | |
| Sulfate | **79.7** | mg/L | 25.0 | 100 | | 11/10/21 19:32 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7429-90-5 | |
| Barium | **73.4** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-39-3 | |
| Boron | **972** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-43-9 | |
| Calcium | **103000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-47-3 | |
| Iron | **1010** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7439-92-1 | |
| Lithium | **28.5** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7439-93-2 | |
| Magnesium | **24600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7439-95-4 | |
| Manganese | **241** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7439-96-5 | |
| Molybdenum | **123** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7439-98-7 | |
| Potassium | **5280** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-09-7 | |
| Silica | **11500** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7631-86-9 | N2 |
| Sodium | **77900** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:01 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **228** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:43 | 7439-96-5 | |
| Molybdenum, Dissolved | **122** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:43 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:22 | 7440-36-0 | |
| Arsenic | **5.2** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:22 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:22 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:22 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **269** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **269** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **562** | mg/L | 10.0 | 1 | | 11/10/21 09:09 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-9I** **Lab ID: 50302158002** Collected: 11/04/21 11:05 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/10/21 16:11 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.20** | mg/L | 0.10 | 1 | | 11/05/21 17:45 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:45 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:27 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/17/21 00:32 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/18/21 23:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-9D** **Lab ID: 50302158003** Collected: 11/04/21 09:55 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **86.1** | mg/L | 25.0 | 100 | | 11/10/21 20:14 | 16887-00-6 | |
| Fluoride | **0.36** | mg/L | 0.10 | 1 | | 11/10/21 19:54 | 16984-48-8 | |
| Sulfate | **129** | mg/L | 25.0 | 100 | | 11/10/21 20:14 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7429-90-5 | |
| Barium | **46.3** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-39-3 | |
| Boron | **1080** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-43-9 | |
| Calcium | **110000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-47-3 | |
| Iron | **1880** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7439-92-1 | |
| Lithium | **23.0** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7439-93-2 | |
| Magnesium | **31200** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7439-95-4 | |
| Manganese | **238** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7439-96-5 | |
| Molybdenum | **41.3** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7439-98-7 | |
| Potassium | **5820** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-09-7 | |
| Silica | **11600** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7631-86-9 | N2 |
| Sodium | **73300** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:03 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **229** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:46 | 7439-96-5 | |
| Molybdenum, Dissolved | **42.2** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:46 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:26 | 7440-36-0 | |
| Arsenic | **9.0** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:26 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:26 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:26 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **269** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **269** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **629** | mg/L | 10.0 | 1 | | 11/10/21 09:10 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-9D** **Lab ID: 50302158003** Collected: 11/04/21 09:55 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/10/21 16:10 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 17:47 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:47 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:29 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 11/17/21 00:43 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 11/18/21 23:24 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: Field Blank 1** **Lab ID: 50302158004** Collected: 11/04/21 13:20 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | ND | mg/L | 0.25 | 1 | | 11/10/21 21:53 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 11/10/21 21:53 | 16984-48-8 | |
| Sulfate | ND | mg/L | 0.25 | 1 | | 11/10/21 21:53 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7429-90-5 | |
| Barium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-39-3 | |
| Boron | ND | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-43-9 | |
| Calcium | ND | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7439-93-2 | |
| Magnesium | ND | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7439-98-7 | |
| Potassium | ND | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-09-7 | |
| Silica | ND | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7631-86-9 | N2 |
| Sodium | ND | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:05 | 7440-23-5 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:31 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:31 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:31 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:31 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **2.2** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **2.2** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | ND | mg/L | 10.0 | 1 | | 11/10/21 09:10 | | PL |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/10/21 16:23 | | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: Field Blank 1** **Lab ID: 50302158004** Collected: 11/04/21 13:20 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2 Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 17:49 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:49 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1 Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:30 | | |
| **5310C TOC** | Analytical Method: SM 5310C Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/17/21 01:11 | 7440-44-0 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649560
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2993087 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/10/21 14:09 | |
| Fluoride | mg/L | ND | 0.10 | 11/10/21 14:09 | |
| Sulfate | mg/L | ND | 0.25 | 11/10/21 14:09 | |

LABORATORY CONTROL SAMPLE: 2993088

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 88 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.43 | 85 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 93 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993089 2993090

| Parameter | Units | 50302156001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 15.2 | 12.5 | 12.5 | 26.2 | 26.2 | 88 | 88 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.53 | 86 | 87 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 246 | 250 | 250 | 467 | 468 | 89 | 89 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649047
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2990952 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/16/21 12:10 | |
| Barium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Boron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Cadmium | ug/L | ND | 2.0 | 11/16/21 12:10 | |
| Calcium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Chromium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Iron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Lead | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Lithium | ug/L | ND | 20.0 | 11/16/21 12:10 | |
| Magnesium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Manganese | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Molybdenum | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Potassium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Silica | ug/L | ND | 450 | 11/16/21 12:10 | N2 |
| Sodium | ug/L | ND | 1000 | 11/16/21 12:10 | |

LABORATORY CONTROL SAMPLE: 2990953

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4590 | 92 | 80-120 | |
| Barium | ug/L | 1000 | 966 | 97 | 80-120 | |
| Boron | ug/L | 1000 | 980 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 935 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 5040 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 979 | 98 | 80-120 | |
| Iron | ug/L | 2500 | 2440 | 98 | 80-120 | |
| Lead | ug/L | 1000 | 931 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4800 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 985 | 98 | 80-120 | |
| Molybdenum | ug/L | 1000 | 965 | 97 | 80-120 | |
| Potassium | ug/L | 5000 | 5020 | 100 | 80-120 | |
| Silica | ug/L | 5350 | 5350 | 100 | | N2 |
| Sodium | ug/L | 5000 | 4900 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990954 2990955

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4640 | 4650 | 93 | 93 | 75-125 | 0 | 20 | |
| Barium | ug/L | 69.2 | 1000 | 1000 | 1010 | 1010 | 94 | 94 | 75-125 | 0 | 20 | |
| Boron | ug/L | 127 | 1000 | 1000 | 1120 | 1130 | 99 | 100 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 927 | 930 | 93 | 93 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 106000 | 5000 | 5000 | 108000 | 107000 | 46 | 18 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 947 | 954 | 95 | 95 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1230 | 2500 | 2500 | 3550 | 3550 | 93 | 93 | 75-125 | 0 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 886 | 893 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1010 | 1010 | 100 | 101 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 30700 | 5000 | 5000 | 34600 | 34200 | 78 | 71 | 75-125 | 1 | 20 | P6 |
| Manganese | ug/L | 118 | 1000 | 1000 | 1060 | 1070 | 95 | 96 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 955 | 962 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 2050 | 5000 | 5000 | 6940 | 7010 | 98 | 99 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12300 | 5350 | 5350 | 17200 | 17000 | 93 | 88 | | 2 | | N2 |
| Sodium | ug/L | 19500 | 5000 | 5000 | 23800 | 23500 | 85 | 79 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990956 2990957

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4620 | 4720 | 92 | 94 | 75-125 | 2 | 20 | |
| Barium | ug/L | 221 | 1000 | 1000 | 1150 | 1160 | 93 | 94 | 75-125 | 1 | 20 | |
| Boron | ug/L | 263 | 1000 | 1000 | 1260 | 1280 | 99 | 101 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 919 | 931 | 92 | 93 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 96600 | 5000 | 5000 | 100000 | 102000 | 77 | 113 | 75-125 | 2 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 946 | 958 | 94 | 96 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1670 | 2500 | 2500 | 3950 | 4000 | 91 | 93 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 871 | 881 | 87 | 88 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1000 | 1020 | 99 | 101 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 29300 | 5000 | 5000 | 33600 | 34200 | 86 | 97 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 303 | 1000 | 1000 | 1240 | 1260 | 93 | 96 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 948 | 960 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 7590 | 5000 | 5000 | 12400 | 12500 | 96 | 98 | 75-125 | 1 | 20 | |
| Silica | ug/L | 10900 | 5350 | 5350 | 15900 | 16100 | 94 | 98 | | 1 | | N2 |
| Sodium | ug/L | 73700 | 5000 | 5000 | 77300 | 78000 | 72 | 86 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649216
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003

METHOD BLANK: 2991499 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |

LABORATORY CONTROL SAMPLE: 2991500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 821 | 82 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 827 | 83 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991501 2991502

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 112 | 1000 | 1000 | 1070 | 1080 | 96 | 96 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 998 | 1010 | 100 | 100 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991503 2991504

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1230 | 1250 | 93 | 95 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 986 | 992 | 98 | 99 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649453
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2992568 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Arsenic | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Cobalt | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Selenium | ug/L | ND | 1.0 | 11/17/21 05:34 | |

LABORATORY CONTROL SAMPLE: 2992569

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.8 | 105 | 80-120 | |
| Arsenic | ug/L | 40 | 37.7 | 94 | 80-120 | |
| Cobalt | ug/L | 40 | 40.3 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 38.3 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992570 2992571

| Parameter | Units | 50302156001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.3 | 41.8 | 105 | 104 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 37.4 | 36.6 | 93 | 91 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.7 | 38.2 | 95 | 94 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.9 | 38.4 | 95 | 94 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649826 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2994528 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/11/21 14:08 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 14:08 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 14:08 | |

LABORATORY CONTROL SAMPLE: 2994529

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 47.9 | 96 | 90-110 | |

SAMPLE DUPLICATE: 2994530

| Parameter | Units | 50302108006 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 676 | 691 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 676 | 691 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2994531

| Parameter | Units | 50302256001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 96.4 | 102 | 5 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 96.4 | 102 | 5 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649493 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2992747 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/10/21 09:08 | |

LABORATORY CONTROL SAMPLE: 2992748

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 300 | 100 | 80-120 | |

SAMPLE DUPLICATE: 2992749

| Parameter | Units | 50302141004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2590 | 2590 | 0 | 10 | |

SAMPLE DUPLICATE: 2992750

| Parameter | Units | 50302141005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1200 | 1170 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 649626
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

SAMPLE DUPLICATE: 2993451

| Parameter | Units | 50302144001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.0 | 7.2 | 2 | 2 | H3 |

SAMPLE DUPLICATE: 2993452

| Parameter | Units | 50302187003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.0 | 7.0 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 648936 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2990476 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 18:01 | |

LABORATORY CONTROL SAMPLE: 2990477

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990478 2990479

| Parameter | Units | 50302158001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.36 | 0.35 | 69 | 67 | 90-110 | 3 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 648910 | Analysis Method: EPA 353.2
QC Batch Method: EPA 353.2 | Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2990259 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/05/21 17:33 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/05/21 17:33 | |

LABORATORY CONTROL SAMPLE: 2990260

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.96 | 96 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 109 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990261 2990262

| Parameter | Units | 50302158001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.51 | 1 | 1 | 1.5 | 1.5 | 101 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 114 | 114 | 90-110 | 0 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 651262
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 3001515 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/18/21 16:17 | |

LABORATORY CONTROL SAMPLE: 3001516

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3001517 3001518

| Parameter | Units | 50302157001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 23.8 | | | 45.4 | 41.4 | | | | 9 | | |

MATRIX SPIKE SAMPLE: 3001519

| Parameter | Units | 50302159004 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.51 | | 2.1 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 650843 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003

METHOD BLANK: 2999707 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/16/21 19:22 | |

LABORATORY CONTROL SAMPLE: 2999708

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2999709 2999710

| Parameter | Units | 50302108019 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 10.6 | 10.6 | 102 | 102 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 2999711

| Parameter | Units | 50302128008 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.7 | 10 | 12.9 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 650844
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158004

METHOD BLANK: 2999712 Matrix: Water
Associated Lab Samples: 50302158004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/17/21 00:52 | |

LABORATORY CONTROL SAMPLE: 2999713

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2999714 2999715

| Parameter | Units | 50302187003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.1 | 10 | 10 | 14.2 | 14.0 | 112 | 109 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 2999716

| Parameter | Units | 50302232002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.2 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 651325
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158001, 50302158002, 50302158003

METHOD BLANK: 3001931 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/18/21 22:41 | |

LABORATORY CONTROL SAMPLE: 3001932

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.7 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3001933 3001934

| Parameter | Units | 50302159004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 3.0 | 10 | 10 | 13.7 | 13.7 | 107 | 108 | 80-120 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-8S** **Lab ID: 50302158001** Collected: 11/04/21 13:00 Received: 11/05/21 13:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.000 ± 0.374 (0.762) C:NA T:89%** | pCi/L | 12/07/21 14:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.336 ± 0.589 (1.28) C:73% T:90%** | pCi/L | 12/07/21 14:32 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.336 ± 0.963 (2.04)** | pCi/L | 12/08/21 14:55 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-9I** **Lab ID: 50302158002** Collected: 11/04/21 11:05 Received: 11/05/21 13:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.16 ± 0.583 (0.196) C:NA T:91%** | pCi/L | 12/07/21 14:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.637 ± 0.510 (1.03) C:74% T:83%** | pCi/L | 12/07/21 14:32 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.80 ± 1.09 (1.23)** | pCi/L | 12/08/21 14:55 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: MW-9D** **Lab ID: 50302158003** Collected: 11/04/21 09:55 Received: 11/05/21 13:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.650 ± 0.431 (0.196) C:NA T:94%** | pCi/L | 12/07/21 14:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.772 ± 0.512 (1.00) C:73% T:88%** | pCi/L | 12/07/21 14:32 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.42 ± 0.943 (1.20)** | pCi/L | 12/08/21 14:55 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

**Sample: Field Blank 1** **Lab ID: 50302158004** Collected: 11/04/21 13:20 Received: 11/05/21 13:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.000 ± 0.482 (1.02) C:NA T:96%** | pCi/L | 12/07/21 14:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **-0.0950 ± 0.515 (1.19) C:74% T:84%** | pCi/L | 12/07/21 14:32 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.000 ± 0.997 (2.21)** | pCi/L | 12/08/21 14:55 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 473873
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2289219 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.178 ± 0.387 (0.713) C:NA T:96% | pCi/L | 12/07/21 13:51 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

QC Batch: 473876
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

METHOD BLANK: 2289221 Matrix: Water
Associated Lab Samples: 50302158001, 50302158002, 50302158003, 50302158004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.560 ± 0.330 (0.597) C:73% T:85% | pCi/L | 12/07/21 11:24 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| PL | The minimum mass of dried residue of 2.5 mg could not be obtained using the routine sample volume of 100 mL. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302158001** | **MW-8S** | EPA 9056 | 649560 | | |
| **50302158002** | **MW-9I** | EPA 9056 | 649560 | | |
| **50302158003** | **MW-9D** | EPA 9056 | 649560 | | |
| **50302158004** | **Field Blank 1** | EPA 9056 | 649560 | | |
| **50302158001** | **MW-8S** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302158002** | **MW-9I** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302158003** | **MW-9D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302158004** | **Field Blank 1** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302158001** | **MW-8S** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302158002** | **MW-9I** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302158003** | **MW-9D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302158001** | **MW-8S** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302158002** | **MW-9I** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302158003** | **MW-9D** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302158004** | **Field Blank 1** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302158001** | **MW-8S** | EPA 903.1 | 473873 | | |
| **50302158002** | **MW-9I** | EPA 903.1 | 473873 | | |
| **50302158003** | **MW-9D** | EPA 903.1 | 473873 | | |
| **50302158004** | **Field Blank 1** | EPA 903.1 | 473873 | | |
| **50302158001** | **MW-8S** | EPA 904.0 | 473876 | | |
| **50302158002** | **MW-9I** | EPA 904.0 | 473876 | | |
| **50302158003** | **MW-9D** | EPA 904.0 | 473876 | | |
| **50302158004** | **Field Blank 1** | EPA 904.0 | 473876 | | |
| **50302158001** | **MW-8S** | Total Radium Calculation | 475472 | | |
| **50302158002** | **MW-9I** | Total Radium Calculation | 475472 | | |
| **50302158003** | **MW-9D** | Total Radium Calculation | 475472 | | |
| **50302158004** | **Field Blank 1** | Total Radium Calculation | 475472 | | |
| **50302158001** | **MW-8S** | SM 2320B | 649826 | | |
| **50302158002** | **MW-9I** | SM 2320B | 649826 | | |
| **50302158003** | **MW-9D** | SM 2320B | 649826 | | |
| **50302158004** | **Field Blank 1** | SM 2320B | 649826 | | |
| **50302158001** | **MW-8S** | SM 2540C | 649493 | | |
| **50302158002** | **MW-9I** | SM 2540C | 649493 | | |
| **50302158003** | **MW-9D** | SM 2540C | 649493 | | |
| **50302158004** | **Field Blank 1** | SM 2540C | 649493 | | |
| **50302158001** | **MW-8S** | SM 4500-H+B | 649626 | | |
| **50302158002** | **MW-9I** | SM 4500-H+B | 649626 | | |
| **50302158003** | **MW-9D** | SM 4500-H+B | 649626 | | |
| **50302158004** | **Field Blank 1** | SM 4500-H+B | 649626 | | |
| **50302158001** | **MW-8S** | SM 4500-S2-D | 648936 | | |
| **50302158002** | **MW-9I** | SM 4500-S2-D | 648936 | | |
| **50302158003** | **MW-9D** | SM 4500-S2-D | 648936 | | |
| **50302158004** | **Field Blank 1** | SM 4500-S2-D | 648936 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50302158

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302158001** | **MW-8S** | EPA 353.2 | 648910 | | |
| **50302158002** | **MW-9I** | EPA 353.2 | 648910 | | |
| **50302158003** | **MW-9D** | EPA 353.2 | 648910 | | |
| **50302158004** | **Field Blank 1** | EPA 353.2 | 648910 | | |
| **50302158001** | **MW-8S** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302158002** | **MW-9I** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302158003** | **MW-9D** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302158004** | **Field Blank 1** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302158001** | **MW-8S** | SM 5310C | 650843 | | |
| **50302158002** | **MW-9I** | SM 5310C | 650843 | | |
| **50302158003** | **MW-9D** | SM 5310C | 650843 | | |
| **50302158004** | **Field Blank 1** | SM 5310C | 650844 | | |
| **50302158001** | **MW-8S** | SM 5310C | 651325 | | |
| **50302158002** | **MW-9I** | SM 5310C | 651325 | | |
| **50302158003** | **MW-9D** | SM 5310C | 651325 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytic

The Chain-of-Custody is a LEGAL DOCUMENT. All rele

**WO# : 50302158**

50302158

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

| Regulatory Agency | |
|---|---|
| | |
| **State / Location** | |
| IN | |

| ITEM # | SAMPLE ID<br>One Character per box.<br>(A-Z, 0-9 / , -)<br>Sample Ids must be unique | MATRIX / CODE<br>Drinking Water DW<br>Water WT<br>Waste Water WW<br>Product P<br>Soil/Solid SL<br>Oil OL<br>Wipe WP<br>Air AR<br>Other OT<br>Tissue TS | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | START TIME | END DATE | END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Requested Analysis Filtered (Y/N) Y/N | Analyses Test: TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | | | |
| 1 | MW-1S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 2 | MW-1D | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 3 | MW-2S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 4 | MW-2D | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 5 | MW-3S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 6 | MW-3D | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-4S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 8 | MW-5S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 9 | MW-6S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 10 | MW-7S | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 11 | MW-7D | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 12 | MW-8S | | WT | | | | 11-4-21 | 13:00 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | VOI |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jashowiak | 11-5-21 | 7:15 | Tasha Pace | 11/5 | 1305 | |
| 6020 (Co, As, Se, Sb) | Tasha Pace | 11/5/21 | 1325 | | 11/5/21 | 1325 | 2.0 Y N Y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | 2.4 |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | 3.0 |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | Andy Jashowiak | | | | | |
| SIGNATURE of SAMPLER: | | DATE Signed: 11-5-21 | | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | Section B Required Project Information: | Section C Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcassociates.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

Regulatory Agency

State / Location: IN

MATRIX CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | |
| 13 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 14 | MW-9I | WT | | 1105 | 11-4 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 15 | MW-9D | WT | | 955 | 11-4 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 003 |
| 16 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 17 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 18 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 19 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 20 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 21 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 22 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 23 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 24 | | WT | | — | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | [signature] Pace | 11-5 | 715 | [signature] Pace | 11/5/21 | 1301 | |
| 6020 (Co, As, Se, Sb) | [signature] Pace | 11/5/21 | 1325 | [signature] | 11/5/21 | 1325 | 2.0 Y N Y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | 2.4 |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | 3.0 |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: P. Greg Harper

SIGNATURE of SAMPLER: [signature]

DATE Signed: 11-5-21

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| Indianapolis, IN 46256 | | | | Address: | |
| Email: | mark.breting@atcassociates.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

| Regulatory Agency | State / Location |
|---|---|
| | IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | Y | | | | | | |
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 30 | Field Blank 1 | WT | | | | 11-4-21 | 13:20 | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | | 004 |
| 31 | MS1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 32 | MSD1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 33 | MS2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 34 | MSD2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 35 | MW-4 | | | | | 11-4-21 | 17:30 | | 11 | 3 | 3 | 4 | | 1 | | | | | | | | | | | | | | | | 005 |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jackson | 11-5-21 | 7:15 | Pace | 11/5 | 1305 | |
| 6020 (Co, As, Se, Sb) | | 11/5/21 | 1325 | | 11/5/21 | 1325 | 2.0 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | 2.4 |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | 3.0 |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | Andy Jackson | | | | | |
| SIGNATURE of SAMPLER: | | DATE Signed: 11-5-21 | | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** 11/5/21 1418

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature:** 2.0/2.0 2.4/2.4 3.0/3.0
Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1445 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | — |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | — |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | — |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | — | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

M-4 to be tested for all parameters on COC, Ferrous Fe done in field, per Marks email. RR 11/5/21

M-4 to be switched onto its own report 50309026-002 and removed from 50302158, per Mark B. 2/14/22

COC PAGE 1 of 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | AT | ✓ | ✓ | |

Container Codes

## Glass

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic | BP4U | 125mL unpreserved plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic | BP4N | 125mL HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic | BP4S | 125mL H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic | | |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac | Syringe Kit | LL Cr+6 sampling kit |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic | | |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic | AF | Air Filter |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic | C | Air Cassettes |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic | R | Terracore kit |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac | SP5T | 120mL Coliform Na Thiosulfate |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic | U | Summa Can |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic | ZPLC | Ziploc Bag |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered | | |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic | WT | Water |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic | SL | Solid |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic | NAL / OL | Non-aqueous liquid / Oil |
| | | | | | | WP | Wipe |

COC PAGE 2 of 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | SL | ✓ | ✓ | |
| 3 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | SL | ✓ | ✓ | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 3 of 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | ✓ | ✓ | ✓ | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | ✓ | ✓ | ✓ | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

## Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

## Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 15, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 05, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Pace Analytical Services Pennsylvania**
1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**
7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50302159001** | **MW-103D** | Water | 11/05/21 09:35 | 11/05/21 13:52 |
| **50302159002** | **MW-105D** | Water | 11/05/21 11:55 | 11/05/21 13:52 |
| **50302159003** | **MW-107I** | Water | 11/05/21 11:40 | 11/05/21 13:52 |
| **50302159004** | **MW-107D** | Water | 11/05/21 10:45 | 11/05/21 13:52 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50302159001** | **MW-103D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302159002** | **MW-105D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302159003** | **MW-107I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302159004** | **MW-107D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | MK1 | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302159001** | **MW-103D** | | | | | |
| EPA 9056 | Chloride | 146 | mg/L | 25.0 | 11/10/21 22:35 | |
| EPA 9056 | Fluoride | 0.13 | mg/L | 0.10 | 11/10/21 22:13 | |
| EPA 9056 | Sulfate | 39.2 | mg/L | 25.0 | 11/10/21 22:35 | |
| EPA 6010 | Barium | 321 | ug/L | 10.0 | 11/16/21 13:09 | |
| EPA 6010 | Boron | 357 | ug/L | 100 | 11/16/21 13:09 | |
| EPA 6010 | Calcium | 89100 | ug/L | 1000 | 11/16/21 13:09 | |
| EPA 6010 | Iron | 2190 | ug/L | 100 | 11/16/21 13:09 | |
| EPA 6010 | Magnesium | 29600 | ug/L | 1000 | 11/16/21 13:09 | |
| EPA 6010 | Manganese | 132 | ug/L | 10.0 | 11/16/21 13:09 | |
| EPA 6010 | Potassium | 5500 | ug/L | 1000 | 11/16/21 13:09 | |
| EPA 6010 | Silica | 12600 | ug/L | 450 | 11/16/21 13:09 | N2 |
| EPA 6010 | Sodium | 80600 | ug/L | 1000 | 11/16/21 13:09 | |
| EPA 6010 | Manganese, Dissolved | 131 | ug/L | 10.0 | 11/16/21 03:50 | |
| EPA 903.1 | Radium-226 | 1.02 ± 0.700 (0.880) C:NA T:84% | pCi/L | | 12/14/21 15:32 | |
| EPA 904.0 | Radium-228 | 0.381 ± 0.386 (0.796) C:72% T:81% | pCi/L | | 12/15/21 14:37 | |
| Total Radium Calculation | Total Radium | 1.40 ± 1.09 (1.68) | pCi/L | | 12/16/21 17:28 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 248 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 248 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2540C | Total Dissolved Solids | 581 | mg/L | 10.0 | 11/10/21 09:10 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/10/21 16:44 | H3 |
| SM 5310C | Total Organic Carbon | 2.9 | mg/L | 1.0 | 11/17/21 01:41 | |
| SM 5310C | Dissolved Organic Carbon | 2.9 | mg/L | 1.0 | 11/19/21 00:07 | |
| **50302159002** | **MW-105D** | | | | | |
| EPA 9056 | Chloride | 113 | mg/L | 2.5 | 11/10/21 23:14 | |
| EPA 9056 | Fluoride | 0.20 | mg/L | 0.10 | 11/10/21 22:54 | |
| EPA 9056 | Sulfate | 87.8 | mg/L | 2.5 | 11/10/21 23:14 | |
| EPA 6010 | Barium | 326 | ug/L | 10.0 | 11/16/21 13:12 | |
| EPA 6010 | Boron | 628 | ug/L | 100 | 11/16/21 13:12 | |
| EPA 6010 | Calcium | 106000 | ug/L | 1000 | 11/16/21 13:12 | |
| EPA 6010 | Iron | 6010 | ug/L | 100 | 11/16/21 13:12 | |
| EPA 6010 | Magnesium | 26000 | ug/L | 1000 | 11/16/21 13:12 | |
| EPA 6010 | Manganese | 125 | ug/L | 10.0 | 11/16/21 13:12 | |
| EPA 6010 | Molybdenum | 12.2 | ug/L | 10.0 | 11/16/21 13:12 | |
| EPA 6010 | Potassium | 5280 | ug/L | 1000 | 11/16/21 13:12 | |
| EPA 6010 | Silica | 12700 | ug/L | 450 | 11/16/21 13:12 | N2 |
| EPA 6010 | Sodium | 69300 | ug/L | 1000 | 11/16/21 13:12 | |
| EPA 6010 | Manganese, Dissolved | 120 | ug/L | 10.0 | 11/16/21 03:52 | |
| EPA 6010 | Molybdenum, Dissolved | 13.0 | ug/L | 10.0 | 11/16/21 03:52 | |
| EPA 6020 | Arsenic | 4.6 | ug/L | 1.0 | 11/17/21 07:05 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302159002** | **MW-105D** | | | | | |
| EPA 903.1 | Radium-226 | 1.00 ± 0.686 (0.862) C:NA T:84% | pCi/L | | 12/14/21 15:32 | |
| EPA 904.0 | Radium-228 | 0.850 ± 0.536 (1.01) C:69% T:76% | pCi/L | | 12/15/21 14:37 | |
| Total Radium Calculation | Total Radium | 1.85 ± 1.22 (1.87) | pCi/L | | 12/16/21 17:28 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 254 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 254 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2540C | Total Dissolved Solids | 590 | mg/L | 10.0 | 11/10/21 09:11 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/10/21 16:53 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.39 | mg/L | 0.15 | 11/18/21 16:32 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/17/21 02:20 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 11/19/21 00:19 | |
| **50302159003** | **MW-107I** | | | | | |
| EPA 9056 | Chloride | 147 | mg/L | 25.0 | 11/10/21 23:56 | |
| EPA 9056 | Fluoride | 0.29 | mg/L | 0.10 | 11/10/21 23:33 | |
| EPA 9056 | Sulfate | 312 | mg/L | 25.0 | 11/10/21 23:56 | |
| EPA 6010 | Aluminum | 243 | ug/L | 200 | 11/16/21 13:14 | |
| EPA 6010 | Barium | 222 | ug/L | 10.0 | 11/16/21 13:14 | |
| EPA 6010 | Boron | 3490 | ug/L | 100 | 11/16/21 13:14 | |
| EPA 6010 | Calcium | 185000 | ug/L | 1000 | 11/16/21 13:14 | |
| EPA 6010 | Iron | 6880 | ug/L | 100 | 11/16/21 13:14 | |
| EPA 6010 | Magnesium | 55100 | ug/L | 1000 | 11/16/21 13:14 | |
| EPA 6010 | Manganese | 243 | ug/L | 10.0 | 11/16/21 13:14 | |
| EPA 6010 | Molybdenum | 15.4 | ug/L | 10.0 | 11/16/21 13:14 | |
| EPA 6010 | Potassium | 2930 | ug/L | 1000 | 11/16/21 13:14 | |
| EPA 6010 | Silica | 20700 | ug/L | 450 | 11/16/21 13:14 | N2 |
| EPA 6010 | Sodium | 72600 | ug/L | 1000 | 11/16/21 13:14 | |
| EPA 6010 | Manganese, Dissolved | 227 | ug/L | 10.0 | 11/16/21 03:54 | |
| EPA 6010 | Molybdenum, Dissolved | 18.8 | ug/L | 10.0 | 11/16/21 03:54 | |
| EPA 6020 | Arsenic | 3.6 | ug/L | 1.0 | 11/17/21 07:10 | |
| EPA 903.1 | Radium-226 | 0.585 ± 0.446 (0.519) C:NA T:89% | pCi/L | | 12/14/21 15:32 | |
| EPA 904.0 | Radium-228 | 0.859 ± 0.443 (0.774) C:73% T:84% | pCi/L | | 12/15/21 14:34 | |
| Total Radium Calculation | Total Radium | 1.44 ± 0.889 (1.29) | pCi/L | | 12/16/21 17:28 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 307 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 307 | mg/L | 2.0 | 11/11/21 16:22 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302159003** | **MW-107I** | | | | | |
| SM 2540C | Total Dissolved Solids | 982 | mg/L | 20.0 | 11/10/21 09:11 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/10/21 16:50 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.66 | mg/L | 0.15 | 11/18/21 16:32 | |
| SM 5310C | Total Organic Carbon | 4.9 | mg/L | 1.0 | 11/17/21 02:32 | |
| SM 5310C | Dissolved Organic Carbon | 4.7 | mg/L | 1.0 | 11/19/21 00:30 | |
| **50302159004** | **MW-107D** | | | | | |
| EPA 9056 | Chloride | 214 | mg/L | 25.0 | 11/11/21 00:34 | |
| EPA 9056 | Fluoride | 0.21 | mg/L | 0.10 | 11/11/21 00:15 | |
| EPA 9056 | Sulfate | 696 | mg/L | 25.0 | 11/11/21 00:34 | |
| EPA 6010 | Barium | 70.0 | ug/L | 10.0 | 11/16/21 13:16 | |
| EPA 6010 | Boron | 9680 | ug/L | 100 | 11/16/21 13:16 | |
| EPA 6010 | Calcium | 261000 | ug/L | 2000 | 11/16/21 14:27 | |
| EPA 6010 | Iron | 7960 | ug/L | 100 | 11/16/21 13:16 | |
| EPA 6010 | Lithium | 53.5 | ug/L | 20.0 | 11/16/21 13:16 | |
| EPA 6010 | Magnesium | 49400 | ug/L | 1000 | 11/16/21 13:16 | |
| EPA 6010 | Manganese | 366 | ug/L | 10.0 | 11/16/21 13:16 | |
| EPA 6010 | Molybdenum | 140 | ug/L | 10.0 | 11/16/21 13:16 | |
| EPA 6010 | Potassium | 9880 | ug/L | 1000 | 11/16/21 13:16 | |
| EPA 6010 | Silica | 17500 | ug/L | 450 | 11/16/21 13:16 | N2 |
| EPA 6010 | Sodium | 174000 | ug/L | 1000 | 11/16/21 13:16 | |
| EPA 6010 | Manganese, Dissolved | 346 | ug/L | 10.0 | 11/16/21 03:56 | |
| EPA 6010 | Molybdenum, Dissolved | 161 | ug/L | 10.0 | 11/16/21 03:56 | |
| EPA 6020 | Arsenic | 2.1 | ug/L | 1.0 | 11/17/21 07:14 | |
| EPA 903.1 | Radium-226 | 0.908 ± 0.593 (0.727) C:NA T:94% | pCi/L | | 12/14/21 15:32 | |
| EPA 904.0 | Radium-228 | 0.644 ± 0.463 (0.903) C:66% T:85% | pCi/L | | 12/15/21 14:35 | |
| Total Radium Calculation | Total Radium | 1.55 ± 1.06 (1.63) | pCi/L | | 12/16/21 17:28 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 194 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 194 | mg/L | 2.0 | 11/11/21 16:22 | |
| SM 2540C | Total Dissolved Solids | 1630 | mg/L | 20.0 | 11/10/21 09:11 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 11/10/21 16:47 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.51 | mg/L | 0.15 | 11/18/21 16:33 | |
| SM 5310C | Total Organic Carbon | 3.1 | mg/L | 1.0 | 11/17/21 02:45 | |
| SM 5310C | Dissolved Organic Carbon | 3.0 | mg/L | 1.0 | 11/19/21 00:48 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-103D** **Lab ID: 50302159001** Collected: 11/05/21 09:35 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **146** | mg/L | 25.0 | 100 | | 11/10/21 22:35 | 16887-00-6 | |
| Fluoride | **0.13** | mg/L | 0.10 | 1 | | 11/10/21 22:13 | 16984-48-8 | |
| Sulfate | **39.2** | mg/L | 25.0 | 100 | | 11/10/21 22:35 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7429-90-5 | |
| Barium | **321** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-39-3 | |
| Boron | **357** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-43-9 | |
| Calcium | **89100** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-47-3 | |
| Iron | **2190** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7439-93-2 | |
| Magnesium | **29600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7439-95-4 | |
| Manganese | **132** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7439-98-7 | |
| Potassium | **5500** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-09-7 | |
| Silica | **12600** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7631-86-9 | N2 |
| Sodium | **80600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:09 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **131** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:50 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:50 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:00 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:00 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:00 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:00 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **248** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Bicarbonate (CaCO3) | **248** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **581** | mg/L | 10.0 | 1 | | 11/10/21 09:10 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-103D** **Lab ID: 50302159001** Collected: 11/05/21 09:35 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 11/10/21 16:44 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 17:53 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:53 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:31 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.9** | mg/L | 1.0 | 1 | | 11/17/21 01:41 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.9** | mg/L | 1.0 | 1 | | 11/19/21 00:07 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-105D** **Lab ID: 50302159002** Collected: 11/05/21 11:55 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **113** | mg/L | 2.5 | 10 | | 11/10/21 23:14 | 16887-00-6 | |
| Fluoride | **0.20** | mg/L | 0.10 | 1 | | 11/10/21 22:54 | 16984-48-8 | |
| Sulfate | **87.8** | mg/L | 2.5 | 10 | | 11/10/21 23:14 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7429-90-5 | |
| Barium | **326** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-39-3 | |
| Boron | **628** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-43-9 | |
| Calcium | **106000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-47-3 | |
| Iron | **6010** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7439-93-2 | |
| Magnesium | **26000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7439-95-4 | |
| Manganese | **125** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7439-96-5 | |
| Molybdenum | **12.2** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7439-98-7 | |
| Potassium | **5280** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-09-7 | |
| Silica | **12700** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7631-86-9 | N2 |
| Sodium | **69300** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:12 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **120** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:52 | 7439-96-5 | |
| Molybdenum, Dissolved | **13.0** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:52 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:05 | 7440-36-0 | |
| Arsenic | **4.6** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:05 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:05 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:05 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **254** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Bicarbonate (CaCO3) | **254** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **590** | mg/L | 10.0 | 1 | | 11/10/21 09:11 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-105D** **Lab ID: 50302159002** Collected: 11/05/21 11:55 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/10/21 16:53 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 17:55 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:55 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.39** | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:32 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/17/21 02:20 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 11/19/21 00:19 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-107I** **Lab ID: 50302159003** Collected: 11/05/21 11:40 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **147** | mg/L | 25.0 | 100 | | 11/10/21 23:56 | 16887-00-6 | |
| Fluoride | **0.29** | mg/L | 0.10 | 1 | | 11/10/21 23:33 | 16984-48-8 | |
| Sulfate | **312** | mg/L | 25.0 | 100 | | 11/10/21 23:56 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **243** | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7429-90-5 | |
| Barium | **222** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-39-3 | |
| Boron | **3490** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-43-9 | |
| Calcium | **185000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-47-3 | |
| Iron | **6880** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7439-93-2 | |
| Magnesium | **55100** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7439-95-4 | |
| Manganese | **243** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7439-96-5 | |
| Molybdenum | **15.4** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7439-98-7 | |
| Potassium | **2930** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-09-7 | |
| Silica | **20700** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7631-86-9 | N2 |
| Sodium | **72600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:14 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **227** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:54 | 7439-96-5 | |
| Molybdenum, Dissolved | **18.8** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:54 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:10 | 7440-36-0 | |
| Arsenic | **3.6** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:10 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:10 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:10 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **307** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Bicarbonate (CaCO3) | **307** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **982** | mg/L | 20.0 | 1 | | 11/10/21 09:11 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-107I** **Lab ID: 50302159003** Collected: 11/05/21 11:40 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/10/21 16:50 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 17:57 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:57 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.66** | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:32 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **4.9** | mg/L | 1.0 | 1 | | 11/17/21 02:32 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **4.7** | mg/L | 1.0 | 1 | | 11/19/21 00:30 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-107D** **Lab ID: 50302159004** Collected: 11/05/21 10:45 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **214** | mg/L | 25.0 | 100 | | 11/11/21 00:34 | 16887-00-6 | |
| Fluoride | **0.21** | mg/L | 0.10 | 1 | | 11/11/21 00:15 | 16984-48-8 | |
| Sulfate | **696** | mg/L | 25.0 | 100 | | 11/11/21 00:34 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7429-90-5 | |
| Barium | **70.0** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7440-39-3 | |
| Boron | **9680** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7440-43-9 | |
| Calcium | **261000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:27 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7440-47-3 | |
| Iron | **7960** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7439-92-1 | |
| Lithium | **53.5** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7439-93-2 | |
| Magnesium | **49400** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7439-95-4 | |
| Manganese | **366** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7439-96-5 | |
| Molybdenum | **140** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7439-98-7 | |
| Potassium | **9880** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7440-09-7 | |
| Silica | **17500** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7631-86-9 | N2 |
| Sodium | **174000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:16 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **346** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:56 | 7439-96-5 | |
| Molybdenum, Dissolved | **161** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:56 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:14 | 7440-36-0 | |
| Arsenic | **2.1** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:14 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:14 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 07:14 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **194** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Bicarbonate (CaCO3) | **194** | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 16:22 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1630** | mg/L | 20.0 | 1 | | 11/10/21 09:11 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-107D** **Lab ID: 50302159004** Collected: 11/05/21 10:45 Received: 11/05/21 13:52 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 11/10/21 16:47 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 18:02 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 18:02 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.51** | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:33 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **3.1** | mg/L | 1.0 | 1 | | 11/17/21 02:45 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.0** | mg/L | 1.0 | 1 | | 11/19/21 00:48 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649560
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2993087 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/10/21 14:09 | |
| Fluoride | mg/L | ND | 0.10 | 11/10/21 14:09 | |
| Sulfate | mg/L | ND | 0.25 | 11/10/21 14:09 | |

LABORATORY CONTROL SAMPLE: 2993088

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 88 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.43 | 85 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 93 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993089 2993090

| Parameter | Units | 50302156001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 15.2 | 12.5 | 12.5 | 26.2 | 26.2 | 88 | 88 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.53 | 86 | 87 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 246 | 250 | 250 | 467 | 468 | 89 | 89 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649047
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2990952 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/16/21 12:10 | |
| Barium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Boron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Cadmium | ug/L | ND | 2.0 | 11/16/21 12:10 | |
| Calcium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Chromium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Iron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Lead | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Lithium | ug/L | ND | 20.0 | 11/16/21 12:10 | |
| Magnesium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Manganese | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Molybdenum | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Potassium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Silica | ug/L | ND | 450 | 11/16/21 12:10 | N2 |
| Sodium | ug/L | ND | 1000 | 11/16/21 12:10 | |

LABORATORY CONTROL SAMPLE: 2990953

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4590 | 92 | 80-120 | |
| Barium | ug/L | 1000 | 966 | 97 | 80-120 | |
| Boron | ug/L | 1000 | 980 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 935 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 5040 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 979 | 98 | 80-120 | |
| Iron | ug/L | 2500 | 2440 | 98 | 80-120 | |
| Lead | ug/L | 1000 | 931 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4800 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 985 | 98 | 80-120 | |
| Molybdenum | ug/L | 1000 | 965 | 97 | 80-120 | |
| Potassium | ug/L | 5000 | 5020 | 100 | 80-120 | |
| Silica | ug/L | 5350 | 5350 | 100 | | N2 |
| Sodium | ug/L | 5000 | 4900 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990954 2990955

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4640 | 4650 | 93 | 93 | 75-125 | 0 | 20 | |
| Barium | ug/L | 69.2 | 1000 | 1000 | 1010 | 1010 | 94 | 94 | 75-125 | 0 | 20 | |
| Boron | ug/L | 127 | 1000 | 1000 | 1120 | 1130 | 99 | 100 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 927 | 930 | 93 | 93 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 106000 | 5000 | 5000 | 108000 | 107000 | 46 | 18 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 947 | 954 | 95 | 95 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1230 | 2500 | 2500 | 3550 | 3550 | 93 | 93 | 75-125 | 0 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 886 | 893 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1010 | 1010 | 100 | 101 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 30700 | 5000 | 5000 | 34600 | 34200 | 78 | 71 | 75-125 | 1 | 20 | P6 |
| Manganese | ug/L | 118 | 1000 | 1000 | 1060 | 1070 | 95 | 96 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 955 | 962 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 2050 | 5000 | 5000 | 6940 | 7010 | 98 | 99 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12300 | 5350 | 5350 | 17200 | 17000 | 93 | 88 | | 2 | | N2 |
| Sodium | ug/L | 19500 | 5000 | 5000 | 23800 | 23500 | 85 | 79 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990956 2990957

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4620 | 4720 | 92 | 94 | 75-125 | 2 | 20 | |
| Barium | ug/L | 221 | 1000 | 1000 | 1150 | 1160 | 93 | 94 | 75-125 | 1 | 20 | |
| Boron | ug/L | 263 | 1000 | 1000 | 1260 | 1280 | 99 | 101 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 919 | 931 | 92 | 93 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 96600 | 5000 | 5000 | 100000 | 102000 | 77 | 113 | 75-125 | 2 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 946 | 958 | 94 | 96 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1670 | 2500 | 2500 | 3950 | 4000 | 91 | 93 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 871 | 881 | 87 | 88 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1000 | 1020 | 99 | 101 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 29300 | 5000 | 5000 | 33600 | 34200 | 86 | 97 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 303 | 1000 | 1000 | 1240 | 1260 | 93 | 96 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 948 | 960 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 7590 | 5000 | 5000 | 12400 | 12500 | 96 | 98 | 75-125 | 1 | 20 | |
| Silica | ug/L | 10900 | 5350 | 5350 | 15900 | 16100 | 94 | 98 | | 1 | | N2 |
| Sodium | ug/L | 73700 | 5000 | 5000 | 77300 | 78000 | 72 | 86 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649216
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2991499 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |

LABORATORY CONTROL SAMPLE: 2991500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 821 | 82 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 827 | 83 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991501 2991502

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 112 | 1000 | 1000 | 1070 | 1080 | 96 | 96 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 998 | 1010 | 100 | 100 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991503 2991504

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1230 | 1250 | 93 | 95 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 986 | 992 | 98 | 99 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649453
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2992568 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Arsenic | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Cobalt | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Selenium | ug/L | ND | 1.0 | 11/17/21 05:34 | |

LABORATORY CONTROL SAMPLE: 2992569

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.8 | 105 | 80-120 | |
| Arsenic | ug/L | 40 | 37.7 | 94 | 80-120 | |
| Cobalt | ug/L | 40 | 40.3 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 38.3 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992570 2992571

| Parameter | Units | 50302156001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.3 | 41.8 | 105 | 104 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 37.4 | 36.6 | 93 | 91 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.7 | 38.2 | 95 | 94 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.9 | 38.4 | 95 | 94 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649827 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2994532 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/11/21 16:22 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 16:22 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 16:22 | |

LABORATORY CONTROL SAMPLE: 2994533

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.6 | 99 | 90-110 | |

SAMPLE DUPLICATE: 2994534

| Parameter | Units | 50302159001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 248 | 254 | 3 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 248 | 254 | 3 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2994535

| Parameter | Units | 50302187003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 130 | 128 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 130 | 128 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649493 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2992747 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/10/21 09:08 | |

LABORATORY CONTROL SAMPLE: 2992748

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 300 | 100 | 80-120 | |

SAMPLE DUPLICATE: 2992749

| Parameter | Units | 50302141004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2590 | 2590 | 0 | 10 | |

SAMPLE DUPLICATE: 2992750

| Parameter | Units | 50302141005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1200 | 1170 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 649626
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

SAMPLE DUPLICATE: 2993451

| Parameter | Units | 50302144001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.0 | 7.2 | 2 | 2 | H3 |

SAMPLE DUPLICATE: 2993452

| Parameter | Units | 50302187003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.0 | 7.0 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 648936 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2990476 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 18:01 | |

LABORATORY CONTROL SAMPLE: 2990477

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990478 2990479

| Parameter | Units | 50302158001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.36 | 0.35 | 69 | 67 | 90-110 | 3 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 648910
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2990259 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/05/21 17:33 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/05/21 17:33 | |

LABORATORY CONTROL SAMPLE: 2990260

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.96 | 96 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 109 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990261 2990262

| Parameter | Units | 50302158001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.51 | 1 | 1 | 1.5 | 1.5 | 101 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 114 | 114 | 90-110 | 0 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 651262 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 3001515 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/18/21 16:17 | |

LABORATORY CONTROL SAMPLE: 3001516

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3001517 3001518

| Parameter | Units | 50302157001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 23.8 | | | 45.4 | 41.4 | | | | 9 | | |

MATRIX SPIKE SAMPLE: 3001519

| Parameter | Units | 50302159004 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.51 | | 2.1 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 650844 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2999712 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/17/21 00:52 | |

LABORATORY CONTROL SAMPLE: 2999713

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2999714 2999715

| Parameter | Units | 50302187003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.1 | 10 | 10 | 14.2 | 14.0 | 112 | 109 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 2999716

| Parameter | Units | 50302232002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.2 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 651325 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 3001931 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/18/21 22:41 | |

LABORATORY CONTROL SAMPLE: 3001932

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.7 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3001933 3001934

| Parameter | Units | 50302159004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 3.0 | 10 | 10 | 13.7 | 13.7 | 107 | 108 | 80-120 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-103D** **Lab ID: 50302159001** Collected: 11/05/21 09:35 Received: 11/05/21 13:52 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.02 ± 0.700 (0.880) C:NA T:84%** | pCi/L | 12/14/21 15:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.381 ± 0.386 (0.796) C:72% T:81%** | pCi/L | 12/15/21 14:37 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.40 ± 1.09 (1.68)** | pCi/L | 12/16/21 17:28 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-105D** **Lab ID: 50302159002** Collected: 11/05/21 11:55 Received: 11/05/21 13:52 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.00 ± 0.686 (0.862) C:NA T:84%** | pCi/L | 12/14/21 15:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.850 ± 0.536 (1.01) C:69% T:76%** | pCi/L | 12/15/21 14:37 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.85 ± 1.22 (1.87)** | pCi/L | 12/16/21 17:28 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-107I** **Lab ID: 50302159003** Collected: 11/05/21 11:40 Received: 11/05/21 13:52 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.585 ± 0.446 (0.519) C:NA T:89%** | pCi/L | 12/14/21 15:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.859 ± 0.443 (0.774) C:73% T:84%** | pCi/L | 12/15/21 14:34 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.44 ± 0.889 (1.29)** | pCi/L | 12/16/21 17:28 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

**Sample: MW-107D** **Lab ID: 50302159004** Collected: 11/05/21 10:45 Received: 11/05/21 13:52 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.908 ± 0.593 (0.727) C:NA T:94%** | pCi/L | 12/14/21 15:32 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.644 ± 0.463 (0.903) C:66% T:85%** | pCi/L | 12/15/21 14:35 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.55 ± 1.06 (1.63)** | pCi/L | 12/16/21 17:28 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 475144
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2295304 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.608 ± 0.347 (0.624) C:71% T:96% | pCi/L | 12/15/21 14:35 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

QC Batch: 475143
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

METHOD BLANK: 2295303 Matrix: Water
Associated Lab Samples: 50302159001, 50302159002, 50302159003, 50302159004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0835 ± 0.268 (0.517) C:NA T:94% | pCi/L | 12/14/21 15:11 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302159001** | **MW-103D** | EPA 9056 | 649560 | | |
| **50302159002** | **MW-105D** | EPA 9056 | 649560 | | |
| **50302159003** | **MW-107I** | EPA 9056 | 649560 | | |
| **50302159004** | **MW-107D** | EPA 9056 | 649560 | | |
| **50302159001** | **MW-103D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302159002** | **MW-105D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302159003** | **MW-107I** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302159004** | **MW-107D** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302159001** | **MW-103D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302159002** | **MW-105D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302159003** | **MW-107I** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302159004** | **MW-107D** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302159001** | **MW-103D** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302159002** | **MW-105D** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302159003** | **MW-107I** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302159004** | **MW-107D** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302159001** | **MW-103D** | EPA 903.1 | 475143 | | |
| **50302159002** | **MW-105D** | EPA 903.1 | 475143 | | |
| **50302159003** | **MW-107I** | EPA 903.1 | 475143 | | |
| **50302159004** | **MW-107D** | EPA 903.1 | 475143 | | |
| **50302159001** | **MW-103D** | EPA 904.0 | 475144 | | |
| **50302159002** | **MW-105D** | EPA 904.0 | 475144 | | |
| **50302159003** | **MW-107I** | EPA 904.0 | 475144 | | |
| **50302159004** | **MW-107D** | EPA 904.0 | 475144 | | |
| **50302159001** | **MW-103D** | Total Radium Calculation | 476561 | | |
| **50302159002** | **MW-105D** | Total Radium Calculation | 476561 | | |
| **50302159003** | **MW-107I** | Total Radium Calculation | 476561 | | |
| **50302159004** | **MW-107D** | Total Radium Calculation | 476561 | | |
| **50302159001** | **MW-103D** | SM 2320B | 649827 | | |
| **50302159002** | **MW-105D** | SM 2320B | 649827 | | |
| **50302159003** | **MW-107I** | SM 2320B | 649827 | | |
| **50302159004** | **MW-107D** | SM 2320B | 649827 | | |
| **50302159001** | **MW-103D** | SM 2540C | 649493 | | |
| **50302159002** | **MW-105D** | SM 2540C | 649493 | | |
| **50302159003** | **MW-107I** | SM 2540C | 649493 | | |
| **50302159004** | **MW-107D** | SM 2540C | 649493 | | |
| **50302159001** | **MW-103D** | SM 4500-H+B | 649626 | | |
| **50302159002** | **MW-105D** | SM 4500-H+B | 649626 | | |
| **50302159003** | **MW-107I** | SM 4500-H+B | 649626 | | |
| **50302159004** | **MW-107D** | SM 4500-H+B | 649626 | | |
| **50302159001** | **MW-103D** | SM 4500-S2-D | 648936 | | |
| **50302159002** | **MW-105D** | SM 4500-S2-D | 648936 | | |
| **50302159003** | **MW-107I** | SM 4500-S2-D | 648936 | | |
| **50302159004** | **MW-107D** | SM 4500-S2-D | 648936 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302159

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302159001** | **MW-103D** | EPA 353.2 | 648910 | | |
| **50302159002** | **MW-105D** | EPA 353.2 | 648910 | | |
| **50302159003** | **MW-107I** | EPA 353.2 | 648910 | | |
| **50302159004** | **MW-107D** | EPA 353.2 | 648910 | | |
| **50302159001** | **MW-103D** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302159002** | **MW-105D** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302159003** | **MW-107I** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302159004** | **MW-107D** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302159001** | **MW-103D** | SM 5310C | 650844 | | |
| **50302159002** | **MW-105D** | SM 5310C | 650844 | | |
| **50302159003** | **MW-107I** | SM 5310C | 650844 | | |
| **50302159004** | **MW-107D** | SM 5310C | 650844 | | |
| **50302159001** | **MW-103D** | SM 5310C | 651325 | | |
| **50302159002** | **MW-105D** | SM 5310C | 651325 | | |
| **50302159003** | **MW-107I** | SM 5310C | 651325 | | |
| **50302159004** | **MW-107D** | SM 5310C | 651325 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50302159

50302159

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

knowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.

Page : 1 Of

**Section A** — Required Client ...n:

**Section C** — Invoice Information:

| | | | |
|---|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: | |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: | |
| Indianapolis, IN 46256 | | Address: | Regulatory Agency |
| Email: mark.breting@atcgs.com | Purchase Order #: | Pace Quote: | |
| Phone: NONE Fax: | Project Name: Harding Street Profile 1 Report 2 | Pace Project Manager: hayden.putt@pacelabs.com, | State / Location |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 | IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Requested Analysis Filtered (Y/N) | | | | Y | | | | | Y | | | | |
| 1 | MW-103D | WT | | | | 11-5 | 935 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 2 | MW-105D | WT | | | | 11-5 | 1155 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 3 | MW-107I | WT | | | | 11-5 | 1140 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 003 |
| 4 | MW-107D | WT | | | | 11-5 | 1045 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 004 |
| 5 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 8 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 9 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 10 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 11 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 12 | | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 11-5 | 1352 | | 11/5/21 | 1352 | 1.9 | Y | N | Y |
| 6020 (Co, As, Se, Sb) | | | | | | | 2.1 | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | |
|---|---|---|---|
| PRINT Name of SAMPLER: P. Craig Hopper | | | |
| SIGNATURE of SAMPLER: | DATE Signed: 11-5-21 | | |

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** BC 1413 11/5/21

1. **Courier:** ☐ FED EX ☐ UPS ☒ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☒ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B (C) D E F

4. **Cooler Temperature:** ①1.9/1.9 ②2.1/2.1
Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☐ Bubble Bags ☒ None ☐ Other _____

6. **Ice Type:** ☒ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** Circle: ~~HNO3 (<2)~~ ~~H2SO4 (<2)~~ ~~NaOH (>10)~~ ~~NaOH/ZnAc (>9)~~ Any non-conformance to pH recommendations ~~will be noted~~ on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO2, NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

**COC PAGE** 1 **of** 1

## Sample Container Count

| COC Line Item | WGFU | R (SBS / DI / MeOH (only) / BK / Kit) | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | SL | ✓ | ✓ | |
| 2 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | ↓ | ↓ | ↓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

** Place a RED dot on containers that are out of conformance **

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 15, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 08, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50302256001** | **MW-102D** | Water | 11/08/21 12:40 | 11/08/21 14:00 |
| **50302256002** | **MW-102D MS** | Water | 11/08/21 12:40 | 11/08/21 14:00 |
| **50302256003** | **MW-102D MSD** | Water | 11/08/21 12:40 | 11/08/21 14:00 |
| **50302256004** | **MW-107S** | Water | 11/08/21 12:25 | 11/08/21 14:00 |
| **50302256005** | **Field Blank 2** | Water | 11/08/21 11:50 | 11/08/21 14:00 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50302256001** | **MW-102D** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG, RAM | 16 | PASI-I |
| | | EPA 6010 | JDG | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302256002** | **MW-102D MS** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| **50302256003** | **MW-102D MSD** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| **50302256004** | **MW-107S** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG, RAM | 15 | PASI-I |
| | | EPA 6010 | JDG | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| **50302256005** | **Field Blank 2** | EPA 9056 | RID | 3 | PASI-I |
| | | EPA 6010 | JDG, RAM | 15 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JC2 | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302256001** | **MW-102D** | | | | | |
| EPA 9056 | Chloride | 164 | mg/L | 25.0 | 11/12/21 09:13 | |
| EPA 9056 | Fluoride | 0.15 | mg/L | 0.10 | 11/12/21 08:36 | |
| EPA 9056 | Sulfate | 1180 | mg/L | 25.0 | 11/12/21 09:13 | |
| EPA 6010 | Barium | 62.8 | ug/L | 10.0 | 11/18/21 15:30 | |
| EPA 6010 | Boron | 21300 | ug/L | 100 | 11/18/21 15:59 | |
| EPA 6010 | Calcium | 310000 | ug/L | 1000 | 11/18/21 15:59 | E |
| EPA 6010 | Iron | 5030 | ug/L | 100 | 11/18/21 15:30 | |
| EPA 6010 | Lithium | 66.2 | ug/L | 20.0 | 11/18/21 15:59 | |
| EPA 6010 | Magnesium | 60800 | ug/L | 1000 | 11/18/21 15:30 | |
| EPA 6010 | Manganese | 461 | ug/L | 10.0 | 11/18/21 15:30 | |
| EPA 6010 | Molybdenum | 512 | ug/L | 10.0 | 11/18/21 15:30 | |
| EPA 6010 | Potassium | 14900 | ug/L | 1000 | 11/18/21 15:59 | |
| EPA 6010 | Silica | 12900 | ug/L | 450 | 11/18/21 15:30 | N2 |
| EPA 6010 | Silicon | 6040 | ug/L | 200 | 11/18/21 15:30 | |
| EPA 6010 | Sodium | 167000 | ug/L | 1000 | 11/18/21 15:59 | |
| EPA 6010 | Manganese, Dissolved | 446 | ug/L | 10.0 | 11/18/21 13:54 | |
| EPA 6010 | Molybdenum, Dissolved | 505 | ug/L | 10.0 | 11/18/21 13:54 | |
| EPA 6020 | Arsenic | 50.0 | ug/L | 1.0 | 11/12/21 06:29 | |
| EPA 903.1 | Radium-226 | 0.439 ± 0.364 (0.473) C:NA T:94% | pCi/L | | 12/10/21 14:13 | |
| EPA 904.0 | Radium-228 | 0.529 ± 0.640 (1.36) C:73% T:84% | pCi/L | | 12/09/21 18:33 | |
| Total Radium Calculation | Total Radium | 0.968 ± 1.00 (1.83) | pCi/L | | 12/13/21 16:24 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 96.4 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 96.4 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2540C | Total Dissolved Solids | 1990 | mg/L | 40.0 | 11/10/21 09:19 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/12/21 12:58 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.64 | mg/L | 0.15 | 11/20/21 11:27 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 11/18/21 22:50 | |
| SM 5310C | Dissolved Organic Carbon | 2.1 | mg/L | 1.0 | 11/19/21 22:39 | |
| **50302256002** | **MW-102D MS** | | | | | |
| EPA 903.1 | Radium-226 | 76.80 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 12/10/21 14:13 | |
| EPA 904.0 | Radium-228 | 83.13 %REC ± NA (NA) C:NA T:NA | pCi/L | | 12/09/21 18:37 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302256003** | **MW-102D MSD** | | | | | |
| EPA 903.1 | Radium-226 | 93.21 %REC 19.31 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 12/10/21 14:13 | |
| EPA 904.0 | Radium-228 | 93.38 %REC 11.62 RPD ± NA (NA) C:NA T:NA | pCi/L | | 12/09/21 18:38 | |
| **50302256004** | **MW-107S** | | | | | |
| EPA 9056 | Chloride | 296 | mg/L | 25.0 | 11/12/21 12:17 | |
| EPA 9056 | Fluoride | 0.65 | mg/L | 0.10 | 11/12/21 11:59 | |
| EPA 9056 | Sulfate | 834 | mg/L | 25.0 | 11/12/21 12:17 | |
| EPA 6010 | Barium | 22.4 | ug/L | 10.0 | 11/18/21 15:44 | |
| EPA 6010 | Boron | 7120 | ug/L | 100 | 11/18/21 16:10 | |
| EPA 6010 | Calcium | 246000 | ug/L | 2000 | 11/19/21 08:09 | |
| EPA 6010 | Iron | 2270 | ug/L | 100 | 11/18/21 15:44 | |
| EPA 6010 | Lithium | 82.5 | ug/L | 20.0 | 11/18/21 16:10 | |
| EPA 6010 | Magnesium | 84800 | ug/L | 1000 | 11/18/21 15:44 | |
| EPA 6010 | Manganese | 455 | ug/L | 10.0 | 11/18/21 15:44 | |
| EPA 6010 | Molybdenum | 82.5 | ug/L | 10.0 | 11/18/21 15:44 | |
| EPA 6010 | Potassium | 12800 | ug/L | 1000 | 11/18/21 16:10 | |
| EPA 6010 | Silica | 12700 | ug/L | 450 | 11/18/21 15:44 | N2 |
| EPA 6010 | Sodium | 242000 | ug/L | 2000 | 11/19/21 08:09 | |
| EPA 6010 | Manganese, Dissolved | 447 | ug/L | 10.0 | 11/18/21 14:05 | |
| EPA 6010 | Molybdenum, Dissolved | 80.3 | ug/L | 10.0 | 11/18/21 14:05 | |
| EPA 903.1 | Radium-226 | 0.526 ± 0.565 (0.824) C:NA T:94% | pCi/L | | 12/10/21 14:13 | |
| EPA 904.0 | Radium-228 | 0.977 ± 0.725 (1.44) C:72% T:84% | pCi/L | | 12/09/21 18:39 | |
| Total Radium Calculation | Total Radium | 1.50 ± 1.29 (2.26) | pCi/L | | 12/13/21 16:24 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 201 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 201 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2540C | Total Dissolved Solids | 1830 | mg/L | 40.0 | 11/10/21 09:19 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 11/12/21 13:00 | H3 |
| SM 5310C | Total Organic Carbon | 1.5 | mg/L | 1.0 | 11/19/21 00:35 | |
| SM 5310C | Dissolved Organic Carbon | 1.6 | mg/L | 1.0 | 11/19/21 23:16 | |
| **50302256005** | **Field Blank 2** | | | | | |
| EPA 903.1 | Radium-226 | 0.136 ± 0.279 (0.458) C:NA T:96% | pCi/L | | 12/10/21 14:13 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302256005** | **Field Blank 2** | | | | | |
| EPA 904.0 | Radium-228 | 0.365 ± 0.589 (1.28) C:73% T:85% | pCi/L | | 12/09/21 18:39 | |
| Total Radium Calculation | Total Radium | 0.501 ± 0.868 (1.74) | pCi/L | | 12/13/21 16:24 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 2.2 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 2.2 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/12/21 13:05 | H3 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-102D** **Lab ID: 50302256001** Collected: 11/08/21 12:40 Received: 11/08/21 14:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **164** | mg/L | 25.0 | 100 | | 11/12/21 09:13 | 16887-00-6 | |
| Fluoride | **0.15** | mg/L | 0.10 | 1 | | 11/12/21 08:36 | 16984-48-8 | |
| Sulfate | **1180** | mg/L | 25.0 | 100 | | 11/12/21 09:13 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7429-90-5 | |
| Barium | **62.8** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7440-39-3 | |
| Boron | **21300** | ug/L | 100 | 1 | 11/16/21 06:55 | 11/18/21 15:59 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7440-43-9 | |
| Calcium | **310000** | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 15:59 | 7440-70-2 | E |
| Chromium | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7440-47-3 | |
| Iron | **5030** | ug/L | 100 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7439-92-1 | |
| Lithium | **66.2** | ug/L | 20.0 | 1 | 11/16/21 06:55 | 11/18/21 15:59 | 7439-93-2 | |
| Magnesium | **60800** | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7439-95-4 | |
| Manganese | **461** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7439-96-5 | |
| Molybdenum | **512** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7439-98-7 | |
| Potassium | **14900** | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 15:59 | 7440-09-7 | |
| Silica | **12900** | ug/L | 450 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7631-86-9 | N2 |
| Silicon | **6040** | ug/L | 200 | 1 | 11/16/21 06:55 | 11/18/21 15:30 | 7440-21-3 | |
| Sodium | **167000** | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 15:59 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **446** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 13:54 | 7439-96-5 | |
| Molybdenum, Dissolved | **505** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 13:54 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:29 | 7440-36-0 | |
| Arsenic | **50.0** | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:29 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:29 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:29 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **96.4** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **96.4** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1990** | mg/L | 40.0 | 1 | | 11/10/21 09:19 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-102D** **Lab ID: 50302256001** Collected: 11/08/21 12:40 Received: 11/08/21 14:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/12/21 12:58 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/11/21 10:30 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/08/21 18:04 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/08/21 18:04 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.64** | mg/L | 0.15 | 1 | 11/19/21 09:30 | 11/20/21 11:27 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 11/18/21 22:50 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 11/19/21 22:39 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-107S** **Lab ID: 50302256004** Collected: 11/08/21 12:25 Received: 11/08/21 14:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **296** | mg/L | 25.0 | 100 | | 11/12/21 12:17 | 16887-00-6 | |
| Fluoride | **0.65** | mg/L | 0.10 | 1 | | 11/12/21 11:59 | 16984-48-8 | |
| Sulfate | **834** | mg/L | 25.0 | 100 | | 11/12/21 12:17 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7429-90-5 | |
| Barium | **22.4** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7440-39-3 | |
| Boron | **7120** | ug/L | 100 | 1 | 11/16/21 06:55 | 11/18/21 16:10 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7440-43-9 | |
| Calcium | **246000** | ug/L | 2000 | 2 | 11/16/21 06:55 | 11/19/21 08:09 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7440-47-3 | |
| Iron | **2270** | ug/L | 100 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7439-92-1 | |
| Lithium | **82.5** | ug/L | 20.0 | 1 | 11/16/21 06:55 | 11/18/21 16:10 | 7439-93-2 | |
| Magnesium | **84800** | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7439-95-4 | |
| Manganese | **455** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7439-96-5 | |
| Molybdenum | **82.5** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7439-98-7 | |
| Potassium | **12800** | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 16:10 | 7440-09-7 | |
| Silica | **12700** | ug/L | 450 | 1 | 11/16/21 06:55 | 11/18/21 15:44 | 7631-86-9 | N2 |
| Sodium | **242000** | ug/L | 2000 | 2 | 11/16/21 06:55 | 11/19/21 08:09 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **447** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 14:05 | 7439-96-5 | |
| Molybdenum, Dissolved | **80.3** | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 14:05 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:53 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:53 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:53 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:53 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **201** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **201** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1830** | mg/L | 40.0 | 1 | | 11/10/21 09:19 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-107S** **Lab ID: 50302256004** Collected: 11/08/21 12:25 Received: 11/08/21 14:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 1 | | 11/12/21 13:00 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/11/21 10:30 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/08/21 18:02 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/08/21 18:02 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/19/21 09:30 | 11/20/21 11:29 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.5** | mg/L | 1.0 | 1 | | 11/19/21 00:35 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 11/19/21 23:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: Field Blank 2** **Lab ID: 50302256005** Collected: 11/08/21 11:50 Received: 11/08/21 14:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | ND | mg/L | 0.25 | 1 | | 11/12/21 13:13 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 11/12/21 13:13 | 16984-48-8 | |
| Sulfate | ND | mg/L | 0.25 | 1 | | 11/12/21 13:13 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7429-90-5 | |
| Barium | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7440-39-3 | |
| Boron | ND | ug/L | 100 | 1 | 11/16/21 06:55 | 11/18/21 16:12 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7440-43-9 | |
| Calcium | ND | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 16:12 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 11/16/21 06:55 | 11/18/21 16:12 | 7439-93-2 | |
| Magnesium | ND | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7439-98-7 | |
| Potassium | ND | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/19/21 08:11 | 7440-09-7 | |
| Silica | ND | ug/L | 450 | 1 | 11/16/21 06:55 | 11/18/21 15:47 | 7631-86-9 | N2 |
| Sodium | ND | ug/L | 1000 | 1 | 11/16/21 06:55 | 11/19/21 08:11 | 7440-23-5 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:57 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:57 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:57 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/12/21 06:57 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **2.2** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **2.2** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | ND | mg/L | 10.0 | 1 | | 11/10/21 09:20 | | PL |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 11/12/21 13:05 | | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: Field Blank 2** **Lab ID: 50302256005** Collected: 11/08/21 11:50 Received: 11/08/21 14:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/11/21 10:30 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/08/21 18:00 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/08/21 18:00 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 11/19/21 09:30 | 11/20/21 11:30 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 11/19/21 00:54 | 7440-44-0 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649633
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2993474 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/12/21 02:45 | |
| Fluoride | mg/L | ND | 0.10 | 11/12/21 02:45 | |
| Sulfate | mg/L | ND | 0.25 | 11/12/21 02:45 | |

LABORATORY CONTROL SAMPLE: 2993475

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 95 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.47 | 94 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 92 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993476 2993477

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 164 | 125 | 125 | 289 | 287 | 100 | 98 | 80-120 | 1 | 15 | |
| Fluoride | mg/L | 0.15 | 0.5 | 0.5 | 0.58 | 0.58 | 87 | 87 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 1180 | 250 | 250 | 1400 | 1400 | 90 | 87 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649725
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2994098 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/18/21 14:25 | |
| Barium | ug/L | ND | 10.0 | 11/18/21 14:25 | |
| Boron | ug/L | ND | 100 | 11/18/21 14:25 | |
| Cadmium | ug/L | ND | 2.0 | 11/18/21 14:25 | |
| Calcium | ug/L | ND | 1000 | 11/18/21 14:25 | |
| Chromium | ug/L | ND | 10.0 | 11/18/21 14:25 | |
| Iron | ug/L | ND | 100 | 11/18/21 14:25 | |
| Lead | ug/L | ND | 10.0 | 11/18/21 14:25 | |
| Lithium | ug/L | ND | 20.0 | 11/18/21 15:54 | |
| Magnesium | ug/L | ND | 1000 | 11/18/21 14:25 | |
| Manganese | ug/L | ND | 10.0 | 11/18/21 14:25 | |
| Molybdenum | ug/L | ND | 10.0 | 11/18/21 14:25 | |
| Potassium | ug/L | ND | 1000 | 11/18/21 15:54 | |
| Silica | ug/L | ND | 450 | 11/18/21 14:25 | N2 |
| Silicon | ug/L | ND | 200 | 11/18/21 14:25 | |
| Sodium | ug/L | ND | 1000 | 11/18/21 15:54 | |

LABORATORY CONTROL SAMPLE: 2994099

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4770 | 95 | 80-120 | |
| Barium | ug/L | 1000 | 994 | 99 | 80-120 | |
| Boron | ug/L | 1000 | 983 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 932 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 4790 | 96 | 80-120 | |
| Chromium | ug/L | 1000 | 980 | 98 | 80-120 | |
| Iron | ug/L | 2500 | 2290 | 92 | 80-120 | |
| Lead | ug/L | 1000 | 918 | 92 | 80-120 | |
| Lithium | ug/L | 1000 | 951 | 95 | 80-120 | |
| Magnesium | ug/L | 5000 | 4610 | 92 | 80-120 | |
| Manganese | ug/L | 1000 | 933 | 93 | 80-120 | |
| Molybdenum | ug/L | 1000 | 969 | 97 | 80-120 | |
| Potassium | ug/L | 5000 | 4810 | 96 | 80-120 | |
| Silica | ug/L | 5350 | 5140 | 96 | | N2 |
| Silicon | ug/L | 2500 | 2400 | 96 | 80-120 | |
| Sodium | ug/L | 5000 | 4550 | 91 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2994100 2994101

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4860 | 4840 | 95 | 95 | 75-125 | 1 | 20 | |
| Barium | ug/L | 62.8 | 1000 | 1000 | 1060 | 1060 | 100 | 99 | 75-125 | 1 | 20 | |
| Boron | ug/L | 21300 | 1000 | 1000 | 22200 | 22300 | 85 | 97 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 965 | 959 | 97 | 96 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 310000 | 5000 | 5000 | 317000 | 314000 | 136 | 74 | 75-125 | 1 | 20 | E,P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 964 | 958 | 96 | 96 | 75-125 | 1 | 20 | |
| Iron | ug/L | 5030 | 2500 | 2500 | 7140 | 7100 | 84 | 83 | 75-125 | 0 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 855 | 858 | 85 | 86 | 75-125 | 0 | 20 | |
| Lithium | ug/L | 66.2 | 1000 | 1000 | 1040 | 1050 | 97 | 98 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 60800 | 5000 | 5000 | 63800 | 63400 | 62 | 53 | 75-125 | 1 | 20 | P6 |
| Manganese | ug/L | 461 | 1000 | 1000 | 1350 | 1350 | 89 | 89 | 75-125 | 0 | 20 | |
| Molybdenum | ug/L | 512 | 1000 | 1000 | 1470 | 1470 | 96 | 96 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 14900 | 5000 | 5000 | 19800 | 19800 | 98 | 99 | 75-125 | 0 | 20 | |
| Silica | ug/L | 12900 | 5350 | 5350 | 16900 | 18200 | 74 | 98 | | 7 | | N2 |
| Silicon | ug/L | 6040 | 2500 | 2500 | 7880 | 8490 | 74 | 98 | 75-125 | 7 | 20 | M0 |
| Sodium | ug/L | 167000 | 5000 | 5000 | 174000 | 170000 | 126 | 62 | 75-125 | 2 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649731
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004

METHOD BLANK: 2994134 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/18/21 12:51 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/18/21 12:51 | |

LABORATORY CONTROL SAMPLE: 2994135

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 932 | 93 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 979 | 98 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2994136 2994137

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 446 | 1000 | 1000 | 1360 | 1370 | 91 | 92 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | 505 | 1000 | 1000 | 1470 | 1480 | 97 | 97 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649456
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2992580 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/12/21 06:19 | |
| Arsenic | ug/L | ND | 1.0 | 11/12/21 06:19 | |
| Cobalt | ug/L | ND | 1.0 | 11/12/21 06:19 | |
| Selenium | ug/L | ND | 1.0 | 11/12/21 06:19 | |

LABORATORY CONTROL SAMPLE: 2992581

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Arsenic | ug/L | 40 | 36.4 | 91 | 80-120 | |
| Cobalt | ug/L | 40 | 38.9 | 97 | 80-120 | |
| Selenium | ug/L | 40 | 38.6 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992582 2992583

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 40.7 | 40.0 | 101 | 100 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | 50.0 | 40 | 40 | 87.9 | 86.8 | 95 | 92 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 36.3 | 36.2 | 90 | 89 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.8 | 38.6 | 96 | 96 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649826 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2994528 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/11/21 14:08 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 14:08 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 14:08 | |

LABORATORY CONTROL SAMPLE: 2994529

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 47.9 | 96 | 90-110 | |

SAMPLE DUPLICATE: 2994530

| Parameter | Units | 50302108006 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 676 | 691 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 676 | 691 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2994531

| Parameter | Units | 50302256001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 96.4 | 102 | 5 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 96.4 | 102 | 5 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649495 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2992762 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/10/21 09:16 | |

LABORATORY CONTROL SAMPLE: 2992763

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 292 | 97 | 80-120 | |

SAMPLE DUPLICATE: 2992764

| Parameter | Units | 50302187003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 209 | 196 | 6 | 10 | |

SAMPLE DUPLICATE: 2992765

| Parameter | Units | 50302256001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1990 | 1910 | 4 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 650034
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

SAMPLE DUPLICATE: 2995987

| Parameter | Units | 50302450001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.9 | 7.9 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 2995988

| Parameter | Units | 50302256001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649783
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2994347 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/11/21 10:30 | |

LABORATORY CONTROL SAMPLE: 2994348

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.52 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2994349 2994350

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.43 | 0.42 | 81 | 79 | 90-110 | 1 | 20 | M3 |

MATRIX SPIKE SAMPLE: 2994351

| Parameter | Units | 50302275001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.50 | 100 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 649158
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 2991311 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/08/21 17:29 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/08/21 17:29 | |

LABORATORY CONTROL SAMPLE: 2991312

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 100 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 110 | 90-110 | |

MATRIX SPIKE SAMPLE: 2991313

| Parameter | Units | 50302232005 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1.0 | 95 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1.1 | 106 | 90-110 | |

MATRIX SPIKE SAMPLE: 2991314

| Parameter | Units | 50302256001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1.0 | 94 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1.1 | 107 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 651470 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 3002746 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/20/21 11:19 | |

LABORATORY CONTROL SAMPLE: 3002747

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE SAMPLE: 3002748

| Parameter | Units | 50302232002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3002749 3002750

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.64 | | | 2.3 | 2.2 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 651378
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004, 50302256005

METHOD BLANK: 3002344 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004, 50302256005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/18/21 20:17 | |

LABORATORY CONTROL SAMPLE: 3002345

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3002346 3002347

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.8 | 10 | 10 | 11.6 | 11.6 | 98 | 98 | 80-120 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3002350 3002351

| Parameter | Units | 50302278003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 13.3 | 10 | 10 | 22.7 | 22.9 | 94 | 95 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 651634
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302256001, 50302256004

METHOD BLANK: 3003579 Matrix: Water
Associated Lab Samples: 50302256001, 50302256004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/19/21 18:02 | |

LABORATORY CONTROL SAMPLE: 3003580

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.6 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3003581 3003582

| Parameter | Units | 50302187003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 3.1 | 10 | 10 | 14.4 | 14.3 | 113 | 112 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3003583 3003584

| Parameter | Units | 50302256001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.1 | 10 | 10 | 12.8 | 13.2 | 107 | 111 | 80-120 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-102D** **Lab ID: 50302256001** Collected: 11/08/21 12:40 Received: 11/08/21 14:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.439 ± 0.364 (0.473) C:NA T:94%** | pCi/L | 12/10/21 14:13 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.529 ± 0.640 (1.36) C:73% T:84%** | pCi/L | 12/09/21 18:33 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.968 ± 1.00 (1.83)** | pCi/L | 12/13/21 16:24 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-102D MS** **Lab ID: 50302256002** Collected: 11/08/21 12:40 Received: 11/08/21 14:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **76.80 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 12/10/21 14:13 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **83.13 %REC ± NA (NA) C:NA T:NA** | pCi/L | 12/09/21 18:37 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-102D MSD** **Lab ID: 50302256003** Collected: 11/08/21 12:40 Received: 11/08/21 14:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **93.21 %REC 19.31 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 12/10/21 14:13 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **93.38 %REC 11.62 RPD ± NA (NA) C:NA T:NA** | pCi/L | 12/09/21 18:38 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: MW-107S** **Lab ID: 50302256004** Collected: 11/08/21 12:25 Received: 11/08/21 14:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.526 ± 0.565 (0.824) C:NA T:94%** | pCi/L | 12/10/21 14:13 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.977 ± 0.725 (1.44) C:72% T:84%** | pCi/L | 12/09/21 18:39 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.50 ± 1.29 (2.26)** | pCi/L | 12/13/21 16:24 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

**Sample: Field Blank 2** **Lab ID: 50302256005** Collected: 11/08/21 11:50 Received: 11/08/21 14:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.136 ± 0.279 (0.458) C:NA T:96%** | pCi/L | 12/10/21 14:13 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.365 ± 0.589 (1.28) C:73% T:85%** | pCi/L | 12/09/21 18:39 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.501 ± 0.868 (1.74)** | pCi/L | 12/13/21 16:24 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 473887
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302256001, 50302256002, 50302256003, 50302256004, 50302256005

METHOD BLANK: 2289254 Matrix: Water
Associated Lab Samples: 50302256001, 50302256002, 50302256003, 50302256004, 50302256005

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.0179 ± 0.350 (0.813) C:65% T:87% | pCi/L | 12/09/21 14:55 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

QC Batch: 473886 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302256001, 50302256002, 50302256003, 50302256004, 50302256005

METHOD BLANK: 2289252 Matrix: Water
Associated Lab Samples: 50302256001, 50302256002, 50302256003, 50302256004, 50302256005

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0660 ± 0.308 (0.553) C:NA T:89% | pCi/L | 12/10/21 13:53 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| E | Analyte concentration exceeded the calibration range. The reported result is estimated. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| PL | The minimum mass of dried residue of 2.5 mg could not be obtained using the routine sample volume of 100 mL. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302256001** | **MW-102D** | EPA 9056 | 649633 | | |
| **50302256004** | **MW-107S** | EPA 9056 | 649633 | | |
| **50302256005** | **Field Blank 2** | EPA 9056 | 649633 | | |
| **50302256001** | **MW-102D** | EPA 3010 | 649725 | EPA 6010 | 651227 |
| **50302256004** | **MW-107S** | EPA 3010 | 649725 | EPA 6010 | 651227 |
| **50302256005** | **Field Blank 2** | EPA 3010 | 649725 | EPA 6010 | 651227 |
| **50302256001** | **MW-102D** | EPA 3010 | 649731 | EPA 6010 | 651222 |
| **50302256004** | **MW-107S** | EPA 3010 | 649731 | EPA 6010 | 651222 |
| **50302256001** | **MW-102D** | EPA 200.2 | 649456 | EPA 6020 | 649629 |
| **50302256004** | **MW-107S** | EPA 200.2 | 649456 | EPA 6020 | 649629 |
| **50302256005** | **Field Blank 2** | EPA 200.2 | 649456 | EPA 6020 | 649629 |
| **50302256001** | **MW-102D** | EPA 903.1 | 473886 | | |
| **50302256002** | **MW-102D MS** | EPA 903.1 | 473886 | | |
| **50302256003** | **MW-102D MSD** | EPA 903.1 | 473886 | | |
| **50302256004** | **MW-107S** | EPA 903.1 | 473886 | | |
| **50302256005** | **Field Blank 2** | EPA 903.1 | 473886 | | |
| **50302256001** | **MW-102D** | EPA 904.0 | 473887 | | |
| **50302256002** | **MW-102D MS** | EPA 904.0 | 473887 | | |
| **50302256003** | **MW-102D MSD** | EPA 904.0 | 473887 | | |
| **50302256004** | **MW-107S** | EPA 904.0 | 473887 | | |
| **50302256005** | **Field Blank 2** | EPA 904.0 | 473887 | | |
| **50302256001** | **MW-102D** | Total Radium Calculation | 476118 | | |
| **50302256004** | **MW-107S** | Total Radium Calculation | 476118 | | |
| **50302256005** | **Field Blank 2** | Total Radium Calculation | 476118 | | |
| **50302256001** | **MW-102D** | SM 2320B | 649826 | | |
| **50302256004** | **MW-107S** | SM 2320B | 649826 | | |
| **50302256005** | **Field Blank 2** | SM 2320B | 649826 | | |
| **50302256001** | **MW-102D** | SM 2540C | 649495 | | |
| **50302256004** | **MW-107S** | SM 2540C | 649495 | | |
| **50302256005** | **Field Blank 2** | SM 2540C | 649495 | | |
| **50302256001** | **MW-102D** | SM 4500-H+B | 650034 | | |
| **50302256004** | **MW-107S** | SM 4500-H+B | 650034 | | |
| **50302256005** | **Field Blank 2** | SM 4500-H+B | 650034 | | |
| **50302256001** | **MW-102D** | SM 4500-S2-D | 649783 | | |
| **50302256004** | **MW-107S** | SM 4500-S2-D | 649783 | | |
| **50302256005** | **Field Blank 2** | SM 4500-S2-D | 649783 | | |
| **50302256001** | **MW-102D** | EPA 353.2 | 649158 | | |
| **50302256004** | **MW-107S** | EPA 353.2 | 649158 | | |
| **50302256005** | **Field Blank 2** | EPA 353.2 | 649158 | | |
| **50302256001** | **MW-102D** | EPA 365.1 | 651470 | EPA 365.1 | 651748 |
| **50302256004** | **MW-107S** | EPA 365.1 | 651470 | EPA 365.1 | 651748 |
| **50302256005** | **Field Blank 2** | EPA 365.1 | 651470 | EPA 365.1 | 651748 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50302256

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302256001** | **MW-102D** | SM 5310C | 651378 | | |
| **50302256004** | **MW-107S** | SM 5310C | 651378 | | |
| **50302256005** | **Field Blank 2** | SM 5310C | 651378 | | |
| **50302256001** | **MW-102D** | SM 5310C | 651634 | | |
| **50302256004** | **MW-107S** | SM 5310C | 651634 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50302256

50302256

Pace Anal
WWW.PACELAB

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

dgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



**Section A**
**Required Client Informa...**

| | |
|---|---|
| Company: | ATC Group Services |
| Address: | 7988 Centerpoint Drive |
| | Indianapolis, IN 46256 |
| Email: | mark.breting@atcgs.com |
| Phone: NONE | Fax: |
| Requested Due Date: | |

**Required Project Information:**

| | |
|---|---|
| Report To: | Mark Breting |
| Copy To: | |
| Purchase Order #: | |
| Project Name: | Harding Street Profile 1 Report 2 |
| Project #: | |

**Section C**
**Invoice Information:**

| | |
|---|---|
| Attention: | |
| Company Name: | |
| Address: | |
| Pace Quote: | |
| Pace Project Manager: | hayden.putt@pacelabs.com, |
| Pace Profile #: | 6246 Line 30 |

**Regulatory Agency**

**State / Location**
IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Y/N | | | | Y | | | | Y | | | | |
| 1 | M-4 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 2 | PZ-100S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 3 | PZ-100D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 4 | PZ-101S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 5 | PZ-101D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | MW-102S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-102D | WT | | | | 11.8.21 | 1240 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001,002,003 |
| 8 | MW-103S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 9 | MW-103I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 10 | MW-103D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 11 | MW-104S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 12 | MW-104D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 11.8.21 | 1400 | | 11-8-21 | 1400 | 4.6 | Y | N | Y |
| 3020 (Co, As, Se, Sb) | | | | | | | 0.2 | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | |
|---|---|---|---|
| PRINT Name of SAMPLER: | | | |
| SIGNATURE of SAMPLER: | DATE Signed: 11.8.21 | | |

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | ATC Group Services | Report To: | Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | | Company Name: | |
| Indianapolis, IN 46256 | | | | Address: | |
| Email: | mark.breting@atcgs.com | Purchase Order #: | | Pace Quote: | |
| Phone: | NONE Fax: | Project Name: | Harding Street Profile 1 Report 2 | Pace Project Manager: | hayden.putt@pacelabs.com, |
| Requested Due Date: | | Project #: | | Pace Profile #: | 6246 Line 30 |

Regulatory Agency: —
State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | |
| 13 | MW-105S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 14 | MW-105I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 15 | MW-105D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 16 | MW-106S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 17 | MW-106I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 18 | MW-106D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 19 | MW-107S | WT | | | | 11-8-21 | 1225 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 004 |
| 20 | MW-107I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 21 | MW-107D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 22 | MW-108S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 23 | MW-108D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 24 | DUP 3 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | [signature] ATC | 11-8-21 | 1400 | [signature] | 11-8-21 | 1400 | 4.6 | Y | N | Y |
| 6020 (Co, As, Se, Sb) | | | | | | | 0.2 | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: [signature]

SIGNATURE of SAMPLER: [signature] DATE Signed: 11-8-21

TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N)

# CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical® WWW.PACELABS.COM

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A Required Client Information: | | Section B Required Project Information: | Section C Invoice Information: | |
|---|---|---|---|---|
| Company: | ATC Group Services | Report To: Mark Breting | Attention: | |
| Address: | 7988 Centerpoint Drive | Copy To: | Company Name: | Regulatory Agency |
| Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@atcgs.com | Purchase Order #: | Pace Quote: | |
| Phone: NONE | Fax: | Project Name: Harding Street Profile 1 Report 2 | Pace Project Manager: hayden.putt@pacelabs.com, | State / Location |
| Requested Due Date: | | Project #: | Pace Profile #: 6246 Line 30 | IN |

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | | |
| 25 | DUP 4 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 26 | Field Blank 2 | WT | | | | 11.8.21 | 1150 | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | X | | 005 |
| 27 | MS3 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 28 | MSD3 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 29 | MS4 | WT | | | | 11.8.21 | 1240 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | 1020 |
| 30 | MSD4 | WT | | | | 11.8.21 | 1240 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | 1020 |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 11-8-21 | 1400 | | 11-8-21 | 1400 | 4.6 | Y | N | Y |
| 6020 (Co, As, Se, Sb) | | | | | | | 0.2 | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | | | | | | |
| SIGNATURE of SAMPLER: | DATE Signed: 11-8-21 | | | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** WS 11-8-21 1410

1. **Courier:** ☐ FED EX ☐ UPS ☑ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 (A) B C D E F

4. **Cooler Temperature:** 4.0/4.0, 0.2/0.2
Temp should be above freezing to 6°C **(Initial/Corrected)**

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9) Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO2/NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1435 | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | Present | Absent | N/A ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

**COC PAGE** 1 **of** 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

1/6 BPIN - pH 7
5/6 BPIN - ✓
** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | WT | W | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE** 2 of 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | W | ✓ | ✓ | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE** 3 of 3

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | 1 | + WS | | | 2 | 1 | 2 | 1 | + WS | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

February 14, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 05, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Guam Certification
Florida: Cert E871149 SEKS WET
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50302158005** | **M-4** | Water | 11/04/21 11:30 | 11/05/21 13:25 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50302158005** | **M-4** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | RAM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SWJ | 3 | PASI-I |
| | | SM 2540C | OAS | 1 | PASI-I |
| | | SM 4500-H+B | ZM | 1 | PASI-I |
| | | SM 4500-S2-D | ZM | 1 | PASI-I |
| | | EPA 353.2 | SKK | 2 | PASI-I |
| | | EPA 365.1 | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |
| | | SM 5310C | GWA | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50302158005** | **M-4** | | | | | |
| EPA 9056 | Chloride | 100 | mg/L | 25.0 | 11/10/21 20:52 | |
| EPA 9056 | Fluoride | 0.17 | mg/L | 0.10 | 11/10/21 20:33 | |
| EPA 9056 | Sulfate | 525 | mg/L | 25.0 | 11/10/21 20:52 | |
| EPA 6010 | Barium | 151 | ug/L | 10.0 | 11/16/21 13:07 | |
| EPA 6010 | Boron | 19000 | ug/L | 100 | 11/16/21 13:07 | |
| EPA 6010 | Calcium | 262000 | ug/L | 2000 | 11/16/21 14:25 | |
| EPA 6010 | Iron | 4150 | ug/L | 100 | 11/16/21 13:07 | |
| EPA 6010 | Lithium | 235 | ug/L | 20.0 | 11/16/21 13:07 | |
| EPA 6010 | Magnesium | 47600 | ug/L | 1000 | 11/16/21 13:07 | |
| EPA 6010 | Manganese | 807 | ug/L | 10.0 | 11/16/21 13:07 | |
| EPA 6010 | Molybdenum | 266 | ug/L | 10.0 | 11/16/21 13:07 | |
| EPA 6010 | Potassium | 18600 | ug/L | 1000 | 11/16/21 13:07 | |
| EPA 6010 | Silica | 13000 | ug/L | 450 | 11/16/21 13:07 | N2 |
| EPA 6010 | Sodium | 113000 | ug/L | 1000 | 11/16/21 13:07 | |
| EPA 6010 | Manganese, Dissolved | 785 | ug/L | 10.0 | 11/16/21 03:48 | |
| EPA 6010 | Molybdenum, Dissolved | 265 | ug/L | 10.0 | 11/16/21 03:48 | |
| EPA 6020 | Arsenic | 867 | ug/L | 10.0 | 11/17/21 06:46 | |
| EPA 903.1 | Radium-226 | 1.15 ± 0.735 (0.923) C:NA T:98% | pCi/L | | 12/07/21 14:05 | |
| EPA 904.0 | Radium-228 | 1.31 ± 0.626 (1.06) C:72% T:88% | pCi/L | | 12/07/21 17:28 | |
| Total Radium Calculation | Total Radium | 2.46 ± 1.36 (1.98) | pCi/L | | 12/08/21 14:55 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 392 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 392 | mg/L | 2.0 | 11/11/21 14:08 | |
| SM 2540C | Total Dissolved Solids | 1370 | mg/L | 20.0 | 11/10/21 09:10 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 11/10/21 16:12 | H3 |
| EPA 365.1 | Phosphate as P04 | 2.8 | mg/L | 0.15 | 11/18/21 16:31 | |
| SM 5310C | Total Organic Carbon | 7.8 | mg/L | 1.0 | 11/17/21 01:29 | |
| SM 5310C | Dissolved Organic Carbon | 5.5 | mg/L | 1.0 | 11/18/21 23:56 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

**Sample: M-4** **Lab ID: 50302158005** Collected: 11/04/21 11:30 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **100** | mg/L | 25.0 | 100 | | 11/10/21 20:52 | 16887-00-6 | |
| Fluoride | **0.17** | mg/L | 0.10 | 1 | | 11/10/21 20:33 | 16984-48-8 | |
| Sulfate | **525** | mg/L | 25.0 | 100 | | 11/10/21 20:52 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7429-90-5 | |
| Barium | **151** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7440-39-3 | |
| Boron | **19000** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7440-43-9 | |
| Calcium | **262000** | ug/L | 2000 | 2 | 11/15/21 13:34 | 11/16/21 14:25 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7440-47-3 | |
| Iron | **4150** | ug/L | 100 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7439-92-1 | |
| Lithium | **235** | ug/L | 20.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7439-93-2 | |
| Magnesium | **47600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7439-95-4 | |
| Manganese | **807** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7439-96-5 | |
| Molybdenum | **266** | ug/L | 10.0 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7439-98-7 | |
| Potassium | **18600** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7440-09-7 | |
| Silica | **13000** | ug/L | 450 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7631-86-9 | N2 |
| Sodium | **113000** | ug/L | 1000 | 1 | 11/15/21 13:34 | 11/16/21 13:07 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **785** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:48 | 7439-96-5 | |
| Molybdenum, Dissolved | **265** | ug/L | 10.0 | 1 | 11/15/21 13:48 | 11/16/21 03:48 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:36 | 7440-36-0 | |
| Arsenic | **867** | ug/L | 10.0 | 10 | 11/10/21 08:38 | 11/17/21 06:46 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:36 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 11/10/21 08:38 | 11/17/21 06:36 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **392** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Bicarbonate (CaCO3) | **392** | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 11/11/21 14:08 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1370** | mg/L | 20.0 | 1 | | 11/10/21 09:10 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

**Sample: M-4** **Lab ID: 50302158005** Collected: 11/04/21 11:30 Received: 11/05/21 13:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 11/10/21 16:12 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 11/05/21 18:01 | 18496-25-8 | |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 11/05/21 17:51 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 11/05/21 17:51 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **2.8** | mg/L | 0.15 | 1 | 11/18/21 13:30 | 11/18/21 16:31 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **7.8** | mg/L | 1.0 | 1 | | 11/17/21 01:29 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **5.5** | mg/L | 1.0 | 1 | | 11/18/21 23:56 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649560
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2993087 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 11/10/21 14:09 | |
| Fluoride | mg/L | ND | 0.10 | 11/10/21 14:09 | |
| Sulfate | mg/L | ND | 0.25 | 11/10/21 14:09 | |

LABORATORY CONTROL SAMPLE: 2993088

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 88 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.43 | 85 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.3 | 93 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2993089 2993090

| Parameter | Units | 50302156001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 15.2 | 12.5 | 12.5 | 26.2 | 26.2 | 88 | 88 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.53 | 86 | 87 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 246 | 250 | 250 | 467 | 468 | 89 | 89 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649047
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2990952 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 11/16/21 12:10 | |
| Barium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Boron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Cadmium | ug/L | ND | 2.0 | 11/16/21 12:10 | |
| Calcium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Chromium | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Iron | ug/L | ND | 100 | 11/16/21 12:10 | |
| Lead | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Lithium | ug/L | ND | 20.0 | 11/16/21 12:10 | |
| Magnesium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Manganese | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Molybdenum | ug/L | ND | 10.0 | 11/16/21 12:10 | |
| Potassium | ug/L | ND | 1000 | 11/16/21 12:10 | |
| Silica | ug/L | ND | 450 | 11/16/21 12:10 | N2 |
| Sodium | ug/L | ND | 1000 | 11/16/21 12:10 | |

LABORATORY CONTROL SAMPLE: 2990953

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 5000 | 4590 | 92 | 80-120 | |
| Barium | ug/L | 1000 | 966 | 97 | 80-120 | |
| Boron | ug/L | 1000 | 980 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 935 | 93 | 80-120 | |
| Calcium | ug/L | 5000 | 5040 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 979 | 98 | 80-120 | |
| Iron | ug/L | 2500 | 2440 | 98 | 80-120 | |
| Lead | ug/L | 1000 | 931 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 5000 | 4800 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 985 | 98 | 80-120 | |
| Molybdenum | ug/L | 1000 | 965 | 97 | 80-120 | |
| Potassium | ug/L | 5000 | 5020 | 100 | 80-120 | |
| Silica | ug/L | 5350 | 5350 | 100 | | N2 |
| Sodium | ug/L | 5000 | 4900 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990954 2990955

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4640 | 4650 | 93 | 93 | 75-125 | 0 | 20 | |
| Barium | ug/L | 69.2 | 1000 | 1000 | 1010 | 1010 | 94 | 94 | 75-125 | 0 | 20 | |
| Boron | ug/L | 127 | 1000 | 1000 | 1120 | 1130 | 99 | 100 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 927 | 930 | 93 | 93 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 106000 | 5000 | 5000 | 108000 | 107000 | 46 | 18 | 75-125 | 1 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 947 | 954 | 95 | 95 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1230 | 2500 | 2500 | 3550 | 3550 | 93 | 93 | 75-125 | 0 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 886 | 893 | 89 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1010 | 1010 | 100 | 101 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 30700 | 5000 | 5000 | 34600 | 34200 | 78 | 71 | 75-125 | 1 | 20 | P6 |
| Manganese | ug/L | 118 | 1000 | 1000 | 1060 | 1070 | 95 | 96 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 955 | 962 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 2050 | 5000 | 5000 | 6940 | 7010 | 98 | 99 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12300 | 5350 | 5350 | 17200 | 17000 | 93 | 88 | | 2 | | N2 |
| Sodium | ug/L | 19500 | 5000 | 5000 | 23800 | 23500 | 85 | 79 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990956 2990957

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 5000 | 5000 | 4620 | 4720 | 92 | 94 | 75-125 | 2 | 20 | |
| Barium | ug/L | 221 | 1000 | 1000 | 1150 | 1160 | 93 | 94 | 75-125 | 1 | 20 | |
| Boron | ug/L | 263 | 1000 | 1000 | 1260 | 1280 | 99 | 101 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 919 | 931 | 92 | 93 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 96600 | 5000 | 5000 | 100000 | 102000 | 77 | 113 | 75-125 | 2 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 946 | 958 | 94 | 96 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1670 | 2500 | 2500 | 3950 | 4000 | 91 | 93 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 871 | 881 | 87 | 88 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1000 | 1020 | 99 | 101 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 29300 | 5000 | 5000 | 33600 | 34200 | 86 | 97 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 303 | 1000 | 1000 | 1240 | 1260 | 93 | 96 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 948 | 960 | 95 | 96 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 7590 | 5000 | 5000 | 12400 | 12500 | 96 | 98 | 75-125 | 1 | 20 | |
| Silica | ug/L | 10900 | 5350 | 5350 | 15900 | 16100 | 94 | 98 | | 1 | | N2 |
| Sodium | ug/L | 73700 | 5000 | 5000 | 77300 | 78000 | 72 | 86 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649216
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2991499 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 11/16/21 02:57 | |

LABORATORY CONTROL SAMPLE: 2991500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 821 | 82 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 827 | 83 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991501 2991502

| Parameter | Units | 50302027005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 112 | 1000 | 1000 | 1070 | 1080 | 96 | 96 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 998 | 1010 | 100 | 100 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2991503 2991504

| Parameter | Units | 50302028002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1230 | 1250 | 93 | 95 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 986 | 992 | 98 | 99 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649453
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2992568 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Arsenic | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Cobalt | ug/L | ND | 1.0 | 11/17/21 05:34 | |
| Selenium | ug/L | ND | 1.0 | 11/17/21 05:34 | |

LABORATORY CONTROL SAMPLE: 2992569

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.8 | 105 | 80-120 | |
| Arsenic | ug/L | 40 | 37.7 | 94 | 80-120 | |
| Cobalt | ug/L | 40 | 40.3 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 38.3 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2992570 2992571

| Parameter | Units | 50302156001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.3 | 41.8 | 105 | 104 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 37.4 | 36.6 | 93 | 91 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.7 | 38.2 | 95 | 94 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.9 | 38.4 | 95 | 94 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649826
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2994528 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 11/11/21 14:08 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 14:08 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 11/11/21 14:08 | |

LABORATORY CONTROL SAMPLE: 2994529

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 47.9 | 96 | 90-110 | |

SAMPLE DUPLICATE: 2994530

| Parameter | Units | 50302108006 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 676 | 691 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 676 | 691 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 2994531

| Parameter | Units | 50302256001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 96.4 | 102 | 5 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 96.4 | 102 | 5 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649493
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2992747 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 11/10/21 09:08 | |

LABORATORY CONTROL SAMPLE: 2992748

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 300 | 100 | 80-120 | |

SAMPLE DUPLICATE: 2992749

| Parameter | Units | 50302141004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2590 | 2590 | 0 | 10 | |

SAMPLE DUPLICATE: 2992750

| Parameter | Units | 50302141005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1200 | 1170 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 649626
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis

Associated Lab Samples: 50302158005

SAMPLE DUPLICATE: 2993451

| Parameter | Units | 50302144001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.0 | 7.2 | 2 | 2 | H3 |

SAMPLE DUPLICATE: 2993452

| Parameter | Units | 50302187003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.0 | 7.0 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 648936
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2990476 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 11/05/21 18:01 | |

LABORATORY CONTROL SAMPLE: 2990477

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.49 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990478 2990479

| Parameter | Units | 50302158001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.36 | 0.35 | 69 | 67 | 90-110 | 3 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 648910
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2990259 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 11/05/21 17:33 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 11/05/21 17:33 | |

LABORATORY CONTROL SAMPLE: 2990260

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.96 | 96 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 1.1 | 109 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2990261 2990262

| Parameter | Units | 50302158001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.51 | 1 | 1 | 1.5 | 1.5 | 101 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 114 | 114 | 90-110 | 0 | 20 | M3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 651262
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 3001515 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 11/18/21 16:17 | |

LABORATORY CONTROL SAMPLE: 3001516

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3001517 3001518

| Parameter | Units | 50302157001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 23.8 | | | 45.4 | 41.4 | | | | 9 | | |

MATRIX SPIKE SAMPLE: 3001519

| Parameter | Units | 50302159004 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.51 | | 2.1 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 650844
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 2999712 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 11/17/21 00:52 | |

LABORATORY CONTROL SAMPLE: 2999713

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2999714 2999715

| Parameter | Units | 50302187003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.1 | 10 | 10 | 14.2 | 14.0 | 112 | 109 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 2999716

| Parameter | Units | 50302232002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.2 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 651325
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50302158005

METHOD BLANK: 3001931 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 11/18/21 22:41 | |

LABORATORY CONTROL SAMPLE: 3001932

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.7 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3001933 3001934

| Parameter | Units | 50302159004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 3.0 | 10 | 10 | 13.7 | 13.7 | 107 | 108 | 80-120 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

**Sample: M-4** **Lab ID: 50302158005** Collected: 11/04/21 11:30 Received: 11/05/21 13:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.15 ± 0.735 (0.923) C:NA T:98%** | pCi/L | 12/07/21 14:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.31 ± 0.626 (1.06) C:72% T:88%** | pCi/L | 12/07/21 17:28 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.46 ± 1.36 (1.98)** | pCi/L | 12/08/21 14:55 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 473873
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302158005

METHOD BLANK: 2289219 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.178 ± 0.387 (0.713) C:NA T:96% | pCi/L | 12/07/21 13:51 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

QC Batch: 473876
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50302158005

METHOD BLANK: 2289221 Matrix: Water
Associated Lab Samples: 50302158005

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.560 ± 0.330 (0.597) C:73% T:85% | pCi/L | 12/07/21 11:24 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50309026

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50302158005** | **M-4** | EPA 9056 | 649560 | | |
| **50302158005** | **M-4** | EPA 3010 | 649047 | EPA 6010 | 650721 |
| **50302158005** | **M-4** | EPA 3010 | 649216 | EPA 6010 | 650609 |
| **50302158005** | **M-4** | EPA 200.2 | 649453 | EPA 6020 | 649632 |
| **50302158005** | **M-4** | EPA 903.1 | 473873 | | |
| **50302158005** | **M-4** | EPA 904.0 | 473876 | | |
| **50302158005** | **M-4** | Total Radium Calculation | 475472 | | |
| **50302158005** | **M-4** | SM 2320B | 649826 | | |
| **50302158005** | **M-4** | SM 2540C | 649493 | | |
| **50302158005** | **M-4** | SM 4500-H+B | 649626 | | |
| **50302158005** | **M-4** | SM 4500-S2-D | 648936 | | |
| **50302158005** | **M-4** | EPA 353.2 | 648910 | | |
| **50302158005** | **M-4** | EPA 365.1 | 651262 | EPA 365.1 | 651348 |
| **50302158005** | **M-4** | SM 5310C | 650844 | | |
| **50302158005** | **M-4** | SM 5310C | 651325 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | Section B Required Project Information: | Section C Invoice Information: |
|---|---|---|
| Company: ATC Group Services | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@atcassociates.com | Purchase Order #: | Pace Quote: |
| Phone: NONE Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 6246 Line 30 |

Regulatory Agency:

State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | | |
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 30 | Field Blank 1 | WT | | | | 11-4-21 | 13:20 | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | | 004 |
| 31 | MS1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 32 | MSD1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 33 | MS2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 34 | MSD2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 35 | M-4 | | | | | 11-4-21 | 17:30 | | 11 | 3 | 3 | 4 | | 1 | | | | | | | | | | | | | | | | 005 |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Andy Jackson | 11-5-21 | 7:15 | Pace | 11/5 | 1305 | |
| 6020 (Co, As, Se, Sb) | | 11/5/21 | 1325 | | 11/5/21 | 1325 | 2.0 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | 2.4 |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | 3.0 |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | Andy Jackson | | | | | |
| SIGNATURE of SAMPLER: | | DATE Signed: 11-5-21 | | | | |

Pace Analytical®

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** 11/5/21 1418

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____
2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No
   **(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**
3. **Thermometer:** 1 2 3 4 5 6 A B C D E F
4. **Cooler Temperature:** 2.0/2.0 2.4/2.4 3.0/3.0
   Temp should be above freezing to 6°C **(Initial/Corrected)**
5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____
6. **Ice Type:** ☑ Wet ☐ Blue ☐ None
7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base pres. Have been CHECKED?: **exceptions: VOA, coliform, LLHg, O&G, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1445 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | — |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | — |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | — |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | — | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

M-4 to be tested for all parameters on COC, Ferrous Fe done in field, per Marks email. RR 11/5/21

M-4 to be switched onto its own report 50309026-002 and removed from 50302158, per Mark B. 2/14/22

**MAY 2022**

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 03, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50315350001** | **MW-10D** | Water | 05/02/22 15:47 | 05/03/22 13:50 |
| **50315350002** | **MW-10S** | Water | 05/02/22 14:55 | 05/03/22 13:50 |
| **50315350003** | **MW-3D** | Water | 05/02/22 15:35 | 05/03/22 13:50 |
| **50315350004** | **MW-3S** | Water | 05/02/22 14:25 | 05/03/22 13:50 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50315350001** | **MW-10D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | MTM | 2 | PASI-I |
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | WZE | 1 | PASI-I |
| | | SM 4500-H+B | WZE | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315350002** | **MW-10S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | MTM | 2 | PASI-I |
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | WZE | 1 | PASI-I |
| | | SM 4500-H+B | WZE | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315350003** | **MW-3D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | MTM | 2 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | WZE | 1 | PASI-I |
| | | SM 4500-H+B | WZE | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315350004** | **MW-3S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | MTM | 2 | PASI-I |
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | WZE | 1 | PASI-I |
| | | SM 4500-H+B | WZE | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315350001** | **MW-10D** | | | | | |
| EPA 9056 | Chloride | 504 | mg/L | 25.0 | 05/06/22 13:08 | |
| EPA 9056 | Fluoride | 1.9 | mg/L | 0.10 | 05/06/22 12:34 | |
| EPA 9056 | Sulfate | 669 | mg/L | 25.0 | 05/06/22 13:08 | |
| EPA 6010 | Barium | 33.0 | ug/L | 10.0 | 05/14/22 15:57 | |
| EPA 6010 | Boron | 2190 | ug/L | 100 | 05/14/22 15:57 | |
| EPA 6010 | Calcium | 193000 | ug/L | 1000 | 05/14/22 15:57 | |
| EPA 6010 | Iron | 1880 | ug/L | 100 | 05/14/22 15:57 | |
| EPA 6010 | Lithium | 65.6 | ug/L | 20.0 | 05/14/22 15:57 | |
| EPA 6010 | Magnesium | 69100 | ug/L | 1000 | 05/14/22 15:57 | |
| EPA 6010 | Manganese | 163 | ug/L | 10.0 | 05/14/22 15:57 | |
| EPA 6010 | Molybdenum | 82.4 | ug/L | 10.0 | 05/14/22 15:57 | |
| EPA 6010 | Potassium | 11200 | ug/L | 1000 | 05/14/22 15:57 | |
| EPA 6010 | Silica | 13400 | ug/L | 450 | 05/14/22 15:57 | N2 |
| EPA 6010 | Sodium | 355000 | ug/L | 2000 | 05/14/22 17:27 | |
| EPA 6010 | Manganese, Dissolved | 176 | ug/L | 10.0 | 05/14/22 14:21 | |
| EPA 6010 | Molybdenum, Dissolved | 91.2 | ug/L | 10.0 | 05/14/22 14:21 | |
| EPA 6020 | Arsenic | 140 | ug/L | 1.0 | 05/09/22 11:31 | |
| EPA 903.1 | Radium-226 | 0.300 ± 0.302 (0.471) C:NA T:88% | pCi/L | | 06/02/22 16:22 | |
| EPA 904.0 | Radium-228 | 0.928 ± 0.369 (0.550) C:82% T:88% | pCi/L | | 05/23/22 13:43 | |
| Total Radium Calculation | Total Radium | 1.23 ± 0.671 (1.02) | pCi/L | | 06/09/22 16:02 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 279 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 279 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2540C | Total Dissolved Solids | 1960 | mg/L | 40.0 | 05/05/22 14:10 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/05/22 15:17 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.32 | mg/L | 0.15 | 05/09/22 10:41 | |
| SM 5310C | Total Organic Carbon | 2.5 | mg/L | 1.0 | 05/09/22 23:02 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 2.0 | 05/13/22 13:19 | |
| **50315350002** | **MW-10S** | | | | | |
| EPA 9056 | Chloride | 288 | mg/L | 25.0 | 05/06/22 13:59 | |
| EPA 9056 | Fluoride | 2.6 | mg/L | 0.10 | 05/06/22 13:25 | |
| EPA 9056 | Sulfate | 412 | mg/L | 25.0 | 05/06/22 13:59 | |
| EPA 6010 | Barium | 75.8 | ug/L | 10.0 | 05/14/22 15:59 | |
| EPA 6010 | Boron | 1130 | ug/L | 100 | 05/14/22 15:59 | |
| EPA 6010 | Calcium | 171000 | ug/L | 1000 | 05/14/22 15:59 | |
| EPA 6010 | Iron | 766 | ug/L | 100 | 05/14/22 15:59 | |
| EPA 6010 | Lithium | 40.8 | ug/L | 20.0 | 05/14/22 15:59 | |
| EPA 6010 | Magnesium | 45500 | ug/L | 1000 | 05/14/22 15:59 | |
| EPA 6010 | Manganese | 304 | ug/L | 10.0 | 05/14/22 15:59 | |
| EPA 6010 | Molybdenum | 65.0 | ug/L | 10.0 | 05/14/22 15:59 | |
| EPA 6010 | Potassium | 7980 | ug/L | 1000 | 05/14/22 15:59 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315350002** | **MW-10S** | | | | | |
| EPA 6010 | Silica | 13900 | ug/L | 450 | 05/14/22 15:59 | N2 |
| EPA 6010 | Sodium | 192000 | ug/L | 1000 | 05/14/22 15:59 | |
| EPA 6010 | Manganese, Dissolved | 302 | ug/L | 10.0 | 05/14/22 14:23 | |
| EPA 6010 | Molybdenum, Dissolved | 64.1 | ug/L | 10.0 | 05/14/22 14:23 | |
| EPA 6020 | Arsenic | 448 | ug/L | 5.0 | 05/10/22 03:09 | |
| EPA 903.1 | Radium-226 | 0.363 ± 0.285 (0.396) C:NA T:88% | pCi/L | | 06/02/22 16:22 | |
| EPA 904.0 | Radium-228 | 0.614 ± 0.325 (0.555) C:82% T:88% | pCi/L | | 05/23/22 13:43 | |
| Total Radium Calculation | Total Radium | 0.977 ± 0.610 (0.951) | pCi/L | | 06/09/22 16:02 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 272 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 272 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2540C | Total Dissolved Solids | 1320 | mg/L | 20.0 | 05/05/22 14:12 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 05/05/22 15:11 | H3 |
| EPA 365.1 | Phosphate as P04 | 1.2 | mg/L | 0.15 | 05/09/22 10:41 | |
| SM 5310C | Total Organic Carbon | 2.0 | mg/L | 1.0 | 05/09/22 23:23 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 05/12/22 17:55 | |
| **50315350003** | **MW-3D** | | | | | |
| EPA 9056 | Chloride | 104 | mg/L | 2.5 | 05/06/22 15:05 | |
| EPA 9056 | Fluoride | 0.14 | mg/L | 0.10 | 05/06/22 14:48 | |
| EPA 9056 | Sulfate | 38.5 | mg/L | 2.5 | 05/06/22 15:05 | |
| EPA 6010 | Barium | 66.0 | ug/L | 10.0 | 05/14/22 16:01 | |
| EPA 6010 | Boron | 250 | ug/L | 100 | 05/14/22 16:01 | |
| EPA 6010 | Calcium | 62900 | ug/L | 1000 | 05/14/22 16:01 | |
| EPA 6010 | Iron | 970 | ug/L | 100 | 05/14/22 16:01 | |
| EPA 6010 | Magnesium | 15200 | ug/L | 1000 | 05/14/22 16:01 | |
| EPA 6010 | Manganese | 157 | ug/L | 10.0 | 05/14/22 16:01 | |
| EPA 6010 | Potassium | 3040 | ug/L | 1000 | 05/14/22 16:01 | |
| EPA 6010 | Silica | 9630 | ug/L | 450 | 05/14/22 16:01 | N2 |
| EPA 6010 | Sodium | 76600 | ug/L | 1000 | 05/14/22 16:01 | |
| EPA 6010 | Manganese, Dissolved | 162 | ug/L | 10.0 | 05/14/22 14:25 | |
| EPA 6020 | Arsenic | 3.3 | ug/L | 1.0 | 05/09/22 11:48 | |
| EPA 903.1 | Radium-226 | 0.278 ± 0.217 (0.255) C:NA T:86% | pCi/L | | 06/02/22 16:22 | |
| EPA 904.0 | Radium-228 | 0.726 ± 0.379 (0.668) C:79% T:86% | pCi/L | | 05/23/22 13:43 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315350003** | **MW-3D** | | | | | |
| Total Radium Calculation | Total Radium | 1.00 ± 0.596 (0.923) | pCi/L | | 06/09/22 16:02 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 236 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 236 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2540C | Total Dissolved Solids | 441 | mg/L | 10.0 | 05/05/22 14:13 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/05/22 15:13 | H3 |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 05/09/22 23:42 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 05/12/22 18:07 | |
| **50315350004** | **MW-3S** | | | | | |
| EPA 9056 | Chloride | 56.6 | mg/L | 2.5 | 05/06/22 15:54 | |
| EPA 9056 | Sulfate | 71.5 | mg/L | 2.5 | 05/06/22 15:54 | |
| EPA 6010 | Barium | 31.4 | ug/L | 10.0 | 05/14/22 16:03 | |
| EPA 6010 | Boron | 447 | ug/L | 100 | 05/14/22 16:03 | |
| EPA 6010 | Calcium | 89700 | ug/L | 1000 | 05/14/22 16:03 | |
| EPA 6010 | Magnesium | 20600 | ug/L | 1000 | 05/14/22 16:03 | |
| EPA 6010 | Manganese | 60.0 | ug/L | 10.0 | 05/14/22 16:03 | |
| EPA 6010 | Molybdenum | 32.9 | ug/L | 10.0 | 05/14/22 16:03 | |
| EPA 6010 | Potassium | 1390 | ug/L | 1000 | 05/14/22 16:03 | |
| EPA 6010 | Silica | 7270 | ug/L | 450 | 05/14/22 16:03 | N2 |
| EPA 6010 | Sodium | 31000 | ug/L | 1000 | 05/14/22 16:03 | |
| EPA 6010 | Molybdenum, Dissolved | 34.7 | ug/L | 10.0 | 05/14/22 14:27 | |
| EPA 6020 | Antimony | 4.9 | ug/L | 1.0 | 05/09/22 06:32 | |
| EPA 6020 | Arsenic | 1.3 | ug/L | 1.0 | 05/09/22 06:32 | |
| EPA 6020 | Selenium | 26.4 | ug/L | 1.0 | 05/09/22 06:32 | |
| EPA 903.1 | Radium-226 | 0.369 ± 0.254 (0.272) C:NA T:80% | pCi/L | | 06/02/22 16:22 | |
| EPA 904.0 | Radium-228 | 0.162 ± 0.327 (0.721) C:78% T:80% | pCi/L | | 05/23/22 13:43 | |
| Total Radium Calculation | Total Radium | 0.531 ± 0.581 (0.993) | pCi/L | | 06/09/22 16:02 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 242 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 242 | mg/L | 2.0 | 05/09/22 12:01 | |
| SM 2540C | Total Dissolved Solids | 457 | mg/L | 10.0 | 05/05/22 14:14 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/05/22 15:06 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.41 | mg/L | 0.10 | 05/03/22 15:59 | |
| SM 5310C | Dissolved Organic Carbon | 1.8 | mg/L | 1.0 | 05/12/22 18:17 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-10D** **Lab ID: 50315350001** Collected: 05/02/22 15:47 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **504** | mg/L | 25.0 | 100 | | 05/06/22 13:08 | 16887-00-6 | |
| Fluoride | **1.9** | mg/L | 0.10 | 1 | | 05/06/22 12:34 | 16984-48-8 | |
| Sulfate | **669** | mg/L | 25.0 | 100 | | 05/06/22 13:08 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7429-90-5 | |
| Barium | **33.0** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7440-39-3 | |
| Boron | **2190** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7440-43-9 | |
| Calcium | **193000** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7440-47-3 | |
| Iron | **1880** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7439-92-1 | |
| Lithium | **65.6** | ug/L | 20.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7439-93-2 | |
| Magnesium | **69100** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7439-95-4 | |
| Manganese | **163** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7439-96-5 | |
| Molybdenum | **82.4** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7439-98-7 | |
| Potassium | **11200** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7440-09-7 | |
| Silica | **13400** | ug/L | 450 | 1 | 05/11/22 08:22 | 05/14/22 15:57 | 7631-86-9 | N2 |
| Sodium | **355000** | ug/L | 2000 | 2 | 05/11/22 08:22 | 05/14/22 17:27 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **176** | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:21 | 7439-96-5 | |
| Molybdenum, Dissolved | **91.2** | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:21 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:31 | 7440-36-0 | |
| Arsenic | **140** | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:31 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/05/22 13:05 | 05/09/22 11:31 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:31 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:31 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:31 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 10:44 | 05/09/22 17:13 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **279** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Bicarbonate (CaCO3) | **279** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-10D** **Lab ID: 50315350001** Collected: 05/02/22 15:47 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1960** | mg/L | 40.0 | 1 | | 05/05/22 14:10 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/05/22 15:17 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/06/22 14:17 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 10:16 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/03/22 16:07 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/03/22 16:07 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.32** | mg/L | 0.15 | 1 | 05/06/22 09:00 | 05/09/22 10:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.5** | mg/L | 1.0 | 1 | | 05/09/22 23:02 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 2.0 | 2 | | 05/13/22 13:19 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-10S** **Lab ID: 50315350002** Collected: 05/02/22 14:55 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **288** | mg/L | 25.0 | 100 | | 05/06/22 13:59 | 16887-00-6 | |
| Fluoride | **2.6** | mg/L | 0.10 | 1 | | 05/06/22 13:25 | 16984-48-8 | |
| Sulfate | **412** | mg/L | 25.0 | 100 | | 05/06/22 13:59 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7429-90-5 | |
| Barium | **75.8** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-39-3 | |
| Boron | **1130** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-43-9 | |
| Calcium | **171000** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-47-3 | |
| Iron | **766** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7439-92-1 | |
| Lithium | **40.8** | ug/L | 20.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7439-93-2 | |
| Magnesium | **45500** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7439-95-4 | |
| Manganese | **304** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7439-96-5 | |
| Molybdenum | **65.0** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7439-98-7 | |
| Potassium | **7980** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-09-7 | |
| Silica | **13900** | ug/L | 450 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7631-86-9 | N2 |
| Sodium | **192000** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 15:59 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **302** | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:23 | 7439-96-5 | |
| Molybdenum, Dissolved | **64.1** | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:23 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:44 | 7440-36-0 | |
| Arsenic | **448** | ug/L | 5.0 | 5 | 05/05/22 13:05 | 05/10/22 03:09 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/05/22 13:05 | 05/09/22 11:44 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:44 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:44 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:44 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 10:44 | 05/09/22 17:15 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **272** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Bicarbonate (CaCO3) | **272** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-10S** **Lab ID: 50315350002** Collected: 05/02/22 14:55 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1320** | mg/L | 20.0 | 1 | | 05/05/22 14:12 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 1 | | 05/05/22 15:11 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/06/22 14:17 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 10:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/03/22 16:03 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/03/22 16:03 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **1.2** | mg/L | 0.15 | 1 | 05/06/22 09:00 | 05/09/22 10:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/09/22 23:23 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/12/22 17:55 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-3D** **Lab ID: 50315350003** Collected: 05/02/22 15:35 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **104** | mg/L | 2.5 | 10 | | 05/06/22 15:05 | 16887-00-6 | |
| Fluoride | **0.14** | mg/L | 0.10 | 1 | | 05/06/22 14:48 | 16984-48-8 | |
| Sulfate | **38.5** | mg/L | 2.5 | 10 | | 05/06/22 15:05 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7429-90-5 | |
| Barium | **66.0** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-39-3 | |
| Boron | **250** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-43-9 | |
| Calcium | **62900** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-47-3 | |
| Iron | **970** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7439-93-2 | |
| Magnesium | **15200** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7439-95-4 | |
| Manganese | **157** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7439-98-7 | |
| Potassium | **3040** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-09-7 | |
| Silica | **9630** | ug/L | 450 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7631-86-9 | N2 |
| Sodium | **76600** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:01 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **162** | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:25 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:25 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:48 | 7440-36-0 | |
| Arsenic | **3.3** | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:48 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/05/22 13:05 | 05/09/22 11:48 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:48 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:48 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 11:48 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 10:44 | 05/09/22 17:18 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **236** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Bicarbonate (CaCO3) | **236** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-3D** **Lab ID: 50315350003** Collected: 05/02/22 15:35 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **441** | mg/L | 10.0 | 1 | | 05/05/22 14:13 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/05/22 15:13 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/06/22 14:17 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 10:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/03/22 16:05 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/03/22 16:05 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/06/22 09:00 | 05/09/22 10:42 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/09/22 23:42 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/12/22 18:07 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-3S** **Lab ID: 50315350004** Collected: 05/02/22 14:25 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **56.6** | mg/L | 2.5 | 10 | | 05/06/22 15:54 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 05/06/22 15:38 | 16984-48-8 | |
| Sulfate | **71.5** | mg/L | 2.5 | 10 | | 05/06/22 15:54 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7429-90-5 | |
| Barium | **31.4** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-39-3 | |
| Boron | **447** | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-43-9 | |
| Calcium | **89700** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7439-93-2 | |
| Magnesium | **20600** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7439-95-4 | |
| Manganese | **60.0** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7439-96-5 | |
| Molybdenum | **32.9** | ug/L | 10.0 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7439-98-7 | |
| Potassium | **1390** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-09-7 | |
| Silica | **7270** | ug/L | 450 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7631-86-9 | N2 |
| Sodium | **31000** | ug/L | 1000 | 1 | 05/11/22 08:22 | 05/14/22 16:03 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:27 | 7439-96-5 | |
| Molybdenum, Dissolved | **34.7** | ug/L | 10.0 | 1 | 05/10/22 14:09 | 05/14/22 14:27 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | **4.9** | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 06:32 | 7440-36-0 | |
| Arsenic | **1.3** | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 06:32 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/05/22 13:05 | 05/09/22 06:32 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 06:32 | 7440-48-4 | |
| Selenium | **26.4** | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 06:32 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/05/22 13:05 | 05/09/22 06:32 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 10:44 | 05/09/22 17:20 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **242** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Bicarbonate (CaCO3) | **242** | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/09/22 12:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-3S** **Lab ID: 50315350004** Collected: 05/02/22 14:25 Received: 05/03/22 13:50 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **457** | mg/L | 10.0 | 1 | | 05/05/22 14:14 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/05/22 15:06 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/06/22 14:17 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 10:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.41** | mg/L | 0.10 | 1 | | 05/03/22 15:59 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/03/22 15:59 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/06/22 09:00 | 05/09/22 10:43 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/10/22 00:02 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 05/12/22 18:17 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674218
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3104169 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/06/22 07:15 | |
| Fluoride | mg/L | ND | 0.10 | 05/06/22 07:15 | |
| Sulfate | mg/L | ND | 0.25 | 05/06/22 07:15 | |

LABORATORY CONTROL SAMPLE: 3104170

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 92 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.46 | 93 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 95 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3104171 3104172

| Parameter | Units | 50315315003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 324 | 125 | 125 | 439 | 437 | 92 | 91 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.13 | 0.5 | 0.5 | 0.52 | 0.52 | 79 | 80 | 80-120 | 1 | 15 | M0 |
| Sulfate | mg/L | 836 | 250 | 250 | 1080 | 1070 | 97 | 95 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674733
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3106756 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/09/22 16:27 | |

LABORATORY CONTROL SAMPLE: 3106757

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 4.7 | 94 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106758 3106759

| Parameter | Units | 50315308001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 4.9 | 4.9 | 97 | 97 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674496
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3105368 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/14/22 19:44 | |
| Barium | ug/L | ND | 10.0 | 05/14/22 19:44 | |
| Boron | ug/L | ND | 100 | 05/14/22 19:44 | |
| Cadmium | ug/L | ND | 2.0 | 05/14/22 19:44 | |
| Calcium | ug/L | ND | 1000 | 05/14/22 19:44 | |
| Chromium | ug/L | ND | 10.0 | 05/14/22 19:44 | |
| Iron | ug/L | ND | 100 | 05/14/22 19:44 | |
| Lead | ug/L | ND | 10.0 | 05/14/22 19:44 | |
| Lithium | ug/L | ND | 20.0 | 05/14/22 19:44 | |
| Magnesium | ug/L | ND | 1000 | 05/14/22 19:44 | |
| Manganese | ug/L | ND | 10.0 | 05/14/22 19:44 | |
| Molybdenum | ug/L | ND | 10.0 | 05/14/22 19:44 | |
| Potassium | ug/L | ND | 1000 | 05/14/22 19:44 | |
| Silica | ug/L | ND | 450 | 05/14/22 19:44 | N2 |
| Sodium | ug/L | ND | 1000 | 05/14/22 19:44 | |

LABORATORY CONTROL SAMPLE: 3105369

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9960 | 100 | 80-120 | |
| Barium | ug/L | 1000 | 1010 | 101 | 80-120 | |
| Boron | ug/L | 1000 | 998 | 100 | 80-120 | |
| Cadmium | ug/L | 1000 | 950 | 95 | 80-120 | |
| Calcium | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 992 | 99 | 80-120 | |
| Iron | ug/L | 10000 | 9940 | 99 | 80-120 | |
| Lead | ug/L | 1000 | 938 | 94 | 80-120 | |
| Lithium | ug/L | 1000 | 994 | 99 | 80-120 | |
| Magnesium | ug/L | 10000 | 9780 | 98 | 80-120 | |
| Manganese | ug/L | 1000 | 975 | 97 | 80-120 | |
| Molybdenum | ug/L | 1000 | 998 | 100 | 80-120 | |
| Potassium | ug/L | 10000 | 9920 | 99 | 80-120 | |
| Silica | ug/L | 10700 | 10300 | 97 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9820 | 98 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3105370 3105371

| Parameter | Units | 50315334004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | 228 | 10000 | 10000 | 10400 | 10300 | 101 | 100 | 75-125 | 1 | 20 | |
| Barium | ug/L | 33.5 | 1000 | 1000 | 1040 | 1020 | 101 | 99 | 75-125 | 2 | 20 | |
| Boron | ug/L | 7220 | 1000 | 1000 | 8470 | 8700 | 124 | 147 | 75-125 | 3 | 20 | P6 |
| Cadmium | ug/L | ND | 1000 | 1000 | 997 | 984 | 100 | 98 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 255000 | 10000 | 10000 | 263000 | 270000 | 78 | 150 | 75-125 | 3 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 999 | 988 | 100 | 99 | 75-125 | 1 | 20 | |
| Iron | ug/L | 6280 | 10000 | 10000 | 16200 | 16300 | 99 | 100 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 920 | 916 | 92 | 92 | 75-125 | 0 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1050 | 1030 | 104 | 102 | 75-125 | 2 | 20 | |
| Magnesium | ug/L | 38600 | 10000 | 10000 | 48900 | 50100 | 103 | 115 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 1240 | 1000 | 1000 | 2240 | 2260 | 100 | 102 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 82.9 | 1000 | 1000 | 1110 | 1110 | 103 | 103 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 2450 | 10000 | 10000 | 12700 | 12600 | 103 | 102 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12100 | 10700 | 10700 | 23200 | 23500 | 103 | 107 | 75-125 | 1 | 20 | N2 |
| Sodium | ug/L | 18900 | 10000 | 10000 | 29300 | 29500 | 103 | 106 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674474
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3105256 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/14/22 14:17 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/14/22 14:17 | |

LABORATORY CONTROL SAMPLE: 3105257

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 1000 | 100 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1030 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3105258 3105259

| Parameter | Units | 50315394002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1.0J | 1000 | 1000 | 976 | 995 | 97 | 99 | 75-125 | 2 | 20 | |
| Molybdenum, Dissolved | ug/L | 1.2J | 1000 | 1000 | 1040 | 1050 | 103 | 105 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674508
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3105529 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/09/22 00:45 | |
| Arsenic | ug/L | ND | 1.0 | 05/09/22 00:45 | |
| Beryllium | ug/L | ND | 0.20 | 05/09/22 00:45 | |
| Cobalt | ug/L | ND | 1.0 | 05/09/22 00:45 | |
| Selenium | ug/L | ND | 1.0 | 05/09/22 00:45 | |
| Thallium | ug/L | ND | 1.0 | 05/09/22 00:45 | |

LABORATORY CONTROL SAMPLE: 3105530

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 43.2 | 108 | 80-120 | |
| Arsenic | ug/L | 40 | 40.7 | 102 | 80-120 | |
| Beryllium | ug/L | 40 | 41.2 | 103 | 80-120 | |
| Cobalt | ug/L | 40 | 41.7 | 104 | 80-120 | |
| Selenium | ug/L | 40 | 40.6 | 102 | 80-120 | |
| Thallium | ug/L | 40 | 40.8 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3105531 3105532

| Parameter | Units | 50315350004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 4.9 | 40 | 40 | 49.3 | 48.9 | 111 | 110 | 75-125 | 1 | 20 | |
| Arsenic | ug/L | 1.3 | 40 | 40 | 42.5 | 42.9 | 103 | 104 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 38.3 | 38.1 | 96 | 95 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 37.0 | 37.2 | 92 | 93 | 75-125 | 1 | 20 | |
| Selenium | ug/L | 26.4 | 40 | 40 | 66.7 | 65.4 | 101 | 97 | 75-125 | 2 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 40.7 | 40.9 | 102 | 102 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 675055 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3108597 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/09/22 12:01 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/09/22 12:01 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/09/22 12:01 | |

LABORATORY CONTROL SAMPLE: 3108598

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 48.5 | 97 | 90-110 | |

SAMPLE DUPLICATE: 3108599

| Parameter | Units | 50315350004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 242 | 268 | 10 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 242 | 268 | 10 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3108600

| Parameter | Units | 50315315003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 142 | 142 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 142 | 142 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674549 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3105787 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/05/22 13:58 | |

LABORATORY CONTROL SAMPLE: 3105788

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 286 | 95 | 80-120 | |

SAMPLE DUPLICATE: 3105789

| Parameter | Units | 50315345002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 509 | 502 | 1 | 10 | |

SAMPLE DUPLICATE: 3105790

| Parameter | Units | 50315345003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1140 | 1150 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674603
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

SAMPLE DUPLICATE: 3105973

| Parameter | Units | 50315334007 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.9 | 7.0 | 2 | 2 | H3 |

SAMPLE DUPLICATE: 3105974

| Parameter | Units | 50315334001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.1 | 7.0 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674775 | Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D | Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3106974 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/06/22 14:17 | |

LABORATORY CONTROL SAMPLE: 3106975

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.50 | 101 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106976 3106977

| Parameter | Units | 50315326001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.026J | 0.5 | 0.5 | 0.46 | 0.46 | 86 | 87 | 90-110 | 1 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3106978

| Parameter | Units | 50315350004 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.53 | 107 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 675306 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3109467 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 10:07 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109468

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 0.99 | 99 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109469 3109470

| Parameter | Units | 50315247002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 59.8 | 100 | 100 | 156 | 157 | 96 | 97 | 90-110 | 0 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3109471

| Parameter | Units | 50315334001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1.0 | 99 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674118
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3103794 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/03/22 09:50 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/03/22 09:50 | |

LABORATORY CONTROL SAMPLE: 3103795

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.95 | 95 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3103796 3103797

| Parameter | Units | 50315315003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.90 | 0.90 | 81 | 81 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.92 | 0.92 | 91 | 91 | 90-110 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3104162

| Parameter | Units | 50315350004 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.41 | 1 | 1.3 | 93 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.94 | 94 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674757 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3106922 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/09/22 13:03 | |

LABORATORY CONTROL SAMPLE: 3106923

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106924 3106925

| Parameter | Units | 50314995001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | <0.15 | | | 1.5 | 1.5 | | | | 3 | | |

MATRIX SPIKE SAMPLE: 3106960

| Parameter | Units | 50315563004 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.6 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 674970 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3108205 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/09/22 20:32 | |

LABORATORY CONTROL SAMPLE: 3108206

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.6 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108207 3108208

| Parameter | Units | 50315385003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 0.74J | 10 | 10 | 10.6 | 10.5 | 99 | 98 | 80-120 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3108209

| Parameter | Units | 50315390001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.1 | 10 | 10.8 | 96 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 675891 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 3112045 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/12/22 15:05 | |

LABORATORY CONTROL SAMPLE: 3112046

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112047 3112048

| Parameter | Units | 50315476002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.8 | 10 | 10 | 11.0 | 11.9 | 92 | 101 | 80-120 | 8 | 20 | |

MATRIX SPIKE SAMPLE: 3112049

| Parameter | Units | 50315308001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 0.34J | 10 | 9.9 | 95 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-10D** **Lab ID: 50315350001** Collected: 05/02/22 15:47 Received: 05/03/22 13:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.300 ± 0.302 (0.471) C:NA T:88%** | pCi/L | 06/02/22 16:22 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.928 ± 0.369 (0.550) C:82% T:88%** | pCi/L | 05/23/22 13:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.23 ± 0.671 (1.02)** | pCi/L | 06/09/22 16:02 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-10S** **Lab ID: 50315350002** Collected: 05/02/22 14:55 Received: 05/03/22 13:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.363 ± 0.285 (0.396) C:NA T:88%** | pCi/L | 06/02/22 16:22 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.614 ± 0.325 (0.555) C:82% T:88%** | pCi/L | 05/23/22 13:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.977 ± 0.610 (0.951)** | pCi/L | 06/09/22 16:02 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-3D** **Lab ID: 50315350003** Collected: 05/02/22 15:35 Received: 05/03/22 13:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.278 ± 0.217 (0.255) C:NA T:86%** | pCi/L | 06/02/22 16:22 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.726 ± 0.379 (0.668) C:79% T:86%** | pCi/L | 05/23/22 13:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.00 ± 0.596 (0.923)** | pCi/L | 06/09/22 16:02 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

**Sample: MW-3S** **Lab ID: 50315350004** Collected: 05/02/22 14:25 Received: 05/03/22 13:50 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.369 ± 0.254 (0.272) C:NA T:80%** | pCi/L | 06/02/22 16:22 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.162 ± 0.327 (0.721) C:78% T:80%** | pCi/L | 05/23/22 13:43 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.531 ± 0.581 (0.993)** | pCi/L | 06/09/22 16:02 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 503379
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 2437427 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.103 ± 0.178 (0.318) C:NA T:88% | pCi/L | 06/02/22 15:57 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

QC Batch: 503380
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

METHOD BLANK: 2437428 Matrix: Water
Associated Lab Samples: 50315350001, 50315350002, 50315350003, 50315350004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.359 ± 0.334 (0.678) C:72% T:88% | pCi/L | 05/23/22 13:43 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315350001** | **MW-10D** | EPA 9056 | 674218 | | |
| **50315350002** | **MW-10S** | EPA 9056 | 674218 | | |
| **50315350003** | **MW-3D** | EPA 9056 | 674218 | | |
| **50315350004** | **MW-3S** | EPA 9056 | 674218 | | |
| **50315350001** | **MW-10D** | EPA 3010 | 674496 | EPA 6010 | 676288 |
| **50315350002** | **MW-10S** | EPA 3010 | 674496 | EPA 6010 | 676288 |
| **50315350003** | **MW-3D** | EPA 3010 | 674496 | EPA 6010 | 676288 |
| **50315350004** | **MW-3S** | EPA 3010 | 674496 | EPA 6010 | 676288 |
| **50315350001** | **MW-10D** | EPA 3010 | 674474 | EPA 6010 | 676283 |
| **50315350002** | **MW-10S** | EPA 3010 | 674474 | EPA 6010 | 676283 |
| **50315350003** | **MW-3D** | EPA 3010 | 674474 | EPA 6010 | 676283 |
| **50315350004** | **MW-3S** | EPA 3010 | 674474 | EPA 6010 | 676283 |
| **50315350001** | **MW-10D** | EPA 200.2 | 674508 | EPA 6020 | 674742 |
| **50315350002** | **MW-10S** | EPA 200.2 | 674508 | EPA 6020 | 674742 |
| **50315350003** | **MW-3D** | EPA 200.2 | 674508 | EPA 6020 | 674742 |
| **50315350004** | **MW-3S** | EPA 200.2 | 674508 | EPA 6020 | 674742 |
| **50315350001** | **MW-10D** | EPA 7470 | 674733 | EPA 7470 | 675234 |
| **50315350002** | **MW-10S** | EPA 7470 | 674733 | EPA 7470 | 675234 |
| **50315350003** | **MW-3D** | EPA 7470 | 674733 | EPA 7470 | 675234 |
| **50315350004** | **MW-3S** | EPA 7470 | 674733 | EPA 7470 | 675234 |
| **50315350001** | **MW-10D** | EPA 903.1 | 503379 | | |
| **50315350002** | **MW-10S** | EPA 903.1 | 503379 | | |
| **50315350003** | **MW-3D** | EPA 903.1 | 503379 | | |
| **50315350004** | **MW-3S** | EPA 903.1 | 503379 | | |
| **50315350001** | **MW-10D** | EPA 904.0 | 503380 | | |
| **50315350002** | **MW-10S** | EPA 904.0 | 503380 | | |
| **50315350003** | **MW-3D** | EPA 904.0 | 503380 | | |
| **50315350004** | **MW-3S** | EPA 904.0 | 503380 | | |
| **50315350001** | **MW-10D** | Total Radium Calculation | 510623 | | |
| **50315350002** | **MW-10S** | Total Radium Calculation | 510623 | | |
| **50315350003** | **MW-3D** | Total Radium Calculation | 510623 | | |
| **50315350004** | **MW-3S** | Total Radium Calculation | 510623 | | |
| **50315350001** | **MW-10D** | SM 2320B | 675055 | | |
| **50315350002** | **MW-10S** | SM 2320B | 675055 | | |
| **50315350003** | **MW-3D** | SM 2320B | 675055 | | |
| **50315350004** | **MW-3S** | SM 2320B | 675055 | | |
| **50315350001** | **MW-10D** | SM 2540C | 674549 | | |
| **50315350002** | **MW-10S** | SM 2540C | 674549 | | |
| **50315350003** | **MW-3D** | SM 2540C | 674549 | | |
| **50315350004** | **MW-3S** | SM 2540C | 674549 | | |
| **50315350001** | **MW-10D** | SM 4500-H+B | 674603 | | |
| **50315350002** | **MW-10S** | SM 4500-H+B | 674603 | | |
| **50315350003** | **MW-3D** | SM 4500-H+B | 674603 | | |
| **50315350004** | **MW-3S** | SM 4500-H+B | 674603 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315350

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315350001** | **MW-10D** | SM 4500-S2-D | 674775 | | |
| **50315350002** | **MW-10S** | SM 4500-S2-D | 674775 | | |
| **50315350003** | **MW-3D** | SM 4500-S2-D | 674775 | | |
| **50315350004** | **MW-3S** | SM 4500-S2-D | 674775 | | |
| **50315350001** | **MW-10D** | HACH 8146 | 675306 | | |
| **50315350002** | **MW-10S** | HACH 8146 | 675306 | | |
| **50315350003** | **MW-3D** | HACH 8146 | 675306 | | |
| **50315350004** | **MW-3S** | HACH 8146 | 675306 | | |
| **50315350001** | **MW-10D** | EPA 353.2 | 674118 | | |
| **50315350002** | **MW-10S** | EPA 353.2 | 674118 | | |
| **50315350003** | **MW-3D** | EPA 353.2 | 674118 | | |
| **50315350004** | **MW-3S** | EPA 353.2 | 674118 | | |
| **50315350001** | **MW-10D** | EPA 365.1 | 674757 | EPA 365.1 | 675315 |
| **50315350002** | **MW-10S** | EPA 365.1 | 674757 | EPA 365.1 | 675315 |
| **50315350003** | **MW-3D** | EPA 365.1 | 674757 | EPA 365.1 | 675315 |
| **50315350004** | **MW-3S** | EPA 365.1 | 674757 | EPA 365.1 | 675315 |
| **50315350001** | **MW-10D** | SM 5310C | 674970 | | |
| **50315350002** | **MW-10S** | SM 5310C | 674970 | | |
| **50315350003** | **MW-3D** | SM 5310C | 674970 | | |
| **50315350004** | **MW-3S** | SM 5310C | 674970 | | |
| **50315350001** | **MW-10D** | SM 5310C | 675891 | | |
| **50315350002** | **MW-10S** | SM 5310C | 675891 | | |
| **50315350003** | **MW-3D** | SM 5310C | 675891 | | |
| **50315350004** | **MW-3S** | SM 5310C | 675891 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50315350

50315350

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Project Information: | | Section C Invoice Information: | |
|---|---|---|---|
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: | Atlas Indianapolis |
| Indianapolis, IN 46256 | | Address: | |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: | |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: | 10498/15 |

| Regulatory Agency |
|---|
| |
| **State / Location** |
| IN |

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | |
| 1 | ~~MW-1S~~ MW-10D | WT | G | 5/2 | 1547 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 2 | ~~MW-1D~~ MW-10S | WT | G | 5/2 | 1455 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 3 | ~~MW-2S~~ MW-3D | WT | G | 5/2 | 1535 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 003 |
| 4 | ~~MW-2D~~ MW-3S | WT | G | 5/2 | 1425 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 004 |
| 5 | ~~MW-3S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | ~~MW-3D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | ~~MW-4S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 8 | ~~MW-4D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 9 | ~~MW-5S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 10 | ~~MW-5D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 11 | ~~MW-6S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 12 | ~~MW-6D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | P. Greg Hopper | | | | | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | | 5/3 | 915 | | 5/3/22 | 1320 |
| ** Dissolved FF 6010 (Mo, Mn) | | 5/3/22 | 1350 | | 5/3/22 | 1350 |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| 2.6 | Y | N | Y |
| 1.2 | X | N | Y |
| | | | |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: P. Greg Hopper

SIGNATURE of SAMPLER:

DATE Signed: 5/3/22

F-IN-Q-290-rev.22, 22Apr2022

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** DMP 05/03/22 14:02

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER ____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D (E) F

4. **Cooler Temperature(s):** 3.2/2.6°C | 1.8/1.2°C | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☑ Other Plastic Bags

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle: HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** $NO_3/NO_2$ Wet | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1430 | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | Present | Absent | N/A ✓ |
| **Rush TAT Requested (4 days or less):** Not Listed | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | | ✓ | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | N/A | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS: RCVD MW-35 05/02/22 1425, not on COC. /DMP 5/3/22

**COC PAGE** 1 **of** 1

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 3 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 4 | | | | | | | MW-35 | 5/2/22 | 1425 | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 05, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50315730001** | **MW-4S** | Water | 05/04/22 11:42 | 05/05/22 15:10 |
| **50315730002** | **MW-5S** | Water | 05/04/22 13:36 | 05/05/22 15:10 |
| **50315730003** | **MW-6S** | Water | 05/04/22 15:11 | 05/05/22 15:10 |
| **50315730004** | **MW-7D** | Water | 05/04/22 14:20 | 05/05/22 15:10 |
| **50315730005** | **MW-2S** | Water | 05/04/22 10:40 | 05/05/22 15:10 |
| **50315730006** | **MW-7S** | Water | 05/04/22 13:10 | 05/05/22 15:10 |
| **50315730007** | **MW-2D** | Water | 05/04/22 10:47 | 05/05/22 15:10 |
| **50315730008** | **MW-13S** | Water | 05/04/22 13:02 | 05/05/22 15:10 |
| **50315730009** | **MW-13D** | Water | 05/04/22 14:31 | 05/05/22 15:10 |
| **50315730010** | **MW-2S RAD MS** | Water | 05/04/22 10:40 | 05/05/22 15:10 |
| **50315730011** | **MW-2S RAD MSD** | Water | 05/04/22 10:40 | 05/05/22 15:10 |
| **50315733006** | **DUP-1** | Water | 05/04/22 13:10 | 05/05/22 15:10 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50315730001** | **MW-4S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730002** | **MW-5S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730003** | **MW-6S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730004** | **MW-7D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730005** | **MW-2S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730006** | **MW-7S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730007** | **MW-2D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730008** | **MW-13S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730009** | **MW-13D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315730010** | **MW-2S RAD MS** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50315730011** | **MW-2S RAD MSD** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50315733006** | **DUP-1** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730001** | **MW-4S** | | | | | |
| EPA 9056 | Chloride | 9.0 | mg/L | 0.25 | 05/18/22 17:39 | |
| EPA 9056 | Sulfate | 415 | mg/L | 25.0 | 05/18/22 17:21 | |
| EPA 6010 | Barium | 90.7 | ug/L | 10.0 | 05/17/22 01:48 | |
| EPA 6010 | Boron | 3510 | ug/L | 100 | 05/17/22 01:48 | |
| EPA 6010 | Calcium | 275000 | ug/L | 2000 | 05/17/22 02:27 | |
| EPA 6010 | Magnesium | 53500 | ug/L | 1000 | 05/17/22 01:48 | |
| EPA 6010 | Potassium | 2150 | ug/L | 1000 | 05/17/22 01:48 | |
| EPA 6010 | Silica | 13700 | ug/L | 450 | 05/17/22 01:48 | N2 |
| EPA 6010 | Sodium | 14600 | ug/L | 1000 | 05/17/22 01:48 | |
| EPA 6020 | Arsenic | 1.1 | ug/L | 1.0 | 05/12/22 17:09 | |
| EPA 6020 | Selenium | 119 | ug/L | 1.0 | 05/12/22 17:09 | |
| EPA 903.1 | Radium-226 | 0.131 ± 0.444 (0.858) C:NA T:99% | pCi/L | | 06/10/22 12:19 | |
| EPA 904.0 | Radium-228 | 0.492 ± 0.316 (0.594) C:81% T:97% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 0.623 ± 0.760 (1.45) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 452 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 452 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2540C | Total Dissolved Solids | 1060 | mg/L | 20.0 | 05/11/22 13:32 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.1 | Std. Units | 0.10 | 05/13/22 15:04 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 4.0 | mg/L | 0.10 | 05/06/22 09:28 | |
| SM 5310C | Dissolved Organic Carbon | 1.2 | mg/L | 1.0 | 05/17/22 09:39 | |
| **50315730002** | **MW-5S** | | | | | |
| EPA 9056 | Chloride | 231 | mg/L | 25.0 | 05/18/22 18:16 | |
| EPA 9056 | Fluoride | 1.8 | mg/L | 0.10 | 05/18/22 17:57 | |
| EPA 9056 | Sulfate | 574 | mg/L | 25.0 | 05/18/22 18:16 | |
| EPA 6010 | Barium | 37.4 | ug/L | 10.0 | 05/17/22 01:50 | |
| EPA 6010 | Boron | 2460 | ug/L | 100 | 05/17/22 01:50 | |
| EPA 6010 | Calcium | 233000 | ug/L | 2000 | 05/17/22 02:29 | |
| EPA 6010 | Lithium | 46.5 | ug/L | 20.0 | 05/17/22 01:50 | |
| EPA 6010 | Magnesium | 58800 | ug/L | 1000 | 05/17/22 01:50 | |
| EPA 6010 | Manganese | 1060 | ug/L | 10.0 | 05/17/22 01:50 | |
| EPA 6010 | Molybdenum | 122 | ug/L | 10.0 | 05/17/22 01:50 | |
| EPA 6010 | Potassium | 8500 | ug/L | 1000 | 05/17/22 01:50 | |
| EPA 6010 | Silica | 15400 | ug/L | 450 | 05/17/22 01:50 | N2 |
| EPA 6010 | Sodium | 171000 | ug/L | 1000 | 05/17/22 01:50 | |
| EPA 6010 | Manganese, Dissolved | 1120 | ug/L | 10.0 | 05/16/22 10:55 | |
| EPA 6010 | Molybdenum, Dissolved | 131 | ug/L | 10.0 | 05/16/22 10:55 | |
| EPA 903.1 | Radium-226 | 0.206 ± 0.447 (0.825) C:NA T:97% | pCi/L | | 06/10/22 12:48 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730002** | **MW-5S** | | | | | |
| EPA 904.0 | Radium-228 | 0.806 ± 0.371 (0.611) C:81% T:89% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 1.01 ± 0.818 (1.44) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 364 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 364 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2540C | Total Dissolved Solids | 1500 | mg/L | 20.0 | 05/11/22 13:33 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 05/13/22 15:05 | H3 |
| SM 5310C | Total Organic Carbon | 2.4 | mg/L | 1.0 | 05/13/22 00:38 | |
| SM 5310C | Dissolved Organic Carbon | 2.3 | mg/L | 1.0 | 05/17/22 09:52 | |
| **50315730003** | **MW-6S** | | | | | |
| EPA 9056 | Chloride | 129 | mg/L | 25.0 | 05/17/22 13:20 | |
| EPA 9056 | Fluoride | 1.3 | mg/L | 0.10 | 05/18/22 18:34 | |
| EPA 9056 | Sulfate | 572 | mg/L | 25.0 | 05/17/22 13:20 | |
| EPA 6010 | Barium | 132 | ug/L | 10.0 | 05/17/22 01:52 | |
| EPA 6010 | Boron | 6290 | ug/L | 100 | 05/17/22 01:52 | |
| EPA 6010 | Calcium | 279000 | ug/L | 2000 | 05/17/22 02:31 | |
| EPA 6010 | Iron | 4190 | ug/L | 100 | 05/17/22 01:52 | |
| EPA 6010 | Lithium | 71.2 | ug/L | 20.0 | 05/17/22 01:52 | |
| EPA 6010 | Magnesium | 72500 | ug/L | 1000 | 05/17/22 01:52 | |
| EPA 6010 | Manganese | 1900 | ug/L | 10.0 | 05/17/22 01:52 | |
| EPA 6010 | Molybdenum | 150 | ug/L | 10.0 | 05/17/22 01:52 | |
| EPA 6010 | Potassium | 11700 | ug/L | 1000 | 05/17/22 01:52 | |
| EPA 6010 | Silica | 14000 | ug/L | 450 | 05/17/22 01:52 | N2 |
| EPA 6010 | Sodium | 127000 | ug/L | 1000 | 05/17/22 01:52 | |
| EPA 6010 | Manganese, Dissolved | 1870 | ug/L | 10.0 | 05/16/22 10:57 | |
| EPA 6010 | Molybdenum, Dissolved | 158 | ug/L | 10.0 | 05/16/22 10:57 | |
| EPA 6020 | Arsenic | 6.9 | ug/L | 1.0 | 05/12/22 17:23 | |
| EPA 6020 | Cobalt | 1.5 | ug/L | 1.0 | 05/12/22 17:23 | |
| EPA 6020 | Selenium | 4.4 | ug/L | 1.0 | 05/12/22 17:23 | |
| EPA 903.1 | Radium-226 | 0.000 ± 0.601 (1.22) C:NA T:92% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 0.508 ± 0.320 (0.584) C:84% T:86% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 0.508 ± 0.921 (1.80) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 528 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 528 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2540C | Total Dissolved Solids | 1520 | mg/L | 20.0 | 05/11/22 13:33 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.1 | Std. Units | 0.10 | 05/13/22 15:06 | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730003** | **MW-6S** | | | | | |
| HACH 8146 | Iron, Ferrous | 0.23 | mg/L | 0.20 | 05/10/22 14:44 | H3,N2 |
| EPA 353.2 | Nitrogen, Nitrate | 0.67 | mg/L | 0.10 | 05/06/22 09:50 | |
| EPA 365.1 | Phosphate as P04 | 0.16 | mg/L | 0.15 | 05/13/22 14:32 | |
| SM 5310C | Total Organic Carbon | 2.9 | mg/L | 1.0 | 05/13/22 00:58 | |
| SM 5310C | Dissolved Organic Carbon | 3.4 | mg/L | 1.0 | 05/17/22 10:04 | |
| **50315730004** | **MW-7D** | | | | | |
| EPA 9056 | Chloride | 174 | mg/L | 25.0 | 05/17/22 14:16 | |
| EPA 9056 | Fluoride | 0.51 | mg/L | 0.10 | 05/17/22 13:39 | |
| EPA 9056 | Sulfate | 671 | mg/L | 25.0 | 05/17/22 14:16 | |
| EPA 6010 | Barium | 42.4 | ug/L | 10.0 | 05/17/22 01:54 | |
| EPA 6010 | Boron | 14300 | ug/L | 100 | 05/17/22 01:54 | |
| EPA 6010 | Calcium | 241000 | ug/L | 2000 | 05/17/22 02:48 | |
| EPA 6010 | Iron | 2020 | ug/L | 100 | 05/17/22 01:54 | |
| EPA 6010 | Lithium | 100 | ug/L | 20.0 | 05/17/22 01:54 | |
| EPA 6010 | Magnesium | 46800 | ug/L | 1000 | 05/17/22 01:54 | |
| EPA 6010 | Manganese | 493 | ug/L | 10.0 | 05/17/22 01:54 | |
| EPA 6010 | Molybdenum | 592 | ug/L | 10.0 | 05/17/22 01:54 | |
| EPA 6010 | Potassium | 16000 | ug/L | 1000 | 05/17/22 01:54 | |
| EPA 6010 | Silica | 13200 | ug/L | 450 | 05/17/22 01:54 | N2 |
| EPA 6010 | Sodium | 167000 | ug/L | 1000 | 05/17/22 01:54 | |
| EPA 6010 | Manganese, Dissolved | 496 | ug/L | 10.0 | 05/16/22 11:04 | |
| EPA 6010 | Molybdenum, Dissolved | 615 | ug/L | 10.0 | 05/16/22 11:04 | |
| EPA 6020 | Arsenic | 484 | ug/L | 4.0 | 05/13/22 17:17 | |
| EPA 903.1 | Radium-226 | 0.479 ± 0.406 (0.503) C:NA T:92% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 0.518 ± 0.343 (0.648) C:78% T:91% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 0.997 ± 0.749 (1.15) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 248 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 248 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2540C | Total Dissolved Solids | 1480 | mg/L | 20.0 | 05/11/22 13:34 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/13/22 15:07 | H3 |
| HACH 8146 | Iron, Ferrous | 0.21 | mg/L | 0.20 | 05/10/22 14:44 | H3,N2 |
| EPA 365.1 | Phosphate as P04 | 0.89 | mg/L | 0.15 | 05/13/22 14:34 | |
| SM 5310C | Total Organic Carbon | 2.3 | mg/L | 1.0 | 05/13/22 01:18 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 05/17/22 10:16 | |
| **50315730005** | **MW-2S** | | | | | |
| EPA 9056 | Chloride | 110 | mg/L | 25.0 | 05/17/22 15:11 | |
| EPA 9056 | Fluoride | 0.39 | mg/L | 0.10 | 05/17/22 14:34 | |
| EPA 9056 | Sulfate | 113 | mg/L | 2.5 | 05/17/22 14:53 | |
| EPA 6010 | Barium | 97.1 | ug/L | 10.0 | 05/17/22 01:56 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730005** | **MW-2S** | | | | | |
| EPA 6010 | Boron | 396 | ug/L | 100 | 05/17/22 01:56 | |
| EPA 6010 | Calcium | 100000 | ug/L | 1000 | 05/17/22 01:56 | |
| EPA 6010 | Iron | 1120 | ug/L | 100 | 05/17/22 01:56 | |
| EPA 6010 | Magnesium | 30800 | ug/L | 1000 | 05/17/22 01:56 | |
| EPA 6010 | Manganese | 382 | ug/L | 10.0 | 05/17/22 01:56 | |
| EPA 6010 | Molybdenum | 15.5 | ug/L | 10.0 | 05/17/22 01:56 | |
| EPA 6010 | Potassium | 4140 | ug/L | 1000 | 05/17/22 01:56 | |
| EPA 6010 | Silica | 8450 | ug/L | 450 | 05/17/22 01:56 | N2 |
| EPA 6010 | Sodium | 106000 | ug/L | 1000 | 05/17/22 01:56 | |
| EPA 6010 | Manganese, Dissolved | 395 | ug/L | 10.0 | 05/16/22 11:06 | |
| EPA 6010 | Molybdenum, Dissolved | 15.8 | ug/L | 10.0 | 05/16/22 11:06 | |
| EPA 6020 | Arsenic | 8.8 | ug/L | 1.0 | 05/12/22 16:35 | |
| EPA 903.1 | Radium-226 | 0.909 ± 0.556 (0.683) C:NA T:96% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 0.756 ± 0.386 (0.668) C:81% T:85% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 1.67 ± 0.942 (1.35) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 295 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 294 | mg/L | 2.0 | 05/12/22 11:04 | |
| SM 2540C | Total Dissolved Solids | 678 | mg/L | 20.0 | 05/11/22 13:34 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 05/13/22 15:09 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.15 | mg/L | 0.10 | 05/06/22 09:11 | |
| EPA 365.1 | Phosphate as P04 | 0.73 | mg/L | 0.15 | 05/13/22 14:35 | |
| SM 5310C | Total Organic Carbon | 2.0 | mg/L | 1.0 | 05/13/22 01:38 | |
| SM 5310C | Dissolved Organic Carbon | 1.7 | mg/L | 1.0 | 05/17/22 10:28 | |
| **50315730006** | **MW-7S** | | | | | |
| EPA 9056 | Chloride | 186 | mg/L | 25.0 | 05/17/22 18:34 | |
| EPA 9056 | Fluoride | 0.72 | mg/L | 0.10 | 05/17/22 17:57 | |
| EPA 9056 | Sulfate | 578 | mg/L | 25.0 | 05/17/22 18:34 | |
| EPA 6010 | Barium | 37.7 | ug/L | 10.0 | 05/17/22 02:06 | |
| EPA 6010 | Boron | 12300 | ug/L | 100 | 05/17/22 02:06 | |
| EPA 6010 | Calcium | 196000 | ug/L | 1000 | 05/17/22 02:06 | |
| EPA 6010 | Iron | 2990 | ug/L | 100 | 05/17/22 02:06 | |
| EPA 6010 | Lithium | 86.7 | ug/L | 20.0 | 05/17/22 02:06 | |
| EPA 6010 | Magnesium | 43800 | ug/L | 1000 | 05/17/22 02:06 | |
| EPA 6010 | Manganese | 392 | ug/L | 10.0 | 05/17/22 02:06 | |
| EPA 6010 | Molybdenum | 582 | ug/L | 10.0 | 05/17/22 02:06 | |
| EPA 6010 | Potassium | 14600 | ug/L | 1000 | 05/17/22 02:06 | |
| EPA 6010 | Silica | 14300 | ug/L | 450 | 05/17/22 02:06 | N2 |
| EPA 6010 | Sodium | 167000 | ug/L | 1000 | 05/17/22 02:06 | |
| EPA 6010 | Manganese, Dissolved | 395 | ug/L | 10.0 | 05/16/22 11:12 | |
| EPA 6010 | Molybdenum, Dissolved | 594 | ug/L | 10.0 | 05/16/22 11:12 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730006** | **MW-7S** | | | | | |
| EPA 6020 | Arsenic | 374 | ug/L | 4.0 | 05/13/22 17:22 | |
| EPA 903.1 | Radium-226 | 0.0784 ± 0.461 (0.941) C:NA T:92% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 0.711 ± 0.383 (0.679) C:78% T:86% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 0.789 ± 0.844 (1.62) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 252 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 252 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1360 | mg/L | 20.0 | 05/11/22 13:35 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/13/22 15:13 | H3 |
| HACH 8146 | Iron, Ferrous | 0.24 | mg/L | 0.20 | 05/10/22 14:45 | H3,N2 |
| EPA 365.1 | Phosphate as P04 | 0.66 | mg/L | 0.15 | 05/13/22 14:37 | |
| SM 5310C | Total Organic Carbon | 2.1 | mg/L | 1.0 | 05/13/22 03:35 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 05/17/22 11:28 | |
| **50315730007** | **MW-2D** | | | | | |
| EPA 9056 | Chloride | 194 | mg/L | 25.0 | 05/17/22 19:29 | |
| EPA 9056 | Fluoride | 0.95 | mg/L | 0.10 | 05/17/22 18:52 | |
| EPA 9056 | Sulfate | 406 | mg/L | 25.0 | 05/17/22 19:29 | |
| EPA 6010 | Barium | 44.2 | ug/L | 10.0 | 05/17/22 02:12 | |
| EPA 6010 | Boron | 1950 | ug/L | 100 | 05/17/22 02:12 | |
| EPA 6010 | Calcium | 243000 | ug/L | 2000 | 05/17/22 02:50 | |
| EPA 6010 | Iron | 2650 | ug/L | 100 | 05/17/22 02:12 | |
| EPA 6010 | Lithium | 49.4 | ug/L | 20.0 | 05/17/22 02:12 | |
| EPA 6010 | Magnesium | 51200 | ug/L | 1000 | 05/17/22 02:12 | |
| EPA 6010 | Manganese | 481 | ug/L | 10.0 | 05/17/22 02:12 | |
| EPA 6010 | Molybdenum | 52.8 | ug/L | 10.0 | 05/17/22 02:12 | |
| EPA 6010 | Potassium | 10800 | ug/L | 1000 | 05/17/22 02:12 | |
| EPA 6010 | Silica | 15100 | ug/L | 450 | 05/17/22 02:12 | N2 |
| EPA 6010 | Sodium | 140000 | ug/L | 1000 | 05/17/22 02:12 | |
| EPA 6010 | Manganese, Dissolved | 459 | ug/L | 10.0 | 05/16/22 11:14 | |
| EPA 6010 | Molybdenum, Dissolved | 53.4 | ug/L | 10.0 | 05/16/22 11:14 | |
| EPA 6020 | Arsenic | 4.0 | ug/L | 1.0 | 05/12/22 17:47 | |
| EPA 903.1 | Radium-226 | 1.35 ± 0.825 (1.01) C:NA T:87% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 0.534 ± 0.343 (0.638) C:74% T:91% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 1.88 ± 1.17 (1.65) | pCi/L | | 06/13/22 14:57 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730007** | **MW-2D** | | | | | |
| SM 2320B | Alkalinity, Total as CaCO3 | 353 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 353 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1280 | mg/L | 20.0 | 05/11/22 13:36 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 05/13/22 15:14 | H3 |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 05/13/22 03:55 | |
| SM 5310C | Dissolved Organic Carbon | 1.6 | mg/L | 1.0 | 05/17/22 11:41 | |
| **50315730008** | **MW-13S** | | | | | |
| EPA 9056 | Chloride | 171 | mg/L | 25.0 | 05/17/22 21:01 | |
| EPA 9056 | Fluoride | 1.1 | mg/L | 0.10 | 05/17/22 20:24 | |
| EPA 9056 | Sulfate | 522 | mg/L | 25.0 | 05/17/22 21:01 | |
| EPA 6010 | Barium | 43.6 | ug/L | 10.0 | 05/17/22 02:15 | |
| EPA 6010 | Boron | 11800 | ug/L | 100 | 05/17/22 02:15 | |
| EPA 6010 | Calcium | 171000 | ug/L | 1000 | 05/17/22 02:15 | |
| EPA 6010 | Iron | 1700 | ug/L | 100 | 05/17/22 02:15 | |
| EPA 6010 | Lithium | 62.2 | ug/L | 20.0 | 05/17/22 02:15 | |
| EPA 6010 | Magnesium | 46500 | ug/L | 1000 | 05/17/22 02:15 | |
| EPA 6010 | Manganese | 412 | ug/L | 10.0 | 05/17/22 02:15 | |
| EPA 6010 | Molybdenum | 557 | ug/L | 10.0 | 05/17/22 02:15 | |
| EPA 6010 | Potassium | 12600 | ug/L | 1000 | 05/17/22 02:15 | |
| EPA 6010 | Silica | 14700 | ug/L | 450 | 05/17/22 02:15 | N2 |
| EPA 6010 | Sodium | 168000 | ug/L | 1000 | 05/17/22 02:15 | |
| EPA 6010 | Manganese, Dissolved | 415 | ug/L | 10.0 | 05/16/22 11:17 | |
| EPA 6010 | Molybdenum, Dissolved | 573 | ug/L | 10.0 | 05/16/22 11:17 | |
| EPA 6020 | Arsenic | 312 | ug/L | 2.0 | 05/13/22 17:26 | |
| EPA 903.1 | Radium-226 | 0.000 ± 0.372 (0.834) C:NA T:90% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 0.448 ± 0.324 (0.626) C:78% T:95% | pCi/L | | 06/04/22 15:08 | |
| Total Radium Calculation | Total Radium | 0.448 ± 0.696 (1.46) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 262 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 262 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1270 | mg/L | 20.0 | 05/11/22 13:36 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/13/22 15:15 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.46 | mg/L | 0.15 | 05/13/22 14:38 | |
| SM 5310C | Total Organic Carbon | 3.0 | mg/L | 1.0 | 05/13/22 04:16 | |
| SM 5310C | Dissolved Organic Carbon | 3.6 | mg/L | 1.0 | 05/17/22 11:53 | |
| **50315730009** | **MW-13D** | | | | | |
| EPA 9056 | Chloride | 226 | mg/L | 25.0 | 05/17/22 21:56 | |
| EPA 9056 | Fluoride | 0.76 | mg/L | 0.10 | 05/17/22 21:19 | |
| EPA 9056 | Sulfate | 688 | mg/L | 25.0 | 05/17/22 21:56 | |
| EPA 6010 | Barium | 30.4 | ug/L | 10.0 | 05/17/22 02:17 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730009** | **MW-13D** | | | | | |
| EPA 6010 | Boron | 14900 | ug/L | 100 | 05/17/22 02:17 | |
| EPA 6010 | Calcium | 196000 | ug/L | 1000 | 05/17/22 02:17 | |
| EPA 6010 | Iron | 1950 | ug/L | 100 | 05/17/22 02:17 | |
| EPA 6010 | Lithium | 76.3 | ug/L | 20.0 | 05/17/22 02:17 | |
| EPA 6010 | Magnesium | 50300 | ug/L | 1000 | 05/17/22 02:17 | |
| EPA 6010 | Manganese | 184 | ug/L | 10.0 | 05/17/22 02:17 | |
| EPA 6010 | Molybdenum | 565 | ug/L | 10.0 | 05/17/22 02:17 | |
| EPA 6010 | Potassium | 15300 | ug/L | 1000 | 05/17/22 02:17 | |
| EPA 6010 | Silica | 14000 | ug/L | 450 | 05/17/22 02:17 | N2 |
| EPA 6010 | Sodium | 177000 | ug/L | 1000 | 05/17/22 02:17 | |
| EPA 6010 | Manganese, Dissolved | 176 | ug/L | 10.0 | 05/16/22 11:19 | |
| EPA 6010 | Molybdenum, Dissolved | 567 | ug/L | 10.0 | 05/16/22 11:19 | |
| EPA 6020 | Arsenic | 245 | ug/L | 2.0 | 05/13/22 17:31 | |
| EPA 903.1 | Radium-226 | 0.280 ± 0.436 (0.755) C:NA T:95% | pCi/L | | 06/10/22 12:48 | |
| EPA 904.0 | Radium-228 | 1.26 ± 0.479 (0.724) C:76% T:90% | pCi/L | | 06/04/22 15:09 | |
| Total Radium Calculation | Total Radium | 1.54 ± 0.915 (1.48) | pCi/L | | 06/13/22 14:57 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 196 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 196 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1420 | mg/L | 20.0 | 05/11/22 13:37 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 05/13/22 15:16 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.27 | mg/L | 0.15 | 05/13/22 14:39 | |
| SM 5310C | Total Organic Carbon | 2.0 | mg/L | 1.0 | 05/13/22 04:57 | |
| SM 5310C | Dissolved Organic Carbon | 2.5 | mg/L | 1.0 | 05/17/22 12:06 | |
| **50315730010** | **MW-2S RAD MS** | | | | | |
| EPA 903.1 | Radium-226 | 73.63 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 06/10/22 13:06 | |
| EPA 904.0 | Radium-228 | 114.44 %REC ± NA (NA) C:NA T:NA | pCi/L | | 06/04/22 15:09 | |
| **50315730011** | **MW-2S RAD MSD** | | | | | |
| EPA 903.1 | Radium-226 | 104.55 %REC 34.70 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 06/10/22 13:06 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315730011** | **MW-2S RAD MSD** | | | | | |
| EPA 904.0 | Radium-228 | 86.12 %REC 28.23 RPD ± NA (NA) C:NA T:NA | pCi/L | | 06/04/22 15:09 | |
| **50315733006** | **DUP-1** | | | | | |
| EPA 9056 | Chloride | 181 | mg/L | 25.0 | 05/18/22 05:55 | |
| EPA 9056 | Fluoride | 0.71 | mg/L | 0.10 | 05/18/22 05:18 | |
| EPA 9056 | Sulfate | 561 | mg/L | 25.0 | 05/18/22 05:55 | |
| EPA 6010 | Barium | 38.1 | ug/L | 10.0 | 05/17/22 02:44 | |
| EPA 6010 | Boron | 12400 | ug/L | 100 | 05/17/22 02:44 | |
| EPA 6010 | Calcium | 196000 | ug/L | 1000 | 05/17/22 02:44 | |
| EPA 6010 | Iron | 3050 | ug/L | 100 | 05/17/22 02:44 | |
| EPA 6010 | Lithium | 87.1 | ug/L | 20.0 | 05/17/22 02:44 | |
| EPA 6010 | Magnesium | 43900 | ug/L | 1000 | 05/17/22 02:44 | |
| EPA 6010 | Manganese | 399 | ug/L | 10.0 | 05/17/22 02:44 | |
| EPA 6010 | Molybdenum | 584 | ug/L | 10.0 | 05/17/22 02:44 | |
| EPA 6010 | Potassium | 14700 | ug/L | 1000 | 05/17/22 02:44 | |
| EPA 6010 | Silica | 14300 | ug/L | 450 | 05/17/22 02:44 | N2 |
| EPA 6010 | Sodium | 168000 | ug/L | 1000 | 05/17/22 02:44 | |
| EPA 6010 | Manganese, Dissolved | 398 | ug/L | 10.0 | 05/16/22 11:43 | |
| EPA 6010 | Molybdenum, Dissolved | 599 | ug/L | 10.0 | 05/16/22 11:43 | |
| EPA 6020 | Arsenic | 364 | ug/L | 5.0 | 05/13/22 17:36 | |
| EPA 903.1 | Radium-226 | -0.0776 ± 0.456 (1.02) C:NA T:89% | pCi/L | | 06/10/22 12:19 | |
| EPA 904.0 | Radium-228 | 0.706 ± 0.341 (0.553) C:79% T:83% | pCi/L | | 06/04/22 15:04 | |
| Total Radium Calculation | Total Radium | 0.706 ± 0.797 (1.57) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 250 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 250 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1330 | mg/L | 20.0 | 05/11/22 15:02 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/13/22 15:30 | H3 |
| HACH 8146 | Iron, Ferrous | 0.22 | mg/L | 0.20 | 05/10/22 15:15 | H3,N2 |
| EPA 365.1 | Phosphate as P04 | 0.66 | mg/L | 0.15 | 05/13/22 14:47 | |
| SM 5310C | Total Organic Carbon | 2.5 | mg/L | 1.0 | 05/13/22 07:20 | |
| SM 5310C | Dissolved Organic Carbon | 2.4 | mg/L | 1.0 | 05/17/22 13:57 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-4S** **Lab ID: 50315730001** Collected: 05/04/22 11:42 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **9.0** | mg/L | 0.25 | 1 | | 05/18/22 17:39 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 05/18/22 17:39 | 16984-48-8 | |
| Sulfate | **415** | mg/L | 25.0 | 100 | | 05/18/22 17:21 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7429-90-5 | |
| Barium | **90.7** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7440-39-3 | |
| Boron | **3510** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7440-43-9 | |
| Calcium | **275000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:27 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7439-93-2 | |
| Magnesium | **53500** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7439-98-7 | |
| Potassium | **2150** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7440-09-7 | |
| Silica | **13700** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7631-86-9 | N2 |
| Sodium | **14600** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:48 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 10:52 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 10:52 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:09 | 7440-36-0 | |
| Arsenic | **1.1** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:09 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:09 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:09 | 7440-48-4 | |
| Selenium | **119** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:09 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:09 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 09:57 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **452** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Bicarbonate (CaCO3) | **452** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-4S** **Lab ID: 50315730001** Collected: 05/04/22 11:42 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1060** | mg/L | 20.0 | 1 | | 05/11/22 13:32 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.1** | Std. Units | 0.10 | 1 | | 05/13/22 15:04 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 14:43 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **4.0** | mg/L | 0.10 | 1 | | 05/06/22 09:28 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:28 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:30 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/13/22 00:17 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.2** | mg/L | 1.0 | 1 | | 05/17/22 09:39 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-5S** **Lab ID: 50315730002** Collected: 05/04/22 13:36 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **231** | mg/L | 25.0 | 100 | | 05/18/22 18:16 | 16887-00-6 | |
| Fluoride | **1.8** | mg/L | 0.10 | 1 | | 05/18/22 17:57 | 16984-48-8 | |
| Sulfate | **574** | mg/L | 25.0 | 100 | | 05/18/22 18:16 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7429-90-5 | |
| Barium | **37.4** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7440-39-3 | |
| Boron | **2460** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7440-43-9 | |
| Calcium | **233000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:29 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7439-92-1 | |
| Lithium | **46.5** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7439-93-2 | |
| Magnesium | **58800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7439-95-4 | |
| Manganese | **1060** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7439-96-5 | |
| Molybdenum | **122** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7439-98-7 | |
| Potassium | **8500** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7440-09-7 | |
| Silica | **15400** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7631-86-9 | N2 |
| Sodium | **171000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:50 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **1120** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 10:55 | 7439-96-5 | |
| Molybdenum, Dissolved | **131** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 10:55 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:14 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:14 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:14 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:14 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:14 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:14 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 09:59 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **364** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Bicarbonate (CaCO3) | **364** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-5S** **Lab ID: 50315730002** Collected: 05/04/22 13:36 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1500** | mg/L | 20.0 | 1 | | 05/11/22 13:33 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 05/13/22 15:05 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 14:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:35 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:35 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:31 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.4** | mg/L | 1.0 | 1 | | 05/13/22 00:38 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 05/17/22 09:52 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-6S** **Lab ID: 50315730003** Collected: 05/04/22 15:11 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **129** | mg/L | 25.0 | 100 | | 05/17/22 13:20 | 16887-00-6 | |
| Fluoride | **1.3** | mg/L | 0.10 | 1 | | 05/18/22 18:34 | 16984-48-8 | |
| Sulfate | **572** | mg/L | 25.0 | 100 | | 05/17/22 13:20 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7429-90-5 | |
| Barium | **132** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7440-39-3 | |
| Boron | **6290** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7440-43-9 | |
| Calcium | **279000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:31 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7440-47-3 | |
| Iron | **4190** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7439-92-1 | |
| Lithium | **71.2** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7439-93-2 | |
| Magnesium | **72500** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7439-95-4 | |
| Manganese | **1900** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7439-96-5 | |
| Molybdenum | **150** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7439-98-7 | |
| Potassium | **11700** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7440-09-7 | |
| Silica | **14000** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7631-86-9 | N2 |
| Sodium | **127000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:52 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **1870** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 10:57 | 7439-96-5 | |
| Molybdenum, Dissolved | **158** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 10:57 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:23 | 7440-36-0 | |
| Arsenic | **6.9** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:23 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:23 | 7440-41-7 | |
| Cobalt | **1.5** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:23 | 7440-48-4 | |
| Selenium | **4.4** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:23 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:23 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:01 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **528** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Bicarbonate (CaCO3) | **528** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-6S** **Lab ID: 50315730003** Collected: 05/04/22 15:11 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1520** | mg/L | 20.0 | 1 | | 05/11/22 13:33 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.1** | Std. Units | 0.10 | 1 | | 05/13/22 15:06 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.23** | mg/L | 0.20 | 1 | | 05/10/22 14:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.67** | mg/L | 0.10 | 1 | | 05/06/22 09:50 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:50 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.16** | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:32 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.9** | mg/L | 1.0 | 1 | | 05/13/22 00:58 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.4** | mg/L | 1.0 | 1 | | 05/17/22 10:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-7D** **Lab ID: 50315730004** Collected: 05/04/22 14:20 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **174** | mg/L | 25.0 | 100 | | 05/17/22 14:16 | 16887-00-6 | |
| Fluoride | **0.51** | mg/L | 0.10 | 1 | | 05/17/22 13:39 | 16984-48-8 | |
| Sulfate | **671** | mg/L | 25.0 | 100 | | 05/17/22 14:16 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7429-90-5 | |
| Barium | **42.4** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7440-39-3 | |
| Boron | **14300** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7440-43-9 | |
| Calcium | **241000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:48 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7440-47-3 | |
| Iron | **2020** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7439-92-1 | |
| Lithium | **100** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7439-93-2 | |
| Magnesium | **46800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7439-95-4 | |
| Manganese | **493** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7439-96-5 | |
| Molybdenum | **592** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7439-98-7 | |
| Potassium | **16000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7440-09-7 | |
| Silica | **13200** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7631-86-9 | N2 |
| Sodium | **167000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:54 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **496** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:04 | 7439-96-5 | |
| Molybdenum, Dissolved | **615** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:04 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:28 | 7440-36-0 | |
| Arsenic | **484** | ug/L | 4.0 | 4 | 05/11/22 15:30 | 05/13/22 17:17 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:28 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:28 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:28 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:28 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:04 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **248** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Bicarbonate (CaCO3) | **248** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-7D** **Lab ID: 50315730004** Collected: 05/04/22 14:20 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1480** | mg/L | 20.0 | 1 | | 05/11/22 13:34 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/13/22 15:07 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.21** | mg/L | 0.20 | 1 | | 05/10/22 14:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:41 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:41 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.89** | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:34 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 05/13/22 01:18 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 05/17/22 10:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2S** **Lab ID: 50315730005** Collected: 05/04/22 10:40 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **110** | mg/L | 25.0 | 100 | | 05/17/22 15:11 | 16887-00-6 | |
| Fluoride | **0.39** | mg/L | 0.10 | 1 | | 05/17/22 14:34 | 16984-48-8 | |
| Sulfate | **113** | mg/L | 2.5 | 10 | | 05/17/22 14:53 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7429-90-5 | |
| Barium | **97.1** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-39-3 | |
| Boron | **396** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-43-9 | |
| Calcium | **100000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-47-3 | |
| Iron | **1120** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7439-93-2 | |
| Magnesium | **30800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7439-95-4 | |
| Manganese | **382** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7439-96-5 | |
| Molybdenum | **15.5** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7439-98-7 | |
| Potassium | **4140** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-09-7 | |
| Silica | **8450** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7631-86-9 | N2 |
| Sodium | **106000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 01:56 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **395** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:06 | 7439-96-5 | |
| Molybdenum, Dissolved | **15.8** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:06 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 16:35 | 7440-36-0 | |
| Arsenic | **8.8** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 16:35 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 16:35 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 16:35 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 16:35 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 16:35 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:06 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **295** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Bicarbonate (CaCO3) | **294** | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/12/22 11:04 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2S** **Lab ID: 50315730005** Collected: 05/04/22 10:40 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **678** | mg/L | 20.0 | 1 | | 05/11/22 13:34 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 1 | | 05/13/22 15:09 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 14:45 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.15** | mg/L | 0.10 | 1 | | 05/06/22 09:11 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:11 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.73** | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:35 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/13/22 01:38 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 05/17/22 10:28 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-7S** **Lab ID: 50315730006** Collected: 05/04/22 13:10 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **186** | mg/L | 25.0 | 100 | | 05/17/22 18:34 | 16887-00-6 | |
| Fluoride | **0.72** | mg/L | 0.10 | 1 | | 05/17/22 17:57 | 16984-48-8 | |
| Sulfate | **578** | mg/L | 25.0 | 100 | | 05/17/22 18:34 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7429-90-5 | |
| Barium | **37.7** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-39-3 | |
| Boron | **12300** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-43-9 | |
| Calcium | **196000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-47-3 | |
| Iron | **2990** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7439-92-1 | |
| Lithium | **86.7** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7439-93-2 | |
| Magnesium | **43800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7439-95-4 | |
| Manganese | **392** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7439-96-5 | |
| Molybdenum | **582** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7439-98-7 | |
| Potassium | **14600** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-09-7 | |
| Silica | **14300** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7631-86-9 | N2 |
| Sodium | **167000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:06 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **395** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:12 | 7439-96-5 | |
| Molybdenum, Dissolved | **594** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:12 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:42 | 7440-36-0 | |
| Arsenic | **374** | ug/L | 4.0 | 4 | 05/11/22 15:30 | 05/13/22 17:22 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:42 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:42 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:42 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:42 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:19 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **252** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **252** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-7S** **Lab ID: 50315730006** Collected: 05/04/22 13:10 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1360** | mg/L | 20.0 | 1 | | 05/11/22 13:35 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/13/22 15:13 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.24** | mg/L | 0.20 | 1 | | 05/10/22 14:45 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:33 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:33 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.66** | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:37 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 05/13/22 03:35 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/17/22 11:28 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2D** **Lab ID: 50315730007** Collected: 05/04/22 10:47 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **194** | mg/L | 25.0 | 100 | | 05/17/22 19:29 | 16887-00-6 | |
| Fluoride | **0.95** | mg/L | 0.10 | 1 | | 05/17/22 18:52 | 16984-48-8 | |
| Sulfate | **406** | mg/L | 25.0 | 100 | | 05/17/22 19:29 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7429-90-5 | |
| Barium | **44.2** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7440-39-3 | |
| Boron | **1950** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7440-43-9 | |
| Calcium | **243000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:50 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7440-47-3 | |
| Iron | **2650** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7439-92-1 | |
| Lithium | **49.4** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7439-93-2 | |
| Magnesium | **51200** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7439-95-4 | |
| Manganese | **481** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7439-96-5 | |
| Molybdenum | **52.8** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7439-98-7 | |
| Potassium | **10800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7440-09-7 | |
| Silica | **15100** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7631-86-9 | N2 |
| Sodium | **140000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:12 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **459** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:14 | 7439-96-5 | |
| Molybdenum, Dissolved | **53.4** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:14 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:47 | 7440-36-0 | |
| Arsenic | **4.0** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:47 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:47 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:47 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:47 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:47 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:21 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **353** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **353** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2D** **Lab ID: 50315730007** Collected: 05/04/22 10:47 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1280** | mg/L | 20.0 | 1 | | 05/11/22 13:36 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 05/13/22 15:14 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 14:46 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:16 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:16 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:38 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 05/13/22 03:55 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/17/22 11:41 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-13S** **Lab ID: 50315730008** Collected: 05/04/22 13:02 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **171** | mg/L | 25.0 | 100 | | 05/17/22 21:01 | 16887-00-6 | |
| Fluoride | **1.1** | mg/L | 0.10 | 1 | | 05/17/22 20:24 | 16984-48-8 | |
| Sulfate | **522** | mg/L | 25.0 | 100 | | 05/17/22 21:01 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7429-90-5 | |
| Barium | **43.6** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-39-3 | |
| Boron | **11800** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-43-9 | |
| Calcium | **171000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-47-3 | |
| Iron | **1700** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7439-92-1 | |
| Lithium | **62.2** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7439-93-2 | |
| Magnesium | **46500** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7439-95-4 | |
| Manganese | **412** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7439-96-5 | |
| Molybdenum | **557** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7439-98-7 | |
| Potassium | **12600** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-09-7 | |
| Silica | **14700** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7631-86-9 | N2 |
| Sodium | **168000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:15 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **415** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:17 | 7439-96-5 | |
| Molybdenum, Dissolved | **573** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:17 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:57 | 7440-36-0 | |
| Arsenic | **312** | ug/L | 2.0 | 2 | 05/11/22 15:30 | 05/13/22 17:26 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 17:57 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:57 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:57 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 17:57 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:24 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **262** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **262** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-13S** **Lab ID: 50315730008** Collected: 05/04/22 13:02 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1270** | mg/L | 20.0 | 1 | | 05/11/22 13:36 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/13/22 15:15 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 14:46 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:31 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:31 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.46** | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:38 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **3.0** | mg/L | 1.0 | 1 | | 05/13/22 04:16 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.6** | mg/L | 1.0 | 1 | | 05/17/22 11:53 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-13D** **Lab ID: 50315730009** Collected: 05/04/22 14:31 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **226** | mg/L | 25.0 | 100 | | 05/17/22 21:56 | 16887-00-6 | |
| Fluoride | **0.76** | mg/L | 0.10 | 1 | | 05/17/22 21:19 | 16984-48-8 | |
| Sulfate | **688** | mg/L | 25.0 | 100 | | 05/17/22 21:56 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7429-90-5 | |
| Barium | **30.4** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-39-3 | |
| Boron | **14900** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-43-9 | |
| Calcium | **196000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-47-3 | |
| Iron | **1950** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7439-92-1 | |
| Lithium | **76.3** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7439-93-2 | |
| Magnesium | **50300** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7439-95-4 | |
| Manganese | **184** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7439-96-5 | |
| Molybdenum | **565** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7439-98-7 | |
| Potassium | **15300** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-09-7 | |
| Silica | **14000** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7631-86-9 | N2 |
| Sodium | **177000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:17 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **176** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:19 | 7439-96-5 | |
| Molybdenum, Dissolved | **567** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:19 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 18:01 | 7440-36-0 | |
| Arsenic | **245** | ug/L | 2.0 | 2 | 05/11/22 15:30 | 05/13/22 17:31 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/11/22 15:30 | 05/12/22 18:01 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 18:01 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 18:01 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/12/22 18:01 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/09/22 17:56 | 05/10/22 10:26 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **196** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **196** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-13D** **Lab ID: 50315730009** Collected: 05/04/22 14:31 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1420** | mg/L | 20.0 | 1 | | 05/11/22 13:37 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 1 | | 05/13/22 15:16 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 08:49 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 14:46 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:42 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:42 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.27** | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:39 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/13/22 04:57 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.5** | mg/L | 1.0 | 1 | | 05/17/22 12:06 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: DUP-1** **Lab ID: 50315733006** Collected: 05/04/22 13:10 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **181** | mg/L | 25.0 | 100 | | 05/18/22 05:55 | 16887-00-6 | |
| Fluoride | **0.71** | mg/L | 0.10 | 1 | | 05/18/22 05:18 | 16984-48-8 | |
| Sulfate | **561** | mg/L | 25.0 | 100 | | 05/18/22 05:55 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7429-90-5 | |
| Barium | **38.1** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-39-3 | |
| Boron | **12400** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-43-9 | |
| Calcium | **196000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-47-3 | |
| Iron | **3050** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7439-92-1 | |
| Lithium | **87.1** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7439-93-2 | |
| Magnesium | **43900** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7439-95-4 | |
| Manganese | **399** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7439-96-5 | |
| Molybdenum | **584** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7439-98-7 | |
| Potassium | **14700** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-09-7 | |
| Silica | **14300** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7631-86-9 | N2 |
| Sodium | **168000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:44 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **398** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:43 | 7439-96-5 | |
| Molybdenum, Dissolved | **599** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:43 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:14 | 7440-36-0 | |
| Arsenic | **364** | ug/L | 5.0 | 5 | 05/11/22 15:30 | 05/13/22 17:36 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:14 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:14 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **250** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **250** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1330** | mg/L | 20.0 | 1 | | 05/11/22 15:02 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: DUP-1** **Lab ID: 50315733006** Collected: 05/04/22 13:10 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/13/22 15:30 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.22** | mg/L | 0.20 | 1 | | 05/10/22 15:15 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:09 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:09 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.66** | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 14:47 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.5** | mg/L | 1.0 | 1 | | 05/13/22 07:20 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.4** | mg/L | 1.0 | 1 | | 05/17/22 13:57 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 676285
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3114230 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/19/22 09:08 | |
| Fluoride | mg/L | ND | 0.10 | 05/19/22 09:08 | |
| Sulfate | mg/L | ND | 0.25 | 05/19/22 09:08 | |

LABORATORY CONTROL SAMPLE: 3114231

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 96 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.54 | 108 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.7 | 109 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114232 3114233

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 110 | 125 | 125 | 287 | 289 | 142 | 144 | 80-120 | 1 | 15 | M0 |
| Fluoride | mg/L | 0.39 | 0.5 | 0.5 | 0.92 | 0.92 | 107 | 107 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 113 | 25 | 25 | 153 | 153 | 161 | 162 | 80-120 | 0 | 15 | M0 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114234 3114235

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 135 | 125 | 125 | 281 | 281 | 116 | 116 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.22 | 0.5 | 0.5 | 0.80 | 0.80 | 117 | 117 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 40.2 | 25 | 25 | 70.4 | 70.2 | 121 | 120 | 80-120 | 0 | 15 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675173
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

METHOD BLANK: 3109005 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/10/22 09:52 | |

LABORATORY CONTROL SAMPLE: 3109006

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 5.4 | 108 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109007 3109008

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 5.0 | 5.0 | 101 | 100 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109009 3109010

| Parameter | Units | 50315786003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 5.2 | 5.0 | 104 | 99 | 75-125 | 5 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675187
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3109067 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/17/22 01:40 | |
| Barium | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Boron | ug/L | ND | 100 | 05/17/22 01:40 | |
| Cadmium | ug/L | ND | 2.0 | 05/17/22 01:40 | |
| Calcium | ug/L | ND | 1000 | 05/17/22 01:40 | |
| Chromium | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Iron | ug/L | ND | 100 | 05/17/22 01:40 | |
| Lead | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Lithium | ug/L | ND | 20.0 | 05/17/22 01:40 | |
| Magnesium | ug/L | ND | 1000 | 05/17/22 01:40 | |
| Manganese | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Molybdenum | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Potassium | ug/L | ND | 1000 | 05/17/22 01:40 | |
| Silica | ug/L | ND | 450 | 05/17/22 01:40 | N2 |
| Sodium | ug/L | ND | 1000 | 05/17/22 01:40 | |

LABORATORY CONTROL SAMPLE: 3109068

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9720 | 97 | 80-120 | |
| Barium | ug/L | 1000 | 986 | 99 | 80-120 | |
| Boron | ug/L | 1000 | 953 | 95 | 80-120 | |
| Cadmium | ug/L | 1000 | 933 | 93 | 80-120 | |
| Calcium | ug/L | 10000 | 10300 | 103 | 80-120 | |
| Chromium | ug/L | 1000 | 968 | 97 | 80-120 | |
| Iron | ug/L | 10000 | 9570 | 96 | 80-120 | |
| Lead | ug/L | 1000 | 928 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1030 | 103 | 80-120 | |
| Magnesium | ug/L | 10000 | 9530 | 95 | 80-120 | |
| Manganese | ug/L | 1000 | 921 | 92 | 80-120 | |
| Molybdenum | ug/L | 1000 | 987 | 99 | 80-120 | |
| Potassium | ug/L | 10000 | 9680 | 97 | 80-120 | |
| Silica | ug/L | 10700 | 10200 | 95 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9660 | 97 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109069 3109070

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9690 | 9760 | 97 | 98 | 75-125 | 1 | 20 | |
| Barium | ug/L | 97.1 | 1000 | 1000 | 1040 | 1080 | 94 | 98 | 75-125 | 3 | 20 | |
| Boron | ug/L | 396 | 1000 | 1000 | 1360 | 1380 | 96 | 99 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 915 | 948 | 91 | 95 | 75-125 | 4 | 20 | |
| Calcium | ug/L | 100000 | 10000 | 10000 | 106000 | 109000 | 55 | 93 | 75-125 | 4 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 934 | 965 | 93 | 96 | 75-125 | 3 | 20 | |
| Iron | ug/L | 1120 | 10000 | 10000 | 10600 | 10700 | 95 | 96 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 867 | 898 | 87 | 90 | 75-125 | 3 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1040 | 1070 | 103 | 106 | 75-125 | 3 | 20 | |
| Magnesium | ug/L | 30800 | 10000 | 10000 | 39400 | 40400 | 85 | 96 | 75-125 | 3 | 20 | |
| Manganese | ug/L | 382 | 1000 | 1000 | 1290 | 1310 | 90 | 93 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | 15.5 | 1000 | 1000 | 974 | 1010 | 96 | 99 | 75-125 | 4 | 20 | |
| Potassium | ug/L | 4140 | 10000 | 10000 | 13700 | 14200 | 95 | 101 | 75-125 | 4 | 20 | |
| Silica | ug/L | 8450 | 10700 | 10700 | 18600 | 19000 | 95 | 98 | 75-125 | 2 | 20 | N2 |
| Sodium | ug/L | 106000 | 10000 | 10000 | 110000 | 115000 | 44 | 97 | 75-125 | 5 | 20 | P6 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109071 3109072

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9810 | 9330 | 98 | 93 | 75-125 | 5 | 20 | |
| Barium | ug/L | 202 | 1000 | 1000 | 1200 | 1120 | 100 | 92 | 75-125 | 7 | 20 | |
| Boron | ug/L | 280 | 1000 | 1000 | 1240 | 1170 | 96 | 89 | 75-125 | 6 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 951 | 890 | 95 | 89 | 75-125 | 7 | 20 | |
| Calcium | ug/L | 91800 | 10000 | 10000 | 103000 | 96500 | 115 | 46 | 75-125 | 7 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 976 | 913 | 97 | 91 | 75-125 | 7 | 20 | |
| Iron | ug/L | 1500 | 10000 | 10000 | 11300 | 10600 | 98 | 91 | 75-125 | 6 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 908 | 852 | 91 | 85 | 75-125 | 6 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1080 | 1010 | 107 | 100 | 75-125 | 7 | 20 | |
| Magnesium | ug/L | 26100 | 10000 | 10000 | 36000 | 33800 | 99 | 76 | 75-125 | 6 | 20 | |
| Manganese | ug/L | 309 | 1000 | 1000 | 1250 | 1180 | 94 | 87 | 75-125 | 6 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 1010 | 939 | 101 | 94 | 75-125 | 7 | 20 | |
| Potassium | ug/L | 7500 | 10000 | 10000 | 17800 | 16600 | 103 | 91 | 75-125 | 7 | 20 | |
| Silica | ug/L | 10700 | 10700 | 10700 | 21600 | 20100 | 102 | 87 | 75-125 | 7 | 20 | N2 |
| Sodium | ug/L | 62700 | 10000 | 10000 | 73500 | 68400 | 108 | 57 | 75-125 | 7 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675141
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3108884 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/16/22 09:48 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/16/22 09:48 | |

LABORATORY CONTROL SAMPLE: 3108885

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 934 | 93 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1010 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108886 3108887

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 395 | 1000 | 1000 | 1390 | 1340 | 99 | 94 | 75-125 | 4 | 20 | |
| Molybdenum, Dissolved | ug/L | 15.8 | 1000 | 1000 | 1080 | 1050 | 107 | 103 | 75-125 | 4 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108888 3108889

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1250 | 1240 | 95 | 94 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1030 | 1040 | 102 | 104 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675545
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

METHOD BLANK: 3110469 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/12/22 15:18 | |
| Arsenic | ug/L | ND | 1.0 | 05/12/22 15:18 | |
| Beryllium | ug/L | ND | 0.20 | 05/12/22 15:18 | |
| Cobalt | ug/L | ND | 1.0 | 05/12/22 15:18 | |
| Selenium | ug/L | ND | 1.0 | 05/12/22 15:18 | |
| Thallium | ug/L | ND | 1.0 | 05/12/22 15:18 | |

LABORATORY CONTROL SAMPLE: 3110470

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 43.8 | 110 | 80-120 | |
| Arsenic | ug/L | 40 | 39.1 | 98 | 80-120 | |
| Beryllium | ug/L | 40 | 42.0 | 105 | 80-120 | |
| Cobalt | ug/L | 40 | 42.4 | 106 | 80-120 | |
| Selenium | ug/L | 40 | 39.7 | 99 | 80-120 | |
| Thallium | ug/L | 40 | 42.4 | 106 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110471 3110472

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.6 | 42.5 | 106 | 106 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | 8.8 | 40 | 40 | 48.3 | 47.7 | 99 | 97 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 41.5 | 41.4 | 104 | 104 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.9 | 38.7 | 96 | 96 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 40.4 | 39.5 | 100 | 98 | 75-125 | 2 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 41.6 | 41.4 | 104 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675548
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733006

METHOD BLANK: 3110481 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/13/22 02:02 | |
| Arsenic | ug/L | ND | 1.0 | 05/13/22 02:02 | |
| Cobalt | ug/L | ND | 1.0 | 05/13/22 02:02 | |
| Selenium | ug/L | ND | 1.0 | 05/13/22 02:02 | |

LABORATORY CONTROL SAMPLE: 3110482

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.7 | 104 | 80-120 | |
| Arsenic | ug/L | 40 | 39.4 | 99 | 80-120 | |
| Cobalt | ug/L | 40 | 40.3 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 40.1 | 100 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110483 3110484

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 45.3 | 42.8 | 113 | 107 | 75-125 | 6 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 39.4 | 38.5 | 98 | 96 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 41.1 | 38.2 | 103 | 95 | 75-125 | 7 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 39.6 | 39.3 | 98 | 98 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675648 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005

METHOD BLANK: 3110939 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/12/22 11:04 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/12/22 11:04 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/12/22 11:04 | |

LABORATORY CONTROL SAMPLE: 3110940

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.6 | 99 | 90-110 | |

SAMPLE DUPLICATE: 3110941

| Parameter | Units | 50315596001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 313 | 317 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 313 | 317 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3110942

| Parameter | Units | 50315730005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 295 | 301 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 294 | 299 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675775
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3111544 Matrix: Water
Associated Lab Samples: 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/13/22 14:51 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/13/22 14:51 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/13/22 14:51 | |

LABORATORY CONTROL SAMPLE: 3111545

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.5 | 99 | 90-110 | |

SAMPLE DUPLICATE: 3111546

| Parameter | Units | 50315730006 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 252 | 256 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 252 | 256 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3111547

| Parameter | Units | 50315733002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 252 | 252 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 252 | 252 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675556
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

METHOD BLANK: 3110504 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/11/22 13:22 | |

LABORATORY CONTROL SAMPLE: 3110505

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 281 | 94 | 80-120 | |

SAMPLE DUPLICATE: 3110506

| Parameter | Units | 50315718001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 703 | 713 | 1 | 10 | |

SAMPLE DUPLICATE: 3110507

| Parameter | Units | 50315730005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 678 | 698 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675557
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733006

METHOD BLANK: 3110508 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/11/22 14:56 | |

LABORATORY CONTROL SAMPLE: 3110509

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 289 | 96 | 80-120 | |

SAMPLE DUPLICATE: 3110510

| Parameter | Units | 50315733002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 535 | 552 | 3 | 10 | |

SAMPLE DUPLICATE: 3110511

| Parameter | Units | 50315786003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1120 | 1080 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 676173
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

SAMPLE DUPLICATE: 3113485

| Parameter | Units | 50315718001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.8 | 7.8 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3113486

| Parameter | Units | 50315730005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.7 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3113487

| Parameter | Units | 50315733002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 674955
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

METHOD BLANK: 3108148 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/07/22 08:49 | |

LABORATORY CONTROL SAMPLE: 3108149

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.53 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108150 3108151

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.52 | 103 | 104 | 90-110 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3108152

| Parameter | Units | 50315769001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.37 | 74 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 674956
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733006

METHOD BLANK: 3108153 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/07/22 09:11 | |

LABORATORY CONTROL SAMPLE: 3108154

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.54 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108155 3108156

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.43 | 0.41 | 86 | 82 | 90-110 | 5 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3108157

| Parameter | Units | 50315777001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.34 | 69 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675310 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

METHOD BLANK: 3109482 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 14:41 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109483

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 0.97 | 97 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109484 3109485

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.2 | 1.1 | 97 | 94 | 90-110 | 3 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3109486

| Parameter | Units | 50315807001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 0.67 | 1 | 1.6 | 96 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675312
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733006

METHOD BLANK: 3109491 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 15:13 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109492

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 100 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109493 3109494

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 101 | 103 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109495 3109496

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 104 | 90-110 | 1 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 674764
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3106949 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/06/22 09:05 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/06/22 09:05 | |

LABORATORY CONTROL SAMPLE: 3106950

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106951 3106952

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.15 | 1 | 1 | 1.1 | 1.1 | 98 | 96 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.95 | 0.96 | 95 | 95 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106953 3106954

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 96 | 96 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675357
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003

METHOD BLANK: 3109637 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/13/22 14:15 | |

LABORATORY CONTROL SAMPLE: 3109638

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.6 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109639 3109640

| Parameter | Units | 50315604001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.6 | 1.5 | | | | 5 | | |

MATRIX SPIKE SAMPLE: 3109641

| Parameter | Units | 50315730001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.6 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675359 | Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 | Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

METHOD BLANK: 3109647 Matrix: Water
Associated Lab Samples: 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/13/22 14:32 | |

LABORATORY CONTROL SAMPLE: 3109648

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109649 3109650

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.73 | | | 2.3 | 2.3 | | | | 0 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675362
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733006

METHOD BLANK: 3109659 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/13/22 14:42 | |

LABORATORY CONTROL SAMPLE: 3109660

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109661 3109662

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.7 | | | | 8 | | |

MATRIX SPIKE SAMPLE: 3109663

| Parameter | Units | 50315807001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 5.5 | | 7.4 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 675018 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3108517 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/12/22 20:20 | |

LABORATORY CONTROL SAMPLE: 3108518

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108519 3108520

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.0 | 10 | 10 | 11.8 | 12.1 | 98 | 101 | 80-120 | 3 | 20 | |

MATRIX SPIKE SAMPLE: 3108521

| Parameter | Units | 50315730008 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.0 | 10 | 12.6 | 96 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 676497
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

METHOD BLANK: 3114854 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315733006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/17/22 08:47 | |

LABORATORY CONTROL SAMPLE: 3114855

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.5 | 105 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114856 3114857

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.7 | 10 | 10 | 12.1 | 13.3 | 104 | 115 | 80-120 | 9 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114858 3114859

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.7 | 10 | 10 | 13.3 | 12.8 | 106 | 101 | 80-120 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-4S** **Lab ID: 50315730001** Collected: 05/04/22 11:42 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.131 ± 0.444 (0.858) C:NA T:99%** | pCi/L | 06/10/22 12:19 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.492 ± 0.316 (0.594) C:81% T:97%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.623 ± 0.760 (1.45)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-5S** **Lab ID: 50315730002** Collected: 05/04/22 13:36 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.206 ± 0.447 (0.825) C:NA T:97%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.806 ± 0.371 (0.611) C:81% T:89%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.01 ± 0.818 (1.44)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-6S** **Lab ID: 50315730003** Collected: 05/04/22 15:11 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.000 ± 0.601 (1.22) C:NA T:92%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.508 ± 0.320 (0.584) C:84% T:86%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.508 ± 0.921 (1.80)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-7D** **Lab ID: 50315730004** Collected: 05/04/22 14:20 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.479 ± 0.406 (0.503) C:NA T:92%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.518 ± 0.343 (0.648) C:78% T:91%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.997 ± 0.749 (1.15)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2S** **Lab ID: 50315730005** Collected: 05/04/22 10:40 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.909 ± 0.556 (0.683) C:NA T:96%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.756 ± 0.386 (0.668) C:81% T:85%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.67 ± 0.942 (1.35)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-7S** **Lab ID: 50315730006** Collected: 05/04/22 13:10 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0784 ± 0.461 (0.941) C:NA T:92%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.711 ± 0.383 (0.679) C:78% T:86%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.789 ± 0.844 (1.62)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2D** **Lab ID: 50315730007** Collected: 05/04/22 10:47 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.35 ± 0.825 (1.01) C:NA T:87%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.534 ± 0.343 (0.638) C:74% T:91%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.88 ± 1.17 (1.65)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-13S** **Lab ID: 50315730008** Collected: 05/04/22 13:02 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.000 ± 0.372 (0.834) C:NA T:90%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.448 ± 0.324 (0.626) C:78% T:95%** | pCi/L | 06/04/22 15:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.448 ± 0.696 (1.46)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-13D** **Lab ID: 50315730009** Collected: 05/04/22 14:31 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.280 ± 0.436 (0.755) C:NA T:95%** | pCi/L | 06/10/22 12:48 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.26 ± 0.479 (0.724) C:76% T:90%** | pCi/L | 06/04/22 15:09 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.54 ± 0.915 (1.48)** | pCi/L | 06/13/22 14:57 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2S RAD MS** **Lab ID: 50315730010** Collected: 05/04/22 10:40 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-226 | EPA 903.1 | **73.63 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 06/10/22 13:06 | 13982-63-3 | |
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-228 | EPA 904.0 | **114.44 %REC ± NA (NA) C:NA T:NA** | pCi/L | 06/04/22 15:09 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: MW-2S RAD MSD** **Lab ID: 50315730011** Collected: 05/04/22 10:40 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **104.55 %REC 34.70 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 06/10/22 13:06 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **86.12 %REC 28.23 RPD ± NA (NA) C:NA T:NA** | pCi/L | 06/04/22 15:09 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

**Sample: DUP-1** **Lab ID: 50315733006** Collected: 05/04/22 13:10 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.0776 ± 0.456 (1.02) C:NA T:89%** | pCi/L | 06/10/22 12:19 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.706 ± 0.341 (0.553) C:79% T:83%** | pCi/L | 06/04/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.706 ± 0.797 (1.57)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 505223
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315733006

METHOD BLANK: 2447130 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.561 ± 0.292 (0.498) C:82% T:95% | pCi/L | 06/04/22 15:04 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 505222
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315733006

METHOD BLANK: 2447105 Matrix: Water
Associated Lab Samples: 50315733006

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.121 ± 0.375 (0.853) C:NA T:87% | pCi/L | 06/10/22 11:52 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 505228 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315730010, 50315730011

METHOD BLANK: 2447141 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315730010, 50315730011

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.000 ± 0.240 (0.489) C:NA T:97% | pCi/L | 06/10/22 12:19 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

QC Batch: 505229
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315730010, 50315730011

METHOD BLANK: 2447144 Matrix: Water
Associated Lab Samples: 50315730001, 50315730002, 50315730003, 50315730004, 50315730005, 50315730006, 50315730007, 50315730008, 50315730009, 50315730010, 50315730011

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.319 ± 0.255 (0.496) C:82% T:95% | pCi/L | 06/04/22 15:08 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50315730001 | MW-4S | EPA 9056 | 676285 | | |
| 50315730002 | MW-5S | EPA 9056 | 676285 | | |
| 50315730003 | MW-6S | EPA 9056 | 676285 | | |
| 50315730004 | MW-7D | EPA 9056 | 676285 | | |
| 50315730005 | MW-2S | EPA 9056 | 676285 | | |
| 50315730006 | MW-7S | EPA 9056 | 676285 | | |
| 50315730007 | MW-2D | EPA 9056 | 676285 | | |
| 50315730008 | MW-13S | EPA 9056 | 676285 | | |
| 50315730009 | MW-13D | EPA 9056 | 676285 | | |
| 50315733006 | DUP-1 | EPA 9056 | 676285 | | |
| 50315730001 | MW-4S | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730002 | MW-5S | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730003 | MW-6S | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730004 | MW-7D | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730005 | MW-2S | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730006 | MW-7S | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730007 | MW-2D | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730008 | MW-13S | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730009 | MW-13D | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315733006 | DUP-1 | EPA 3010 | 675187 | EPA 6010 | 676544 |
| 50315730001 | MW-4S | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730002 | MW-5S | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730003 | MW-6S | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730004 | MW-7D | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730005 | MW-2S | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730006 | MW-7S | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730007 | MW-2D | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730008 | MW-13S | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730009 | MW-13D | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315733006 | DUP-1 | EPA 3010 | 675141 | EPA 6010 | 676400 |
| 50315730001 | MW-4S | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730002 | MW-5S | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730003 | MW-6S | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730004 | MW-7D | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730005 | MW-2S | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730006 | MW-7S | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730007 | MW-2D | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730008 | MW-13S | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315730009 | MW-13D | EPA 200.2 | 675545 | EPA 6020 | 675754 |
| 50315733006 | DUP-1 | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| 50315730001 | MW-4S | EPA 7470 | 675173 | EPA 7470 | 675300 |
| 50315730002 | MW-5S | EPA 7470 | 675173 | EPA 7470 | 675300 |
| 50315730003 | MW-6S | EPA 7470 | 675173 | EPA 7470 | 675300 |
| 50315730004 | MW-7D | EPA 7470 | 675173 | EPA 7470 | 675300 |
| 50315730005 | MW-2S | EPA 7470 | 675173 | EPA 7470 | 675300 |
| 50315730006 | MW-7S | EPA 7470 | 675173 | EPA 7470 | 675300 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315730007** | **MW-2D** | EPA 7470 | 675173 | EPA 7470 | 675300 |
| **50315730008** | **MW-13S** | EPA 7470 | 675173 | EPA 7470 | 675300 |
| **50315730009** | **MW-13D** | EPA 7470 | 675173 | EPA 7470 | 675300 |
| **50315730001** | **MW-4S** | EPA 903.1 | 505228 | | |
| **50315730002** | **MW-5S** | EPA 903.1 | 505228 | | |
| **50315730003** | **MW-6S** | EPA 903.1 | 505228 | | |
| **50315730004** | **MW-7D** | EPA 903.1 | 505228 | | |
| **50315730005** | **MW-2S** | EPA 903.1 | 505228 | | |
| **50315730006** | **MW-7S** | EPA 903.1 | 505228 | | |
| **50315730007** | **MW-2D** | EPA 903.1 | 505228 | | |
| **50315730008** | **MW-13S** | EPA 903.1 | 505228 | | |
| **50315730009** | **MW-13D** | EPA 903.1 | 505228 | | |
| **50315733006** | **DUP-1** | EPA 903.1 | 505222 | | |
| **50315730010** | **MW-2S RAD MS** | EPA 903.1 | 505228 | | |
| **50315730011** | **MW-2S RAD MSD** | EPA 903.1 | 505228 | | |
| **50315730001** | **MW-4S** | EPA 904.0 | 505229 | | |
| **50315730002** | **MW-5S** | EPA 904.0 | 505229 | | |
| **50315730003** | **MW-6S** | EPA 904.0 | 505229 | | |
| **50315730004** | **MW-7D** | EPA 904.0 | 505229 | | |
| **50315730005** | **MW-2S** | EPA 904.0 | 505229 | | |
| **50315730006** | **MW-7S** | EPA 904.0 | 505229 | | |
| **50315730007** | **MW-2D** | EPA 904.0 | 505229 | | |
| **50315730008** | **MW-13S** | EPA 904.0 | 505229 | | |
| **50315730009** | **MW-13D** | EPA 904.0 | 505229 | | |
| **50315733006** | **DUP-1** | EPA 904.0 | 505223 | | |
| **50315730010** | **MW-2S RAD MS** | EPA 904.0 | 505229 | | |
| **50315730011** | **MW-2S RAD MSD** | EPA 904.0 | 505229 | | |
| **50315730001** | **MW-4S** | Total Radium Calculation | 511320 | | |
| **50315730002** | **MW-5S** | Total Radium Calculation | 511320 | | |
| **50315730003** | **MW-6S** | Total Radium Calculation | 511320 | | |
| **50315730004** | **MW-7D** | Total Radium Calculation | 511320 | | |
| **50315730005** | **MW-2S** | Total Radium Calculation | 511320 | | |
| **50315730006** | **MW-7S** | Total Radium Calculation | 511320 | | |
| **50315730007** | **MW-2D** | Total Radium Calculation | 511320 | | |
| **50315730008** | **MW-13S** | Total Radium Calculation | 511320 | | |
| **50315730009** | **MW-13D** | Total Radium Calculation | 511320 | | |
| **50315733006** | **DUP-1** | Total Radium Calculation | 511333 | | |
| **50315730001** | **MW-4S** | SM 2320B | 675648 | | |
| **50315730002** | **MW-5S** | SM 2320B | 675648 | | |
| **50315730003** | **MW-6S** | SM 2320B | 675648 | | |
| **50315730004** | **MW-7D** | SM 2320B | 675648 | | |
| **50315730005** | **MW-2S** | SM 2320B | 675648 | | |
| **50315730006** | **MW-7S** | SM 2320B | 675775 | | |
| **50315730007** | **MW-2D** | SM 2320B | 675775 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315730008** | **MW-13S** | SM 2320B | 675775 | | |
| **50315730009** | **MW-13D** | SM 2320B | 675775 | | |
| **50315733006** | **DUP-1** | SM 2320B | 675775 | | |
| **50315730001** | **MW-4S** | SM 2540C | 675556 | | |
| **50315730002** | **MW-5S** | SM 2540C | 675556 | | |
| **50315730003** | **MW-6S** | SM 2540C | 675556 | | |
| **50315730004** | **MW-7D** | SM 2540C | 675556 | | |
| **50315730005** | **MW-2S** | SM 2540C | 675556 | | |
| **50315730006** | **MW-7S** | SM 2540C | 675556 | | |
| **50315730007** | **MW-2D** | SM 2540C | 675556 | | |
| **50315730008** | **MW-13S** | SM 2540C | 675556 | | |
| **50315730009** | **MW-13D** | SM 2540C | 675556 | | |
| **50315733006** | **DUP-1** | SM 2540C | 675557 | | |
| **50315730001** | **MW-4S** | SM 4500-H+B | 676173 | | |
| **50315730002** | **MW-5S** | SM 4500-H+B | 676173 | | |
| **50315730003** | **MW-6S** | SM 4500-H+B | 676173 | | |
| **50315730004** | **MW-7D** | SM 4500-H+B | 676173 | | |
| **50315730005** | **MW-2S** | SM 4500-H+B | 676173 | | |
| **50315730006** | **MW-7S** | SM 4500-H+B | 676173 | | |
| **50315730007** | **MW-2D** | SM 4500-H+B | 676173 | | |
| **50315730008** | **MW-13S** | SM 4500-H+B | 676173 | | |
| **50315730009** | **MW-13D** | SM 4500-H+B | 676173 | | |
| **50315733006** | **DUP-1** | SM 4500-H+B | 676173 | | |
| **50315730001** | **MW-4S** | SM 4500-S2-D | 674955 | | |
| **50315730002** | **MW-5S** | SM 4500-S2-D | 674955 | | |
| **50315730003** | **MW-6S** | SM 4500-S2-D | 674955 | | |
| **50315730004** | **MW-7D** | SM 4500-S2-D | 674955 | | |
| **50315730005** | **MW-2S** | SM 4500-S2-D | 674955 | | |
| **50315730006** | **MW-7S** | SM 4500-S2-D | 674955 | | |
| **50315730007** | **MW-2D** | SM 4500-S2-D | 674955 | | |
| **50315730008** | **MW-13S** | SM 4500-S2-D | 674955 | | |
| **50315730009** | **MW-13D** | SM 4500-S2-D | 674955 | | |
| **50315733006** | **DUP-1** | SM 4500-S2-D | 674956 | | |
| **50315730001** | **MW-4S** | HACH 8146 | 675310 | | |
| **50315730002** | **MW-5S** | HACH 8146 | 675310 | | |
| **50315730003** | **MW-6S** | HACH 8146 | 675310 | | |
| **50315730004** | **MW-7D** | HACH 8146 | 675310 | | |
| **50315730005** | **MW-2S** | HACH 8146 | 675310 | | |
| **50315730006** | **MW-7S** | HACH 8146 | 675310 | | |
| **50315730007** | **MW-2D** | HACH 8146 | 675310 | | |
| **50315730008** | **MW-13S** | HACH 8146 | 675310 | | |
| **50315730009** | **MW-13D** | HACH 8146 | 675310 | | |
| **50315733006** | **DUP-1** | HACH 8146 | 675312 | | |
| **50315730001** | **MW-4S** | EPA 353.2 | 674764 | | |
| **50315730002** | **MW-5S** | EPA 353.2 | 674764 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315730

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315730003** | **MW-6S** | EPA 353.2 | 674764 | | |
| **50315730004** | **MW-7D** | EPA 353.2 | 674764 | | |
| **50315730005** | **MW-2S** | EPA 353.2 | 674764 | | |
| **50315730006** | **MW-7S** | EPA 353.2 | 674764 | | |
| **50315730007** | **MW-2D** | EPA 353.2 | 674764 | | |
| **50315730008** | **MW-13S** | EPA 353.2 | 674764 | | |
| **50315730009** | **MW-13D** | EPA 353.2 | 674764 | | |
| **50315733006** | **DUP-1** | EPA 353.2 | 674764 | | |
| **50315730001** | **MW-4S** | EPA 365.1 | 675357 | EPA 365.1 | 676253 |
| **50315730002** | **MW-5S** | EPA 365.1 | 675357 | EPA 365.1 | 676253 |
| **50315730003** | **MW-6S** | EPA 365.1 | 675357 | EPA 365.1 | 676253 |
| **50315730004** | **MW-7D** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315730005** | **MW-2S** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315730006** | **MW-7S** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315730007** | **MW-2D** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315730008** | **MW-13S** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315730009** | **MW-13D** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315733006** | **DUP-1** | EPA 365.1 | 675362 | EPA 365.1 | 676256 |
| **50315730001** | **MW-4S** | SM 5310C | 675018 | | |
| **50315730002** | **MW-5S** | SM 5310C | 675018 | | |
| **50315730003** | **MW-6S** | SM 5310C | 675018 | | |
| **50315730004** | **MW-7D** | SM 5310C | 675018 | | |
| **50315730005** | **MW-2S** | SM 5310C | 675018 | | |
| **50315730006** | **MW-7S** | SM 5310C | 675018 | | |
| **50315730007** | **MW-2D** | SM 5310C | 675018 | | |
| **50315730008** | **MW-13S** | SM 5310C | 675018 | | |
| **50315730009** | **MW-13D** | SM 5310C | 675018 | | |
| **50315733006** | **DUP-1** | SM 5310C | 675018 | | |
| **50315730001** | **MW-4S** | SM 5310C | 676497 | | |
| **50315730002** | **MW-5S** | SM 5310C | 676497 | | |
| **50315730003** | **MW-6S** | SM 5310C | 676497 | | |
| **50315730004** | **MW-7D** | SM 5310C | 676497 | | |
| **50315730005** | **MW-2S** | SM 5310C | 676497 | | |
| **50315730006** | **MW-7S** | SM 5310C | 676497 | | |
| **50315730007** | **MW-2D** | SM 5310C | 676497 | | |
| **50315730008** | **MW-13S** | SM 5310C | 676497 | | |
| **50315730009** | **MW-13D** | SM 5310C | 676497 | | |
| **50315733006** | **DUP-1** | SM 5310C | 676497 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50315730

50315730

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytica

The Chain-of-Custody is a LEGAL DOCUMENT. Al

Page : 1 Of 3

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

| Regulatory Agency | |
|---|---|
| State / Location | IN |

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Y/N | Analyses Test: TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | | |
| 1 | ~~MW-1S~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 2 | ~~MW-1D~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 3 | ~~MW-2S~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 4 | ~~MW-2D~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 5 | ~~MW-3S~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | ~~MW-3D~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-4S | WT | G | | | 5-4-22 | 1142 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 8 | MW-5S | WT | G | | | | 1336 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 9 | MW-6S | WT | G | | | | 1511 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 003 |
| 10 | ~~MW-7S~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 11 | ~~MW-7D~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 12 | ~~MW-8S~~ | ~~WT~~ | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Colton Palmer | 5-4-22 | | Zeb Tim PACE | 5/5/22 | 1341 |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | Zeb Tim PACE | 5/5/22 | 1510 | Hayden Putt | 5/5/22 | 1510 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| | | | |
| see SCUF | Y | N | Y |
| | | | |

| SAMPLER NAME AND SIGNATURE | | |
|---|---|---|
| PRINT Name of SAMPLER: | Colton Palmer | |
| SIGNATURE of SAMPLER: | Colton Palmer | DATE Signed: 5-4-22 |

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

| Regulatory Agency | |
|---|---|
| | |
| **State / Location** | |
| | IN |

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | Y | | | | | Y | | | | | |
| 1 | ~~MW-1S~~ MW-7D | WT | | 5/4 | 14:20 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 004 |
| 2 | ~~MW-1D~~ MW-2S | WT | | 5/4 | 1040 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 005 |
| 3 | ~~MW-2S~~ MS (MW-2S) | WT | | 5/4 | 1040 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 4 | ~~MW-2D~~ MSD (MW-2S) | WT | | 5/5 | 1040 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | ↓ |
| 5 | ~~MW-9S~~ MW-7S (MW-2S) | WT | | 5/4 | 1310 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 006 |
| 6 | ~~MW-9D~~ MW-2D | WT | | 5/4 | 1047 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 007 |
| 7 | ~~MW-4S~~ MW-13S | WT | | 5/4 | 1302 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 008 |
| 8 | ~~MW-5S~~ MW-13D | WT | | 5/4 | 1431 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 009 |
| 9 | ~~MW-6S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 10 | ~~MW-7S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 11 | ~~MW-7D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 12 | ~~MW-8S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | P. Greg Hopper | 5/5 | 0600 | [illegible] Pace | 5/5/22 | 1345 |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | [illegible] Pace | 5/5/22 | 1510 | Hayden Putt | 5/5/22 | 1510 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| | | | |
| See SCUR | Y | N | Y |
| | | | |
| | | | |

| SAMPLER NAME AND SIGNATURE | | |
|---|---|---|
| PRINT Name of SAMPLER: | P. Greg Hopper | TEMP in C |
| SIGNATURE of SAMPLER: | | Received on Ice (Y/N) |
| DATE Signed: | 5/5/22 | Custody Sealed Cooler (Y/N) |
| | | Samples Intact (Y/N) |

F-IN-Q-290-rev.22, 22Apr2022

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** HRP 5/5/22 1720

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☐ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** see Sum comments
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | — |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** $NO_3$ $NO_2$ | — | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: walkin | |
| **Rush TAT Requested (4 days or less):** | | — |
| Custody Signatures Present? | — | |
| Containers Intact?: | — | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | — | |
| Extra labels on Terracore Vials? (soils only) | NA | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9) ~~Any non-conformance to pH recommendations will be noted on the container count form~~ | — | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | — |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | — |
| Headspace Wisconsin Sulfide? | | | — |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | — |
| ~~Trip Blank Present?~~ | | — | |
| Trip Blank Custody Seals?: | | — | |

COMMENTS:

Temps: cooler 1. 1.4 / 1.2 7. 0.6 / 0.4
2. 1.2 / 1.0 8. 0.5 / 0.3
3. 1.2 / 1.0 9. 0.7 / 0.5
4. 1.3 / 1.1 10. 0.8 / 0.6
5. 0.8 / 0.6 11. 0.9 / 0.7
6. 0.6 / 0.4

**COC PAGE** 1 **of** 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | 1 | 1 | X HP | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 8 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 9 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| ~~VG9H~~ | ~~40mL HCl clear vial~~ | ~~AG1H~~ | ~~1L HCl amber glass~~ | ~~BP2N~~ | ~~500mL HNO3 plastic~~ |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 2 of 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | ~~1~~ HP | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | 3 | 3 | ~~3~~ HP | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | WT | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 6 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| ~~VG9H~~ | ~~40mL HCl clear vial~~ | ~~AG1H~~ | ~~1L HCl amber glass~~ | ~~BP2N~~ | ~~500mL HNO3 plastic~~ |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 05, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50315733001** | **MW-103S** | Water | 05/04/22 13:50 | 05/05/22 15:10 |
| **50315733002** | **MW-103I** | Water | 05/04/22 11:15 | 05/05/22 15:10 |
| **50315733003** | **MW-103D** | Water | 05/04/22 12:50 | 05/05/22 15:10 |
| **50315733004** | **PZ-101S** | Water | 05/04/22 15:10 | 05/05/22 15:10 |
| **50315733005** | **FB** | Water | 05/04/22 13:50 | 05/05/22 15:10 |
| **50315733007** | **PZ-101D** | Water | 05/04/22 15:18 | 05/05/22 15:10 |
| **50315733008** | **MW-103I RAD MS** | Water | 05/04/22 11:15 | 05/05/22 15:10 |
| **50315733009** | **MW-103I RAD MSD** | Water | 05/04/22 11:15 | 05/05/22 15:10 |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50315733001** | **MW-103S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315733002** | **MW-103I** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315733003** | **MW-103D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315733004** | **PZ-101S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315733005** | **FB** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315733007** | **PZ-101D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | DJS | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315733008** | **MW-103I RAD MS** | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| **50315733009** | **MW-103I RAD MSD** | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315733001** | **MW-103S** | | | | | |
| EPA 9056 | Chloride | 68.4 | mg/L | 2.5 | 05/17/22 22:33 | |
| EPA 9056 | Fluoride | 0.27 | mg/L | 0.10 | 05/17/22 22:15 | |
| EPA 9056 | Sulfate | 435 | mg/L | 25.0 | 05/17/22 22:52 | |
| EPA 6010 | Barium | 65.2 | ug/L | 10.0 | 05/17/22 02:19 | |
| EPA 6010 | Boron | 887 | ug/L | 100 | 05/17/22 02:19 | |
| EPA 6010 | Calcium | 291000 | ug/L | 2000 | 05/17/22 02:52 | |
| EPA 6010 | Iron | 16300 | ug/L | 100 | 05/17/22 02:19 | |
| EPA 6010 | Magnesium | 80200 | ug/L | 1000 | 05/17/22 02:19 | |
| EPA 6010 | Manganese | 289 | ug/L | 10.0 | 05/17/22 02:19 | |
| EPA 6010 | Molybdenum | 22.4 | ug/L | 10.0 | 05/17/22 02:19 | |
| EPA 6010 | Potassium | 2140 | ug/L | 1000 | 05/17/22 02:19 | |
| EPA 6010 | Silica | 25100 | ug/L | 450 | 05/17/22 02:19 | N2 |
| EPA 6010 | Sodium | 47000 | ug/L | 1000 | 05/17/22 02:19 | |
| EPA 6010 | Manganese, Dissolved | 292 | ug/L | 10.0 | 05/16/22 11:21 | |
| EPA 6010 | Molybdenum, Dissolved | 23.0 | ug/L | 10.0 | 05/16/22 11:21 | |
| EPA 6020 | Arsenic | 21.2 | ug/L | 1.0 | 05/13/22 02:45 | |
| EPA 6020 | Cobalt | 2.1 | ug/L | 1.0 | 05/13/22 02:45 | |
| EPA 903.1 | Radium-226 | -0.304 ± 0.422 (1.07) C:NA T:90% | pCi/L | | 06/10/22 12:05 | |
| EPA 904.0 | Radium-228 | 0.832 ± 0.453 (0.828) C:76% T:87% | pCi/L | | 06/04/22 15:03 | |
| Total Radium Calculation | Total Radium | 0.832 ± 0.875 (1.90) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 626 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 626 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1370 | mg/L | 20.0 | 05/11/22 13:38 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.9 | Std. Units | 0.10 | 05/13/22 15:18 | H3 |
| HACH 8146 | Iron, Ferrous | 1.1 | mg/L | 0.50 | 05/10/22 15:13 | H3,N2 |
| SM 5310C | Total Organic Carbon | 5.6 | mg/L | 1.0 | 05/13/22 05:37 | |
| SM 5310C | Dissolved Organic Carbon | 5.2 | mg/L | 1.0 | 05/17/22 12:18 | |
| **50315733002** | **MW-103I** | | | | | |
| EPA 9056 | Chloride | 135 | mg/L | 25.0 | 05/18/22 00:24 | |
| EPA 9056 | Fluoride | 0.22 | mg/L | 0.10 | 05/17/22 23:47 | |
| EPA 9056 | Sulfate | 40.2 | mg/L | 2.5 | 05/18/22 00:05 | |
| EPA 6010 | Barium | 202 | ug/L | 10.0 | 05/17/22 02:21 | |
| EPA 6010 | Boron | 280 | ug/L | 100 | 05/17/22 02:21 | |
| EPA 6010 | Calcium | 91800 | ug/L | 1000 | 05/17/22 02:21 | |
| EPA 6010 | Iron | 1500 | ug/L | 100 | 05/17/22 02:21 | |
| EPA 6010 | Magnesium | 26100 | ug/L | 1000 | 05/17/22 02:21 | |
| EPA 6010 | Manganese | 309 | ug/L | 10.0 | 05/17/22 02:21 | |
| EPA 6010 | Potassium | 7500 | ug/L | 1000 | 05/17/22 02:21 | |
| EPA 6010 | Silica | 10700 | ug/L | 450 | 05/17/22 02:21 | N2 |
| EPA 6010 | Sodium | 62700 | ug/L | 1000 | 05/17/22 02:21 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315733002** | **MW-103I** | | | | | |
| EPA 6010 | Manganese, Dissolved | 300 | ug/L | 10.0 | 05/16/22 11:24 | |
| EPA 903.1 | Radium-226 | 0.956 ± 0.517 (0.522) C:NA T:91% | pCi/L | | 06/10/22 12:05 | |
| EPA 904.0 | Radium-228 | 1.66 ± 0.518 (0.655) C:83% T:87% | pCi/L | | 06/04/22 15:03 | |
| Total Radium Calculation | Total Radium | 2.62 ± 1.04 (1.18) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 252 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 252 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 535 | mg/L | 10.0 | 05/11/22 14:58 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/13/22 15:19 | H3 |
| SM 5310C | Total Organic Carbon | 2.7 | mg/L | 1.0 | 05/13/22 18:28 | |
| SM 5310C | Dissolved Organic Carbon | 2.7 | mg/L | 1.0 | 05/17/22 12:29 | |
| **50315733003** | **MW-103D** | | | | | |
| EPA 9056 | Chloride | 209 | mg/L | 25.0 | 05/18/22 03:46 | |
| EPA 9056 | Fluoride | 0.19 | mg/L | 0.10 | 05/18/22 03:09 | |
| EPA 9056 | Sulfate | 53.6 | mg/L | 2.5 | 05/18/22 03:28 | |
| EPA 6010 | Barium | 370 | ug/L | 10.0 | 05/17/22 02:37 | |
| EPA 6010 | Boron | 359 | ug/L | 100 | 05/17/22 02:37 | |
| EPA 6010 | Calcium | 92700 | ug/L | 1000 | 05/17/22 02:37 | |
| EPA 6010 | Iron | 2350 | ug/L | 100 | 05/17/22 02:37 | |
| EPA 6010 | Magnesium | 30600 | ug/L | 1000 | 05/17/22 02:37 | |
| EPA 6010 | Manganese | 130 | ug/L | 10.0 | 05/17/22 02:37 | |
| EPA 6010 | Potassium | 6080 | ug/L | 1000 | 05/17/22 02:37 | |
| EPA 6010 | Silica | 13200 | ug/L | 450 | 05/17/22 02:37 | N2 |
| EPA 6010 | Sodium | 81800 | ug/L | 1000 | 05/17/22 02:37 | |
| EPA 6010 | Manganese, Dissolved | 126 | ug/L | 10.0 | 05/16/22 11:39 | |
| EPA 903.1 | Radium-226 | 0.728 ± 0.732 (1.15) C:NA T:87% | pCi/L | | 06/10/22 12:05 | |
| EPA 904.0 | Radium-228 | 1.17 ± 0.469 (0.748) C:80% T:89% | pCi/L | | 06/04/22 15:03 | |
| Total Radium Calculation | Total Radium | 1.90 ± 1.20 (1.90) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 259 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 257 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 588 | mg/L | 10.0 | 05/11/22 14:59 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/13/22 15:22 | H3 |
| SM 5310C | Total Organic Carbon | 2.2 | mg/L | 1.0 | 05/13/22 19:03 | |
| SM 5310C | Dissolved Organic Carbon | 3.7 | mg/L | 1.0 | 05/17/22 13:33 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315733004** | **PZ-101S** | | | | | |
| EPA 9056 | Chloride | 112 | mg/L | 2.5 | 05/18/22 04:23 | |
| EPA 9056 | Fluoride | 0.22 | mg/L | 0.10 | 05/18/22 04:05 | |
| EPA 9056 | Sulfate | 567 | mg/L | 25.0 | 05/18/22 04:41 | |
| EPA 6010 | Barium | 168 | ug/L | 10.0 | 05/17/22 02:39 | |
| EPA 6010 | Boron | 7690 | ug/L | 100 | 05/17/22 02:39 | |
| EPA 6010 | Calcium | 233000 | ug/L | 2000 | 05/17/22 02:54 | |
| EPA 6010 | Iron | 5870 | ug/L | 100 | 05/17/22 02:39 | |
| EPA 6010 | Lithium | 101 | ug/L | 20.0 | 05/17/22 02:39 | |
| EPA 6010 | Magnesium | 50300 | ug/L | 1000 | 05/17/22 02:39 | |
| EPA 6010 | Manganese | 783 | ug/L | 10.0 | 05/17/22 02:39 | |
| EPA 6010 | Molybdenum | 117 | ug/L | 10.0 | 05/17/22 02:39 | |
| EPA 6010 | Potassium | 10900 | ug/L | 1000 | 05/17/22 02:39 | |
| EPA 6010 | Silica | 12700 | ug/L | 450 | 05/17/22 02:39 | N2 |
| EPA 6010 | Sodium | 105000 | ug/L | 1000 | 05/17/22 02:39 | |
| EPA 6010 | Manganese, Dissolved | 770 | ug/L | 10.0 | 05/16/22 11:41 | |
| EPA 6010 | Molybdenum, Dissolved | 120 | ug/L | 10.0 | 05/16/22 11:41 | |
| EPA 6020 | Arsenic | 15.6 | ug/L | 1.0 | 05/13/22 02:55 | |
| EPA 903.1 | Radium-226 | 0.947 ± 0.758 (1.13) C:NA T:90% | pCi/L | | 06/10/22 12:05 | |
| EPA 904.0 | Radium-228 | 0.895 ± 0.479 (0.860) C:71% T:82% | pCi/L | | 06/04/22 15:03 | |
| Total Radium Calculation | Total Radium | 1.84 ± 1.24 (1.99) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 290 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 290 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2540C | Total Dissolved Solids | 1260 | mg/L | 20.0 | 05/11/22 15:00 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.3 | Std. Units | 0.10 | 05/13/22 15:23 | H3 |
| HACH 8146 | Iron, Ferrous | 0.71 | mg/L | 0.20 | 05/10/22 15:15 | H3,N2 |
| SM 5310C | Total Organic Carbon | 1.5 | mg/L | 1.0 | 05/13/22 06:03 | |
| SM 5310C | Dissolved Organic Carbon | 1.3 | mg/L | 1.0 | 05/17/22 13:44 | |
| **50315733005** | **FB** | | | | | |
| EPA 903.1 | Radium-226 | -0.346 ± 0.409 (1.04) C:NA T:95% | pCi/L | | 06/10/22 12:19 | |
| EPA 904.0 | Radium-228 | 0.139 ± 0.279 (0.616) C:79% T:83% | pCi/L | | 06/04/22 15:04 | |
| Total Radium Calculation | Total Radium | 0.139 ± 0.688 (1.66) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 9.2 | mg/L | 2.0 | 05/13/22 14:51 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 9.2 | mg/L | 2.0 | 05/13/22 14:51 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315733005** | **FB** | | | | | |
| SM 4500-H+B | pH at 25 Degrees C | 6.0 | Std. Units | 0.10 | 05/13/22 15:28 | H3 |
| **50315733007** | **PZ-101D** | | | | | |
| EPA 9056 | Chloride | 142 | mg/L | 25.0 | 05/18/22 07:27 | |
| EPA 9056 | Fluoride | 0.24 | mg/L | 0.10 | 05/18/22 06:50 | |
| EPA 9056 | Sulfate | 648 | mg/L | 25.0 | 05/18/22 07:27 | |
| EPA 6010 | Barium | 84.1 | ug/L | 10.0 | 05/17/22 02:46 | |
| EPA 6010 | Boron | 7380 | ug/L | 100 | 05/17/22 02:46 | |
| EPA 6010 | Calcium | 223000 | ug/L | 2000 | 05/17/22 02:56 | |
| EPA 6010 | Iron | 3590 | ug/L | 100 | 05/17/22 02:46 | |
| EPA 6010 | Lithium | 112 | ug/L | 20.0 | 05/17/22 02:46 | |
| EPA 6010 | Magnesium | 44400 | ug/L | 1000 | 05/17/22 02:46 | |
| EPA 6010 | Manganese | 416 | ug/L | 10.0 | 05/17/22 02:46 | |
| EPA 6010 | Molybdenum | 183 | ug/L | 10.0 | 05/17/22 02:46 | |
| EPA 6010 | Potassium | 14100 | ug/L | 1000 | 05/17/22 02:46 | |
| EPA 6010 | Silica | 12000 | ug/L | 450 | 05/17/22 02:46 | N2 |
| EPA 6010 | Sodium | 123000 | ug/L | 1000 | 05/17/22 02:46 | |
| EPA 6010 | Manganese, Dissolved | 420 | ug/L | 10.0 | 05/16/22 11:45 | |
| EPA 6010 | Molybdenum, Dissolved | 190 | ug/L | 10.0 | 05/16/22 11:45 | |
| EPA 6020 | Arsenic | 4.7 | ug/L | 1.0 | 05/13/22 03:19 | |
| EPA 903.1 | Radium-226 | 0.0783 ± 0.406 (0.843) C:NA T:86% | pCi/L | | 06/10/22 12:19 | |
| EPA 904.0 | Radium-228 | 1.31 ± 0.443 (0.596) C:81% T:91% | pCi/L | | 06/04/22 15:04 | |
| Total Radium Calculation | Total Radium | 1.39 ± 0.849 (1.44) | pCi/L | | 06/13/22 15:00 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 266 | mg/L | 2.0 | 05/12/22 14:47 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 266 | mg/L | 2.0 | 05/12/22 14:47 | |
| SM 2540C | Total Dissolved Solids | 1270 | mg/L | 20.0 | 05/11/22 15:03 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/13/22 15:31 | H3 |
| HACH 8146 | Iron, Ferrous | 0.25 | mg/L | 0.20 | 05/10/22 15:16 | H3,N2 |
| SM 5310C | Total Organic Carbon | 1.1 | mg/L | 1.0 | 05/13/22 19:15 | |
| SM 5310C | Dissolved Organic Carbon | 1.5 | mg/L | 1.0 | 05/17/22 14:08 | |
| **50315733008** | **MW-103I RAD MS** | | | | | |
| EPA 903.1 | Radium-226 | 99.80 %REC ± NA (NA) C:NA T:9NA% | pCi/L | | 06/10/22 12:19 | |
| EPA 904.0 | Radium-228 | 91.22 %REC ± NA (NA) C:NA T:NA | pCi/L | | 06/04/22 15:05 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315733009** | **MW-103I RAD MSD** | | | | | |
| EPA 903.1 | Radium-226 | 99.79 %REC 0.01 RPD ± NA (NA) C:NA T:9NA% | pCi/L | | 06/10/22 12:19 | |
| EPA 904.0 | Radium-228 | 117.41 %REC 25.11 RPD ± NA (NA) C:NA T:NA | pCi/L | | 06/04/22 15:05 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103S** **Lab ID: 50315733001** Collected: 05/04/22 13:50 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **68.4** | mg/L | 2.5 | 10 | | 05/17/22 22:33 | 16887-00-6 | |
| Fluoride | **0.27** | mg/L | 0.10 | 1 | | 05/17/22 22:15 | 16984-48-8 | |
| Sulfate | **435** | mg/L | 25.0 | 100 | | 05/17/22 22:52 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7429-90-5 | |
| Barium | **65.2** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7440-39-3 | |
| Boron | **887** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7440-43-9 | |
| Calcium | **291000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:52 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7440-47-3 | |
| Iron | **16300** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7439-93-2 | |
| Magnesium | **80200** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7439-95-4 | |
| Manganese | **289** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7439-96-5 | |
| Molybdenum | **22.4** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7439-98-7 | |
| Potassium | **2140** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7440-09-7 | |
| Silica | **25100** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7631-86-9 | N2 |
| Sodium | **47000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:19 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **292** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:21 | 7439-96-5 | |
| Molybdenum, Dissolved | **23.0** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:21 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:45 | 7440-36-0 | |
| Arsenic | **21.2** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:45 | 7440-38-2 | |
| Cobalt | **2.1** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:45 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:45 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **626** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **626** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1370** | mg/L | 20.0 | 1 | | 05/11/22 13:38 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103S** **Lab ID: 50315733001** Collected: 05/04/22 13:50 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.9** | Std. Units | 0.10 | 1 | | 05/13/22 15:18 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **1.1** | mg/L | 0.50 | 2.5 | | 05/10/22 15:13 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:37 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:37 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:40 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **5.6** | mg/L | 1.0 | 1 | | 05/13/22 05:37 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **5.2** | mg/L | 1.0 | 1 | | 05/17/22 12:18 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103I** **Lab ID: 50315733002** Collected: 05/04/22 11:15 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **135** | mg/L | 25.0 | 100 | | 05/18/22 00:24 | 16887-00-6 | |
| Fluoride | **0.22** | mg/L | 0.10 | 1 | | 05/17/22 23:47 | 16984-48-8 | |
| Sulfate | **40.2** | mg/L | 2.5 | 10 | | 05/18/22 00:05 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7429-90-5 | |
| Barium | **202** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-39-3 | |
| Boron | **280** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-43-9 | |
| Calcium | **91800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-47-3 | |
| Iron | **1500** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7439-93-2 | |
| Magnesium | **26100** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7439-95-4 | |
| Manganese | **309** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7439-98-7 | |
| Potassium | **7500** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-09-7 | |
| Silica | **10700** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7631-86-9 | N2 |
| Sodium | **62700** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:21 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **300** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:24 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:24 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:12 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:12 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:12 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:12 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **252** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **252** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **535** | mg/L | 10.0 | 1 | | 05/11/22 14:58 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103I** **Lab ID: 50315733002** Collected: 05/04/22 11:15 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/13/22 15:19 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:14 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:18 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:18 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 14:44 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.7** | mg/L | 1.0 | 1 | | 05/13/22 18:28 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.7** | mg/L | 1.0 | 1 | | 05/17/22 12:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103D** **Lab ID: 50315733003** Collected: 05/04/22 12:50 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **209** | mg/L | 25.0 | 100 | | 05/18/22 03:46 | 16887-00-6 | |
| Fluoride | **0.19** | mg/L | 0.10 | 1 | | 05/18/22 03:09 | 16984-48-8 | |
| Sulfate | **53.6** | mg/L | 2.5 | 10 | | 05/18/22 03:28 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7429-90-5 | |
| Barium | **370** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-39-3 | |
| Boron | **359** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-43-9 | |
| Calcium | **92700** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-47-3 | |
| Iron | **2350** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7439-93-2 | |
| Magnesium | **30600** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7439-95-4 | |
| Manganese | **130** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7439-98-7 | |
| Potassium | **6080** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-09-7 | |
| Silica | **13200** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7631-86-9 | N2 |
| Sodium | **81800** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:37 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **126** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:39 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:39 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:50 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:50 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:50 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:50 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **259** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **257** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **588** | mg/L | 10.0 | 1 | | 05/11/22 14:59 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103D** **Lab ID: 50315733003** Collected: 05/04/22 12:50 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/13/22 15:22 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:15 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:29 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:29 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 05/13/22 19:03 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.7** | mg/L | 1.0 | 1 | | 05/17/22 13:33 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: PZ-101S** **Lab ID: 50315733004** Collected: 05/04/22 15:10 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **112** | mg/L | 2.5 | 10 | | 05/18/22 04:23 | 16887-00-6 | |
| Fluoride | **0.22** | mg/L | 0.10 | 1 | | 05/18/22 04:05 | 16984-48-8 | |
| Sulfate | **567** | mg/L | 25.0 | 100 | | 05/18/22 04:41 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7429-90-5 | |
| Barium | **168** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7440-39-3 | |
| Boron | **7690** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7440-43-9 | |
| Calcium | **233000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:54 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7440-47-3 | |
| Iron | **5870** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7439-92-1 | |
| Lithium | **101** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7439-93-2 | |
| Magnesium | **50300** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7439-95-4 | |
| Manganese | **783** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7439-96-5 | |
| Molybdenum | **117** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7439-98-7 | |
| Potassium | **10900** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7440-09-7 | |
| Silica | **12700** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7631-86-9 | N2 |
| Sodium | **105000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:39 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **770** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:41 | 7439-96-5 | |
| Molybdenum, Dissolved | **120** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:41 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:55 | 7440-36-0 | |
| Arsenic | **15.6** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:55 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:55 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 02:55 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **290** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **290** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1260** | mg/L | 20.0 | 1 | | 05/11/22 15:00 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: PZ-101S** **Lab ID: 50315733004** Collected: 05/04/22 15:10 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.3** | Std. Units | 0.10 | 1 | | 05/13/22 15:23 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.71** | mg/L | 0.20 | 1 | | 05/10/22 15:15 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:44 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:44 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.5** | mg/L | 1.0 | 1 | | 05/13/22 06:03 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/17/22 13:44 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: FB** **Lab ID: 50315733005** Collected: 05/04/22 13:50 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | ND | mg/L | 0.25 | 1 | | 05/18/22 05:00 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 05/18/22 05:00 | 16984-48-8 | |
| Sulfate | ND | mg/L | 0.25 | 1 | | 05/18/22 05:00 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7429-90-5 | |
| Barium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-39-3 | |
| Boron | ND | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-43-9 | |
| Calcium | ND | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7439-93-2 | |
| Magnesium | ND | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7439-98-7 | |
| Potassium | ND | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-09-7 | |
| Silica | ND | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7631-86-9 | N2 |
| Sodium | ND | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:41 | 7440-23-5 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:00 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:00 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:00 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:00 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **9.2** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Bicarbonate (CaCO3) | **9.2** | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/13/22 14:51 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | ND | mg/L | 10.0 | 1 | | 05/11/22 15:00 | | PL |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **6.0** | Std. Units | 0.10 | 1 | | 05/13/22 15:28 | | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: FB** **Lab ID: 50315733005** Collected: 05/04/22 13:50 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:15 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:39 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:39 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 11:00 | 05/13/22 14:42 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/13/22 06:21 | 7440-44-0 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: PZ-101D** **Lab ID: 50315733007** Collected: 05/04/22 15:18 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **142** | mg/L | 25.0 | 100 | | 05/18/22 07:27 | 16887-00-6 | |
| Fluoride | **0.24** | mg/L | 0.10 | 1 | | 05/18/22 06:50 | 16984-48-8 | |
| Sulfate | **648** | mg/L | 25.0 | 100 | | 05/18/22 07:27 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7429-90-5 | |
| Barium | **84.1** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7440-39-3 | |
| Boron | **7380** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7440-43-9 | |
| Calcium | **223000** | ug/L | 2000 | 2 | 05/13/22 08:51 | 05/17/22 02:56 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7440-47-3 | |
| Iron | **3590** | ug/L | 100 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7439-92-1 | |
| Lithium | **112** | ug/L | 20.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7439-93-2 | |
| Magnesium | **44400** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7439-95-4 | |
| Manganese | **416** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7439-96-5 | |
| Molybdenum | **183** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7439-98-7 | |
| Potassium | **14100** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7440-09-7 | |
| Silica | **12000** | ug/L | 450 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7631-86-9 | N2 |
| Sodium | **123000** | ug/L | 1000 | 1 | 05/13/22 08:51 | 05/17/22 02:46 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **420** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:45 | 7439-96-5 | |
| Molybdenum, Dissolved | **190** | ug/L | 10.0 | 1 | 05/13/22 08:51 | 05/16/22 11:45 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:19 | 7440-36-0 | |
| Arsenic | **4.7** | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:19 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:19 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/11/22 15:30 | 05/13/22 03:19 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **266** | mg/L | 2.0 | 1 | | 05/12/22 14:47 | | |
| Alkalinity,Bicarbonate (CaCO3) | **266** | mg/L | 2.0 | 1 | | 05/12/22 14:47 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/12/22 14:47 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1270** | mg/L | 20.0 | 1 | | 05/11/22 15:03 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: PZ-101D** **Lab ID: 50315733007** Collected: 05/04/22 15:18 Received: 05/05/22 15:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/13/22 15:31 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:11 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.25** | mg/L | 0.20 | 1 | | 05/10/22 15:16 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 09:52 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 09:52 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 14:47 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 05/13/22 19:15 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.5** | mg/L | 1.0 | 1 | | 05/17/22 14:08 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 676285
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3114230 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/19/22 09:08 | |
| Fluoride | mg/L | ND | 0.10 | 05/19/22 09:08 | |
| Sulfate | mg/L | ND | 0.25 | 05/19/22 09:08 | |

LABORATORY CONTROL SAMPLE: 3114231

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 96 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.54 | 108 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.7 | 109 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114232 3114233

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 110 | 125 | 125 | 287 | 289 | 142 | 144 | 80-120 | 1 | 15 | M0 |
| Fluoride | mg/L | 0.39 | 0.5 | 0.5 | 0.92 | 0.92 | 107 | 107 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 113 | 25 | 25 | 153 | 153 | 161 | 162 | 80-120 | 0 | 15 | M0 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114234 3114235

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 135 | 125 | 125 | 281 | 281 | 116 | 116 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.22 | 0.5 | 0.5 | 0.80 | 0.80 | 117 | 117 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 40.2 | 25 | 25 | 70.4 | 70.2 | 121 | 120 | 80-120 | 0 | 15 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675187
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3109067 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/17/22 01:40 | |
| Barium | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Boron | ug/L | ND | 100 | 05/17/22 01:40 | |
| Cadmium | ug/L | ND | 2.0 | 05/17/22 01:40 | |
| Calcium | ug/L | ND | 1000 | 05/17/22 01:40 | |
| Chromium | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Iron | ug/L | ND | 100 | 05/17/22 01:40 | |
| Lead | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Lithium | ug/L | ND | 20.0 | 05/17/22 01:40 | |
| Magnesium | ug/L | ND | 1000 | 05/17/22 01:40 | |
| Manganese | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Molybdenum | ug/L | ND | 10.0 | 05/17/22 01:40 | |
| Potassium | ug/L | ND | 1000 | 05/17/22 01:40 | |
| Silica | ug/L | ND | 450 | 05/17/22 01:40 | N2 |
| Sodium | ug/L | ND | 1000 | 05/17/22 01:40 | |

LABORATORY CONTROL SAMPLE: 3109068

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9720 | 97 | 80-120 | |
| Barium | ug/L | 1000 | 986 | 99 | 80-120 | |
| Boron | ug/L | 1000 | 953 | 95 | 80-120 | |
| Cadmium | ug/L | 1000 | 933 | 93 | 80-120 | |
| Calcium | ug/L | 10000 | 10300 | 103 | 80-120 | |
| Chromium | ug/L | 1000 | 968 | 97 | 80-120 | |
| Iron | ug/L | 10000 | 9570 | 96 | 80-120 | |
| Lead | ug/L | 1000 | 928 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1030 | 103 | 80-120 | |
| Magnesium | ug/L | 10000 | 9530 | 95 | 80-120 | |
| Manganese | ug/L | 1000 | 921 | 92 | 80-120 | |
| Molybdenum | ug/L | 1000 | 987 | 99 | 80-120 | |
| Potassium | ug/L | 10000 | 9680 | 97 | 80-120 | |
| Silica | ug/L | 10700 | 10200 | 95 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9660 | 97 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109069 3109070

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9690 | 9760 | 97 | 98 | 75-125 | 1 | 20 | |
| Barium | ug/L | 97.1 | 1000 | 1000 | 1040 | 1080 | 94 | 98 | 75-125 | 3 | 20 | |
| Boron | ug/L | 396 | 1000 | 1000 | 1360 | 1380 | 96 | 99 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 915 | 948 | 91 | 95 | 75-125 | 4 | 20 | |
| Calcium | ug/L | 100000 | 10000 | 10000 | 106000 | 109000 | 55 | 93 | 75-125 | 4 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 934 | 965 | 93 | 96 | 75-125 | 3 | 20 | |
| Iron | ug/L | 1120 | 10000 | 10000 | 10600 | 10700 | 95 | 96 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 867 | 898 | 87 | 90 | 75-125 | 3 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1040 | 1070 | 103 | 106 | 75-125 | 3 | 20 | |
| Magnesium | ug/L | 30800 | 10000 | 10000 | 39400 | 40400 | 85 | 96 | 75-125 | 3 | 20 | |
| Manganese | ug/L | 382 | 1000 | 1000 | 1290 | 1310 | 90 | 93 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | 15.5 | 1000 | 1000 | 974 | 1010 | 96 | 99 | 75-125 | 4 | 20 | |
| Potassium | ug/L | 4140 | 10000 | 10000 | 13700 | 14200 | 95 | 101 | 75-125 | 4 | 20 | |
| Silica | ug/L | 8450 | 10700 | 10700 | 18600 | 19000 | 95 | 98 | 75-125 | 2 | 20 | N2 |
| Sodium | ug/L | 106000 | 10000 | 10000 | 110000 | 115000 | 44 | 97 | 75-125 | 5 | 20 | P6 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109071 3109072

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9810 | 9330 | 98 | 93 | 75-125 | 5 | 20 | |
| Barium | ug/L | 202 | 1000 | 1000 | 1200 | 1120 | 100 | 92 | 75-125 | 7 | 20 | |
| Boron | ug/L | 280 | 1000 | 1000 | 1240 | 1170 | 96 | 89 | 75-125 | 6 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 951 | 890 | 95 | 89 | 75-125 | 7 | 20 | |
| Calcium | ug/L | 91800 | 10000 | 10000 | 103000 | 96500 | 115 | 46 | 75-125 | 7 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 976 | 913 | 97 | 91 | 75-125 | 7 | 20 | |
| Iron | ug/L | 1500 | 10000 | 10000 | 11300 | 10600 | 98 | 91 | 75-125 | 6 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 908 | 852 | 91 | 85 | 75-125 | 6 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1080 | 1010 | 107 | 100 | 75-125 | 7 | 20 | |
| Magnesium | ug/L | 26100 | 10000 | 10000 | 36000 | 33800 | 99 | 76 | 75-125 | 6 | 20 | |
| Manganese | ug/L | 309 | 1000 | 1000 | 1250 | 1180 | 94 | 87 | 75-125 | 6 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 1010 | 939 | 101 | 94 | 75-125 | 7 | 20 | |
| Potassium | ug/L | 7500 | 10000 | 10000 | 17800 | 16600 | 103 | 91 | 75-125 | 7 | 20 | |
| Silica | ug/L | 10700 | 10700 | 10700 | 21600 | 20100 | 102 | 87 | 75-125 | 7 | 20 | N2 |
| Sodium | ug/L | 62700 | 10000 | 10000 | 73500 | 68400 | 108 | 57 | 75-125 | 7 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675141
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733007

METHOD BLANK: 3108884 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/16/22 09:48 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/16/22 09:48 | |

LABORATORY CONTROL SAMPLE: 3108885

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 934 | 93 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1010 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108886 3108887

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 395 | 1000 | 1000 | 1390 | 1340 | 99 | 94 | 75-125 | 4 | 20 | |
| Molybdenum, Dissolved | ug/L | 15.8 | 1000 | 1000 | 1080 | 1050 | 107 | 103 | 75-125 | 4 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108888 3108889

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 300 | 1000 | 1000 | 1250 | 1240 | 95 | 94 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1030 | 1040 | 102 | 104 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675548
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3110481 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/13/22 02:02 | |
| Arsenic | ug/L | ND | 1.0 | 05/13/22 02:02 | |
| Cobalt | ug/L | ND | 1.0 | 05/13/22 02:02 | |
| Selenium | ug/L | ND | 1.0 | 05/13/22 02:02 | |

LABORATORY CONTROL SAMPLE: 3110482

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.7 | 104 | 80-120 | |
| Arsenic | ug/L | 40 | 39.4 | 99 | 80-120 | |
| Cobalt | ug/L | 40 | 40.3 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 40.1 | 100 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110483 3110484

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 45.3 | 42.8 | 113 | 107 | 75-125 | 6 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 39.4 | 38.5 | 98 | 96 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 41.1 | 38.2 | 103 | 95 | 75-125 | 7 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 39.6 | 39.3 | 98 | 98 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675775 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005

METHOD BLANK: 3111544 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/13/22 14:51 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/13/22 14:51 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/13/22 14:51 | |

LABORATORY CONTROL SAMPLE: 3111545

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.5 | 99 | 90-110 | |

SAMPLE DUPLICATE: 3111546

| Parameter | Units | 50315730006 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 252 | 256 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 252 | 256 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3111547

| Parameter | Units | 50315733002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 252 | 252 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 252 | 252 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675776
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733007

METHOD BLANK: 3111548 Matrix: Water
Associated Lab Samples: 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/12/22 14:47 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/12/22 14:47 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/12/22 14:47 | |

LABORATORY CONTROL SAMPLE: 3111549

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 47.0 | 94 | 90-110 | |

SAMPLE DUPLICATE: 3111550

| Parameter | Units | 50315564008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 115 | 118 | 3 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 115 | 118 | 3 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3111551

| Parameter | Units | 50315566001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 255 | 259 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 255 | 259 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675556
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001

METHOD BLANK: 3110504 Matrix: Water
Associated Lab Samples: 50315733001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/11/22 13:22 | |

LABORATORY CONTROL SAMPLE: 3110505

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 281 | 94 | 80-120 | |

SAMPLE DUPLICATE: 3110506

| Parameter | Units | 50315718001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 703 | 713 | 1 | 10 | |

SAMPLE DUPLICATE: 3110507

| Parameter | Units | 50315730005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 678 | 698 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675557 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3110508 Matrix: Water
Associated Lab Samples: 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/11/22 14:56 | |

LABORATORY CONTROL SAMPLE: 3110509

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 289 | 96 | 80-120 | |

SAMPLE DUPLICATE: 3110510

| Parameter | Units | 50315733002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 535 | 552 | 3 | 10 | |

SAMPLE DUPLICATE: 3110511

| Parameter | Units | 50315786003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1120 | 1080 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 676173
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

SAMPLE DUPLICATE: 3113485

| Parameter | Units | 50315718001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.8 | 7.8 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3113486

| Parameter | Units | 50315730005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.7 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3113487

| Parameter | Units | 50315733002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 674956 — Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D — Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3108153 — Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/07/22 09:11 | |

LABORATORY CONTROL SAMPLE: 3108154

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.54 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108155 3108156

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.43 | 0.41 | 86 | 82 | 90-110 | 5 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3108157

| Parameter | Units | 50315777001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.34 | 69 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675312 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3109491 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 15:13 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109492

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 100 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109493 3109494

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 101 | 103 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109495 3109496

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 104 | 90-110 | 1 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 674764
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

METHOD BLANK: 3106949 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/06/22 09:05 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/06/22 09:05 | |

LABORATORY CONTROL SAMPLE: 3106950

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106951 3106952

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.15 | 1 | 1 | 1.1 | 1.1 | 98 | 96 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.95 | 0.96 | 95 | 95 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3106953 3106954

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 96 | 96 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675359
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733003, 50315733004, 50315733005

METHOD BLANK: 3109647 Matrix: Water
Associated Lab Samples: 50315733001, 50315733003, 50315733004, 50315733005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/13/22 14:32 | |

LABORATORY CONTROL SAMPLE: 3109648

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109649 3109650

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.73 | | | 2.3 | 2.3 | | | | 0 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675362
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733002, 50315733007

METHOD BLANK: 3109659 Matrix: Water
Associated Lab Samples: 50315733002, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/13/22 14:42 | |

LABORATORY CONTROL SAMPLE: 3109660

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109661 3109662

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.7 | | | | 8 | | |

MATRIX SPIKE SAMPLE: 3109663

| Parameter | Units | 50315807001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 5.5 | | 7.4 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 675018 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733004, 50315733005

METHOD BLANK: 3108517 Matrix: Water
Associated Lab Samples: 50315733001, 50315733004, 50315733005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/12/22 20:20 | |

LABORATORY CONTROL SAMPLE: 3108518

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108519 3108520

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.0 | 10 | 10 | 11.8 | 12.1 | 98 | 101 | 80-120 | 3 | 20 | |

MATRIX SPIKE SAMPLE: 3108521

| Parameter | Units | 50315730008 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.0 | 10 | 12.6 | 96 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 676186 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733002, 50315733003, 50315733007

METHOD BLANK: 3113651 Matrix: Water
Associated Lab Samples: 50315733002, 50315733003, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/13/22 17:42 | |

LABORATORY CONTROL SAMPLE: 3113652

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.7 | 97 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113653 3113654

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.7 | 10 | 10 | 11.9 | 11.8 | 92 | 91 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113655 3113656

| Parameter | Units | 50315751001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 15.9 | 40 | 40 | 52.1 | 57.8 | 91 | 105 | 80-120 | 10 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 676497 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733007

METHOD BLANK: 3114854 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/17/22 08:47 | |

LABORATORY CONTROL SAMPLE: 3114855

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.5 | 105 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114856 3114857

| Parameter | Units | 50315730005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.7 | 10 | 10 | 12.1 | 13.3 | 104 | 115 | 80-120 | 9 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114858 3114859

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.7 | 10 | 10 | 13.3 | 12.8 | 106 | 101 | 80-120 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103S** **Lab ID: 50315733001** Collected: 05/04/22 13:50 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.304 ± 0.422 (1.07) C:NA T:90%** | pCi/L | 06/10/22 12:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.832 ± 0.453 (0.828) C:76% T:87%** | pCi/L | 06/04/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.832 ± 0.875 (1.90)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103I** **Lab ID: 50315733002** Collected: 05/04/22 11:15 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.956 ± 0.517 (0.522) C:NA T:91%** | pCi/L | 06/10/22 12:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.66 ± 0.518 (0.655) C:83% T:87%** | pCi/L | 06/04/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.62 ± 1.04 (1.18)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103D** **Lab ID: 50315733003** Collected: 05/04/22 12:50 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.728 ± 0.732 (1.15) C:NA T:87%** | pCi/L | 06/10/22 12:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.17 ± 0.469 (0.748) C:80% T:89%** | pCi/L | 06/04/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.90 ± 1.20 (1.90)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: PZ-101S** **Lab ID: 50315733004** Collected: 05/04/22 15:10 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.947 ± 0.758 (1.13) C:NA T:90%** | pCi/L | 06/10/22 12:05 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.895 ± 0.479 (0.860) C:71% T:82%** | pCi/L | 06/04/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.84 ± 1.24 (1.99)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: FB** **Lab ID: 50315733005** Collected: 05/04/22 13:50 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.346 ± 0.409 (1.04) C:NA T:95%** | pCi/L | 06/10/22 12:19 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.139 ± 0.279 (0.616) C:79% T:83%** | pCi/L | 06/04/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.139 ± 0.688 (1.66)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: PZ-101D** **Lab ID: 50315733007** Collected: 05/04/22 15:18 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0783 ± 0.406 (0.843) C:NA T:86%** | pCi/L | 06/10/22 12:19 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.31 ± 0.443 (0.596) C:81% T:91%** | pCi/L | 06/04/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.39 ± 0.849 (1.44)** | pCi/L | 06/13/22 15:00 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103I RAD MS** **Lab ID: 50315733008** Collected: 05/04/22 11:15 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-226 | EPA 903.1 | **99.80 %REC ± NA (NA) C:NA T:9NA%** | pCi/L | 06/10/22 12:19 | 13982-63-3 | |
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-228 | EPA 904.0 | **91.22 %REC ± NA (NA) C:NA T:NA** | pCi/L | 06/04/22 15:05 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

**Sample: MW-103I RAD MSD** **Lab ID: 50315733009** Collected: 05/04/22 11:15 Received: 05/05/22 15:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **99.79 %REC 0.01 RPD ± NA (NA) C:NA T:9NA%** | pCi/L | 06/10/22 12:19 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **117.41 %REC 25.11 RPD ± NA (NA) C:NA T:NA** | pCi/L | 06/04/22 15:05 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 505223
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007, 50315733008, 50315733009

METHOD BLANK: 2447130 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007, 50315733008, 50315733009

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.561 ± 0.292 (0.498) C:82% T:95% | pCi/L | 06/04/22 15:04 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

QC Batch: 505222 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007, 50315733008, 50315733009

METHOD BLANK: 2447105 Matrix: Water
Associated Lab Samples: 50315733001, 50315733002, 50315733003, 50315733004, 50315733005, 50315733007, 50315733008, 50315733009

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.121 ± 0.375 (0.853) C:NA T:87% | pCi/L | 06/10/22 11:52 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| PL | The minimum mass of dried residue of 2.5 mg could not be obtained using the routine sample volume of 100 mL. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315733001** | **MW-103S** | EPA 9056 | 676285 | | |
| **50315733002** | **MW-103I** | EPA 9056 | 676285 | | |
| **50315733003** | **MW-103D** | EPA 9056 | 676285 | | |
| **50315733004** | **PZ-101S** | EPA 9056 | 676285 | | |
| **50315733005** | **FB** | EPA 9056 | 676285 | | |
| **50315733007** | **PZ-101D** | EPA 9056 | 676285 | | |
| **50315733001** | **MW-103S** | EPA 3010 | 675187 | EPA 6010 | 676544 |
| **50315733002** | **MW-103I** | EPA 3010 | 675187 | EPA 6010 | 676544 |
| **50315733003** | **MW-103D** | EPA 3010 | 675187 | EPA 6010 | 676544 |
| **50315733004** | **PZ-101S** | EPA 3010 | 675187 | EPA 6010 | 676544 |
| **50315733005** | **FB** | EPA 3010 | 675187 | EPA 6010 | 676544 |
| **50315733007** | **PZ-101D** | EPA 3010 | 675187 | EPA 6010 | 676544 |
| **50315733001** | **MW-103S** | EPA 3010 | 675141 | EPA 6010 | 676400 |
| **50315733002** | **MW-103I** | EPA 3010 | 675141 | EPA 6010 | 676400 |
| **50315733003** | **MW-103D** | EPA 3010 | 675141 | EPA 6010 | 676400 |
| **50315733004** | **PZ-101S** | EPA 3010 | 675141 | EPA 6010 | 676400 |
| **50315733007** | **PZ-101D** | EPA 3010 | 675141 | EPA 6010 | 676400 |
| **50315733001** | **MW-103S** | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| **50315733002** | **MW-103I** | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| **50315733003** | **MW-103D** | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| **50315733004** | **PZ-101S** | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| **50315733005** | **FB** | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| **50315733007** | **PZ-101D** | EPA 200.2 | 675548 | EPA 6020 | 675755 |
| **50315733001** | **MW-103S** | EPA 903.1 | 505222 | | |
| **50315733002** | **MW-103I** | EPA 903.1 | 505222 | | |
| **50315733003** | **MW-103D** | EPA 903.1 | 505222 | | |
| **50315733004** | **PZ-101S** | EPA 903.1 | 505222 | | |
| **50315733005** | **FB** | EPA 903.1 | 505222 | | |
| **50315733007** | **PZ-101D** | EPA 903.1 | 505222 | | |
| **50315733008** | **MW-103I RAD MS** | EPA 903.1 | 505222 | | |
| **50315733009** | **MW-103I RAD MSD** | EPA 903.1 | 505222 | | |
| **50315733001** | **MW-103S** | EPA 904.0 | 505223 | | |
| **50315733002** | **MW-103I** | EPA 904.0 | 505223 | | |
| **50315733003** | **MW-103D** | EPA 904.0 | 505223 | | |
| **50315733004** | **PZ-101S** | EPA 904.0 | 505223 | | |
| **50315733005** | **FB** | EPA 904.0 | 505223 | | |
| **50315733007** | **PZ-101D** | EPA 904.0 | 505223 | | |
| **50315733008** | **MW-103I RAD MS** | EPA 904.0 | 505223 | | |
| **50315733009** | **MW-103I RAD MSD** | EPA 904.0 | 505223 | | |
| **50315733001** | **MW-103S** | Total Radium Calculation | 511333 | | |
| **50315733002** | **MW-103I** | Total Radium Calculation | 511333 | | |
| **50315733003** | **MW-103D** | Total Radium Calculation | 511333 | | |
| **50315733004** | **PZ-101S** | Total Radium Calculation | 511333 | | |
| **50315733005** | **FB** | Total Radium Calculation | 511333 | | |
| **50315733007** | **PZ-101D** | Total Radium Calculation | 511333 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315733001** | **MW-103S** | SM 2320B | 675775 | | |
| **50315733002** | **MW-103I** | SM 2320B | 675775 | | |
| **50315733003** | **MW-103D** | SM 2320B | 675775 | | |
| **50315733004** | **PZ-101S** | SM 2320B | 675775 | | |
| **50315733005** | **FB** | SM 2320B | 675775 | | |
| **50315733007** | **PZ-101D** | SM 2320B | 675776 | | |
| **50315733001** | **MW-103S** | SM 2540C | 675556 | | |
| **50315733002** | **MW-103I** | SM 2540C | 675557 | | |
| **50315733003** | **MW-103D** | SM 2540C | 675557 | | |
| **50315733004** | **PZ-101S** | SM 2540C | 675557 | | |
| **50315733005** | **FB** | SM 2540C | 675557 | | |
| **50315733007** | **PZ-101D** | SM 2540C | 675557 | | |
| **50315733001** | **MW-103S** | SM 4500-H+B | 676173 | | |
| **50315733002** | **MW-103I** | SM 4500-H+B | 676173 | | |
| **50315733003** | **MW-103D** | SM 4500-H+B | 676173 | | |
| **50315733004** | **PZ-101S** | SM 4500-H+B | 676173 | | |
| **50315733005** | **FB** | SM 4500-H+B | 676173 | | |
| **50315733007** | **PZ-101D** | SM 4500-H+B | 676173 | | |
| **50315733001** | **MW-103S** | SM 4500-S2-D | 674956 | | |
| **50315733002** | **MW-103I** | SM 4500-S2-D | 674956 | | |
| **50315733003** | **MW-103D** | SM 4500-S2-D | 674956 | | |
| **50315733004** | **PZ-101S** | SM 4500-S2-D | 674956 | | |
| **50315733005** | **FB** | SM 4500-S2-D | 674956 | | |
| **50315733007** | **PZ-101D** | SM 4500-S2-D | 674956 | | |
| **50315733001** | **MW-103S** | HACH 8146 | 675312 | | |
| **50315733002** | **MW-103I** | HACH 8146 | 675312 | | |
| **50315733003** | **MW-103D** | HACH 8146 | 675312 | | |
| **50315733004** | **PZ-101S** | HACH 8146 | 675312 | | |
| **50315733005** | **FB** | HACH 8146 | 675312 | | |
| **50315733007** | **PZ-101D** | HACH 8146 | 675312 | | |
| **50315733001** | **MW-103S** | EPA 353.2 | 674764 | | |
| **50315733002** | **MW-103I** | EPA 353.2 | 674764 | | |
| **50315733003** | **MW-103D** | EPA 353.2 | 674764 | | |
| **50315733004** | **PZ-101S** | EPA 353.2 | 674764 | | |
| **50315733005** | **FB** | EPA 353.2 | 674764 | | |
| **50315733007** | **PZ-101D** | EPA 353.2 | 674764 | | |
| **50315733001** | **MW-103S** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315733002** | **MW-103I** | EPA 365.1 | 675362 | EPA 365.1 | 676256 |
| **50315733003** | **MW-103D** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315733004** | **PZ-101S** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315733005** | **FB** | EPA 365.1 | 675359 | EPA 365.1 | 676255 |
| **50315733007** | **PZ-101D** | EPA 365.1 | 675362 | EPA 365.1 | 676256 |
| **50315733001** | **MW-103S** | SM 5310C | 675018 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315733

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315733002** | **MW-103I** | SM 5310C | 676186 | | |
| **50315733003** | **MW-103D** | SM 5310C | 676186 | | |
| **50315733004** | **PZ-101S** | SM 5310C | 675018 | | |
| **50315733005** | **FB** | SM 5310C | 675018 | | |
| **50315733007** | **PZ-101D** | SM 5310C | 676186 | | |
| **50315733001** | **MW-103S** | SM 5310C | 676497 | | |
| **50315733002** | **MW-103I** | SM 5310C | 676497 | | |
| **50315733003** | **MW-103D** | SM 5310C | 676497 | | |
| **50315733004** | **PZ-101S** | SM 5310C | 676497 | | |
| **50315733007** | **PZ-101D** | SM 5310C | 676497 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

# CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical® WWW.PACELABS.COM

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.

WO# : 50315733



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Acco |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 2 | Pace Project Manager: | |
| Requested Due Date: | | Project #: | | Pace Profile #: | |

MATRIX CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | |
| 1 | ~~MW-103S~~ MW-103S | WT | | 5/4 | 1350 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | ~~010~~ 001 |
| 2 | ~~PZ-100S~~ MW-103I | WT | | 5/4 | 1115 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | ~~011~~ 002 |
| 3 | ~~PZ-100D~~ MW-103D | WT | | 5/4 | 1250 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | HP ~~012~~ 003 |
| 4 | ~~PZ-101S~~ PZ-101S | WT | | 5/4 | 1510 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | ~~013~~ 004 |
| 5 | ~~PZ-101D~~ MS-3 (MW-103I) | WT | | 5/4 | 1115 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | ~~(011)~~ (002) |
| 6 | ~~MW-102S~~ MSD-3 (MW-103I) | WT | | 5/4 | 1115 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | ~~(011)~~ (002) |
| 7 | ~~MW-102D~~ FB | WT | | 5/4 | 1350 | | | | ~~9~~ 11 | 3 | ~~2~~ 3 | ~~3~~ 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | HP filtered ~~014~~ 005 |
| 8 | ~~MW-103S~~ DUP-1 | WT | | 5/4 | 0000 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | ~~015~~ DUP 006 |
| 9 | ~~MW-103I~~ PZ-101D | WT | | 5/4 | 1518 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | 007 PZ-101D |
| 10 | ~~MW-103D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | |
| 11 | ~~MW-104S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | |
| 12 | ~~MW-104D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | P. Cress Hopper | 5/5 | 0800 | Pace | 5/5/22 | 134 |
| 6020 (Co, As, Se, Sb) | Pace | 5/5 | 1510 | Hayden Pratt | 5/5/22 | 1510 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| | | | |
| See Sheet | Y | N | Y |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: P. Cress Hopper

SIGNATURE of SAMPLER: [signature] DATE Signed:

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** HRP 5/5/22 1720

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☐ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** see Exc comments
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | — |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** $NO_3$ $NO_2$ | — | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: walkin | |
| **Rush TAT Requested (4 days or less):** | | — |
| Custody Signatures Present? | — | |
| Containers Intact?: | — | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | — | |
| Extra labels on Terracore Vials? (soils only) | NA | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** ~~Any non-conformance to pH~~ recommendations ~~will be noted on~~ the container count form | — | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | — |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | — |
| Headspace Wisconsin Sulfide? | | | — |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | — |
| Trip Blank Present? | | — | |
| Trip Blank Custody Seals?: | | — | |

COMMENTS:

Temps: cooler 1. 1.4 / 1.2 7. 0.6 / 0.4
2. 1.2 / 1.0 8. 0.5 / 0.3
3. 1.2 / 1.0 9. 0.7 / 0.5
4. 1.3 / 1.1 10. 0.8 / 0.6
5. 0.8 / 0.6 11. 0.9 / 0.7
6. 0.6 / 0.4

Dup-1 and PZ-101D not on COC

PZ-101D: 5/4/22 1518 hrp 5/5/22

# Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | 001 | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | 002 | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | | | | |
| 3 | | | | | | | | | | | | | | 003 | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | | | |
| 4 | | | | | | | | | | 004 | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | 005 | | 1 | | | | 2 | 1 | 2 | 1 | | 1 | | 1 | | | | | | | | |
| 8 | | | | | | | | | | 006 | | ↓ | 1 | | | ↓ | ↓ | ↓ | ↓ | 1 | ↓ | | ↓ | | | | | WT | ✓ | ✓ | |
| 9 | | | | | | | | | | 007 | | ↓ | 1 | | | ↓ | ↓ | ↓ | ↓ | 1 | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

** Place a RED dot on containers that are out of conformance **

Container Codes

## Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

## Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 06, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50315836001** | **MW-106S** | Water | 05/05/22 11:43 | 05/06/22 13:20 |
| **50315836002** | **MW-106D** | Water | 05/05/22 12:54 | 05/06/22 13:20 |
| **50315836003** | **MW-107S** | Water | 05/05/22 10:25 | 05/06/22 13:20 |
| **50315836004** | **MW-107I** | Water | 05/05/22 13:05 | 05/06/22 13:20 |
| **50315836005** | **MW-107D** | Water | 05/05/22 11:50 | 05/06/22 13:20 |
| **50315836006** | **DUP 3** | Water | 05/05/22 00:00 | 05/06/22 13:20 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50315836001** | **MW-106S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836002** | **MW-106D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836003** | **MW-107S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836004** | **MW-107I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836005** | **MW-107D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836006** | **DUP 3** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836001** | **MW-106S** | | | | | |
| EPA 9056 | Chloride | 12.4 | mg/L | 2.5 | 05/20/22 10:16 | |
| EPA 9056 | Fluoride | 0.28 | mg/L | 0.10 | 05/20/22 09:59 | |
| EPA 9056 | Sulfate | 1120 | mg/L | 25.0 | 05/20/22 10:33 | |
| EPA 6010 | Aluminum | 541 | ug/L | 200 | 05/19/22 10:02 | |
| EPA 6010 | Barium | 21.4 | ug/L | 10.0 | 05/19/22 10:02 | |
| EPA 6010 | Boron | 388 | ug/L | 100 | 05/19/22 10:02 | |
| EPA 6010 | Calcium | 312000 | ug/L | 2000 | 05/19/22 13:41 | |
| EPA 6010 | Iron | 4230 | ug/L | 100 | 05/19/22 10:02 | |
| EPA 6010 | Lithium | 31.7 | ug/L | 20.0 | 05/19/22 10:02 | |
| EPA 6010 | Magnesium | 121000 | ug/L | 1000 | 05/19/22 10:02 | |
| EPA 6010 | Manganese | 1030 | ug/L | 10.0 | 05/19/22 10:02 | |
| EPA 6010 | Molybdenum | 18.9 | ug/L | 10.0 | 05/19/22 10:02 | |
| EPA 6010 | Potassium | 7060 | ug/L | 1000 | 05/19/22 10:02 | |
| EPA 6010 | Silica | 9660 | ug/L | 450 | 05/19/22 10:02 | N2 |
| EPA 6010 | Sodium | 21200 | ug/L | 1000 | 05/19/22 10:02 | |
| EPA 6010 | Manganese, Dissolved | 1010 | ug/L | 10.0 | 05/17/22 03:06 | |
| EPA 6010 | Molybdenum, Dissolved | 18.4 | ug/L | 10.0 | 05/17/22 03:06 | |
| EPA 6020 | Arsenic | 3.6 | ug/L | 1.0 | 05/14/22 06:31 | |
| EPA 6020 | Cobalt | 1.4 | ug/L | 1.0 | 05/14/22 06:31 | |
| EPA 6020 | Selenium | 1.0 | ug/L | 1.0 | 05/14/22 06:31 | |
| EPA 903.1 | Radium-226 | 0.0541 ± 0.281 (0.582) C:NA T:90% | pCi/L | | 06/15/22 12:00 | |
| EPA 904.0 | Radium-228 | 0.680 ± 0.379 (0.680) C:80% T:85% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 0.734 ± 0.660 (1.26) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 348 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 348 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 1780 | mg/L | 20.0 | 05/12/22 15:53 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 05/14/22 17:00 | H3 |
| HACH 8146 | Iron, Ferrous | 0.90 | mg/L | 0.20 | 05/10/22 15:16 | H3,N2 |
| EPA 353.2 | Nitrogen, Nitrate | 0.11 | mg/L | 0.10 | 05/06/22 17:39 | |
| **50315836002** | **MW-106D** | | | | | |
| EPA 9056 | Chloride | 264 | mg/L | 25.0 | 05/20/22 06:49 | |
| EPA 9056 | Fluoride | 0.28 | mg/L | 0.10 | 05/20/22 06:32 | |
| EPA 9056 | Sulfate | 702 | mg/L | 25.0 | 05/20/22 06:49 | |
| EPA 6010 | Barium | 31.0 | ug/L | 10.0 | 05/19/22 10:04 | |
| EPA 6010 | Boron | 13300 | ug/L | 100 | 05/19/22 10:04 | |
| EPA 6010 | Calcium | 277000 | ug/L | 2000 | 05/19/22 13:43 | |
| EPA 6010 | Iron | 4520 | ug/L | 100 | 05/19/22 10:04 | |
| EPA 6010 | Lithium | 120 | ug/L | 20.0 | 05/19/22 10:04 | |
| EPA 6010 | Magnesium | 52500 | ug/L | 1000 | 05/19/22 10:04 | |
| EPA 6010 | Manganese | 328 | ug/L | 10.0 | 05/19/22 10:04 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836002** | **MW-106D** | | | | | |
| EPA 6010 | Molybdenum | 244 | ug/L | 10.0 | 05/19/22 10:04 | |
| EPA 6010 | Potassium | 15400 | ug/L | 1000 | 05/19/22 10:04 | |
| EPA 6010 | Silica | 14900 | ug/L | 450 | 05/19/22 10:04 | N2 |
| EPA 6010 | Sodium | 199000 | ug/L | 1000 | 05/19/22 10:04 | |
| EPA 6010 | Manganese, Dissolved | 324 | ug/L | 10.0 | 05/17/22 03:08 | |
| EPA 6010 | Molybdenum, Dissolved | 246 | ug/L | 10.0 | 05/17/22 03:08 | |
| EPA 6020 | Arsenic | 195 | ug/L | 1.0 | 05/14/22 06:36 | |
| EPA 903.1 | Radium-226 | 0.302 ± 0.343 (0.541) C:NA T:92% | pCi/L | | 06/15/22 12:00 | |
| EPA 904.0 | Radium-228 | 0.694 ± 0.362 (0.622) C:83% T:83% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 0.996 ± 0.705 (1.16) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 242 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 242 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 1660 | mg/L | 40.0 | 05/12/22 15:54 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 05/14/22 17:02 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.75 | mg/L | 0.15 | 05/13/22 15:07 | |
| SM 5310C | Total Organic Carbon | 1.7 | mg/L | 1.0 | 05/14/22 03:48 | |
| SM 5310C | Dissolved Organic Carbon | 2.1 | mg/L | 1.0 | 05/17/22 16:08 | |
| **50315836003** | **MW-107S** | | | | | |
| EPA 9056 | Chloride | 266 | mg/L | 25.0 | 05/20/22 08:14 | |
| EPA 9056 | Fluoride | 0.68 | mg/L | 0.10 | 05/20/22 07:06 | |
| EPA 9056 | Sulfate | 732 | mg/L | 25.0 | 05/20/22 08:14 | |
| EPA 6010 | Barium | 17.0 | ug/L | 10.0 | 05/19/22 10:06 | |
| EPA 6010 | Boron | 6250 | ug/L | 100 | 05/19/22 10:06 | |
| EPA 6010 | Calcium | 238000 | ug/L | 2000 | 05/19/22 13:45 | |
| EPA 6010 | Iron | 2050 | ug/L | 100 | 05/19/22 10:06 | |
| EPA 6010 | Lithium | 84.0 | ug/L | 20.0 | 05/19/22 10:06 | |
| EPA 6010 | Magnesium | 79900 | ug/L | 1000 | 05/19/22 10:06 | |
| EPA 6010 | Manganese | 420 | ug/L | 10.0 | 05/19/22 10:06 | |
| EPA 6010 | Molybdenum | 64.3 | ug/L | 10.0 | 05/19/22 10:06 | |
| EPA 6010 | Potassium | 11800 | ug/L | 1000 | 05/19/22 10:06 | |
| EPA 6010 | Silica | 11800 | ug/L | 450 | 05/19/22 10:06 | N2 |
| EPA 6010 | Sodium | 236000 | ug/L | 2000 | 05/19/22 13:45 | |
| EPA 6010 | Manganese, Dissolved | 414 | ug/L | 10.0 | 05/17/22 03:10 | |
| EPA 6010 | Molybdenum, Dissolved | 63.2 | ug/L | 10.0 | 05/17/22 03:10 | |
| EPA 903.1 | Radium-226 | 0.691 ± 0.527 (0.749) C:NA T:96% | pCi/L | | 06/15/22 12:00 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836003** | **MW-107S** | | | | | |
| EPA 904.0 | Radium-228 | 0.168 ± 0.358 (0.794) C:71% T:81% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 0.859 ± 0.885 (1.54) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 231 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 231 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 1720 | mg/L | 40.0 | 05/12/22 15:59 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/14/22 17:03 | H3 |
| HACH 8146 | Iron, Ferrous | 0.36 | mg/L | 0.20 | 05/10/22 15:17 | H3,N2 |
| EPA 365.1 | Phosphate as P04 | 0.18 | mg/L | 0.15 | 05/13/22 15:08 | |
| SM 5310C | Total Organic Carbon | 1.2 | mg/L | 1.0 | 05/14/22 04:01 | |
| SM 5310C | Dissolved Organic Carbon | 1.8 | mg/L | 1.0 | 05/17/22 16:22 | |
| **50315836004** | **MW-107I** | | | | | |
| EPA 9056 | Chloride | 176 | mg/L | 25.0 | 05/20/22 09:05 | |
| EPA 9056 | Fluoride | 0.28 | mg/L | 0.10 | 05/20/22 08:31 | |
| EPA 9056 | Sulfate | 485 | mg/L | 25.0 | 05/20/22 09:05 | |
| EPA 6010 | Barium | 241 | ug/L | 10.0 | 05/19/22 10:09 | |
| EPA 6010 | Boron | 3270 | ug/L | 100 | 05/19/22 10:09 | |
| EPA 6010 | Calcium | 221000 | ug/L | 2000 | 05/19/22 13:47 | |
| EPA 6010 | Iron | 8120 | ug/L | 100 | 05/19/22 10:09 | |
| EPA 6010 | Magnesium | 63100 | ug/L | 1000 | 05/19/22 10:09 | |
| EPA 6010 | Manganese | 241 | ug/L | 10.0 | 05/19/22 10:09 | |
| EPA 6010 | Molybdenum | 17.8 | ug/L | 10.0 | 05/19/22 10:09 | |
| EPA 6010 | Potassium | 3530 | ug/L | 1000 | 05/19/22 10:09 | |
| EPA 6010 | Silica | 20400 | ug/L | 450 | 05/19/22 10:09 | N2 |
| EPA 6010 | Sodium | 83800 | ug/L | 1000 | 05/19/22 10:09 | |
| EPA 6010 | Manganese, Dissolved | 238 | ug/L | 10.0 | 05/17/22 03:13 | |
| EPA 6010 | Molybdenum, Dissolved | 17.7 | ug/L | 10.0 | 05/17/22 03:13 | |
| EPA 6020 | Arsenic | 2.5 | ug/L | 1.0 | 05/14/22 06:45 | |
| EPA 903.1 | Radium-226 | 0.429 ± 0.495 (0.805) C:NA T:94% | pCi/L | | 06/15/22 12:00 | |
| EPA 904.0 | Radium-228 | 0.638 ± 0.391 (0.726) C:83% T:83% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 1.07 ± 0.886 (1.53) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 286 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 286 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 1200 | mg/L | 20.0 | 05/12/22 16:00 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/14/22 17:04 | H3 |
| HACH 8146 | Iron, Ferrous | 0.23 | mg/L | 0.20 | 05/10/22 15:18 | H3,N2 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836004** | **MW-107I** | | | | | |
| EPA 365.1 | Phosphate as P04 | 0.79 | mg/L | 0.15 | 05/13/22 15:08 | |
| SM 5310C | Total Organic Carbon | 2.9 | mg/L | 1.0 | 05/14/22 04:13 | |
| SM 5310C | Dissolved Organic Carbon | 3.3 | mg/L | 1.0 | 05/17/22 16:35 | |
| **50315836005** | **MW-107D** | | | | | |
| EPA 9056 | Chloride | 242 | mg/L | 25.0 | 05/20/22 09:56 | |
| EPA 9056 | Fluoride | 0.34 | mg/L | 0.10 | 05/20/22 09:22 | |
| EPA 9056 | Sulfate | 708 | mg/L | 25.0 | 05/20/22 09:56 | |
| EPA 6010 | Barium | 136 | ug/L | 10.0 | 05/19/22 10:11 | |
| EPA 6010 | Boron | 7500 | ug/L | 100 | 05/19/22 10:11 | |
| EPA 6010 | Calcium | 213000 | ug/L | 2000 | 05/19/22 13:49 | |
| EPA 6010 | Iron | 6560 | ug/L | 100 | 05/19/22 10:11 | |
| EPA 6010 | Lithium | 68.2 | ug/L | 20.0 | 05/19/22 10:11 | |
| EPA 6010 | Magnesium | 54600 | ug/L | 1000 | 05/19/22 10:11 | |
| EPA 6010 | Manganese | 362 | ug/L | 10.0 | 05/19/22 10:11 | |
| EPA 6010 | Molybdenum | 124 | ug/L | 10.0 | 05/19/22 10:11 | |
| EPA 6010 | Potassium | 18700 | ug/L | 1000 | 05/19/22 10:11 | |
| EPA 6010 | Silica | 13900 | ug/L | 450 | 05/19/22 10:11 | N2 |
| EPA 6010 | Sodium | 224000 | ug/L | 2000 | 05/19/22 13:49 | |
| EPA 6010 | Manganese, Dissolved | 353 | ug/L | 10.0 | 05/17/22 03:15 | |
| EPA 6010 | Molybdenum, Dissolved | 124 | ug/L | 10.0 | 05/17/22 03:15 | |
| EPA 6020 | Arsenic | 3.0 | ug/L | 1.0 | 05/14/22 07:00 | |
| EPA 903.1 | Radium-226 | 0.526 ± 0.417 (0.566) C:NA T:96% | pCi/L | | 06/15/22 12:00 | |
| EPA 904.0 | Radium-228 | 0.467 ± 0.404 (0.815) C:82% T:80% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 0.993 ± 0.821 (1.38) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 221 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 221 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 1540 | mg/L | 20.0 | 05/12/22 16:00 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/14/22 17:04 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.11 | mg/L | 0.10 | 05/06/22 17:45 | |
| EPA 365.1 | Phosphate as P04 | 0.60 | mg/L | 0.15 | 05/13/22 15:09 | |
| SM 5310C | Total Organic Carbon | 1.8 | mg/L | 1.0 | 05/14/22 04:27 | |
| SM 5310C | Dissolved Organic Carbon | 2.1 | mg/L | 1.0 | 05/17/22 16:49 | |
| **50315836006** | **DUP 3** | | | | | |
| EPA 9056 | Chloride | 274 | mg/L | 25.0 | 05/20/22 12:29 | |
| EPA 9056 | Fluoride | 0.66 | mg/L | 0.10 | 05/20/22 10:13 | |
| EPA 9056 | Sulfate | 749 | mg/L | 25.0 | 05/20/22 12:29 | |
| EPA 6010 | Barium | 16.3 | ug/L | 10.0 | 05/19/22 10:13 | |
| EPA 6010 | Boron | 6240 | ug/L | 100 | 05/19/22 10:13 | |
| EPA 6010 | Calcium | 230000 | ug/L | 2000 | 05/19/22 13:51 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836006** | **DUP 3** | | | | | |
| EPA 6010 | Iron | 2030 | ug/L | 100 | 05/19/22 10:13 | |
| EPA 6010 | Lithium | 83.5 | ug/L | 20.0 | 05/19/22 10:13 | |
| EPA 6010 | Magnesium | 80200 | ug/L | 1000 | 05/19/22 10:13 | |
| EPA 6010 | Manganese | 420 | ug/L | 10.0 | 05/19/22 10:13 | |
| EPA 6010 | Molybdenum | 64.4 | ug/L | 10.0 | 05/19/22 10:13 | |
| EPA 6010 | Potassium | 11700 | ug/L | 1000 | 05/19/22 10:13 | |
| EPA 6010 | Silica | 11800 | ug/L | 450 | 05/19/22 10:13 | N2 |
| EPA 6010 | Sodium | 228000 | ug/L | 2000 | 05/19/22 13:51 | |
| EPA 6010 | Manganese, Dissolved | 409 | ug/L | 10.0 | 05/17/22 03:17 | |
| EPA 6010 | Molybdenum, Dissolved | 62.7 | ug/L | 10.0 | 05/17/22 03:17 | |
| EPA 903.1 | Radium-226 | 0.815 ± 0.541 (0.712) C:NA T:86% | pCi/L | | 06/15/22 12:00 | |
| EPA 904.0 | Radium-228 | 0.295 ± 0.359 (0.758) C:83% T:86% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 1.11 ± 0.900 (1.47) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 229 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 229 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 1640 | mg/L | 40.0 | 05/12/22 16:01 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/14/22 17:05 | H3 |
| SM 5310C | Total Organic Carbon | 1.2 | mg/L | 1.0 | 05/14/22 04:40 | |
| SM 5310C | Dissolved Organic Carbon | 2.4 | mg/L | 1.0 | 05/17/22 17:03 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-106S** **Lab ID: 50315836001** Collected: 05/05/22 11:43 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **12.4** | mg/L | 2.5 | 10 | | 05/20/22 10:16 | 16887-00-6 | |
| Fluoride | **0.28** | mg/L | 0.10 | 1 | | 05/20/22 09:59 | 16984-48-8 | |
| Sulfate | **1120** | mg/L | 25.0 | 100 | | 05/20/22 10:33 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **541** | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7429-90-5 | |
| Barium | **21.4** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7440-39-3 | |
| Boron | **388** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7440-43-9 | |
| Calcium | **312000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:41 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7440-47-3 | |
| Iron | **4230** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7439-92-1 | |
| Lithium | **31.7** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7439-93-2 | |
| Magnesium | **121000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7439-95-4 | |
| Manganese | **1030** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7439-96-5 | |
| Molybdenum | **18.9** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7439-98-7 | |
| Potassium | **7060** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7440-09-7 | |
| Silica | **9660** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7631-86-9 | N2 |
| Sodium | **21200** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:02 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **1010** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:06 | 7439-96-5 | |
| Molybdenum, Dissolved | **18.4** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:06 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:31 | 7440-36-0 | |
| Arsenic | **3.6** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:31 | 7440-38-2 | |
| Cobalt | **1.4** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:31 | 7440-48-4 | |
| Selenium | **1.0** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:31 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **348** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **348** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1780** | mg/L | 20.0 | 1 | | 05/12/22 15:53 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-106S** **Lab ID: 50315836001** Collected: 05/05/22 11:43 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 1 | | 05/14/22 17:00 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.90** | mg/L | 0.20 | 1 | | 05/10/22 15:16 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.11** | mg/L | 0.10 | 1 | | 05/06/22 17:39 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 17:39 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 15:07 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/14/22 03:34 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/17/22 15:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-106D** **Lab ID: 50315836002** Collected: 05/05/22 12:54 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **264** | mg/L | 25.0 | 100 | | 05/20/22 06:49 | 16887-00-6 | |
| Fluoride | **0.28** | mg/L | 0.10 | 1 | | 05/20/22 06:32 | 16984-48-8 | |
| Sulfate | **702** | mg/L | 25.0 | 100 | | 05/20/22 06:49 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7429-90-5 | |
| Barium | **31.0** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7440-39-3 | |
| Boron | **13300** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7440-43-9 | |
| Calcium | **277000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:43 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7440-47-3 | |
| Iron | **4520** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7439-92-1 | |
| Lithium | **120** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7439-93-2 | |
| Magnesium | **52500** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7439-95-4 | |
| Manganese | **328** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7439-96-5 | |
| Molybdenum | **244** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7439-98-7 | |
| Potassium | **15400** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7440-09-7 | |
| Silica | **14900** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7631-86-9 | N2 |
| Sodium | **199000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:04 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **324** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:08 | 7439-96-5 | |
| Molybdenum, Dissolved | **246** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:08 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:36 | 7440-36-0 | |
| Arsenic | **195** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:36 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:36 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:36 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **242** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **242** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1660** | mg/L | 40.0 | 1 | | 05/12/22 15:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-106D** **Lab ID: 50315836002** Collected: 05/05/22 12:54 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 1 | | 05/14/22 17:02 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 18:01 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 18:01 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.75** | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 15:07 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 05/14/22 03:48 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 05/17/22 16:08 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107S** **Lab ID: 50315836003** Collected: 05/05/22 10:25 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **266** | mg/L | 25.0 | 100 | | 05/20/22 08:14 | 16887-00-6 | |
| Fluoride | **0.68** | mg/L | 0.10 | 1 | | 05/20/22 07:06 | 16984-48-8 | |
| Sulfate | **732** | mg/L | 25.0 | 100 | | 05/20/22 08:14 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7429-90-5 | |
| Barium | **17.0** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7440-39-3 | |
| Boron | **6250** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7440-43-9 | |
| Calcium | **238000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:45 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7440-47-3 | |
| Iron | **2050** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7439-92-1 | |
| Lithium | **84.0** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7439-93-2 | |
| Magnesium | **79900** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7439-95-4 | |
| Manganese | **420** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7439-96-5 | |
| Molybdenum | **64.3** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7439-98-7 | |
| Potassium | **11800** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7440-09-7 | |
| Silica | **11800** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:06 | 7631-86-9 | N2 |
| Sodium | **236000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:45 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **414** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:10 | 7439-96-5 | |
| Molybdenum, Dissolved | **63.2** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:10 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:41 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:41 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:41 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:41 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **231** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **231** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1720** | mg/L | 40.0 | 1 | | 05/12/22 15:59 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107S** **Lab ID: 50315836003** Collected: 05/05/22 10:25 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/14/22 17:03 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.36** | mg/L | 0.20 | 1 | | 05/10/22 15:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 17:28 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 17:28 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.18** | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 15:08 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.2** | mg/L | 1.0 | 1 | | 05/14/22 04:01 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 05/17/22 16:22 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107I** **Lab ID: 50315836004** Collected: 05/05/22 13:05 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **176** | mg/L | 25.0 | 100 | | 05/20/22 09:05 | 16887-00-6 | |
| Fluoride | **0.28** | mg/L | 0.10 | 1 | | 05/20/22 08:31 | 16984-48-8 | |
| Sulfate | **485** | mg/L | 25.0 | 100 | | 05/20/22 09:05 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7429-90-5 | |
| Barium | **241** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7440-39-3 | |
| Boron | **3270** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7440-43-9 | |
| Calcium | **221000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:47 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7440-47-3 | |
| Iron | **8120** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7439-93-2 | |
| Magnesium | **63100** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7439-95-4 | |
| Manganese | **241** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7439-96-5 | |
| Molybdenum | **17.8** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7439-98-7 | |
| Potassium | **3530** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7440-09-7 | |
| Silica | **20400** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7631-86-9 | N2 |
| Sodium | **83800** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:09 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **238** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:13 | 7439-96-5 | |
| Molybdenum, Dissolved | **17.7** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:13 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:45 | 7440-36-0 | |
| Arsenic | **2.5** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:45 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:45 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 06:45 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **286** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **286** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1200** | mg/L | 20.0 | 1 | | 05/12/22 16:00 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107I** **Lab ID: 50315836004** Collected: 05/05/22 13:05 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/14/22 17:04 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.23** | mg/L | 0.20 | 1 | | 05/10/22 15:18 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 18:07 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 18:07 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.79** | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 15:08 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.9** | mg/L | 1.0 | 1 | | 05/14/22 04:13 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.3** | mg/L | 1.0 | 1 | | 05/17/22 16:35 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107D** **Lab ID: 50315836005** Collected: 05/05/22 11:50 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **242** | mg/L | 25.0 | 100 | | 05/20/22 09:56 | 16887-00-6 | |
| Fluoride | **0.34** | mg/L | 0.10 | 1 | | 05/20/22 09:22 | 16984-48-8 | |
| Sulfate | **708** | mg/L | 25.0 | 100 | | 05/20/22 09:56 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7429-90-5 | |
| Barium | **136** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7440-39-3 | |
| Boron | **7500** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7440-43-9 | |
| Calcium | **213000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:49 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7440-47-3 | |
| Iron | **6560** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7439-92-1 | |
| Lithium | **68.2** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7439-93-2 | |
| Magnesium | **54600** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7439-95-4 | |
| Manganese | **362** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7439-96-5 | |
| Molybdenum | **124** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7439-98-7 | |
| Potassium | **18700** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7440-09-7 | |
| Silica | **13900** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:11 | 7631-86-9 | N2 |
| Sodium | **224000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:49 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **353** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:15 | 7439-96-5 | |
| Molybdenum, Dissolved | **124** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:15 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:00 | 7440-36-0 | |
| Arsenic | **3.0** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:00 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:00 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:00 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **221** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **221** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1540** | mg/L | 20.0 | 1 | | 05/12/22 16:00 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107D** **Lab ID: 50315836005** Collected: 05/05/22 11:50 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/14/22 17:04 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:18 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.11** | mg/L | 0.10 | 1 | | 05/06/22 17:45 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 17:45 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.60** | mg/L | 0.15 | 1 | 05/10/22 12:30 | 05/13/22 15:09 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.8** | mg/L | 1.0 | 1 | | 05/14/22 04:27 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 05/17/22 16:49 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: DUP 3** **Lab ID: 50315836006** Collected: 05/05/22 00:00 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **274** | mg/L | 25.0 | 100 | | 05/20/22 12:29 | 16887-00-6 | |
| Fluoride | **0.66** | mg/L | 0.10 | 1 | | 05/20/22 10:13 | 16984-48-8 | |
| Sulfate | **749** | mg/L | 25.0 | 100 | | 05/20/22 12:29 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7429-90-5 | |
| Barium | **16.3** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7440-39-3 | |
| Boron | **6240** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7440-43-9 | |
| Calcium | **230000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:51 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7440-47-3 | |
| Iron | **2030** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7439-92-1 | |
| Lithium | **83.5** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7439-93-2 | |
| Magnesium | **80200** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7439-95-4 | |
| Manganese | **420** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7439-96-5 | |
| Molybdenum | **64.4** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7439-98-7 | |
| Potassium | **11700** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7440-09-7 | |
| Silica | **11800** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:13 | 7631-86-9 | N2 |
| Sodium | **228000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 13:51 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **409** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:17 | 7439-96-5 | |
| Molybdenum, Dissolved | **62.7** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:17 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:05 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:05 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:05 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:05 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **229** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **229** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1640** | mg/L | 40.0 | 1 | | 05/12/22 16:01 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: DUP 3** **Lab ID: 50315836006** Collected: 05/05/22 00:00 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/14/22 17:05 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:18 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 17:04 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 17:04 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:38 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.2** | mg/L | 1.0 | 1 | | 05/14/22 04:40 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.4** | mg/L | 1.0 | 1 | | 05/17/22 17:03 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 676957 | Analysis Method: EPA 9056
QC Batch Method: EPA 9056 | Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3116792 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/20/22 11:41 | |
| Fluoride | mg/L | ND | 0.10 | 05/20/22 11:41 | |
| Sulfate | mg/L | ND | 0.25 | 05/20/22 11:41 | |

LABORATORY CONTROL SAMPLE: 3116793

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 91 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.49 | 97 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 95 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116794 3116795

| Parameter | Units | 50315786003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 103 | 12.5 | 12.5 | 112 | 113 | 76 | 79 | 80-120 | 0 | 15 | M0 |
| Fluoride | mg/L | 0.067J | 0.5 | 0.5 | 0.52 | 0.53 | 91 | 93 | 80-120 | 2 | 15 | |
| Sulfate | mg/L | 529 | 250 | 250 | 743 | 738 | 85 | 84 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675195
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3109105 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/19/22 09:50 | |
| Barium | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Boron | ug/L | ND | 100 | 05/19/22 09:50 | |
| Cadmium | ug/L | ND | 2.0 | 05/19/22 09:50 | |
| Calcium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Chromium | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Iron | ug/L | ND | 100 | 05/19/22 09:50 | |
| Lead | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Lithium | ug/L | ND | 20.0 | 05/19/22 09:50 | |
| Magnesium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Manganese | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Molybdenum | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Potassium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Silica | ug/L | ND | 450 | 05/19/22 09:50 | N2 |
| Sodium | ug/L | ND | 1000 | 05/19/22 09:50 | |

LABORATORY CONTROL SAMPLE: 3109106

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9890 | 99 | 80-120 | |
| Barium | ug/L | 1000 | 982 | 98 | 80-120 | |
| Boron | ug/L | 1000 | 983 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 972 | 97 | 80-120 | |
| Calcium | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 997 | 100 | 80-120 | |
| Iron | ug/L | 10000 | 9670 | 97 | 80-120 | |
| Lead | ug/L | 1000 | 954 | 95 | 80-120 | |
| Lithium | ug/L | 1000 | 1050 | 105 | 80-120 | |
| Magnesium | ug/L | 10000 | 9600 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 975 | 97 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Potassium | ug/L | 10000 | 9870 | 99 | 80-120 | |
| Silica | ug/L | 10700 | 10200 | 96 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9930 | 99 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109107 3109108

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 10000 | 101 | 100 | 75-125 | 0 | 20 | |
| Barium | ug/L | 56.0 | 1000 | 1000 | 1070 | 1060 | 101 | 101 | 75-125 | 1 | 20 | |
| Boron | ug/L | 110 | 1000 | 1000 | 1140 | 1140 | 103 | 103 | 75-125 | 0 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 99900 | 10000 | 10000 | 110000 | 112000 | 106 | 120 | 75-125 | 1 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 0 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9810 | 9760 | 98 | 98 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 956 | 956 | 96 | 96 | 75-125 | 0 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1120 | 1120 | 112 | 112 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 26000 | 10000 | 10000 | 35800 | 36100 | 98 | 101 | 75-125 | 1 | 20 | |
| Manganese | ug/L | 13.9 | 1000 | 1000 | 1000 | 1000 | 99 | 99 | 75-125 | 0 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 1050 | 1050 | 105 | 105 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 1270 | 10000 | 10000 | 11700 | 11700 | 104 | 104 | 75-125 | 0 | 20 | |
| Silica | ug/L | 12300 | 10700 | 10700 | 22900 | 23000 | 99 | 100 | 75-125 | 0 | 20 | N2 |
| Sodium | ug/L | 8210 | 10000 | 10000 | 18600 | 18600 | 104 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675145
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3108904 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/17/22 03:02 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/17/22 03:02 | |

LABORATORY CONTROL SAMPLE: 3108905

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 1000 | 100 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1040 | 104 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108906 3108907

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 14.4 | 1000 | 1000 | 1010 | 1000 | 100 | 99 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1050 | 1040 | 105 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675800
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3111670 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Arsenic | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Cobalt | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Selenium | ug/L | ND | 1.0 | 05/14/22 05:38 | |

LABORATORY CONTROL SAMPLE: 3111671

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.2 | 103 | 80-120 | |
| Arsenic | ug/L | 40 | 36.8 | 92 | 80-120 | |
| Cobalt | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 38.0 | 95 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111672 3111673

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.7 | 41.3 | 109 | 103 | 75-125 | 6 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 37.2 | 38.9 | 93 | 97 | 75-125 | 4 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 39.9 | 38.1 | 98 | 94 | 75-125 | 5 | 20 | |
| Selenium | ug/L | 1.9 | 40 | 40 | 39.0 | 41.2 | 93 | 98 | 75-125 | 5 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111684 3111685

| Parameter | Units | 50315953004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 0.090J | 40 | 40 | 43.4 | 42.2 | 108 | 105 | 75-125 | 3 | 20 | |
| Arsenic | ug/L | 0.27J | 40 | 40 | 38.6 | 38.1 | 96 | 95 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | 0.13J | 40 | 40 | 38.5 | 37.2 | 96 | 93 | 75-125 | 3 | 20 | |
| Selenium | ug/L | 0.39J | 40 | 40 | 39.6 | 39.5 | 98 | 98 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 676431 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3114685 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/16/22 18:42 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 18:42 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 18:42 | |

LABORATORY CONTROL SAMPLE: 3114686

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.2 | 98 | 90-110 | |

SAMPLE DUPLICATE: 3114688

| Parameter | Units | 50315792009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 628 | 528 | 17 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 628 | 528 | 17 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675789
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002

METHOD BLANK: 3111637 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/12/22 15:38 | |

LABORATORY CONTROL SAMPLE: 3111638

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 283 | 94 | 80-120 | |

SAMPLE DUPLICATE: 3111639

| Parameter | Units | 50315810009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 336 | 332 | 1 | 10 | |

SAMPLE DUPLICATE: 3111640

| Parameter | Units | 50315822001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 834 | 858 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675790 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3111641 Matrix: Water
Associated Lab Samples: 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/12/22 15:57 | |

LABORATORY CONTROL SAMPLE: 3111642

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 295 | 98 | 80-120 | |

SAMPLE DUPLICATE: 3111643

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 399 | 410 | 3 | 10 | |

SAMPLE DUPLICATE: 3111644

| Parameter | Units | 50315848011 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2590 | 2590 | 0 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 676299
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

SAMPLE DUPLICATE: 3114316

| Parameter | Units | 50315836001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.6 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3114317

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 674957 — Analysis Method: SM 4500-S2-D
QC Batch Method: SM 4500-S2-D — Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3108158 — Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/07/22 09:45 | |

LABORATORY CONTROL SAMPLE: 3108159

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.53 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108160 3108161

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.54 | 0.53 | 109 | 107 | 90-110 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108162 3108163

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.54 | 0.52 | 109 | 103 | 90-110 | 5 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675312 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3109491 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 15:13 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109492

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 100 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109493 3109494

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 101 | 103 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109495 3109496

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 104 | 90-110 | 1 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 674902 — Analysis Method: EPA 353.2
QC Batch Method: EPA 353.2 — Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836003, 50315836005, 50315836006

METHOD BLANK: 3107776 — Matrix: Water
Associated Lab Samples: 50315836001, 50315836003, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/06/22 17:00 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/06/22 17:00 | |

LABORATORY CONTROL SAMPLE: 3107777

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 103 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.96 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3107778 3107779

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 2.7 | 1 | 1 | 3.7 | 3.7 | 99 | 97 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.98 | 0.99 | 96 | 97 | 90-110 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3107782

| Parameter | Units | 50315836007 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 3.8 | 1 | 4.6 | 85 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.97 | 97 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 674905
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836002, 50315836004

METHOD BLANK: 3107793 Matrix: Water
Associated Lab Samples: 50315836002, 50315836004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/06/22 17:54 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/06/22 17:54 | |

LABORATORY CONTROL SAMPLE: 3107794

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 103 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3107795 3107796

| Parameter | Units | 50315822002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 100 | 90-110 | 2 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.98 | 96 | 98 | 90-110 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 3107797

| Parameter | Units | 50315857003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.67 | 1 | 1.7 | 106 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.99 | 99 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675364
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005

METHOD BLANK: 3109668 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/13/22 15:00 | |

LABORATORY CONTROL SAMPLE: 3109669

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109670 3109671

| Parameter | Units | 50315742001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 5.9 | | | 7.6 | 7.6 | | | | 0 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 675566
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836006

METHOD BLANK: 3110550 Matrix: Water
Associated Lab Samples: 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 08:33 | |

LABORATORY CONTROL SAMPLE: 3110551

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110552 3110553

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.4 | 1.4 | | | | 4 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110554 3110555

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 1.5 | | | 3.1 | 2.9 | | | | 7 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 676189 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3113658 — Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/13/22 23:42 | |

LABORATORY CONTROL SAMPLE: 3113659

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.9 | 99 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113660 3113661

| Parameter | Units | 50315748001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 0.86 | 10 | 10 | 10.8 | 10.8 | 100 | 100 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3113662

| Parameter | Units | 50315838001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.1 | 104 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 676499 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 3114861 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/17/22 14:37 | |

LABORATORY CONTROL SAMPLE: 3114862

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114863 3114864

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 10 | 10.6 | 10.8 | 103 | 105 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114865 3114866

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 11.8 | 100 | 100 | 111 | 106 | 99 | 94 | 80-120 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-106S** **Lab ID: 50315836001** Collected: 05/05/22 11:43 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0541 ± 0.281 (0.582) C:NA T:90%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.680 ± 0.379 (0.680) C:80% T:85%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.734 ± 0.660 (1.26)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-106D** **Lab ID: 50315836002** Collected: 05/05/22 12:54 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.302 ± 0.343 (0.541) C:NA T:92%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.694 ± 0.362 (0.622) C:83% T:83%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.996 ± 0.705 (1.16)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107S** **Lab ID: 50315836003** Collected: 05/05/22 10:25 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.691 ± 0.527 (0.749) C:NA T:96%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.168 ± 0.358 (0.794) C:71% T:81%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.859 ± 0.885 (1.54)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107I** **Lab ID: 50315836004** Collected: 05/05/22 13:05 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.429 ± 0.495 (0.805) C:NA T:94%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.638 ± 0.391 (0.726) C:83% T:83%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.07 ± 0.886 (1.53)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: MW-107D** **Lab ID: 50315836005** Collected: 05/05/22 11:50 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.526 ± 0.417 (0.566) C:NA T:96%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.467 ± 0.404 (0.815) C:82% T:80%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.993 ± 0.821 (1.38)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

**Sample: DUP 3** **Lab ID: 50315836006** Collected: 05/05/22 00:00 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.815 ± 0.541 (0.712) C:NA T:86%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.295 ± 0.359 (0.758) C:83% T:86%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.11 ± 0.900 (1.47)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 505239
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 2447174 Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.190 ± 0.249 (0.604) C:NA T:96% | pCi/L | 06/15/22 12:00 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

QC Batch: 505241
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

METHOD BLANK: 2447182
Matrix: Water
Associated Lab Samples: 50315836001, 50315836002, 50315836003, 50315836004, 50315836005, 50315836006

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.235 ± 0.296 (0.628) C:85% T:87% | pCi/L | 06/08/22 16:06 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315836001** | **MW-106S** | EPA 9056 | 676957 | | |
| **50315836002** | **MW-106D** | EPA 9056 | 676957 | | |
| **50315836003** | **MW-107S** | EPA 9056 | 676957 | | |
| **50315836004** | **MW-107I** | EPA 9056 | 676957 | | |
| **50315836005** | **MW-107D** | EPA 9056 | 676957 | | |
| **50315836006** | **DUP 3** | EPA 9056 | 676957 | | |
| **50315836001** | **MW-106S** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836002** | **MW-106D** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836003** | **MW-107S** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836004** | **MW-107I** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836005** | **MW-107D** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836006** | **DUP 3** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836001** | **MW-106S** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836002** | **MW-106D** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836003** | **MW-107S** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836004** | **MW-107I** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836005** | **MW-107D** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836006** | **DUP 3** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836001** | **MW-106S** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836002** | **MW-106D** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836003** | **MW-107S** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836004** | **MW-107I** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836005** | **MW-107D** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836006** | **DUP 3** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836001** | **MW-106S** | EPA 903.1 | 505239 | | |
| **50315836002** | **MW-106D** | EPA 903.1 | 505239 | | |
| **50315836003** | **MW-107S** | EPA 903.1 | 505239 | | |
| **50315836004** | **MW-107I** | EPA 903.1 | 505239 | | |
| **50315836005** | **MW-107D** | EPA 903.1 | 505239 | | |
| **50315836006** | **DUP 3** | EPA 903.1 | 505239 | | |
| **50315836001** | **MW-106S** | EPA 904.0 | 505241 | | |
| **50315836002** | **MW-106D** | EPA 904.0 | 505241 | | |
| **50315836003** | **MW-107S** | EPA 904.0 | 505241 | | |
| **50315836004** | **MW-107I** | EPA 904.0 | 505241 | | |
| **50315836005** | **MW-107D** | EPA 904.0 | 505241 | | |
| **50315836006** | **DUP 3** | EPA 904.0 | 505241 | | |
| **50315836001** | **MW-106S** | Total Radium Calculation | 512513 | | |
| **50315836002** | **MW-106D** | Total Radium Calculation | 512513 | | |
| **50315836003** | **MW-107S** | Total Radium Calculation | 512513 | | |
| **50315836004** | **MW-107I** | Total Radium Calculation | 512513 | | |
| **50315836005** | **MW-107D** | Total Radium Calculation | 512513 | | |
| **50315836006** | **DUP 3** | Total Radium Calculation | 512513 | | |
| **50315836001** | **MW-106S** | SM 2320B | 676431 | | |
| **50315836002** | **MW-106D** | SM 2320B | 676431 | | |
| **50315836003** | **MW-107S** | SM 2320B | 676431 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50315836004 | MW-107I | SM 2320B | 676431 | | |
| 50315836005 | MW-107D | SM 2320B | 676431 | | |
| 50315836006 | DUP 3 | SM 2320B | 676431 | | |
| 50315836001 | MW-106S | SM 2540C | 675789 | | |
| 50315836002 | MW-106D | SM 2540C | 675789 | | |
| 50315836003 | MW-107S | SM 2540C | 675790 | | |
| 50315836004 | MW-107I | SM 2540C | 675790 | | |
| 50315836005 | MW-107D | SM 2540C | 675790 | | |
| 50315836006 | DUP 3 | SM 2540C | 675790 | | |
| 50315836001 | MW-106S | SM 4500-H+B | 676299 | | |
| 50315836002 | MW-106D | SM 4500-H+B | 676299 | | |
| 50315836003 | MW-107S | SM 4500-H+B | 676299 | | |
| 50315836004 | MW-107I | SM 4500-H+B | 676299 | | |
| 50315836005 | MW-107D | SM 4500-H+B | 676299 | | |
| 50315836006 | DUP 3 | SM 4500-H+B | 676299 | | |
| 50315836001 | MW-106S | SM 4500-S2-D | 674957 | | |
| 50315836002 | MW-106D | SM 4500-S2-D | 674957 | | |
| 50315836003 | MW-107S | SM 4500-S2-D | 674957 | | |
| 50315836004 | MW-107I | SM 4500-S2-D | 674957 | | |
| 50315836005 | MW-107D | SM 4500-S2-D | 674957 | | |
| 50315836006 | DUP 3 | SM 4500-S2-D | 674957 | | |
| 50315836001 | MW-106S | HACH 8146 | 675312 | | |
| 50315836002 | MW-106D | HACH 8146 | 675312 | | |
| 50315836003 | MW-107S | HACH 8146 | 675312 | | |
| 50315836004 | MW-107I | HACH 8146 | 675312 | | |
| 50315836005 | MW-107D | HACH 8146 | 675312 | | |
| 50315836006 | DUP 3 | HACH 8146 | 675312 | | |
| 50315836001 | MW-106S | EPA 353.2 | 674902 | | |
| 50315836002 | MW-106D | EPA 353.2 | 674905 | | |
| 50315836003 | MW-107S | EPA 353.2 | 674902 | | |
| 50315836004 | MW-107I | EPA 353.2 | 674905 | | |
| 50315836005 | MW-107D | EPA 353.2 | 674902 | | |
| 50315836006 | DUP 3 | EPA 353.2 | 674902 | | |
| 50315836001 | MW-106S | EPA 365.1 | 675364 | EPA 365.1 | 676257 |
| 50315836002 | MW-106D | EPA 365.1 | 675364 | EPA 365.1 | 676257 |
| 50315836003 | MW-107S | EPA 365.1 | 675364 | EPA 365.1 | 676257 |
| 50315836004 | MW-107I | EPA 365.1 | 675364 | EPA 365.1 | 676257 |
| 50315836005 | MW-107D | EPA 365.1 | 675364 | EPA 365.1 | 676257 |
| 50315836006 | DUP 3 | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| 50315836001 | MW-106S | SM 5310C | 676189 | | |
| 50315836002 | MW-106D | SM 5310C | 676189 | | |
| 50315836003 | MW-107S | SM 5310C | 676189 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50315836

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315836004** | **MW-107I** | SM 5310C | 676189 | | |
| **50315836005** | **MW-107D** | SM 5310C | 676189 | | |
| **50315836006** | **DUP 3** | SM 5310C | 676189 | | |
| **50315836001** | **MW-106S** | SM 5310C | 676499 | | |
| **50315836002** | **MW-106D** | SM 5310C | 676499 | | |
| **50315836003** | **MW-107S** | SM 5310C | 676499 | | |
| **50315836004** | **MW-107I** | SM 5310C | 676499 | | |
| **50315836005** | **MW-107D** | SM 5310C | 676499 | | |
| **50315836006** | **DUP 3** | SM 5310C | 676499 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Do

WO# : 50315836

50315836

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields mus

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacela

| Section A<br>Required Client Information: | | Section B<br>Required Project Information: | | Section C<br>Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 2 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/16 |

| Regulatory Agency | |
|---|---|
| State / Location | IN |

| ITEM # | SAMPLE ID<br>One Character per box.<br>(A-Z, 0-9 / , -)<br>Sample Ids must be unique<br>MATRIX / CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | Y | | | | | | | | Y | | | | | | |
| 13 | MW-105S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 14 | MW-105I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 15 | MW-105D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 16 | MW-106S | WT | G | | | 5/5/22 | 1143 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | 001 |
| 17 | MW-106I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 18 | MW-106D | WT | G | | | 5/5/22 | 1254 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | 002 |
| 19 | MW-107S | WT | G | | | 5/5/22 | 1025 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | 003 |
| 20 | MW-107I | WT | G | | | 5/5/22 | 1305 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | 004 |
| 21 | MW-107D | WT | G | | | 5/5/22 | 1150 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | 005 |
| 22 | MW-108S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 23 | MW-108D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 24 | DUP 3 | WT | G | | | 5/5/22 | 0000 | | 11 | 3 | 3 | 4 | | 1 | | | | X | X | X | X | X | X | X | X | X | X | X | | | 006 |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / Atlas | 5/6/22 | 0945 | Pace | 5/6/22 | 945 | |
| 6020 (Co, As, Se, Sb) | Pace | 5/6/22 | 1320 | | 5/6/22 | 1320 | Seal |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | P. Greg Hopper | | | | | |
| SIGNATURE of SAMPLER: | Mark Breting / fa | DATE Signed: 5/6/22 | | | | |

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** 5/6/22 1405

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____
2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No
   **(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**
3. **Thermometer:** 1 2 3 4 5 6 A B C D E F
4. **Cooler Temperature(s):** (Initial/Corrected) RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)
5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____
6. **Ice Type:** ☑ Wet ☐ Blue ☐ None
7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
   Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** ~~HNO3 (<2)~~ ~~H2SO4 (<2)~~ NaOH (>10) ~~NaOH/ZnAc (>9)~~ Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1500 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | — |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | — |
| Custody Signatures Present? | — | | Headspace Wisconsin Sulfide? | | | — |
| Containers Intact?: | — | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS: 1.8/1.6 0.6/0.4 0.8/0.6 0.7/0.5 1.6/1.4

Samples 007-010 moved to 50317428. hrp 5/26/22

**COC PAGE** 1 **of** 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 7 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 06, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50315857001** | **MW-9I** | Water | 05/06/22 10:55 | 05/06/22 14:20 |
| **50315857002** | **MW-9D** | Water | 05/06/22 11:07 | 05/06/22 14:20 |
| **50315857003** | **MW-12S** | Water | 05/06/22 12:50 | 05/06/22 14:20 |
| **50315857004** | **MW-12D** | Water | 05/06/22 12:25 | 05/06/22 14:20 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50315857001** | **MW-9I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315857002** | **MW-9D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315857003** | **MW-12S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315857004** | **MW-12D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315857001** | **MW-9I** | | | | | |
| EPA 9056 | Chloride | 123 | mg/L | 25.0 | 05/20/22 14:06 | |
| EPA 9056 | Fluoride | 1.2 | mg/L | 0.10 | 05/20/22 13:29 | |
| EPA 9056 | Sulfate | 106 | mg/L | 2.5 | 05/20/22 13:47 | |
| EPA 6010 | Barium | 78.1 | ug/L | 10.0 | 05/19/22 10:46 | |
| EPA 6010 | Boron | 1350 | ug/L | 100 | 05/19/22 10:46 | |
| EPA 6010 | Calcium | 104000 | ug/L | 1000 | 05/19/22 10:46 | |
| EPA 6010 | Iron | 927 | ug/L | 100 | 05/19/22 10:46 | |
| EPA 6010 | Lithium | 25.6 | ug/L | 20.0 | 05/19/22 10:46 | |
| EPA 6010 | Magnesium | 27300 | ug/L | 1000 | 05/19/22 10:46 | |
| EPA 6010 | Manganese | 238 | ug/L | 10.0 | 05/19/22 10:46 | |
| EPA 6010 | Molybdenum | 111 | ug/L | 10.0 | 05/19/22 10:46 | |
| EPA 6010 | Potassium | 6100 | ug/L | 1000 | 05/19/22 10:46 | |
| EPA 6010 | Silica | 11000 | ug/L | 450 | 05/19/22 10:46 | N2 |
| EPA 6010 | Sodium | 76900 | ug/L | 1000 | 05/19/22 10:46 | |
| EPA 6010 | Manganese, Dissolved | 246 | ug/L | 10.0 | 05/17/22 03:35 | |
| EPA 6010 | Molybdenum, Dissolved | 109 | ug/L | 10.0 | 05/17/22 03:35 | |
| EPA 6020 | Arsenic | 11.3 | ug/L | 1.0 | 05/15/22 12:54 | |
| EPA 903.1 | Radium-226 | 0.328 ± 0.305 (0.402) C:NA T:101% | pCi/L | | 06/02/22 13:55 | |
| EPA 904.0 | Radium-228 | 0.783 ± 0.364 (0.586) C:76% T:89% | pCi/L | | 05/31/22 15:04 | |
| Total Radium Calculation | Total Radium | 1.11 ± 0.669 (0.988) | pCi/L | | 06/09/22 15:51 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 268 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 268 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2540C | Total Dissolved Solids | 628 | mg/L | 10.0 | 05/13/22 09:15 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/14/22 17:08 | H3 |
| HACH 8146 | Iron, Ferrous | 0.65 | mg/L | 0.20 | 05/10/22 12:23 | H3,N2 |
| SM 5310C | Dissolved Organic Carbon | 1.0 | mg/L | 1.0 | 05/17/22 18:22 | |
| **50315857002** | **MW-9D** | | | | | |
| EPA 9056 | Chloride | 127 | mg/L | 25.0 | 05/20/22 14:44 | |
| EPA 9056 | Fluoride | 0.48 | mg/L | 0.10 | 05/20/22 14:24 | |
| EPA 9056 | Sulfate | 200 | mg/L | 25.0 | 05/20/22 14:44 | |
| EPA 6010 | Barium | 56.0 | ug/L | 10.0 | 05/19/22 10:52 | |
| EPA 6010 | Boron | 1260 | ug/L | 100 | 05/19/22 10:52 | |
| EPA 6010 | Calcium | 134000 | ug/L | 1000 | 05/19/22 10:52 | |
| EPA 6010 | Iron | 1900 | ug/L | 100 | 05/19/22 10:52 | |
| EPA 6010 | Lithium | 22.6 | ug/L | 20.0 | 05/19/22 10:52 | |
| EPA 6010 | Magnesium | 35700 | ug/L | 1000 | 05/19/22 10:52 | |
| EPA 6010 | Manganese | 283 | ug/L | 10.0 | 05/19/22 10:52 | |
| EPA 6010 | Molybdenum | 47.5 | ug/L | 10.0 | 05/19/22 10:52 | |
| EPA 6010 | Potassium | 6200 | ug/L | 1000 | 05/19/22 10:52 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315857002** | **MW-9D** | | | | | |
| EPA 6010 | Silica | 11800 | ug/L | 450 | 05/19/22 10:52 | N2 |
| EPA 6010 | Sodium | 77900 | ug/L | 1000 | 05/19/22 10:52 | |
| EPA 6010 | Manganese, Dissolved | 278 | ug/L | 10.0 | 05/17/22 03:37 | |
| EPA 6010 | Molybdenum, Dissolved | 47.5 | ug/L | 10.0 | 05/17/22 03:37 | |
| EPA 6020 | Arsenic | 21.3 | ug/L | 1.0 | 05/15/22 13:06 | |
| EPA 903.1 | Radium-226 | 0.229 ± 0.356 (0.617) C:NA T:95% | pCi/L | | 06/02/22 13:55 | |
| EPA 904.0 | Radium-228 | 0.302 ± 0.278 (0.560) C:80% T:94% | pCi/L | | 05/31/22 15:04 | |
| Total Radium Calculation | Total Radium | 0.531 ± 0.634 (1.18) | pCi/L | | 06/09/22 15:51 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 262 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 262 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2540C | Total Dissolved Solids | 724 | mg/L | 20.0 | 05/13/22 09:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/14/22 17:09 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.67 | mg/L | 0.10 | 05/06/22 18:24 | |
| SM 5310C | Dissolved Organic Carbon | 2.3 | mg/L | 1.0 | 05/17/22 18:34 | |
| **50315857003** | **MW-12S** | | | | | |
| EPA 9056 | Chloride | 174 | mg/L | 25.0 | 05/20/22 15:19 | |
| EPA 9056 | Fluoride | 2.1 | mg/L | 0.10 | 05/20/22 15:01 | |
| EPA 9056 | Sulfate | 425 | mg/L | 25.0 | 05/20/22 15:19 | |
| EPA 6010 | Barium | 31.1 | ug/L | 10.0 | 05/19/22 10:54 | |
| EPA 6010 | Boron | 3240 | ug/L | 100 | 05/19/22 10:54 | |
| EPA 6010 | Calcium | 178000 | ug/L | 1000 | 05/19/22 10:54 | |
| EPA 6010 | Lithium | 67.8 | ug/L | 20.0 | 05/19/22 10:54 | |
| EPA 6010 | Magnesium | 50600 | ug/L | 1000 | 05/19/22 10:54 | |
| EPA 6010 | Manganese | 523 | ug/L | 10.0 | 05/19/22 10:54 | |
| EPA 6010 | Molybdenum | 118 | ug/L | 10.0 | 05/19/22 10:54 | |
| EPA 6010 | Potassium | 8480 | ug/L | 1000 | 05/19/22 10:54 | |
| EPA 6010 | Silica | 16000 | ug/L | 450 | 05/19/22 10:54 | N2 |
| EPA 6010 | Sodium | 155000 | ug/L | 1000 | 05/19/22 10:54 | |
| EPA 6010 | Manganese, Dissolved | 536 | ug/L | 10.0 | 05/17/22 03:39 | |
| EPA 6010 | Molybdenum, Dissolved | 120 | ug/L | 10.0 | 05/17/22 03:39 | |
| EPA 6020 | Antimony | 2.0 | ug/L | 1.0 | 05/13/22 14:17 | |
| EPA 6020 | Arsenic | 46.0 | ug/L | 1.0 | 05/15/22 13:10 | |
| EPA 6020 | Selenium | 26.3 | ug/L | 1.0 | 05/15/22 13:10 | |
| EPA 903.1 | Radium-226 | 0.0640 ± 0.517 (1.02) C:NA T:89% | pCi/L | | 06/02/22 13:55 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315857003** | **MW-12S** | | | | | |
| EPA 904.0 | Radium-228 | 0.671 ± 0.366 (0.653) C:77% T:93% | pCi/L | | 05/31/22 15:04 | |
| Total Radium Calculation | Total Radium | 0.735 ± 0.883 (1.67) | pCi/L | | 06/09/22 15:51 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 344 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 344 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2540C | Total Dissolved Solids | 1240 | mg/L | 20.0 | 05/13/22 09:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/14/22 17:09 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.67 | mg/L | 0.10 | 05/06/22 18:31 | |
| SM 5310C | Total Organic Carbon | 1.9 | mg/L | 1.0 | 05/14/22 17:14 | |
| SM 5310C | Dissolved Organic Carbon | 3.4 | mg/L | 1.0 | 05/17/22 18:47 | |
| **50315857004** | **MW-12D** | | | | | |
| EPA 9056 | Chloride | 161 | mg/L | 25.0 | 05/20/22 13:07 | |
| EPA 9056 | Fluoride | 1.9 | mg/L | 0.10 | 05/20/22 12:30 | |
| EPA 9056 | Sulfate | 551 | mg/L | 25.0 | 05/20/22 13:07 | |
| EPA 6010 | Barium | 26.7 | ug/L | 10.0 | 05/19/22 10:56 | |
| EPA 6010 | Boron | 6050 | ug/L | 100 | 05/19/22 10:56 | |
| EPA 6010 | Calcium | 214000 | ug/L | 2000 | 05/19/22 15:41 | |
| EPA 6010 | Iron | 1950 | ug/L | 100 | 05/19/22 10:56 | |
| EPA 6010 | Lithium | 74.8 | ug/L | 20.0 | 05/19/22 10:56 | |
| EPA 6010 | Magnesium | 49800 | ug/L | 1000 | 05/19/22 10:56 | |
| EPA 6010 | Manganese | 450 | ug/L | 10.0 | 05/19/22 10:56 | |
| EPA 6010 | Molybdenum | 154 | ug/L | 10.0 | 05/19/22 10:56 | |
| EPA 6010 | Potassium | 11700 | ug/L | 1000 | 05/19/22 10:56 | |
| EPA 6010 | Silica | 14700 | ug/L | 450 | 05/19/22 10:56 | N2 |
| EPA 6010 | Sodium | 145000 | ug/L | 1000 | 05/19/22 10:56 | |
| EPA 6010 | Manganese, Dissolved | 462 | ug/L | 10.0 | 05/17/22 03:42 | |
| EPA 6010 | Molybdenum, Dissolved | 151 | ug/L | 10.0 | 05/17/22 03:42 | |
| EPA 6020 | Arsenic | 387 | ug/L | 5.0 | 05/15/22 13:15 | |
| EPA 903.1 | Radium-226 | 0.567 ± 0.327 (0.128) C:NA T:100% | pCi/L | | 06/02/22 13:55 | |
| EPA 904.0 | Radium-228 | 0.823 ± 0.401 (0.691) C:75% T:95% | pCi/L | | 05/31/22 15:04 | |
| Total Radium Calculation | Total Radium | 1.39 ± 0.728 (0.819) | pCi/L | | 06/09/22 15:51 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 295 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 295 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2540C | Total Dissolved Solids | 1380 | mg/L | 20.0 | 05/13/22 09:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/14/22 17:09 | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315857004** | **MW-12D** | | | | | |
| EPA 365.1 | Phosphate as P04 | 0.36 | mg/L | 0.15 | 05/14/22 08:44 | |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 05/14/22 17:26 | |
| SM 5310C | Dissolved Organic Carbon | 1.3 | mg/L | 1.0 | 05/17/22 18:59 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-9I** **Lab ID: 50315857001** Collected: 05/06/22 10:55 Received: 05/06/22 14:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **123** | mg/L | 25.0 | 100 | | 05/20/22 14:06 | 16887-00-6 | |
| Fluoride | **1.2** | mg/L | 0.10 | 1 | | 05/20/22 13:29 | 16984-48-8 | |
| Sulfate | **106** | mg/L | 2.5 | 10 | | 05/20/22 13:47 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7429-90-5 | |
| Barium | **78.1** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-39-3 | |
| Boron | **1350** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-43-9 | |
| Calcium | **104000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-47-3 | |
| Iron | **927** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7439-92-1 | |
| Lithium | **25.6** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7439-93-2 | |
| Magnesium | **27300** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7439-95-4 | |
| Manganese | **238** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7439-96-5 | |
| Molybdenum | **111** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7439-98-7 | |
| Potassium | **6100** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-09-7 | |
| Silica | **11000** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7631-86-9 | N2 |
| Sodium | **76900** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:46 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **246** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:35 | 7439-96-5 | |
| Molybdenum, Dissolved | **109** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:35 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:00 | 7440-36-0 | |
| Arsenic | **11.3** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 12:54 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/13/22 14:00 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:00 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 12:54 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:00 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/11/22 18:11 | 05/12/22 13:05 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **268** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Bicarbonate (CaCO3) | **268** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-9I** **Lab ID: 50315857001** Collected: 05/06/22 10:55 Received: 05/06/22 14:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **628** | mg/L | 10.0 | 1 | | 05/13/22 09:15 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/14/22 17:08 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | **0.65** | mg/L | 0.20 | 1 | | 05/10/22 12:23 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 18:22 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 18:22 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:42 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/14/22 16:50 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.0** | mg/L | 1.0 | 1 | | 05/17/22 18:22 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-9D** **Lab ID: 50315857002** Collected: 05/06/22 11:07 Received: 05/06/22 14:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **127** | mg/L | 25.0 | 100 | | 05/20/22 14:44 | 16887-00-6 | |
| Fluoride | **0.48** | mg/L | 0.10 | 1 | | 05/20/22 14:24 | 16984-48-8 | |
| Sulfate | **200** | mg/L | 25.0 | 100 | | 05/20/22 14:44 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7429-90-5 | |
| Barium | **56.0** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-39-3 | |
| Boron | **1260** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-43-9 | |
| Calcium | **134000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-47-3 | |
| Iron | **1900** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7439-92-1 | |
| Lithium | **22.6** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7439-93-2 | |
| Magnesium | **35700** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7439-95-4 | |
| Manganese | **283** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7439-96-5 | |
| Molybdenum | **47.5** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7439-98-7 | |
| Potassium | **6200** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-09-7 | |
| Silica | **11800** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7631-86-9 | N2 |
| Sodium | **77900** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:52 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **278** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:37 | 7439-96-5 | |
| Molybdenum, Dissolved | **47.5** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:37 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:04 | 7440-36-0 | |
| Arsenic | **21.3** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 13:06 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/13/22 14:04 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:04 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 13:06 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:04 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/11/22 18:11 | 05/12/22 13:08 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **262** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Bicarbonate (CaCO3) | **262** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-9D** **Lab ID: 50315857002** Collected: 05/06/22 11:07 Received: 05/06/22 14:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **724** | mg/L | 20.0 | 1 | | 05/13/22 09:16 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/14/22 17:09 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 12:23 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.67** | mg/L | 0.10 | 1 | | 05/06/22 18:24 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 18:24 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:43 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/14/22 17:01 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 05/17/22 18:34 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-12S** **Lab ID: 50315857003** Collected: 05/06/22 12:50 Received: 05/06/22 14:20 Matrix: Water

Comments: • Upon receipt at the laboratory, 2.5 mls of nitric acid were added to the sample to meet the sample preservation requirement of pH <2 for radiochemistry analysis for one container.

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **174** | mg/L | 25.0 | 100 | | 05/20/22 15:19 | 16887-00-6 | |
| Fluoride | **2.1** | mg/L | 0.10 | 1 | | 05/20/22 15:01 | 16984-48-8 | |
| Sulfate | **425** | mg/L | 25.0 | 100 | | 05/20/22 15:19 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7429-90-5 | |
| Barium | **31.1** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-39-3 | |
| Boron | **3240** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-43-9 | |
| Calcium | **178000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7439-92-1 | |
| Lithium | **67.8** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7439-93-2 | |
| Magnesium | **50600** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7439-95-4 | |
| Manganese | **523** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7439-96-5 | |
| Molybdenum | **118** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7439-98-7 | |
| Potassium | **8480** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-09-7 | |
| Silica | **16000** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7631-86-9 | N2 |
| Sodium | **155000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:54 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **536** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:39 | 7439-96-5 | |
| Molybdenum, Dissolved | **120** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:39 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | **2.0** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:17 | 7440-36-0 | |
| Arsenic | **46.0** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 13:10 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/13/22 14:17 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:17 | 7440-48-4 | |
| Selenium | **26.3** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 13:10 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:17 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/11/22 18:11 | 05/12/22 13:10 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **344** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-12S** **Lab ID: 50315857003** Collected: 05/06/22 12:50 Received: 05/06/22 14:20 Matrix: Water

Comments: • Upon receipt at the laboratory, 2.5 mls of nitric acid were added to the sample to meet the sample preservation requirement of pH <2 for radiochemistry analysis for one container.

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity,Bicarbonate (CaCO3) | **344** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1240** | mg/L | 20.0 | 1 | | 05/13/22 09:16 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/14/22 17:09 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 12:23 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.67** | mg/L | 0.10 | 1 | | 05/06/22 18:31 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 18:31 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:43 | | |
| **5310C TOC** | Analytical Method: SM 5310C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 05/14/22 17:14 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.4** | mg/L | 1.0 | 1 | | 05/17/22 18:47 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-12D** **Lab ID: 50315857004** Collected: 05/06/22 12:25 Received: 05/06/22 14:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **161** | mg/L | 25.0 | 100 | | 05/20/22 13:07 | 16887-00-6 | |
| Fluoride | **1.9** | mg/L | 0.10 | 1 | | 05/20/22 12:30 | 16984-48-8 | |
| Sulfate | **551** | mg/L | 25.0 | 100 | | 05/20/22 13:07 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7429-90-5 | |
| Barium | **26.7** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7440-39-3 | |
| Boron | **6050** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7440-43-9 | |
| Calcium | **214000** | ug/L | 2000 | 2 | 05/14/22 14:28 | 05/19/22 15:41 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7440-47-3 | |
| Iron | **1950** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7439-92-1 | |
| Lithium | **74.8** | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7439-93-2 | |
| Magnesium | **49800** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7439-95-4 | |
| Manganese | **450** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7439-96-5 | |
| Molybdenum | **154** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7439-98-7 | |
| Potassium | **11700** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7440-09-7 | |
| Silica | **14700** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7631-86-9 | N2 |
| Sodium | **145000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:56 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **462** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:42 | 7439-96-5 | |
| Molybdenum, Dissolved | **151** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:42 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:21 | 7440-36-0 | |
| Arsenic | **387** | ug/L | 5.0 | 5 | 05/12/22 14:20 | 05/15/22 13:15 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/13/22 14:21 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:21 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/15/22 13:19 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/13/22 14:21 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/11/22 18:11 | 05/12/22 13:13 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **295** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Bicarbonate (CaCO3) | **295** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-12D** **Lab ID: 50315857004** Collected: 05/06/22 12:25 Received: 05/06/22 14:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1380** | mg/L | 20.0 | 1 | | 05/13/22 09:16 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/14/22 17:09 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 12:23 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/06/22 18:29 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 18:29 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.36** | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:44 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/14/22 17:26 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/17/22 18:59 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 676962
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3116809 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/20/22 12:15 | |
| Fluoride | mg/L | ND | 0.10 | 05/20/22 12:15 | |
| Sulfate | mg/L | ND | 0.25 | 05/20/22 12:15 | |

LABORATORY CONTROL SAMPLE: 3116810

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 90 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 97 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116811 3116812

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 15.8 | 12.5 | 12.5 | 27.4 | 27.4 | 93 | 93 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.12 | 0.5 | 0.5 | 0.50 | 0.49 | 74 | 73 | 80-120 | 1 | 15 | M0 |
| Sulfate | mg/L | 49.0 | 25 | 25 | 77.4 | 72.9 | 113 | 95 | 80-120 | 6 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116813 3116814

| Parameter | Units | 50315985002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 50.3 | 12.5 | 12.5 | 63.0 | 64.1 | 102 | 110 | 80-120 | 2 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.41 | 0.41 | 75 | 77 | 80-120 | 2 | 15 | M0 |
| Sulfate | mg/L | 1620 | 250 | 250 | 1780 | 1800 | 64 | 70 | 80-120 | 1 | 15 | M0 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116815 3116816

| Parameter | Units | 50315986002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 60.8 | 12.5 | 12.5 | 71.9 | 72.1 | 89 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.39 | 0.40 | 76 | 78 | 80-120 | 2 | 15 | M0 |
| Sulfate | mg/L | 1530 | 250 | 250 | 1770 | 1750 | 96 | 86 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 675412 | Analysis Method: EPA 7470
QC Batch Method: EPA 7470 | Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3109872 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/12/22 12:00 | |

LABORATORY CONTROL SAMPLE: 3109873

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 5.2 | 104 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109874 3109875

| Parameter | Units | 50315315003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 3.9 | 4.9 | 77 | 97 | 75-125 | 22 | 20 | R1 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109876 3109877

| Parameter | Units | 50315810005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 4.5 | 4.7 | 89 | 93 | 75-125 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 675195
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3109105 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/19/22 09:50 | |
| Barium | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Boron | ug/L | ND | 100 | 05/19/22 09:50 | |
| Cadmium | ug/L | ND | 2.0 | 05/19/22 09:50 | |
| Calcium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Chromium | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Iron | ug/L | ND | 100 | 05/19/22 09:50 | |
| Lead | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Lithium | ug/L | ND | 20.0 | 05/19/22 09:50 | |
| Magnesium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Manganese | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Molybdenum | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Potassium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Silica | ug/L | ND | 450 | 05/19/22 09:50 | N2 |
| Sodium | ug/L | ND | 1000 | 05/19/22 09:50 | |

LABORATORY CONTROL SAMPLE: 3109106

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9890 | 99 | 80-120 | |
| Barium | ug/L | 1000 | 982 | 98 | 80-120 | |
| Boron | ug/L | 1000 | 983 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 972 | 97 | 80-120 | |
| Calcium | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 997 | 100 | 80-120 | |
| Iron | ug/L | 10000 | 9670 | 97 | 80-120 | |
| Lead | ug/L | 1000 | 954 | 95 | 80-120 | |
| Lithium | ug/L | 1000 | 1050 | 105 | 80-120 | |
| Magnesium | ug/L | 10000 | 9600 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 975 | 97 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Potassium | ug/L | 10000 | 9870 | 99 | 80-120 | |
| Silica | ug/L | 10700 | 10200 | 96 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9930 | 99 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109107 3109108

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 10000 | 101 | 100 | 75-125 | 0 | 20 | |
| Barium | ug/L | 56.0 | 1000 | 1000 | 1070 | 1060 | 101 | 101 | 75-125 | 1 | 20 | |
| Boron | ug/L | 110 | 1000 | 1000 | 1140 | 1140 | 103 | 103 | 75-125 | 0 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 99900 | 10000 | 10000 | 110000 | 112000 | 106 | 120 | 75-125 | 1 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 0 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9810 | 9760 | 98 | 98 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 956 | 956 | 96 | 96 | 75-125 | 0 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1120 | 1120 | 112 | 112 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 26000 | 10000 | 10000 | 35800 | 36100 | 98 | 101 | 75-125 | 1 | 20 | |
| Manganese | ug/L | 13.9 | 1000 | 1000 | 1000 | 1000 | 99 | 99 | 75-125 | 0 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 1050 | 1050 | 105 | 105 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 1270 | 10000 | 10000 | 11700 | 11700 | 104 | 104 | 75-125 | 0 | 20 | |
| Silica | ug/L | 12300 | 10700 | 10700 | 22900 | 23000 | 99 | 100 | 75-125 | 0 | 20 | N2 |
| Sodium | ug/L | 8210 | 10000 | 10000 | 18600 | 18600 | 104 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 675145
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3108904 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/17/22 03:02 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/17/22 03:02 | |

LABORATORY CONTROL SAMPLE: 3108905

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 1000 | 100 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1040 | 104 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108906 3108907

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 14.4 | 1000 | 1000 | 1010 | 1000 | 100 | 99 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1050 | 1040 | 105 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 675803
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3111682 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/13/22 12:54 | |
| Arsenic | ug/L | ND | 1.0 | 05/13/22 12:54 | |
| Beryllium | ug/L | ND | 0.20 | 05/13/22 12:54 | |
| Cobalt | ug/L | ND | 1.0 | 05/13/22 12:54 | |
| Selenium | ug/L | ND | 1.0 | 05/13/22 12:54 | |
| Thallium | ug/L | ND | 1.0 | 05/13/22 12:54 | |

LABORATORY CONTROL SAMPLE: 3111683

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 43.1 | 108 | 80-120 | |
| Arsenic | ug/L | 40 | 40.7 | 102 | 80-120 | |
| Beryllium | ug/L | 40 | 42.1 | 105 | 80-120 | |
| Cobalt | ug/L | 40 | 40.7 | 102 | 80-120 | |
| Selenium | ug/L | 40 | 40.1 | 100 | 80-120 | |
| Thallium | ug/L | 40 | 40.2 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111674 3111675

| Parameter | Units | 50315984002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 44.0 | 43.8 | 109 | 109 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | 16.9 | 40 | 40 | 55.9 | 55.1 | 97 | 95 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 43.9 | 43.6 | 110 | 109 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | 2.4 | 40 | 40 | 40.3 | 40.2 | 95 | 94 | 75-125 | 0 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 45.3 | 43.2 | 111 | 106 | 75-125 | 5 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 40.7 | 40.4 | 102 | 101 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111686 3111687

| Parameter | Units | 50315985002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 44.0 | 43.8 | 109 | 109 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | 16.9 | 40 | 40 | 55.9 | 55.1 | 97 | 95 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 43.9 | 43.6 | 110 | 109 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | 2.4 | 40 | 40 | 40.3 | 40.2 | 95 | 94 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111686 3111687

| Parameter | Units | 50315985002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Selenium | ug/L | ND | 40 | 40 | 45.3 | 43.2 | 111 | 106 | 75-125 | 5 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 40.7 | 40.4 | 102 | 101 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 676456 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3114738 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/16/22 17:27 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 17:27 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 17:27 | |

LABORATORY CONTROL SAMPLE: 3114739

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.8 | 100 | 90-110 | |

SAMPLE DUPLICATE: 3114740

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 301 | 310 | 3 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 301 | 310 | 3 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3114741

| Parameter | Units | 50315769003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 289 | 297 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 289 | 297 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 676063 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3112901 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/13/22 09:13 | |

LABORATORY CONTROL SAMPLE: 3112902

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 290 | 97 | 80-120 | |

SAMPLE DUPLICATE: 3112903

| Parameter | Units | 50315848017 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1560 | 1460 | 6 | 10 | |

SAMPLE DUPLICATE: 3112904

| Parameter | Units | 50315883004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 614 | 636 | 4 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 676299
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

SAMPLE DUPLICATE: 3114316

| Parameter | Units | 50315836001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.6 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3114317

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 674957
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3108158 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/07/22 09:45 | |

LABORATORY CONTROL SAMPLE: 3108159

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.53 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108160 3108161

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.54 | 0.53 | 109 | 107 | 90-110 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108162 3108163

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.54 | 0.52 | 109 | 103 | 90-110 | 5 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 675307 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3109472 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 12:19 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109473

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 0.96 | 96 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109474 3109475

| Parameter | Units | 50315476002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 0.59 | 1 | 1 | 1.6 | 1.5 | 101 | 96 | 90-110 | 4 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3109476

| Parameter | Units | 50315596001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 0.93 | 93 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 674905
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3107793 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/06/22 17:54 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/06/22 17:54 | |

LABORATORY CONTROL SAMPLE: 3107794

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 103 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3107795 3107796

| Parameter | Units | 50315822002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 100 | 90-110 | 2 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.98 | 96 | 98 | 90-110 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 3107797

| Parameter | Units | 50315857003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.67 | 1 | 1.7 | 106 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.99 | 99 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 675566
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3110550 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 08:33 | |

LABORATORY CONTROL SAMPLE: 3110551

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110552 3110553

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.4 | 1.4 | | | | 4 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110554 3110555

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 1.5 | | | 3.1 | 2.9 | | | | 7 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 676192 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3113670 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/14/22 15:48 | |

LABORATORY CONTROL SAMPLE: 3113671

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113672 3113673

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 10.1 | 9.7 | 97 | 93 | 80-120 | 3 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113674 3113675

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 11.2 | 20 | 20 | 30.3 | 28.8 | 95 | 88 | 80-120 | 5 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 676499 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 3114861 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/17/22 14:37 | |

LABORATORY CONTROL SAMPLE: 3114862

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114863 3114864

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 10 | 10.6 | 10.8 | 103 | 105 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114865 3114866

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 11.8 | 100 | 100 | 111 | 106 | 99 | 94 | 80-120 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-9I** **Lab ID: 50315857001** Collected: 05/06/22 10:55 Received: 05/06/22 14:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.328 ± 0.305 (0.402) C:NA T:101%** | pCi/L | 06/02/22 13:55 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.783 ± 0.364 (0.586) C:76% T:89%** | pCi/L | 05/31/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.11 ± 0.669 (0.988)** | pCi/L | 06/09/22 15:51 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-9D** **Lab ID: 50315857002** Collected: 05/06/22 11:07 Received: 05/06/22 14:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.229 ± 0.356 (0.617) C:NA T:95%** | pCi/L | 06/02/22 13:55 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.302 ± 0.278 (0.560) C:80% T:94%** | pCi/L | 05/31/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.531 ± 0.634 (1.18)** | pCi/L | 06/09/22 15:51 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-12S** **Lab ID: 50315857003** Collected: 05/06/22 12:50 Received: 05/06/22 14:20 Matrix: Water
PWS: Site ID: Sample Type:

Comments: • Upon receipt at the laboratory, 2.5 mls of nitric acid were added to the sample to meet the sample preservation requirement of pH <2 for radiochemistry analysis for one container.

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0640 ± 0.517 (1.02) C:NA T:89%** | pCi/L | 06/02/22 13:55 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.671 ± 0.366 (0.653) C:77% T:93%** | pCi/L | 05/31/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.735 ± 0.883 (1.67)** | pCi/L | 06/09/22 15:51 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

**Sample: MW-12D** **Lab ID: 50315857004** Collected: 05/06/22 12:25 Received: 05/06/22 14:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.567 ± 0.327 (0.128) C:NA T:100%** | pCi/L | 06/02/22 13:55 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.823 ± 0.401 (0.691) C:75% T:95%** | pCi/L | 05/31/22 15:04 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.39 ± 0.728 (0.819)** | pCi/L | 06/09/22 15:51 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 503410
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 2437473 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.780 ± 0.313 (0.462) C:85% T:93% | pCi/L | 05/31/22 11:54 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

QC Batch: 503409
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

METHOD BLANK: 2437472 Matrix: Water
Associated Lab Samples: 50315857001, 50315857002, 50315857003, 50315857004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0395 ± 0.232 (0.517) C:NA T:96% | pCi/L | 06/02/22 13:31 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| R1 | RPD value was outside control limits. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315857001** | **MW-9I** | EPA 9056 | 676962 | | |
| **50315857002** | **MW-9D** | EPA 9056 | 676962 | | |
| **50315857003** | **MW-12S** | EPA 9056 | 676962 | | |
| **50315857004** | **MW-12D** | EPA 9056 | 676962 | | |
| **50315857001** | **MW-9I** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315857002** | **MW-9D** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315857003** | **MW-12S** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315857004** | **MW-12D** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315857001** | **MW-9I** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315857002** | **MW-9D** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315857003** | **MW-12S** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315857004** | **MW-12D** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315857001** | **MW-9I** | EPA 200.2 | 675803 | EPA 6020 | 676025 |
| **50315857002** | **MW-9D** | EPA 200.2 | 675803 | EPA 6020 | 676025 |
| **50315857003** | **MW-12S** | EPA 200.2 | 675803 | EPA 6020 | 676025 |
| **50315857004** | **MW-12D** | EPA 200.2 | 675803 | EPA 6020 | 676025 |
| **50315857001** | **MW-9I** | EPA 7470 | 675412 | EPA 7470 | 675770 |
| **50315857002** | **MW-9D** | EPA 7470 | 675412 | EPA 7470 | 675770 |
| **50315857003** | **MW-12S** | EPA 7470 | 675412 | EPA 7470 | 675770 |
| **50315857004** | **MW-12D** | EPA 7470 | 675412 | EPA 7470 | 675770 |
| **50315857001** | **MW-9I** | EPA 903.1 | 503409 | | |
| **50315857002** | **MW-9D** | EPA 903.1 | 503409 | | |
| **50315857003** | **MW-12S** | EPA 903.1 | 503409 | | |
| **50315857004** | **MW-12D** | EPA 903.1 | 503409 | | |
| **50315857001** | **MW-9I** | EPA 904.0 | 503410 | | |
| **50315857002** | **MW-9D** | EPA 904.0 | 503410 | | |
| **50315857003** | **MW-12S** | EPA 904.0 | 503410 | | |
| **50315857004** | **MW-12D** | EPA 904.0 | 503410 | | |
| **50315857001** | **MW-9I** | Total Radium Calculation | 510610 | | |
| **50315857002** | **MW-9D** | Total Radium Calculation | 510610 | | |
| **50315857003** | **MW-12S** | Total Radium Calculation | 510610 | | |
| **50315857004** | **MW-12D** | Total Radium Calculation | 510610 | | |
| **50315857001** | **MW-9I** | SM 2320B | 676456 | | |
| **50315857002** | **MW-9D** | SM 2320B | 676456 | | |
| **50315857003** | **MW-12S** | SM 2320B | 676456 | | |
| **50315857004** | **MW-12D** | SM 2320B | 676456 | | |
| **50315857001** | **MW-9I** | SM 2540C | 676063 | | |
| **50315857002** | **MW-9D** | SM 2540C | 676063 | | |
| **50315857003** | **MW-12S** | SM 2540C | 676063 | | |
| **50315857004** | **MW-12D** | SM 2540C | 676063 | | |
| **50315857001** | **MW-9I** | SM 4500-H+B | 676299 | | |
| **50315857002** | **MW-9D** | SM 4500-H+B | 676299 | | |
| **50315857003** | **MW-12S** | SM 4500-H+B | 676299 | | |
| **50315857004** | **MW-12D** | SM 4500-H+B | 676299 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50315857

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315857001** | **MW-9I** | SM 4500-S2-D | 674957 | | |
| **50315857002** | **MW-9D** | SM 4500-S2-D | 674957 | | |
| **50315857003** | **MW-12S** | SM 4500-S2-D | 674957 | | |
| **50315857004** | **MW-12D** | SM 4500-S2-D | 674957 | | |
| **50315857001** | **MW-9I** | HACH 8146 | 675307 | | |
| **50315857002** | **MW-9D** | HACH 8146 | 675307 | | |
| **50315857003** | **MW-12S** | HACH 8146 | 675307 | | |
| **50315857004** | **MW-12D** | HACH 8146 | 675307 | | |
| **50315857001** | **MW-9I** | EPA 353.2 | 674905 | | |
| **50315857002** | **MW-9D** | EPA 353.2 | 674905 | | |
| **50315857003** | **MW-12S** | EPA 353.2 | 674905 | | |
| **50315857004** | **MW-12D** | EPA 353.2 | 674905 | | |
| **50315857001** | **MW-9I** | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| **50315857002** | **MW-9D** | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| **50315857003** | **MW-12S** | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| **50315857004** | **MW-12D** | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| **50315857001** | **MW-9I** | SM 5310C | 676192 | | |
| **50315857002** | **MW-9D** | SM 5310C | 676192 | | |
| **50315857003** | **MW-12S** | SM 5310C | 676192 | | |
| **50315857004** | **MW-12D** | SM 5310C | 676192 | | |
| **50315857001** | **MW-9I** | SM 5310C | 676499 | | |
| **50315857002** | **MW-9D** | SM 5310C | 676499 | | |
| **50315857003** | **MW-12S** | SM 5310C | 676499 | | |
| **50315857004** | **MW-12D** | SM 5310C | 676499 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

5031585 7



**Section A**
**Required Client Information:**

| | |
|---|---|
| Company: | Atlas Indianapolis |
| Address: | 7988 Centerpoint Drive Suite 100 |
| | Indianapolis, IN 46256 |
| Email: | mark.breting@oneatlas.com |
| Phone: | (317)579-4082 Fax: |
| Requested Due Date: | |

**Section B**
**Required Project Information:**

| | |
|---|---|
| Report To: | Mark Breting |
| Copy To: | |
| Purchase Order #: | |
| Project Name: | Harding St Profile 1 Report 1 |
| Project #: | |

**Section C**
**Invoice Information:**

| | |
|---|---|
| Attention: | Accounts Payable - Paula Sedam |
| Company Name: | Atlas Indianapolis |
| Address: | |
| Pace Quote: | |
| Pace Project Manager: | Hayden Putt |
| Pace Profile #: | 10498/15 |

**Regulatory Agency**

**State / Location**
IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Requested Analysis Filtered (Y/N) Y/N | Analyses Test: TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | |
| 13 | ~~MW-9S~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 14 | MW-9I | WT | G | 5/6 | 1055 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | -001 |
| 15 | MW-9D | WT | G | 5/6 | 1107 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | -002 |
| 16 | ~~MW-10S~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 17 | ~~MW-10D~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 18 | ~~MW-11D~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 19 | MW-12S | WT | G | 5/6 | 1250 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | -003 |
| 20 | ~~MW-11S~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 21 | MW-12D | WT | G | 5/6 | 1225 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | -004 |
| 22 | ~~MW-13S~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 23 | ~~MW-13D~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |
| 24 | ~~MW-14D~~ | WT | | | | | | | ~~11~~ | ~~3~~ | ~~3~~ | ~~4~~ | | ~~1~~ | | | | | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | ~~X~~ | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | P. Greg Hopper | 5/6/22 | 1420 | | 5/6/22 | 1420 | 1.6 | Y | 3 | Y |
| Tl) 7470 Hg | | | | | | | 2.2 | | | |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: P. Greg Hopper

SIGNATURE of SAMPLER: P. Greg Hopper

DATE Signed: 5/6/22

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** MN 5/6/22 1530

1. **Courier:** ☐ FED EX ☐ UPS ☑ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** (Initial/Corrected) RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

| | | | |
|---|---|---|---|
| 1.8/1.6 | 2.4/2.2 | | |

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | – |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | – | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1550 | |
| **Rush TAT Requested (4 days or less):** | | – |
| Custody Signatures Present? | – | |
| Containers Intact?: | – | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** ~~HNO3 (<2)~~ ~~H2SO4 (<2)~~ NaOH (>10) ~~NaOH/ZnAc (>9)~~ Any non-conformance to pH recommendations will be noted on the container count form | – | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | – |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | – |
| Headspace Wisconsin Sulfide? | | | – |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | – |
| Trip Blank Present? | | – | |
| Trip Blank Custody Seals?: | | – | |

COMMENTS:

**COC PAGE ____ of ____**

## Sample Container Count

SBS / DI / MeOH (only) / BK / Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S ✓ | AG3SF ✓ | AG3C | BP1U | BP1N | BP2U ✓ | BP3U ✓ | BP3N ✓ | BP3F ✓ | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | ✓ | ✓ | |
| 3 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | ✓ | ✓ | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | ✓ | ✓ | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | | ✓ | ✓ | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 10, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316084001** | **MW-1S** | Water | 05/09/22 16:11 | 05/10/22 14:25 |
| **50316084002** | **MW-1D** | Water | 05/09/22 15:04 | 05/10/22 14:25 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316084001** | **MW-1S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316084002** | **MW-1D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316084001** | **MW-1S** | | | | | |
| EPA 9056 | Chloride | 124 | mg/L | 2.5 | 05/21/22 16:27 | |
| EPA 9056 | Fluoride | 0.41 | mg/L | 0.10 | 05/21/22 16:08 | |
| EPA 9056 | Sulfate | 56.1 | mg/L | 2.5 | 05/21/22 16:27 | |
| EPA 6010 | Barium | 69.9 | ug/L | 10.0 | 05/21/22 13:17 | |
| EPA 6010 | Boron | 375 | ug/L | 100 | 05/21/22 13:17 | |
| EPA 6010 | Calcium | 92200 | ug/L | 1000 | 05/21/22 13:17 | |
| EPA 6010 | Iron | 3380 | ug/L | 100 | 05/21/22 13:17 | |
| EPA 6010 | Magnesium | 23600 | ug/L | 1000 | 05/21/22 13:17 | |
| EPA 6010 | Manganese | 268 | ug/L | 10.0 | 05/21/22 13:17 | |
| EPA 6010 | Molybdenum | 25.9 | ug/L | 10.0 | 05/21/22 13:17 | |
| EPA 6010 | Potassium | 5790 | ug/L | 1000 | 05/21/22 13:17 | |
| EPA 6010 | Silica | 12600 | ug/L | 450 | 05/21/22 13:17 | N2 |
| EPA 6010 | Sodium | 63700 | ug/L | 1000 | 05/21/22 13:17 | |
| EPA 6010 | Manganese, Dissolved | 250 | ug/L | 10.0 | 05/21/22 02:02 | |
| EPA 6010 | Molybdenum, Dissolved | 25.2 | ug/L | 10.0 | 05/21/22 02:02 | |
| EPA 6020 | Arsenic | 9.6 | ug/L | 1.0 | 05/14/22 07:14 | |
| EPA 903.1 | Radium-226 | 0.559 ± 0.685 (1.13) C:NA T:95% | pCi/L | | 06/17/22 16:10 | |
| EPA 904.0 | Radium-228 | 0.397 ± 0.410 (0.843) C:58% T:90% | pCi/L | | 06/14/22 13:33 | |
| Total Radium Calculation | Total Radium | 0.956 ± 1.10 (1.97) | pCi/L | | 06/20/22 14:27 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 260 | mg/L | 2.0 | 05/17/22 15:54 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 260 | mg/L | 2.0 | 05/17/22 15:54 | |
| SM 2540C | Total Dissolved Solids | 529 | mg/L | 10.0 | 05/13/22 16:01 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/16/22 11:21 | H3 |
| EPA 365.1 | Phosphate as P04 | 2.0 | mg/L | 0.15 | 05/14/22 13:53 | |
| SM 5310C | Total Organic Carbon | 2.0 | mg/L | 1.0 | 05/19/22 21:33 | |
| SM 5310C | Dissolved Organic Carbon | 2.3 | mg/L | 1.0 | 05/18/22 17:54 | |
| **50316084002** | **MW-1D** | | | | | |
| EPA 9056 | Chloride | 93.7 | mg/L | 2.5 | 05/21/22 17:59 | |
| EPA 9056 | Fluoride | 0.42 | mg/L | 0.10 | 05/21/22 17:40 | |
| EPA 9056 | Sulfate | 48.2 | mg/L | 2.5 | 05/21/22 17:59 | |
| EPA 6010 | Barium | 78.0 | ug/L | 10.0 | 05/21/22 13:19 | |
| EPA 6010 | Boron | 288 | ug/L | 100 | 05/21/22 13:19 | |
| EPA 6010 | Calcium | 85300 | ug/L | 1000 | 05/21/22 13:19 | |
| EPA 6010 | Iron | 2270 | ug/L | 100 | 05/21/22 13:19 | |
| EPA 6010 | Magnesium | 19100 | ug/L | 1000 | 05/21/22 13:19 | |
| EPA 6010 | Manganese | 197 | ug/L | 10.0 | 05/21/22 13:19 | |
| EPA 6010 | Molybdenum | 37.7 | ug/L | 10.0 | 05/21/22 13:19 | |
| EPA 6010 | Potassium | 6300 | ug/L | 1000 | 05/21/22 13:19 | |
| EPA 6010 | Silica | 15400 | ug/L | 450 | 05/21/22 13:19 | N2 |
| EPA 6010 | Sodium | 60300 | ug/L | 1000 | 05/21/22 13:19 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316084002** | **MW-1D** | | | | | |
| EPA 6010 | Manganese, Dissolved | 189 | ug/L | 10.0 | 05/21/22 02:04 | |
| EPA 6010 | Molybdenum, Dissolved | 37.1 | ug/L | 10.0 | 05/21/22 02:04 | |
| EPA 6020 | Arsenic | 4.5 | ug/L | 1.0 | 05/14/22 07:29 | |
| EPA 903.1 | Radium-226 | 0.408 ± 0.501 (0.818) C:NA T:100% | pCi/L | | 06/17/22 16:10 | |
| EPA 904.0 | Radium-228 | 0.603 ± 0.530 (1.07) C:59% T:83% | pCi/L | | 06/14/22 13:28 | |
| Total Radium Calculation | Total Radium | 1.01 ± 1.03 (1.89) | pCi/L | | 06/20/22 14:27 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 259 | mg/L | 2.0 | 05/17/22 15:54 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 259 | mg/L | 2.0 | 05/17/22 15:54 | |
| SM 2540C | Total Dissolved Solids | 470 | mg/L | 10.0 | 05/13/22 16:01 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/16/22 11:22 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.12 | mg/L | 0.10 | 05/10/22 17:13 | |
| EPA 365.1 | Phosphate as P04 | 0.30 | mg/L | 0.15 | 05/14/22 13:53 | |
| SM 5310C | Total Organic Carbon | 2.1 | mg/L | 1.0 | 05/19/22 22:07 | |
| SM 5310C | Dissolved Organic Carbon | 2.3 | mg/L | 1.0 | 05/18/22 18:05 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Sample: MW-1S** **Lab ID: 50316084001** Collected: 05/09/22 16:11 Received: 05/10/22 14:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **124** | mg/L | 2.5 | 10 | | 05/21/22 16:27 | 16887-00-6 | |
| Fluoride | **0.41** | mg/L | 0.10 | 1 | | 05/21/22 16:08 | 16984-48-8 | |
| Sulfate | **56.1** | mg/L | 2.5 | 10 | | 05/21/22 16:27 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7429-90-5 | |
| Barium | **69.9** | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-39-3 | |
| Boron | **375** | ug/L | 100 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-43-9 | |
| Calcium | **92200** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-47-3 | |
| Iron | **3380** | ug/L | 100 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7439-93-2 | |
| Magnesium | **23600** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7439-95-4 | |
| Manganese | **268** | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7439-96-5 | |
| Molybdenum | **25.9** | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7439-98-7 | |
| Potassium | **5790** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-09-7 | |
| Silica | **12600** | ug/L | 450 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7631-86-9 | N2 |
| Sodium | **63700** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:17 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **250** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:02 | 7439-96-5 | |
| Molybdenum, Dissolved | **25.2** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:02 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:14 | 7440-36-0 | |
| Arsenic | **9.6** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:14 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/14/22 07:14 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:14 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:14 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:14 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/17/22 17:03 | 05/18/22 10:05 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **260** | mg/L | 2.0 | 1 | | 05/17/22 15:54 | | |
| Alkalinity,Bicarbonate (CaCO3) | **260** | mg/L | 2.0 | 1 | | 05/17/22 15:54 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/17/22 15:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Sample: MW-1S** **Lab ID: 50316084001** Collected: 05/09/22 16:11 Received: 05/10/22 14:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **529** | mg/L | 10.0 | 1 | | 05/13/22 16:01 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/16/22 11:21 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 09:47 | 18496-25-8 | P4 |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/11/22 08:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/10/22 17:18 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/10/22 17:18 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **2.0** | mg/L | 0.15 | 1 | 05/12/22 10:00 | 05/14/22 13:53 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/19/22 21:33 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 05/18/22 17:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Sample: MW-1D** **Lab ID: 50316084002** Collected: 05/09/22 15:04 Received: 05/10/22 14:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **93.7** | mg/L | 2.5 | 10 | | 05/21/22 17:59 | 16887-00-6 | |
| Fluoride | **0.42** | mg/L | 0.10 | 1 | | 05/21/22 17:40 | 16984-48-8 | |
| Sulfate | **48.2** | mg/L | 2.5 | 10 | | 05/21/22 17:59 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7429-90-5 | |
| Barium | **78.0** | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-39-3 | |
| Boron | **288** | ug/L | 100 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-43-9 | |
| Calcium | **85300** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-47-3 | |
| Iron | **2270** | ug/L | 100 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7439-93-2 | |
| Magnesium | **19100** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7439-95-4 | |
| Manganese | **197** | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7439-96-5 | |
| Molybdenum | **37.7** | ug/L | 10.0 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7439-98-7 | |
| Potassium | **6300** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-09-7 | |
| Silica | **15400** | ug/L | 450 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7631-86-9 | N2 |
| Sodium | **60300** | ug/L | 1000 | 1 | 05/18/22 09:15 | 05/21/22 13:19 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **189** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:04 | 7439-96-5 | |
| Molybdenum, Dissolved | **37.1** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:04 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:29 | 7440-36-0 | |
| Arsenic | **4.5** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:29 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/14/22 07:29 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:29 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:29 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:29 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/17/22 17:03 | 05/18/22 10:07 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **259** | mg/L | 2.0 | 1 | | 05/17/22 15:54 | | |
| Alkalinity,Bicarbonate (CaCO3) | **259** | mg/L | 2.0 | 1 | | 05/17/22 15:54 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/17/22 15:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Sample: MW-1D** **Lab ID: 50316084002** Collected: 05/09/22 15:04 Received: 05/10/22 14:25 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **470** | mg/L | 10.0 | 1 | | 05/13/22 16:01 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/16/22 11:22 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 09:47 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/11/22 08:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.12** | mg/L | 0.10 | 1 | | 05/10/22 17:13 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/10/22 17:13 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.30** | mg/L | 0.15 | 1 | 05/12/22 10:00 | 05/14/22 13:53 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 05/19/22 22:07 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.3** | mg/L | 1.0 | 1 | | 05/18/22 18:05 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 677226
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3118110 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/21/22 10:18 | |
| Fluoride | mg/L | ND | 0.10 | 05/21/22 10:18 | |
| Sulfate | mg/L | ND | 0.25 | 05/21/22 10:18 | |

LABORATORY CONTROL SAMPLE: 3118111

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 93 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.53 | 107 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 97 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3118112 3118113

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 46.8 | 12.5 | 12.5 | 58.2 | 59.4 | 91 | 101 | 80-120 | 2 | 15 | |
| Fluoride | mg/L | 0.17 | 0.5 | 0.5 | 0.73 | 0.73 | 113 | 113 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 29.1 | 25 | 25 | 52.5 | 52.7 | 94 | 94 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676495
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3114850 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/18/22 09:23 | |

LABORATORY CONTROL SAMPLE: 3114851

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 5.1 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114852 3114853

| Parameter | Units | 50315569006 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 5.0 | 5.0 | 101 | 99 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676717
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3115599 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/21/22 12:45 | |
| Barium | ug/L | ND | 10.0 | 05/21/22 12:45 | |
| Boron | ug/L | ND | 100 | 05/21/22 12:45 | |
| Cadmium | ug/L | ND | 2.0 | 05/21/22 12:45 | |
| Calcium | ug/L | ND | 1000 | 05/21/22 12:45 | |
| Chromium | ug/L | ND | 10.0 | 05/21/22 12:45 | |
| Iron | ug/L | ND | 100 | 05/21/22 12:45 | |
| Lead | ug/L | ND | 10.0 | 05/21/22 12:45 | |
| Lithium | ug/L | ND | 20.0 | 05/21/22 12:45 | |
| Magnesium | ug/L | ND | 1000 | 05/21/22 12:45 | |
| Manganese | ug/L | ND | 10.0 | 05/21/22 12:45 | |
| Molybdenum | ug/L | ND | 10.0 | 05/21/22 12:45 | |
| Potassium | ug/L | ND | 1000 | 05/21/22 12:45 | |
| Silica | ug/L | ND | 450 | 05/21/22 12:45 | N2 |
| Sodium | ug/L | ND | 1000 | 05/21/22 12:45 | |

LABORATORY CONTROL SAMPLE: 3115600

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 10000 | 100 | 80-120 | |
| Barium | ug/L | 1000 | 1030 | 103 | 80-120 | |
| Boron | ug/L | 1000 | 1000 | 100 | 80-120 | |
| Cadmium | ug/L | 1000 | 975 | 98 | 80-120 | |
| Calcium | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Chromium | ug/L | 1000 | 994 | 99 | 80-120 | |
| Iron | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Lead | ug/L | 1000 | 953 | 95 | 80-120 | |
| Lithium | ug/L | 1000 | 999 | 100 | 80-120 | |
| Magnesium | ug/L | 10000 | 9700 | 97 | 80-120 | |
| Manganese | ug/L | 1000 | 967 | 97 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Potassium | ug/L | 10000 | 9770 | 98 | 80-120 | |
| Silica | ug/L | 10700 | 10100 | 95 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9730 | 97 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115601 3115602

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9840 | 9990 | 98 | 99 | 75-125 | 2 | 20 | |
| Barium | ug/L | 55.8 | 1000 | 1000 | 1060 | 1080 | 100 | 102 | 75-125 | 1 | 20 | |
| Boron | ug/L | 352 | 1000 | 1000 | 1350 | 1380 | 100 | 102 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 969 | 982 | 97 | 98 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 82900 | 10000 | 10000 | 93100 | 93400 | 102 | 105 | 75-125 | 0 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 961 | 972 | 96 | 97 | 75-125 | 1 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9840 | 10000 | 97 | 99 | 75-125 | 2 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 910 | 917 | 91 | 92 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1030 | 1040 | 102 | 103 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 20700 | 10000 | 10000 | 30100 | 30600 | 94 | 99 | 75-125 | 2 | 20 | |
| Manganese | ug/L | ND | 1000 | 1000 | 930 | 944 | 92 | 94 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 1010 | 1010 | 100 | 101 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 2030 | 10000 | 10000 | 11800 | 12100 | 97 | 101 | 75-125 | 3 | 20 | |
| Silica | ug/L | 10100 | 10700 | 10700 | 20500 | 20700 | 97 | 99 | 75-125 | 1 | 20 | N2 |
| Sodium | ug/L | 30100 | 10000 | 10000 | 39900 | 40600 | 98 | 105 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 677124
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3117566 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |

LABORATORY CONTROL SAMPLE: 3117567

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 951 | 95 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1030 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117568 3117569

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 1000 | 1000 | 944 | 934 | 94 | 93 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 675800
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3111670 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Arsenic | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Beryllium | ug/L | ND | 0.20 | 05/14/22 05:38 | |
| Cobalt | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Selenium | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Thallium | ug/L | ND | 1.0 | 05/14/22 05:38 | |

LABORATORY CONTROL SAMPLE: 3111671

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.2 | 103 | 80-120 | |
| Arsenic | ug/L | 40 | 36.8 | 92 | 80-120 | |
| Beryllium | ug/L | 40 | 39.3 | 98 | 80-120 | |
| Cobalt | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 38.0 | 95 | 80-120 | |
| Thallium | ug/L | 40 | 40.5 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111672 3111673

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.7 | 41.3 | 109 | 103 | 75-125 | 6 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 37.2 | 38.9 | 93 | 97 | 75-125 | 4 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 41.4 | 39.8 | 103 | 99 | 75-125 | 4 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 39.9 | 38.1 | 98 | 94 | 75-125 | 5 | 20 | |
| Selenium | ug/L | 1.9 | 40 | 40 | 39.0 | 41.2 | 93 | 98 | 75-125 | 5 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 43.0 | 40.7 | 107 | 102 | 75-125 | 6 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111684 3111685

| Parameter | Units | 50315953004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 0.090J | 40 | 40 | 43.4 | 42.2 | 108 | 105 | 75-125 | 3 | 20 | |
| Arsenic | ug/L | 0.27J | 40 | 40 | 38.6 | 38.1 | 96 | 95 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 41.0 | 40.0 | 102 | 100 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | 0.13J | 40 | 40 | 38.5 | 37.2 | 96 | 93 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111684 3111685

| Parameter | Units | 50315953004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Selenium | ug/L | 0.39J | 40 | 40 | 39.6 | 39.5 | 98 | 98 | 75-125 | 0 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 43.0 | 41.6 | 107 | 104 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676606
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3115198 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 2.6 | 2.0 | 05/17/22 15:54 | B |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 2.6 | 2.0 | 05/17/22 15:54 | B |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/17/22 15:54 | |

LABORATORY CONTROL SAMPLE: 3115199

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.9 | 100 | 90-110 | |

SAMPLE DUPLICATE: 3115200

| Parameter | Units | 50315748001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 282 | 281 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 282 | 281 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | <2.0 | ND | | 20 | |

SAMPLE DUPLICATE: 3115201

| Parameter | Units | 50316088002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 265 | 265 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 265 | 265 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676066
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3112913 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/13/22 16:00 | |

LABORATORY CONTROL SAMPLE: 3112914

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 284 | 95 | 80-120 | |

SAMPLE DUPLICATE: 3112915

| Parameter | Units | 50316042001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1290 | 1260 | 2 | 10 | |

SAMPLE DUPLICATE: 3112916

| Parameter | Units | 50316171013 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 366 | 376 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676415
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

SAMPLE DUPLICATE: 3114620

| Parameter | Units | 50316088002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3114621

| Parameter | Units | 50315315003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.4 | 7.4 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676049
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3112813 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/13/22 09:47 | |

LABORATORY CONTROL SAMPLE: 3112814

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.53 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112815 3112816

| Parameter | Units | 50315984002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.50 | 103 | 100 | 90-110 | 3 | 20 | |

MATRIX SPIKE SAMPLE: 3112817

| Parameter | Units | 50316029001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.48 | 96 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 675534
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3110433 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/11/22 08:43 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3110434

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 104 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110435 3110436

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 100 | 103 | 90-110 | 3 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110437 3110438

| Parameter | Units | 50316118001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 0.96 | 1.0 | 96 | 100 | 90-110 | 4 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 675488
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3110210 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/10/22 17:01 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/10/22 17:01 | |

LABORATORY CONTROL SAMPLE: 3110211

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.96 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110212 3110213

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1.8 | 1 | 1 | 2.9 | 2.8 | 101 | 99 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 95 | 95 | 90-110 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3110214

| Parameter | Units | 50316081001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.96 | 96 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 675801
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3111676 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 13:46 | |

LABORATORY CONTROL SAMPLE: 3111677

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE SAMPLE: 3111678

| Parameter | Units | 50316176001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111679 3111680

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.4 | | | | 5 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 677201
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3117995 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/19/22 19:49 | |

LABORATORY CONTROL SAMPLE: 3117996

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.1 | 101 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117997 3117998

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 11.0 | 11.0 | 105 | 105 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3117999

| Parameter | Units | 50316097003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.2 | 10 | 12.6 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 676937
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 3116644 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/18/22 16:40 | |

LABORATORY CONTROL SAMPLE: 3116645

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.4 | 104 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116646 3116647

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 10 | 11.3 | 10.6 | 109 | 101 | 80-120 | 7 | 20 | |

MATRIX SPIKE SAMPLE: 3116648

| Parameter | Units | 50316115002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.5 | 10 | 12.9 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Sample: MW-1S** **Lab ID: 50316084001** Collected: 05/09/22 16:11 Received: 05/10/22 14:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.559 ± 0.685 (1.13) C:NA T:95%** | pCi/L | 06/17/22 16:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.397 ± 0.410 (0.843) C:58% T:90%** | pCi/L | 06/14/22 13:33 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.956 ± 1.10 (1.97)** | pCi/L | 06/20/22 14:27 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

**Sample: MW-1D** **Lab ID: 50316084002** Collected: 05/09/22 15:04 Received: 05/10/22 14:25 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.408 ± 0.501 (0.818) C:NA T:100%** | pCi/L | 06/17/22 16:10 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.603 ± 0.530 (1.07) C:59% T:83%** | pCi/L | 06/14/22 13:28 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.01 ± 1.03 (1.89)** | pCi/L | 06/20/22 14:27 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 505319
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 2447557 Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.310 ± 0.323 (0.456) C:NA T:98% | pCi/L | 06/17/22 16:10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

QC Batch: 505320
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316084001, 50316084002

METHOD BLANK: 2447559
Matrix: Water
Associated Lab Samples: 50316084001, 50316084002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.284 ± 0.352 (0.741) C:64% T:87% | pCi/L | 06/14/22 13:33 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| B | Analyte was detected in the associated method blank. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P4 | Sample field preservation does not meet EPA or method recommendations for this analysis. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316084

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316084001** | **MW-1S** | EPA 9056 | 677226 | | |
| **50316084002** | **MW-1D** | EPA 9056 | 677226 | | |
| **50316084001** | **MW-1S** | EPA 3010 | 676717 | EPA 6010 | 677558 |
| **50316084002** | **MW-1D** | EPA 3010 | 676717 | EPA 6010 | 677558 |
| **50316084001** | **MW-1S** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316084002** | **MW-1D** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316084001** | **MW-1S** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50316084002** | **MW-1D** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50316084001** | **MW-1S** | EPA 7470 | 676495 | EPA 7470 | 676788 |
| **50316084002** | **MW-1D** | EPA 7470 | 676495 | EPA 7470 | 676788 |
| **50316084001** | **MW-1S** | EPA 903.1 | 505319 | | |
| **50316084002** | **MW-1D** | EPA 903.1 | 505319 | | |
| **50316084001** | **MW-1S** | EPA 904.0 | 505320 | | |
| **50316084002** | **MW-1D** | EPA 904.0 | 505320 | | |
| **50316084001** | **MW-1S** | Total Radium Calculation | 513050 | | |
| **50316084002** | **MW-1D** | Total Radium Calculation | 513050 | | |
| **50316084001** | **MW-1S** | SM 2320B | 676606 | | |
| **50316084002** | **MW-1D** | SM 2320B | 676606 | | |
| **50316084001** | **MW-1S** | SM 2540C | 676066 | | |
| **50316084002** | **MW-1D** | SM 2540C | 676066 | | |
| **50316084001** | **MW-1S** | SM 4500-H+B | 676415 | | |
| **50316084002** | **MW-1D** | SM 4500-H+B | 676415 | | |
| **50316084001** | **MW-1S** | SM 4500-S2-D | 676049 | | |
| **50316084002** | **MW-1D** | SM 4500-S2-D | 676049 | | |
| **50316084001** | **MW-1S** | HACH 8146 | 675534 | | |
| **50316084002** | **MW-1D** | HACH 8146 | 675534 | | |
| **50316084001** | **MW-1S** | EPA 353.2 | 675488 | | |
| **50316084002** | **MW-1D** | EPA 353.2 | 675488 | | |
| **50316084001** | **MW-1S** | EPA 365.1 | 675801 | EPA 365.1 | 676390 |
| **50316084002** | **MW-1D** | EPA 365.1 | 675801 | EPA 365.1 | 676390 |
| **50316084001** | **MW-1S** | SM 5310C | 677201 | | |
| **50316084002** | **MW-1D** | SM 5310C | 677201 | | |
| **50316084001** | **MW-1S** | SM 5310C | 676937 | | |
| **50316084002** | **MW-1D** | SM 5310C | 676937 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields m

WO# : 50316084

50316084

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sec |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

State / Loc: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | |
| 1 | MW-1S | WT | G | | | 5/9/2022 | 16:11 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 2 | MW-1D | WT | G | | | 5/9/2022 | 15:04 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 3 | MW-2S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 4 | MW-2D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 5 | MW-3S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 6 | MW-3D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 7 | MW-4S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 8 | MW-5S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 9 | MW-6S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 10 | MW-7S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 11 | MW-7D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 12 | MW-8S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / Atlas | 5/10/22 | 945A | Pace | 5/10/22 | 810 | | | | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | Pace | 5/10/22 | 1425 | | 5/10/22 | 1425 | 1.0 | Y | N | Y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | |
|---|---|---|---|
| PRINT Name of SAMPLER: | MARK BRETING | | |
| SIGNATURE of SAMPLER: | Mark Breting | DATE Signed: | 5/10/2022 |

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** MDW 5/16/22 1455

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** 1.4/1.0 | | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1530 | |
| **Rush TAT Requested (4 days or less):** | | ✓ |
| Custody Signatures Present? | ✓ | |
| Containers Intact?: | ✓ | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** ~~HNO3 (<2)~~ ~~H2SO4 (<2)~~ NaOH (>10) ~~NaOH/ZnAc (>9)~~ Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Headspace Wisconsin Sulfide? | | | ✓ |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | ✓ |
| Trip Blank Present? | | ✓ | |
| Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

**COC PAGE ____ of ____**

## Sample Container Count

SBS / DI / MeOH (only) / BK Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | 7 | |
| 2 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 11, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316219001** | **MW-11D** | Water | 05/10/22 14:00 | 05/11/22 15:45 |
| **50316219002** | **DUP 2** | Water | 05/10/22 14:00 | 05/11/22 15:45 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316219001** | **MW-11D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316219002** | **DUP 2** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316219001** | **MW-11D** | | | | | |
| EPA 9056 | Chloride | 71.0 | mg/L | 2.5 | 05/20/22 23:44 | |
| EPA 9056 | Fluoride | 0.30 | mg/L | 0.10 | 05/20/22 23:27 | |
| EPA 9056 | Sulfate | 598 | mg/L | 25.0 | 05/21/22 00:01 | |
| EPA 6010 | Barium | 25.6 | ug/L | 10.0 | 05/23/22 13:50 | |
| EPA 6010 | Boron | 11900 | ug/L | 100 | 05/23/22 13:50 | |
| EPA 6010 | Calcium | 225000 | ug/L | 2000 | 05/23/22 14:03 | |
| EPA 6010 | Iron | 5990 | ug/L | 100 | 05/23/22 13:50 | |
| EPA 6010 | Lithium | 147 | ug/L | 20.0 | 05/23/22 13:50 | |
| EPA 6010 | Magnesium | 52500 | ug/L | 1000 | 05/23/22 13:50 | |
| EPA 6010 | Manganese | 45.2 | ug/L | 10.0 | 05/23/22 13:50 | |
| EPA 6010 | Potassium | 3080 | ug/L | 1000 | 05/23/22 13:50 | |
| EPA 6010 | Silica | 16500 | ug/L | 450 | 05/23/22 13:50 | N2 |
| EPA 6010 | Sodium | 79400 | ug/L | 1000 | 05/23/22 13:50 | |
| EPA 6010 | Manganese, Dissolved | 40.1 | ug/L | 10.0 | 05/21/22 02:44 | |
| EPA 6020 | Arsenic | 16.1 | ug/L | 1.0 | 05/16/22 15:49 | |
| EPA 903.1 | Radium-226 | 0.190 ± 0.248 (0.408) C:NA T:89% | pCi/L | | 06/20/22 16:50 | |
| EPA 904.0 | Radium-228 | 1.33 ± 0.792 (1.48) C:42% T:89% | pCi/L | | 06/09/22 12:52 | |
| Total Radium Calculation | Total Radium | 1.52 ± 1.04 (1.89) | pCi/L | | 06/21/22 14:37 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 264 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 264 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2540C | Total Dissolved Solids | 1210 | mg/L | 20.0 | 05/17/22 12:56 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 05/16/22 14:35 | H3 |
| SM 5310C | Dissolved Organic Carbon | 1.1 | mg/L | 1.0 | 05/22/22 23:02 | |
| **50316219002** | **DUP 2** | | | | | |
| EPA 9056 | Chloride | 70.7 | mg/L | 2.5 | 05/21/22 01:09 | |
| EPA 9056 | Fluoride | 0.33 | mg/L | 0.10 | 05/21/22 00:52 | |
| EPA 9056 | Sulfate | 587 | mg/L | 25.0 | 05/21/22 01:26 | |
| EPA 6010 | Barium | 24.4 | ug/L | 10.0 | 05/23/22 13:53 | |
| EPA 6010 | Boron | 11700 | ug/L | 100 | 05/23/22 13:53 | |
| EPA 6010 | Calcium | 223000 | ug/L | 2000 | 05/23/22 14:09 | |
| EPA 6010 | Iron | 5810 | ug/L | 100 | 05/23/22 13:53 | |
| EPA 6010 | Lithium | 145 | ug/L | 20.0 | 05/23/22 13:53 | |
| EPA 6010 | Magnesium | 51700 | ug/L | 1000 | 05/23/22 13:53 | |
| EPA 6010 | Manganese | 41.7 | ug/L | 10.0 | 05/23/22 13:53 | |
| EPA 6010 | Potassium | 2900 | ug/L | 1000 | 05/23/22 13:53 | |
| EPA 6010 | Silica | 16700 | ug/L | 450 | 05/23/22 13:53 | N2 |
| EPA 6010 | Sodium | 78200 | ug/L | 1000 | 05/23/22 13:53 | |
| EPA 6010 | Manganese, Dissolved | 39.1 | ug/L | 10.0 | 05/21/22 02:46 | |
| EPA 6020 | Arsenic | 15.9 | ug/L | 1.0 | 05/16/22 15:54 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316219002** | **DUP 2** | | | | | |
| EPA 903.1 | Radium-226 | 0.319 ± 0.224 (0.108) C:NA T:87% | pCi/L | | 06/20/22 17:09 | |
| EPA 904.0 | Radium-228 | 0.572 ± 0.467 (0.931) C:61% T:87% | pCi/L | | 06/09/22 12:53 | |
| Total Radium Calculation | Total Radium | 0.891 ± 0.691 (1.04) | pCi/L | | 06/21/22 14:37 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 262 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 262 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2540C | Total Dissolved Solids | 1190 | mg/L | 20.0 | 05/17/22 12:56 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/16/22 14:36 | H3 |
| SM 5310C | Dissolved Organic Carbon | 1.0 | mg/L | 1.0 | 05/22/22 23:12 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Sample: MW-11D** **Lab ID: 50316219001** Collected: 05/10/22 14:00 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **71.0** | mg/L | 2.5 | 10 | | 05/20/22 23:44 | 16887-00-6 | |
| Fluoride | **0.30** | mg/L | 0.10 | 1 | | 05/20/22 23:27 | 16984-48-8 | |
| Sulfate | **598** | mg/L | 25.0 | 100 | | 05/21/22 00:01 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7429-90-5 | |
| Barium | **25.6** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7440-39-3 | |
| Boron | **11900** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7440-43-9 | |
| Calcium | **225000** | ug/L | 2000 | 2 | 05/19/22 14:22 | 05/23/22 14:03 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7440-47-3 | |
| Iron | **5990** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7439-92-1 | |
| Lithium | **147** | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7439-93-2 | |
| Magnesium | **52500** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7439-95-4 | |
| Manganese | **45.2** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7439-98-7 | |
| Potassium | **3080** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7440-09-7 | |
| Silica | **16500** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7631-86-9 | N2 |
| Sodium | **79400** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:50 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **40.1** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:44 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:44 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:49 | 7440-36-0 | |
| Arsenic | **16.1** | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:49 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/15/22 12:00 | 05/16/22 15:49 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:49 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:49 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:49 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/18/22 09:12 | 05/18/22 20:16 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **264** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Bicarbonate (CaCO3) | **264** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Sample: MW-11D** **Lab ID: 50316219001** Collected: 05/10/22 14:00 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1210** | mg/L | 20.0 | 1 | | 05/17/22 12:56 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 05/16/22 14:35 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 11:20 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 20:16 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 09:10 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:10 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/12/22 11:30 | 05/14/22 14:34 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/21/22 20:08 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 05/22/22 23:02 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Sample: DUP 2** **Lab ID: 50316219002** Collected: 05/10/22 14:00 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **70.7** | mg/L | 2.5 | 10 | | 05/21/22 01:09 | 16887-00-6 | |
| Fluoride | **0.33** | mg/L | 0.10 | 1 | | 05/21/22 00:52 | 16984-48-8 | |
| Sulfate | **587** | mg/L | 25.0 | 100 | | 05/21/22 01:26 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7429-90-5 | |
| Barium | **24.4** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7440-39-3 | |
| Boron | **11700** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7440-43-9 | |
| Calcium | **223000** | ug/L | 2000 | 2 | 05/19/22 14:22 | 05/23/22 14:09 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7440-47-3 | |
| Iron | **5810** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7439-92-1 | |
| Lithium | **145** | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7439-93-2 | |
| Magnesium | **51700** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7439-95-4 | |
| Manganese | **41.7** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7439-98-7 | |
| Potassium | **2900** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7440-09-7 | |
| Silica | **16700** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7631-86-9 | N2 |
| Sodium | **78200** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:53 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **39.1** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:46 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:46 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:54 | 7440-36-0 | |
| Arsenic | **15.9** | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:54 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/15/22 12:00 | 05/16/22 15:54 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:54 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:54 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 15:54 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/18/22 09:12 | 05/18/22 20:18 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **262** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Bicarbonate (CaCO3) | **262** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Sample: DUP 2** **Lab ID: 50316219002** Collected: 05/10/22 14:00 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1190** | mg/L | 20.0 | 1 | | 05/17/22 12:56 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/16/22 14:36 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 11:20 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 20:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 09:12 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:12 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/12/22 11:30 | 05/14/22 14:34 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/21/22 21:08 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.0** | mg/L | 1.0 | 1 | | 05/22/22 23:12 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 677373
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3118869 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/20/22 18:21 | |
| Fluoride | mg/L | ND | 0.10 | 05/20/22 18:21 | |
| Sulfate | mg/L | ND | 0.25 | 05/20/22 18:21 | |

LABORATORY CONTROL SAMPLE: 3118870

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 92 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 95 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.6 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3118871 3118872

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 88.8 | 12.5 | 12.5 | 99.9 | 100 | 89 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.32 | 0.5 | 0.5 | 0.81 | 0.82 | 98 | 99 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 88.0 | 25 | 25 | 109 | 109 | 85 | 82 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676749
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3115783 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/22/22 15:39 | |

LABORATORY CONTROL SAMPLE: 3115784

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 5.1 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115785 3115786

| Parameter | Units | 50316148001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 5.3 | 5.2 | 106 | 103 | 75-125 | 3 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115787 3115788

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 5.1 | 5.1 | 102 | 101 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676911
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3116499 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/23/22 13:01 | |
| Barium | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Boron | ug/L | ND | 100 | 05/23/22 13:01 | |
| Cadmium | ug/L | ND | 2.0 | 05/23/22 13:01 | |
| Calcium | ug/L | ND | 1000 | 05/23/22 13:01 | |
| Chromium | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Iron | ug/L | ND | 100 | 05/23/22 13:01 | |
| Lead | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Lithium | ug/L | ND | 20.0 | 05/23/22 13:01 | |
| Magnesium | ug/L | ND | 1000 | 05/23/22 13:01 | |
| Manganese | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Molybdenum | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Potassium | ug/L | ND | 1000 | 05/23/22 13:01 | |
| Silica | ug/L | ND | 450 | 05/23/22 13:01 | N2 |
| Sodium | ug/L | ND | 1000 | 05/23/22 13:01 | |

LABORATORY CONTROL SAMPLE: 3116500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9940 | 99 | 80-120 | |
| Barium | ug/L | 1000 | 1080 | 108 | 80-120 | |
| Boron | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Cadmium | ug/L | 1000 | 986 | 99 | 80-120 | |
| Calcium | ug/L | 10000 | 10600 | 106 | 80-120 | |
| Chromium | ug/L | 1000 | 991 | 99 | 80-120 | |
| Iron | ug/L | 10000 | 10600 | 106 | 80-120 | |
| Lead | ug/L | 1000 | 970 | 97 | 80-120 | |
| Lithium | ug/L | 1000 | 1030 | 103 | 80-120 | |
| Magnesium | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Manganese | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1040 | 104 | 80-120 | |
| Potassium | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Silica | ug/L | 10700 | 10400 | 97 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 10100 | 101 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116501 3116502

| Parameter | Units | 50316214007 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 10100 | 100 | 100 | 75-125 | 0 | 20 | |
| Barium | ug/L | 313 | 1000 | 1000 | 1360 | 1350 | 104 | 104 | 75-125 | 0 | 20 | |
| Boron | ug/L | ND | 1000 | 1000 | 1130 | 1120 | 103 | 102 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 986 | 981 | 98 | 98 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 70400 | 10000 | 10000 | 76500 | 76400 | 60 | 59 | 75-125 | 0 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 998 | 992 | 100 | 99 | 75-125 | 1 | 20 | |
| Iron | ug/L | 4060 | 10000 | 10000 | 14100 | 14000 | 101 | 100 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 942 | 935 | 94 | 94 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1060 | 1060 | 106 | 105 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 39300 | 10000 | 10000 | 47100 | 46800 | 78 | 75 | 75-125 | 1 | 20 | |
| Manganese | ug/L | 74.2 | 1000 | 1000 | 1050 | 1040 | 98 | 97 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 35.9 | 1000 | 1000 | 1070 | 1060 | 103 | 103 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 1490 | 10000 | 10000 | 11600 | 11700 | 101 | 102 | 75-125 | 1 | 20 | |
| Silica | ug/L | 14100 | 10700 | 10700 | 23900 | 23800 | 91 | 90 | 75-125 | 0 | 20 | N2 |
| Sodium | ug/L | 43900 | 10000 | 10000 | 52400 | 52600 | 86 | 88 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 677124
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3117566 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |

LABORATORY CONTROL SAMPLE: 3117567

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 951 | 95 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1030 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117568 3117569

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 1000 | 1000 | 944 | 934 | 94 | 93 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676262
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3114075 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Arsenic | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Beryllium | ug/L | ND | 0.20 | 05/16/22 14:41 | |
| Cobalt | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Selenium | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Thallium | ug/L | ND | 1.0 | 05/16/22 14:41 | |

LABORATORY CONTROL SAMPLE: 3114076

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 43.2 | 108 | 80-120 | |
| Arsenic | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Beryllium | ug/L | 40 | 38.0 | 95 | 80-120 | |
| Cobalt | ug/L | 40 | 40.8 | 102 | 80-120 | |
| Selenium | ug/L | 40 | 40.6 | 101 | 80-120 | |
| Thallium | ug/L | 40 | 42.4 | 106 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114077 3114078

| Parameter | Units | 50315619003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 0.14J | 40 | 40 | 43.7 | 44.8 | 109 | 112 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 38.7 | 38.3 | 96 | 95 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 39.5 | 40.8 | 99 | 102 | 75-125 | 3 | 20 | |
| Cobalt | ug/L | 0.10J | 40 | 40 | 38.2 | 39.0 | 95 | 97 | 75-125 | 2 | 20 | |
| Selenium | ug/L | 2.8 | 40 | 40 | 40.8 | 40.2 | 95 | 93 | 75-125 | 2 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 42.4 | 43.6 | 106 | 109 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676826
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3116141 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 2.2 | 2.0 | 05/18/22 17:48 | B |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 2.2 | 2.0 | 05/18/22 17:48 | B |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/18/22 17:48 | |

LABORATORY CONTROL SAMPLE: 3116142

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 52.3 | 105 | 90-110 | |

SAMPLE DUPLICATE: 3116143

| Parameter | Units | 50316216002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 235 | 244 | 4 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 235 | 244 | 4 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3116144

| Parameter | Units | 50316218009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 288 | 285 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 278 | 274 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | 9.8 | 10.8 | 10 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676568
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3115085 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/17/22 12:50 | |

LABORATORY CONTROL SAMPLE: 3115086

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 282 | 94 | 80-120 | |

SAMPLE DUPLICATE: 3115087

| Parameter | Units | 50316214007 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 408 | 399 | 2 | 10 | |

SAMPLE DUPLICATE: 3115088

| Parameter | Units | 50316218009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 399 | 387 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676460
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

SAMPLE DUPLICATE: 3114756

| Parameter | Units | 50316224003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.8 | 7.9 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3114757

| Parameter | Units | 50316227002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.9 | 6.9 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 676051
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3112818 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/13/22 11:20 | |

LABORATORY CONTROL SAMPLE: 3112819

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.50 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112820 3112821

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.51 | 0.52 | 102 | 103 | 90-110 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3112822

| Parameter | Units | 50316146001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.52 | 104 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 678174
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3122311 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/24/22 20:10 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3122312

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 102 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122313 3122314

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 107 | 107 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3122315

| Parameter | Units | 50316152006 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 5.7 | 10 | 16.0 | 103 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 675779
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3111592 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/12/22 08:38 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/12/22 08:38 | |

LABORATORY CONTROL SAMPLE: 3111593

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.97 | 97 | 90-110 | |

MATRIX SPIKE SAMPLE: 3111594

| Parameter | Units | 50316224002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 0.99 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.96 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111595 3111596

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 96 | 96 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 95 | 95 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 675807
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3111708 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 14:32 | |

LABORATORY CONTROL SAMPLE: 3111709

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111710 3111711

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.49 | | | 1.6 | 1.6 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 677562
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3120248 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/21/22 15:50 | |

LABORATORY CONTROL SAMPLE: 3120249

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.1 | 101 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120250 3120251

| Parameter | Units | 50316218009 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 4.9 | 10 | 10 | 15.2 | 15.6 | 103 | 107 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 3120252

| Parameter | Units | 50316219001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.1 | 102 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 677651
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 3120505 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/22/22 22:11 | |

LABORATORY CONTROL SAMPLE: 3120506

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.3 | 103 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120507 3120508

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.2 | 10 | 10 | 11.8 | 11.8 | 107 | 107 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3120509

| Parameter | Units | 50316227001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.0 | 10 | 12.4 | 104 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Sample: MW-11D** **Lab ID: 50316219001** Collected: 05/10/22 14:00 Received: 05/11/22 15:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.190 ± 0.248 (0.408) C:NA T:89%** | pCi/L | 06/20/22 16:50 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.33 ± 0.792 (1.48) C:42% T:89%** | pCi/L | 06/09/22 12:52 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.52 ± 1.04 (1.89)** | pCi/L | 06/21/22 14:37 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

**Sample: DUP 2** **Lab ID: 50316219002** Collected: 05/10/22 14:00 Received: 05/11/22 15:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.319 ± 0.224 (0.108) C:NA T:87%** | pCi/L | 06/20/22 17:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.572 ± 0.467 (0.931) C:61% T:87%** | pCi/L | 06/09/22 12:53 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.891 ± 0.691 (1.04)** | pCi/L | 06/21/22 14:37 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 506530
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 2453870 Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0750 ± 0.171 (0.404) C:NA T:87% | pCi/L | 06/20/22 16:50 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

QC Batch: 506531
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316219001, 50316219002

METHOD BLANK: 2453872
Matrix: Water
Associated Lab Samples: 50316219001, 50316219002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.641 ± 0.403 (0.744) C:66% T:87% | pCi/L | 06/09/22 13:02 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| B | Analyte was detected in the associated method blank. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316219

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316219001** | **MW-11D** | EPA 9056 | 677373 | | |
| **50316219002** | **DUP 2** | EPA 9056 | 677373 | | |
| **50316219001** | **MW-11D** | EPA 3010 | 676911 | EPA 6010 | 677773 |
| **50316219002** | **DUP 2** | EPA 3010 | 676911 | EPA 6010 | 677773 |
| **50316219001** | **MW-11D** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316219002** | **DUP 2** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316219001** | **MW-11D** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316219002** | **DUP 2** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316219001** | **MW-11D** | EPA 7470 | 676749 | EPA 7470 | 676943 |
| **50316219002** | **DUP 2** | EPA 7470 | 676749 | EPA 7470 | 676943 |
| **50316219001** | **MW-11D** | EPA 903.1 | 506530 | | |
| **50316219002** | **DUP 2** | EPA 903.1 | 506530 | | |
| **50316219001** | **MW-11D** | EPA 904.0 | 506531 | | |
| **50316219002** | **DUP 2** | EPA 904.0 | 506531 | | |
| **50316219001** | **MW-11D** | Total Radium Calculation | 513364 | | |
| **50316219002** | **DUP 2** | Total Radium Calculation | 513364 | | |
| **50316219001** | **MW-11D** | SM 2320B | 676826 | | |
| **50316219002** | **DUP 2** | SM 2320B | 676826 | | |
| **50316219001** | **MW-11D** | SM 2540C | 676568 | | |
| **50316219002** | **DUP 2** | SM 2540C | 676568 | | |
| **50316219001** | **MW-11D** | SM 4500-H+B | 676460 | | |
| **50316219002** | **DUP 2** | SM 4500-H+B | 676460 | | |
| **50316219001** | **MW-11D** | SM 4500-S2-D | 676051 | | |
| **50316219002** | **DUP 2** | SM 4500-S2-D | 676051 | | |
| **50316219001** | **MW-11D** | HACH 8146 | 678174 | | |
| **50316219002** | **DUP 2** | HACH 8146 | 678174 | | |
| **50316219001** | **MW-11D** | EPA 353.2 | 675779 | | |
| **50316219002** | **DUP 2** | EPA 353.2 | 675779 | | |
| **50316219001** | **MW-11D** | EPA 365.1 | 675807 | EPA 365.1 | 676393 |
| **50316219002** | **DUP 2** | EPA 365.1 | 675807 | EPA 365.1 | 676393 |
| **50316219001** | **MW-11D** | SM 5310C | 677562 | | |
| **50316219002** | **DUP 2** | SM 5310C | 677562 | | |
| **50316219001** | **MW-11D** | SM 5310C | 677651 | | |
| **50316219002** | **DUP 2** | SM 5310C | 677651 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50316219

50316219

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Required Client Info: | | Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

| Regulatory Agency |
|---|
| State / Location |
| IN |

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | Requested Analysis Filtered (Y/N) | | | | Y | | | | | Y | | | | |
| 13 | MW-9S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 14 | MW-9I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 15 | MW-9D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 16 | MW-10S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 17 | MW-10D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 18 | MW-11D | WT | G | | | 5/10/22 | 1400 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | GC1 |
| 19 | MW-12S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 20 | MW-11S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 21 | MW-12D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 22 | MW-13S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 23 | MW-13D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 24 | MW-14D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / ATLAS | 5/11/22 | 0800 | [signature] pace | 5/11/22 | 1435 | | | | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | [signature] | 5/10/22 | 1545 | [signature] | 5-11-22 | 13:45 | 4.6 | y | N | y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | Kendra Reininger | | | | | |
| SIGNATURE of SAMPLER: | Mark Breting FOR Kendra Reininger | DATE Signed: 5/11/22 | | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A – Required Client Information: | | Section B – Required Project Information: | | Section C – Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

Regulatory Agency:

State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | |
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | G | | | 5/10/22 | 0000 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 30 | Field Blank 1 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | | |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting for Pace | 5/11/22 | 0800 | Pace | 5/11/22 | 1430 | | | | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | Pace | 5/11/22 | 1545 | | 5-11-22 | 15:45 | 4.6 | y | N | y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | Kenden Reininga | | | | | |
| SIGNATURE of SAMPLER: | Mark Breting for Ken | DATE Signed: 5/11/22 | | | | |
| | Kenden Reininga | | | | | |

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** RC 5-11-22 16:03

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** 5.2/4.6 | | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** $NO_3/NO_2$ | ✓ | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1630 | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ |
| Custody Signatures Present? | ✓ | |
| Containers Intact?: | ✓ | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** Circle: **HNO3 (<2)** **H2SO4 (<2)** **NaOH (>10)** **NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Headspace Wisconsin Sulfide? | | | ✓ |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | ✓ |
| Trip Blank Present? | | ✓ | |
| Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

COC PAGE 1 of 2

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | SBS / DI / MeOH (only) / BK / Kit R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 2 of 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 11, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316220001** | **MW-108S** | Water | 05/10/22 12:40 | 05/11/22 15:45 |
| **50316220002** | **MW-108D** | Water | 05/10/22 13:45 | 05/11/22 15:45 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316220001** | **MW-108S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316220002** | **MW-108D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316220001** | **MW-108S** | | | | | |
| EPA 9056 | Chloride | 181 | mg/L | 25.0 | 05/21/22 02:17 | |
| EPA 9056 | Fluoride | 0.65 | mg/L | 0.10 | 05/21/22 01:43 | |
| EPA 9056 | Sulfate | 959 | mg/L | 25.0 | 05/21/22 02:17 | |
| EPA 6010 | Barium | 38.7 | ug/L | 10.0 | 05/23/22 13:55 | |
| EPA 6010 | Boron | 2300 | ug/L | 100 | 05/23/22 13:55 | |
| EPA 6010 | Calcium | 288000 | ug/L | 2000 | 05/23/22 14:11 | |
| EPA 6010 | Iron | 4850 | ug/L | 100 | 05/23/22 13:55 | |
| EPA 6010 | Lithium | 79.3 | ug/L | 20.0 | 05/23/22 13:55 | |
| EPA 6010 | Magnesium | 100000 | ug/L | 1000 | 05/23/22 13:55 | |
| EPA 6010 | Manganese | 556 | ug/L | 10.0 | 05/23/22 13:55 | |
| EPA 6010 | Molybdenum | 108 | ug/L | 10.0 | 05/23/22 13:55 | |
| EPA 6010 | Potassium | 13700 | ug/L | 1000 | 05/23/22 13:55 | |
| EPA 6010 | Silica | 14200 | ug/L | 450 | 05/23/22 13:55 | N2 |
| EPA 6010 | Sodium | 182000 | ug/L | 1000 | 05/23/22 13:55 | |
| EPA 6010 | Manganese, Dissolved | 536 | ug/L | 10.0 | 05/21/22 02:48 | |
| EPA 6010 | Molybdenum, Dissolved | 107 | ug/L | 10.0 | 05/21/22 02:48 | |
| EPA 903.1 | Radium-226 | 0.296 ± 0.274 (0.399) C:NA T:85% | pCi/L | | 06/20/22 17:09 | |
| EPA 904.0 | Radium-228 | 0.364 ± 0.530 (1.14) C:55% T:85% | pCi/L | | 06/09/22 12:56 | |
| Total Radium Calculation | Total Radium | 0.660 ± 0.804 (1.54) | pCi/L | | 06/21/22 14:37 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 337 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 337 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2540C | Total Dissolved Solids | 1960 | mg/L | 40.0 | 05/17/22 12:57 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.1 | Std. Units | 0.10 | 05/16/22 14:37 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.15 | mg/L | 0.15 | 05/14/22 14:36 | |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 05/21/22 21:21 | |
| SM 5310C | Dissolved Organic Carbon | 1.6 | mg/L | 1.0 | 05/22/22 23:25 | |
| **50316220002** | **MW-108D** | | | | | |
| EPA 9056 | Chloride | 217 | mg/L | 25.0 | 05/21/22 03:08 | |
| EPA 9056 | Fluoride | 0.41 | mg/L | 0.10 | 05/21/22 02:34 | |
| EPA 9056 | Sulfate | 712 | mg/L | 25.0 | 05/21/22 03:08 | |
| EPA 6010 | Barium | 43.1 | ug/L | 10.0 | 05/23/22 13:57 | |
| EPA 6010 | Boron | 5800 | ug/L | 100 | 05/23/22 13:57 | |
| EPA 6010 | Calcium | 226000 | ug/L | 2000 | 05/23/22 14:13 | |
| EPA 6010 | Iron | 5800 | ug/L | 100 | 05/23/22 13:57 | |
| EPA 6010 | Lithium | 81.0 | ug/L | 20.0 | 05/23/22 13:57 | |
| EPA 6010 | Magnesium | 61800 | ug/L | 1000 | 05/23/22 13:57 | |
| EPA 6010 | Manganese | 393 | ug/L | 10.0 | 05/23/22 13:57 | |
| EPA 6010 | Molybdenum | 150 | ug/L | 10.0 | 05/23/22 13:57 | |
| EPA 6010 | Potassium | 13100 | ug/L | 1000 | 05/23/22 13:57 | |
| EPA 6010 | Silica | 14100 | ug/L | 450 | 05/23/22 13:57 | N2 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316220002** | **MW-108D** | | | | | |
| EPA 6010 | Sodium | 192000 | ug/L | 1000 | 05/23/22 13:57 | |
| EPA 6010 | Manganese, Dissolved | 384 | ug/L | 10.0 | 05/21/22 02:50 | |
| EPA 6010 | Molybdenum, Dissolved | 153 | ug/L | 10.0 | 05/21/22 02:50 | |
| EPA 903.1 | Radium-226 | 0.385 ± 0.270 (0.325) C:NA T:100% | pCi/L | | 06/20/22 17:09 | |
| EPA 904.0 | Radium-228 | 1.08 ± 0.618 (1.14) C:50% T:100% | pCi/L | | 06/09/22 12:56 | |
| Total Radium Calculation | Total Radium | 1.47 ± 0.888 (1.47) | pCi/L | | 06/21/22 14:37 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 258 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 258 | mg/L | 2.0 | 05/18/22 17:48 | |
| SM 2540C | Total Dissolved Solids | 1610 | mg/L | 20.0 | 05/17/22 12:57 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/16/22 14:39 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.25 | mg/L | 0.10 | 05/12/22 09:08 | |
| EPA 365.1 | Phosphate as P04 | 0.25 | mg/L | 0.15 | 05/14/22 14:37 | |
| SM 5310C | Total Organic Carbon | 1.5 | mg/L | 1.0 | 05/21/22 21:34 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 05/22/22 23:38 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Sample: MW-108S** **Lab ID: 50316220001** Collected: 05/10/22 12:40 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **181** | mg/L | 25.0 | 100 | | 05/21/22 02:17 | 16887-00-6 | |
| Fluoride | **0.65** | mg/L | 0.10 | 1 | | 05/21/22 01:43 | 16984-48-8 | |
| Sulfate | **959** | mg/L | 25.0 | 100 | | 05/21/22 02:17 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7429-90-5 | |
| Barium | **38.7** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7440-39-3 | |
| Boron | **2300** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7440-43-9 | |
| Calcium | **288000** | ug/L | 2000 | 2 | 05/19/22 14:22 | 05/23/22 14:11 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7440-47-3 | |
| Iron | **4850** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7439-92-1 | |
| Lithium | **79.3** | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7439-93-2 | |
| Magnesium | **100000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7439-95-4 | |
| Manganese | **556** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7439-96-5 | |
| Molybdenum | **108** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7439-98-7 | |
| Potassium | **13700** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7440-09-7 | |
| Silica | **14200** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7631-86-9 | N2 |
| Sodium | **182000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:55 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **536** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:48 | 7439-96-5 | |
| Molybdenum, Dissolved | **107** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:48 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:38 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:38 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:38 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:38 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **337** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Bicarbonate (CaCO3) | **337** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1960** | mg/L | 40.0 | 1 | | 05/17/22 12:57 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Sample: MW-108S** **Lab ID: 50316220001** Collected: 05/10/22 12:40 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.1** | Std. Units | 0.10 | 1 | | 05/16/22 14:37 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 13:06 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 20:14 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 08:55 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 08:55 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.15** | mg/L | 0.15 | 1 | 05/12/22 11:30 | 05/14/22 14:36 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/21/22 21:21 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/22/22 23:25 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Sample: MW-108D** **Lab ID: 50316220002** Collected: 05/10/22 13:45 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **217** | mg/L | 25.0 | 100 | | 05/21/22 03:08 | 16887-00-6 | |
| Fluoride | **0.41** | mg/L | 0.10 | 1 | | 05/21/22 02:34 | 16984-48-8 | |
| Sulfate | **712** | mg/L | 25.0 | 100 | | 05/21/22 03:08 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7429-90-5 | |
| Barium | **43.1** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7440-39-3 | |
| Boron | **5800** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7440-43-9 | |
| Calcium | **226000** | ug/L | 2000 | 2 | 05/19/22 14:22 | 05/23/22 14:13 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7440-47-3 | |
| Iron | **5800** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7439-92-1 | |
| Lithium | **81.0** | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7439-93-2 | |
| Magnesium | **61800** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7439-95-4 | |
| Manganese | **393** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7439-96-5 | |
| Molybdenum | **150** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7439-98-7 | |
| Potassium | **13100** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7440-09-7 | |
| Silica | **14100** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7631-86-9 | N2 |
| Sodium | **192000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/23/22 13:57 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **384** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:50 | 7439-96-5 | |
| Molybdenum, Dissolved | **153** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:50 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:43 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:43 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:43 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:43 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **258** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Bicarbonate (CaCO3) | **258** | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 17:48 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1610** | mg/L | 20.0 | 1 | | 05/17/22 12:57 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Sample: MW-108D** **Lab ID: 50316220002** Collected: 05/10/22 13:45 Received: 05/11/22 15:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/16/22 14:39 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 13:06 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 20:16 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.25** | mg/L | 0.10 | 1 | | 05/12/22 09:08 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:08 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.25** | mg/L | 0.15 | 1 | 05/12/22 11:30 | 05/14/22 14:37 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.5** | mg/L | 1.0 | 1 | | 05/21/22 21:34 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 05/22/22 23:38 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 677373
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3118869 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/20/22 18:21 | |
| Fluoride | mg/L | ND | 0.10 | 05/20/22 18:21 | |
| Sulfate | mg/L | ND | 0.25 | 05/20/22 18:21 | |

LABORATORY CONTROL SAMPLE: 3118870

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 92 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 95 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.6 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3118871 3118872

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 88.8 | 12.5 | 12.5 | 99.9 | 100 | 89 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.32 | 0.5 | 0.5 | 0.81 | 0.82 | 98 | 99 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 88.0 | 25 | 25 | 109 | 109 | 85 | 82 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 676911
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3116499 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/23/22 13:01 | |
| Barium | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Boron | ug/L | ND | 100 | 05/23/22 13:01 | |
| Cadmium | ug/L | ND | 2.0 | 05/23/22 13:01 | |
| Calcium | ug/L | ND | 1000 | 05/23/22 13:01 | |
| Chromium | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Iron | ug/L | ND | 100 | 05/23/22 13:01 | |
| Lead | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Lithium | ug/L | ND | 20.0 | 05/23/22 13:01 | |
| Magnesium | ug/L | ND | 1000 | 05/23/22 13:01 | |
| Manganese | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Molybdenum | ug/L | ND | 10.0 | 05/23/22 13:01 | |
| Potassium | ug/L | ND | 1000 | 05/23/22 13:01 | |
| Silica | ug/L | ND | 450 | 05/23/22 13:01 | N2 |
| Sodium | ug/L | ND | 1000 | 05/23/22 13:01 | |

LABORATORY CONTROL SAMPLE: 3116500

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9940 | 99 | 80-120 | |
| Barium | ug/L | 1000 | 1080 | 108 | 80-120 | |
| Boron | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Cadmium | ug/L | 1000 | 986 | 99 | 80-120 | |
| Calcium | ug/L | 10000 | 10600 | 106 | 80-120 | |
| Chromium | ug/L | 1000 | 991 | 99 | 80-120 | |
| Iron | ug/L | 10000 | 10600 | 106 | 80-120 | |
| Lead | ug/L | 1000 | 970 | 97 | 80-120 | |
| Lithium | ug/L | 1000 | 1030 | 103 | 80-120 | |
| Magnesium | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Manganese | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1040 | 104 | 80-120 | |
| Potassium | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Silica | ug/L | 10700 | 10400 | 97 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 10100 | 101 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116501 3116502

| Parameter | Units | 50316214007 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 10100 | 100 | 100 | 75-125 | 0 | 20 | |
| Barium | ug/L | 313 | 1000 | 1000 | 1360 | 1350 | 104 | 104 | 75-125 | 0 | 20 | |
| Boron | ug/L | ND | 1000 | 1000 | 1130 | 1120 | 103 | 102 | 75-125 | 1 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 986 | 981 | 98 | 98 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 70400 | 10000 | 10000 | 76500 | 76400 | 60 | 59 | 75-125 | 0 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 998 | 992 | 100 | 99 | 75-125 | 1 | 20 | |
| Iron | ug/L | 4060 | 10000 | 10000 | 14100 | 14000 | 101 | 100 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 942 | 935 | 94 | 94 | 75-125 | 1 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1060 | 1060 | 106 | 105 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 39300 | 10000 | 10000 | 47100 | 46800 | 78 | 75 | 75-125 | 1 | 20 | |
| Manganese | ug/L | 74.2 | 1000 | 1000 | 1050 | 1040 | 98 | 97 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 35.9 | 1000 | 1000 | 1070 | 1060 | 103 | 103 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 1490 | 10000 | 10000 | 11600 | 11700 | 101 | 102 | 75-125 | 1 | 20 | |
| Silica | ug/L | 14100 | 10700 | 10700 | 23900 | 23800 | 91 | 90 | 75-125 | 0 | 20 | N2 |
| Sodium | ug/L | 43900 | 10000 | 10000 | 52400 | 52600 | 86 | 88 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 677124
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3117566 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |

LABORATORY CONTROL SAMPLE: 3117567

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 951 | 95 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1030 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117568 3117569

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 1000 | 1000 | 944 | 934 | 94 | 93 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 676262
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3114075 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Arsenic | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Cobalt | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Selenium | ug/L | ND | 1.0 | 05/16/22 14:41 | |

LABORATORY CONTROL SAMPLE: 3114076

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 43.2 | 108 | 80-120 | |
| Arsenic | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Cobalt | ug/L | 40 | 40.8 | 102 | 80-120 | |
| Selenium | ug/L | 40 | 40.6 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114077 3114078

| Parameter | Units | 50315619003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 0.14J | 40 | 40 | 43.7 | 44.8 | 109 | 112 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 38.7 | 38.3 | 96 | 95 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | 0.10J | 40 | 40 | 38.2 | 39.0 | 95 | 97 | 75-125 | 2 | 20 | |
| Selenium | ug/L | 2.8 | 40 | 40 | 40.8 | 40.2 | 95 | 93 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 676826
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3116141 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 2.2 | 2.0 | 05/18/22 17:48 | B |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 2.2 | 2.0 | 05/18/22 17:48 | B |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/18/22 17:48 | |

LABORATORY CONTROL SAMPLE: 3116142

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 52.3 | 105 | 90-110 | |

SAMPLE DUPLICATE: 3116143

| Parameter | Units | 50316216002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 235 | 244 | 4 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 235 | 244 | 4 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3116144

| Parameter | Units | 50316218009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 288 | 285 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 278 | 274 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | 9.8 | 10.8 | 10 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 676568
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3115085 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/17/22 12:50 | |

LABORATORY CONTROL SAMPLE: 3115086

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 282 | 94 | 80-120 | |

SAMPLE DUPLICATE: 3115087

| Parameter | Units | 50316214007 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 408 | 399 | 2 | 10 | |

SAMPLE DUPLICATE: 3115088

| Parameter | Units | 50316218009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 399 | 387 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 676460
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

SAMPLE DUPLICATE: 3114756

| Parameter | Units | 50316224003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.8 | 7.9 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3114757

| Parameter | Units | 50316227002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.9 | 6.9 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 676128
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3113215 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/13/22 13:06 | |

LABORATORY CONTROL SAMPLE: 3113216

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.54 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113217 3113218

| Parameter | Units | 50316227002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.39 | 0.39 | 77 | 77 | 90-110 | 0 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3113219

| Parameter | Units | 50316356001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.52 | 105 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 678174
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3122311 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/24/22 20:10 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3122312

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 102 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122313 3122314

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 107 | 107 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3122315

| Parameter | Units | 50316152006 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 5.7 | 10 | 16.0 | 103 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 675779
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3111592 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/12/22 08:38 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/12/22 08:38 | |

LABORATORY CONTROL SAMPLE: 3111593

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.97 | 97 | 90-110 | |

MATRIX SPIKE SAMPLE: 3111594

| Parameter | Units | 50316224002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 0.99 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.96 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111595 3111596

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 96 | 96 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 95 | 95 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 675807
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3111708 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 14:32 | |

LABORATORY CONTROL SAMPLE: 3111709

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111710 3111711

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.49 | | | 1.6 | 1.6 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 677562
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3120248 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/21/22 15:50 | |

LABORATORY CONTROL SAMPLE: 3120249

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.1 | 101 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120250 3120251

| Parameter | Units | 50316218009 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 4.9 | 10 | 10 | 15.2 | 15.6 | 103 | 107 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 3120252

| Parameter | Units | 50316219001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.1 | 102 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 677651
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 3120505 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/22/22 22:11 | |

LABORATORY CONTROL SAMPLE: 3120506

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.3 | 103 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120507 3120508

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.2 | 10 | 10 | 11.8 | 11.8 | 107 | 107 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3120509

| Parameter | Units | 50316227001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.0 | 10 | 12.4 | 104 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Sample: MW-108S** **Lab ID: 50316220001** Collected: 05/10/22 12:40 Received: 05/11/22 15:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.296 ± 0.274 (0.399) C:NA T:85%** | pCi/L | 06/20/22 17:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.364 ± 0.530 (1.14) C:55% T:85%** | pCi/L | 06/09/22 12:56 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.660 ± 0.804 (1.54)** | pCi/L | 06/21/22 14:37 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

**Sample: MW-108D** **Lab ID: 50316220002** Collected: 05/10/22 13:45 Received: 05/11/22 15:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.385 ± 0.270 (0.325) C:NA T:100%** | pCi/L | 06/20/22 17:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.08 ± 0.618 (1.14) C:50% T:100%** | pCi/L | 06/09/22 12:56 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.47 ± 0.888 (1.47)** | pCi/L | 06/21/22 14:37 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 506530
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 2453870 Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0750 ± 0.171 (0.404) C:NA T:87% | pCi/L | 06/20/22 16:50 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

QC Batch: 506531
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316220001, 50316220002

METHOD BLANK: 2453872
Matrix: Water
Associated Lab Samples: 50316220001, 50316220002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.641 ± 0.403 (0.744) C:66% T:87% | pCi/L | 06/09/22 13:02 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| B | Analyte was detected in the associated method blank. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316220

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316220001** | **MW-108S** | EPA 9056 | 677373 | | |
| **50316220002** | **MW-108D** | EPA 9056 | 677373 | | |
| **50316220001** | **MW-108S** | EPA 3010 | 676911 | EPA 6010 | 677773 |
| **50316220002** | **MW-108D** | EPA 3010 | 676911 | EPA 6010 | 677773 |
| **50316220001** | **MW-108S** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316220002** | **MW-108D** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316220001** | **MW-108S** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316220002** | **MW-108D** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316220001** | **MW-108S** | EPA 903.1 | 506530 | | |
| **50316220002** | **MW-108D** | EPA 903.1 | 506530 | | |
| **50316220001** | **MW-108S** | EPA 904.0 | 506531 | | |
| **50316220002** | **MW-108D** | EPA 904.0 | 506531 | | |
| **50316220001** | **MW-108S** | Total Radium Calculation | 513364 | | |
| **50316220002** | **MW-108D** | Total Radium Calculation | 513364 | | |
| **50316220001** | **MW-108S** | SM 2320B | 676826 | | |
| **50316220002** | **MW-108D** | SM 2320B | 676826 | | |
| **50316220001** | **MW-108S** | SM 2540C | 676568 | | |
| **50316220002** | **MW-108D** | SM 2540C | 676568 | | |
| **50316220001** | **MW-108S** | SM 4500-H+B | 676460 | | |
| **50316220002** | **MW-108D** | SM 4500-H+B | 676460 | | |
| **50316220001** | **MW-108S** | SM 4500-S2-D | 676128 | | |
| **50316220002** | **MW-108D** | SM 4500-S2-D | 676128 | | |
| **50316220001** | **MW-108S** | HACH 8146 | 678174 | | |
| **50316220002** | **MW-108D** | HACH 8146 | 678174 | | |
| **50316220001** | **MW-108S** | EPA 353.2 | 675779 | | |
| **50316220002** | **MW-108D** | EPA 353.2 | 675779 | | |
| **50316220001** | **MW-108S** | EPA 365.1 | 675807 | EPA 365.1 | 676393 |
| **50316220002** | **MW-108D** | EPA 365.1 | 675807 | EPA 365.1 | 676393 |
| **50316220001** | **MW-108S** | SM 5310C | 677562 | | |
| **50316220002** | **MW-108D** | SM 5310C | 677562 | | |
| **50316220001** | **MW-108S** | SM 5310C | 677651 | | |
| **50316220002** | **MW-108D** | SM 5310C | 677651 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50316220

50316220

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

...y constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam | |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: Atlas Indianapolis | Regulatory Agency |
| Indianapolis, IN 46256 | | Address: | |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: | |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 2 | Pace Project Manager: Hayden Putt | State / Location |
| Requested Due Date: | Project #: | Pace Profile #: 10498/16 | IN |

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | Requested Analysis Filtered (Y/N) | | | | Y | | | | Y | | | | | |
| 13 | ~~MW-105S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 14 | ~~MW-105I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 15 | ~~MW-105D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 16 | ~~MW-106S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 17 | ~~MW-106I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 18 | ~~MW-106D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 19 | ~~MW-107S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 20 | ~~MW-107I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 21 | ~~MW-107D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 22 | MW-108S | WT | G | 10/5 | 1240 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 23 | MW-108D | WT | G | 10/5 | 1345 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 24 | ~~DUP 3~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 0600 | 10/6 | | 5/11/22 | 1430 | | | | |
| 6020 (Co, As, Se, Sb) | Pac | 5/11/22 | 1545 | | 5-11-22 | 15:45 | 1.3 | y | N | y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | P. Gates Hopper | | | | | |
| SIGNATURE of SAMPLER: | | DATE Signed: 10/6/22 | | | | |

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** RC 5-11-22 16:03

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D (E) F

4. **Cooler Temperature(s):** 1.9/1.3 | | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** Circle: (HNO3 (<2)) (H2SO4 (<2)) NaOH (>10) (NaOH/ZnAc (>9)) Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** Analysis: $NO_3/NO_2$ | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1630 | ✓ | | Present | Absent | N/A ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | |
| Custody Signatures Present? | ✓ | | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| | | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

COC PAGE 1 of 1

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 11 | | | | | | | | | | | | 1 | 1 | | | 1 | 1 | 1 | 1 | 1 | 1 | | 1 | | | | | 1 | 1 | 1 | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 11, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316233001** | **MW-105S** | Water | 05/11/22 10:10 | 05/11/22 15:30 |
| **50316233002** | **MW-105I** | Water | 05/11/22 11:45 | 05/11/22 15:30 |
| **50316233003** | **MW-105D** | Water | 05/11/22 13:50 | 05/11/22 15:30 |
| **50316233004** | **DUP 4** | Water | 05/11/22 08:00 | 05/11/22 15:30 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316233001** | **MW-105S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316233002** | **MW-105I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316233003** | **MW-105D** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316233004** | **DUP 4** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | DJS | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | SWJ | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316233001** | **MW-105S** | | | | | |
| EPA 9056 | Chloride | 118 | mg/L | 25.0 | 05/23/22 22:45 | |
| EPA 9056 | Fluoride | 0.28 | mg/L | 0.10 | 05/23/22 22:11 | |
| EPA 9056 | Sulfate | 1230 | mg/L | 25.0 | 05/23/22 22:45 | |
| EPA 6010 | Barium | 32.7 | ug/L | 10.0 | 05/22/22 12:14 | |
| EPA 6010 | Boron | 22800 | ug/L | 100 | 05/22/22 12:14 | |
| EPA 6010 | Calcium | 335000 | ug/L | 2000 | 05/22/22 12:58 | |
| EPA 6010 | Iron | 8870 | ug/L | 100 | 05/22/22 12:14 | |
| EPA 6010 | Lithium | 306 | ug/L | 20.0 | 05/22/22 12:14 | |
| EPA 6010 | Magnesium | 85700 | ug/L | 1000 | 05/22/22 12:14 | |
| EPA 6010 | Manganese | 204 | ug/L | 10.0 | 05/22/22 12:14 | |
| EPA 6010 | Molybdenum | 74.0 | ug/L | 10.0 | 05/22/22 12:14 | |
| EPA 6010 | Potassium | 19200 | ug/L | 1000 | 05/22/22 12:14 | |
| EPA 6010 | Silica | 15300 | ug/L | 450 | 05/22/22 12:14 | N2 |
| EPA 6010 | Sodium | 132000 | ug/L | 1000 | 05/22/22 12:14 | |
| EPA 6010 | Manganese, Dissolved | 208 | ug/L | 10.0 | 05/22/22 02:47 | |
| EPA 6010 | Molybdenum, Dissolved | 72.3 | ug/L | 10.0 | 05/22/22 02:47 | |
| EPA 6020 | Arsenic | 5.5 | ug/L | 1.0 | 05/16/22 20:48 | |
| EPA 903.1 | Radium-226 | 0.436 ± 0.262 (0.107) C:NA T:93% | pCi/L | | 06/21/22 15:49 | |
| EPA 904.0 | Radium-228 | 0.945 ± 0.396 (0.623) C:81% T:93% | pCi/L | | 06/07/22 15:03 | |
| Total Radium Calculation | Total Radium | 1.38 ± 0.658 (0.730) | pCi/L | | 06/27/22 17:40 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 283 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 283 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2540C | Total Dissolved Solids | 2090 | mg/L | 40.0 | 05/18/22 09:36 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 05/16/22 15:23 | H3 |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 05/22/22 00:09 | |
| SM 5310C | Dissolved Organic Carbon | 1.5 | mg/L | 1.0 | 05/23/22 01:52 | |
| **50316233002** | **MW-105I** | | | | | |
| EPA 9056 | Chloride | 118 | mg/L | 2.5 | 05/23/22 23:19 | |
| EPA 9056 | Fluoride | 0.13 | mg/L | 0.10 | 05/23/22 23:02 | |
| EPA 9056 | Sulfate | 87.4 | mg/L | 2.5 | 05/23/22 23:19 | |
| EPA 6010 | Barium | 346 | ug/L | 10.0 | 05/22/22 12:16 | |
| EPA 6010 | Boron | 393 | ug/L | 100 | 05/22/22 12:16 | |
| EPA 6010 | Calcium | 103000 | ug/L | 1000 | 05/22/22 12:16 | |
| EPA 6010 | Iron | 4690 | ug/L | 100 | 05/22/22 12:16 | |
| EPA 6010 | Magnesium | 25100 | ug/L | 1000 | 05/22/22 12:16 | |
| EPA 6010 | Manganese | 124 | ug/L | 10.0 | 05/22/22 12:16 | |
| EPA 6010 | Potassium | 5470 | ug/L | 1000 | 05/22/22 12:16 | |
| EPA 6010 | Silica | 12100 | ug/L | 450 | 05/22/22 12:16 | N2 |
| EPA 6010 | Sodium | 68400 | ug/L | 1000 | 05/22/22 12:16 | |
| EPA 6010 | Manganese, Dissolved | 126 | ug/L | 10.0 | 05/22/22 02:49 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316233002** | **MW-105I** | | | | | |
| EPA 903.1 | Radium-226 | -0.0380 ± 0.268 (0.570) C:NA T:94% | pCi/L | | 06/21/22 16:08 | |
| EPA 904.0 | Radium-228 | 0.668 ± 0.420 (0.785) C:66% T:94% | pCi/L | | 06/07/22 15:03 | |
| Total Radium Calculation | Total Radium | 0.668 ± 0.688 (1.36) | pCi/L | | 06/27/22 17:40 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 284 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 284 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2540C | Total Dissolved Solids | 585 | mg/L | 10.0 | 05/18/22 09:37 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 05/16/22 15:24 | H3 |
| SM 5310C | Total Organic Carbon | 1.6 | mg/L | 1.0 | 05/22/22 00:32 | |
| SM 5310C | Dissolved Organic Carbon | 1.6 | mg/L | 1.0 | 05/23/22 02:03 | |
| **50316233003** | **MW-105D** | | | | | |
| EPA 9056 | Chloride | 115 | mg/L | 2.5 | 05/24/22 00:10 | |
| EPA 9056 | Fluoride | 0.22 | mg/L | 0.10 | 05/23/22 23:53 | |
| EPA 9056 | Sulfate | 120 | mg/L | 2.5 | 05/24/22 00:10 | |
| EPA 6010 | Barium | 332 | ug/L | 10.0 | 05/22/22 12:18 | |
| EPA 6010 | Boron | 1100 | ug/L | 100 | 05/22/22 12:18 | |
| EPA 6010 | Calcium | 101000 | ug/L | 1000 | 05/22/22 12:18 | |
| EPA 6010 | Iron | 5700 | ug/L | 100 | 05/22/22 12:18 | |
| EPA 6010 | Magnesium | 25000 | ug/L | 1000 | 05/22/22 12:18 | |
| EPA 6010 | Manganese | 115 | ug/L | 10.0 | 05/22/22 12:18 | |
| EPA 6010 | Molybdenum | 17.4 | ug/L | 10.0 | 05/22/22 12:18 | |
| EPA 6010 | Potassium | 5420 | ug/L | 1000 | 05/22/22 12:18 | |
| EPA 6010 | Silica | 12200 | ug/L | 450 | 05/22/22 12:18 | N2 |
| EPA 6010 | Sodium | 71400 | ug/L | 1000 | 05/22/22 12:18 | |
| EPA 6010 | Manganese, Dissolved | 121 | ug/L | 10.0 | 05/22/22 02:55 | |
| EPA 6010 | Molybdenum, Dissolved | 17.1 | ug/L | 10.0 | 05/22/22 02:55 | |
| EPA 6020 | Arsenic | 4.7 | ug/L | 1.0 | 05/16/22 21:07 | |
| EPA 903.1 | Radium-226 | 1.73 ± 0.561 (0.112) C:NA T:88% | pCi/L | | 06/21/22 16:23 | |
| EPA 904.0 | Radium-228 | 1.09 ± 0.545 (0.933) C:55% T:88% | pCi/L | | 06/07/22 15:03 | |
| Total Radium Calculation | Total Radium | 2.82 ± 1.11 (1.05) | pCi/L | | 06/27/22 17:40 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 272 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 272 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2540C | Total Dissolved Solids | 609 | mg/L | 10.0 | 05/18/22 09:37 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/16/22 15:25 | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316233003** | **MW-105D** | | | | | |
| EPA 353.2 | Nitrogen, Nitrate | 0.10 | mg/L | 0.10 | 05/12/22 09:45 | |
| EPA 365.1 | Phosphate as P04 | 0.26 | mg/L | 0.15 | 05/14/22 16:16 | |
| SM 5310C | Total Organic Carbon | 1.6 | mg/L | 1.0 | 05/22/22 00:49 | |
| SM 5310C | Dissolved Organic Carbon | 1.9 | mg/L | 1.0 | 05/23/22 02:15 | |
| **50316233004** | **DUP 4** | | | | | |
| EPA 9056 | Chloride | 114 | mg/L | 25.0 | 05/24/22 01:52 | |
| EPA 9056 | Fluoride | 0.27 | mg/L | 0.10 | 05/24/22 01:18 | |
| EPA 9056 | Sulfate | 1140 | mg/L | 25.0 | 05/24/22 01:52 | |
| EPA 6010 | Barium | 33.1 | ug/L | 10.0 | 05/22/22 12:21 | |
| EPA 6010 | Boron | 23000 | ug/L | 100 | 05/22/22 12:21 | |
| EPA 6010 | Calcium | 335000 | ug/L | 2000 | 05/22/22 13:00 | |
| EPA 6010 | Iron | 8940 | ug/L | 100 | 05/22/22 12:21 | |
| EPA 6010 | Lithium | 312 | ug/L | 20.0 | 05/22/22 12:21 | |
| EPA 6010 | Magnesium | 85400 | ug/L | 1000 | 05/22/22 12:21 | |
| EPA 6010 | Manganese | 204 | ug/L | 10.0 | 05/22/22 12:21 | |
| EPA 6010 | Molybdenum | 74.5 | ug/L | 10.0 | 05/22/22 12:21 | |
| EPA 6010 | Potassium | 19400 | ug/L | 1000 | 05/22/22 12:21 | |
| EPA 6010 | Silica | 15600 | ug/L | 450 | 05/22/22 12:21 | N2 |
| EPA 6010 | Sodium | 133000 | ug/L | 1000 | 05/22/22 12:21 | |
| EPA 6010 | Manganese, Dissolved | 212 | ug/L | 10.0 | 05/22/22 02:57 | |
| EPA 6010 | Molybdenum, Dissolved | 72.5 | ug/L | 10.0 | 05/22/22 02:57 | |
| EPA 6020 | Arsenic | 5.4 | ug/L | 1.0 | 05/16/22 21:12 | |
| EPA 903.1 | Radium-226 | 1.01 ± 0.397 (0.101) C:NA T:88% | pCi/L | | 06/21/22 16:23 | |
| EPA 904.0 | Radium-228 | 0.720 ± 0.414 (0.742) C:67% T:88% | pCi/L | | 06/07/22 15:03 | |
| Total Radium Calculation | Total Radium | 1.73 ± 0.811 (0.843) | pCi/L | | 06/27/22 17:40 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 286 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 286 | mg/L | 2.0 | 05/18/22 16:09 | |
| SM 2540C | Total Dissolved Solids | 2130 | mg/L | 40.0 | 05/18/22 09:37 | |
| SM 4500-H+B | pH at 25 Degrees C | 6.9 | Std. Units | 0.10 | 05/16/22 15:28 | H3 |
| SM 5310C | Total Organic Carbon | 1.3 | mg/L | 1.0 | 05/22/22 01:01 | |
| SM 5310C | Dissolved Organic Carbon | 1.3 | mg/L | 1.0 | 05/23/22 02:52 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105S** **Lab ID: 50316233001** Collected: 05/11/22 10:10 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **118** | mg/L | 25.0 | 100 | | 05/23/22 22:45 | 16887-00-6 | |
| Fluoride | **0.28** | mg/L | 0.10 | 1 | | 05/23/22 22:11 | 16984-48-8 | |
| Sulfate | **1230** | mg/L | 25.0 | 100 | | 05/23/22 22:45 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7429-90-5 | |
| Barium | **32.7** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7440-39-3 | |
| Boron | **22800** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7440-43-9 | |
| Calcium | **335000** | ug/L | 2000 | 2 | 05/19/22 14:22 | 05/22/22 12:58 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7440-47-3 | |
| Iron | **8870** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7439-92-1 | |
| Lithium | **306** | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7439-93-2 | |
| Magnesium | **85700** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7439-95-4 | |
| Manganese | **204** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7439-96-5 | |
| Molybdenum | **74.0** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7439-98-7 | |
| Potassium | **19200** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7440-09-7 | |
| Silica | **15300** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7631-86-9 | N2 |
| Sodium | **132000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:14 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **208** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:47 | 7439-96-5 | |
| Molybdenum, Dissolved | **72.3** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:47 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:48 | 7440-36-0 | |
| Arsenic | **5.5** | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:48 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:48 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:48 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **283** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Bicarbonate (CaCO3) | **283** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **2090** | mg/L | 40.0 | 1 | | 05/18/22 09:36 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105S** **Lab ID: 50316233001** Collected: 05/11/22 10:10 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 05/16/22 15:23 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 09:09 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 20:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 09:18 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:18 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/13/22 11:00 | 05/14/22 16:14 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/22/22 00:09 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.5** | mg/L | 1.0 | 1 | | 05/23/22 01:52 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105I** **Lab ID: 50316233002** Collected: 05/11/22 11:45 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **118** | mg/L | 2.5 | 10 | | 05/23/22 23:19 | 16887-00-6 | |
| Fluoride | **0.13** | mg/L | 0.10 | 1 | | 05/23/22 23:02 | 16984-48-8 | |
| Sulfate | **87.4** | mg/L | 2.5 | 10 | | 05/23/22 23:19 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7429-90-5 | |
| Barium | **346** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-39-3 | |
| Boron | **393** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-43-9 | |
| Calcium | **103000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-47-3 | |
| Iron | **4690** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7439-93-2 | |
| Magnesium | **25100** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7439-95-4 | |
| Manganese | **124** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7439-98-7 | |
| Potassium | **5470** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-09-7 | |
| Silica | **12100** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7631-86-9 | N2 |
| Sodium | **68400** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:16 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **126** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:49 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:49 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:52 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:52 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:52 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 20:52 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **284** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Bicarbonate (CaCO3) | **284** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **585** | mg/L | 10.0 | 1 | | 05/18/22 09:37 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105I** **Lab ID: 50316233002** Collected: 05/11/22 11:45 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 05/16/22 15:24 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 09:09 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 21:42 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 09:27 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:27 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/13/22 11:00 | 05/14/22 16:15 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/22/22 00:32 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/23/22 02:03 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105D** **Lab ID: 50316233003** Collected: 05/11/22 13:50 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **115** | mg/L | 2.5 | 10 | | 05/24/22 00:10 | 16887-00-6 | |
| Fluoride | **0.22** | mg/L | 0.10 | 1 | | 05/23/22 23:53 | 16984-48-8 | |
| Sulfate | **120** | mg/L | 2.5 | 10 | | 05/24/22 00:10 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7429-90-5 | |
| Barium | **332** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-39-3 | |
| Boron | **1100** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-43-9 | |
| Calcium | **101000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-47-3 | |
| Iron | **5700** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7439-93-2 | |
| Magnesium | **25000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7439-95-4 | |
| Manganese | **115** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7439-96-5 | |
| Molybdenum | **17.4** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7439-98-7 | |
| Potassium | **5420** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-09-7 | |
| Silica | **12200** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7631-86-9 | N2 |
| Sodium | **71400** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:18 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **121** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:55 | 7439-96-5 | |
| Molybdenum, Dissolved | **17.1** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:55 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:07 | 7440-36-0 | |
| Arsenic | **4.7** | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:07 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:07 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:07 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **272** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Bicarbonate (CaCO3) | **272** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **609** | mg/L | 10.0 | 1 | | 05/18/22 09:37 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105D** **Lab ID: 50316233003** Collected: 05/11/22 13:50 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/16/22 15:25 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 09:09 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 21:46 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.10** | mg/L | 0.10 | 1 | | 05/12/22 09:45 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:45 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.26** | mg/L | 0.15 | 1 | 05/13/22 11:00 | 05/14/22 16:16 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/22/22 00:49 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 05/23/22 02:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: DUP 4** **Lab ID: 50316233004** Collected: 05/11/22 08:00 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **114** | mg/L | 25.0 | 100 | | 05/24/22 01:52 | 16887-00-6 | |
| Fluoride | **0.27** | mg/L | 0.10 | 1 | | 05/24/22 01:18 | 16984-48-8 | |
| Sulfate | **1140** | mg/L | 25.0 | 100 | | 05/24/22 01:52 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7429-90-5 | |
| Barium | **33.1** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7440-39-3 | |
| Boron | **23000** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7440-43-9 | |
| Calcium | **335000** | ug/L | 2000 | 2 | 05/19/22 14:22 | 05/22/22 13:00 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7440-47-3 | |
| Iron | **8940** | ug/L | 100 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7439-92-1 | |
| Lithium | **312** | ug/L | 20.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7439-93-2 | |
| Magnesium | **85400** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7439-95-4 | |
| Manganese | **204** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7439-96-5 | |
| Molybdenum | **74.5** | ug/L | 10.0 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7439-98-7 | |
| Potassium | **19400** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7440-09-7 | |
| Silica | **15600** | ug/L | 450 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7631-86-9 | N2 |
| Sodium | **133000** | ug/L | 1000 | 1 | 05/19/22 14:22 | 05/22/22 12:21 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **212** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:57 | 7439-96-5 | |
| Molybdenum, Dissolved | **72.5** | ug/L | 10.0 | 1 | 05/21/22 14:36 | 05/22/22 02:57 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:12 | 7440-36-0 | |
| Arsenic | **5.4** | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:12 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:12 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/15/22 12:00 | 05/16/22 21:12 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **286** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Bicarbonate (CaCO3) | **286** | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/18/22 16:09 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **2130** | mg/L | 40.0 | 1 | | 05/18/22 09:37 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: DUP 4** **Lab ID: 50316233004** Collected: 05/11/22 08:00 Received: 05/11/22 15:30 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **6.9** | Std. Units | 0.10 | 1 | | 05/16/22 15:28 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 09:09 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 20:17 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 09:16 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 09:16 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/13/22 11:00 | 05/14/22 16:17 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/22/22 01:01 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.3** | mg/L | 1.0 | 1 | | 05/23/22 02:52 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 677373
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3118869 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/20/22 18:21 | |
| Fluoride | mg/L | ND | 0.10 | 05/20/22 18:21 | |
| Sulfate | mg/L | ND | 0.25 | 05/20/22 18:21 | |

LABORATORY CONTROL SAMPLE: 3118870

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 92 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 95 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.6 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3118871 3118872

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 88.8 | 12.5 | 12.5 | 99.9 | 100 | 89 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.32 | 0.5 | 0.5 | 0.81 | 0.82 | 98 | 99 | 80-120 | 1 | 15 | |
| Sulfate | mg/L | 88.0 | 25 | 25 | 109 | 109 | 85 | 82 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676914
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3116514 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/22/22 11:37 | |
| Barium | ug/L | ND | 10.0 | 05/22/22 11:37 | |
| Boron | ug/L | ND | 100 | 05/22/22 11:37 | |
| Cadmium | ug/L | ND | 2.0 | 05/22/22 11:37 | |
| Calcium | ug/L | ND | 1000 | 05/22/22 11:37 | |
| Chromium | ug/L | ND | 10.0 | 05/22/22 11:37 | |
| Iron | ug/L | ND | 100 | 05/22/22 11:37 | |
| Lead | ug/L | ND | 10.0 | 05/22/22 11:37 | |
| Lithium | ug/L | ND | 20.0 | 05/22/22 11:37 | |
| Magnesium | ug/L | ND | 1000 | 05/22/22 11:37 | |
| Manganese | ug/L | ND | 10.0 | 05/22/22 11:37 | |
| Molybdenum | ug/L | ND | 10.0 | 05/22/22 11:37 | |
| Potassium | ug/L | ND | 1000 | 05/22/22 11:37 | |
| Silica | ug/L | ND | 450 | 05/22/22 11:37 | N2 |
| Sodium | ug/L | ND | 1000 | 05/22/22 11:37 | |

LABORATORY CONTROL SAMPLE: 3116515

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Barium | ug/L | 1000 | 1070 | 107 | 80-120 | |
| Boron | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Cadmium | ug/L | 1000 | 988 | 99 | 80-120 | |
| Calcium | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Chromium | ug/L | 1000 | 1030 | 103 | 80-120 | |
| Iron | ug/L | 10000 | 10500 | 105 | 80-120 | |
| Lead | ug/L | 1000 | 967 | 97 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 10000 | 9900 | 99 | 80-120 | |
| Manganese | ug/L | 1000 | 971 | 97 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1060 | 106 | 80-120 | |
| Potassium | ug/L | 10000 | 10300 | 103 | 80-120 | |
| Silica | ug/L | 10700 | 10300 | 96 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 10100 | 101 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116516 3116517

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10200 | 10200 | 101 | 102 | 75-125 | 0 | 20 | |
| Barium | ug/L | 60.9 | 1000 | 1000 | 1140 | 1110 | 108 | 105 | 75-125 | 2 | 20 | |
| Boron | ug/L | 867 | 1000 | 1000 | 1900 | 1900 | 104 | 103 | 75-125 | 0 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 994 | 992 | 99 | 99 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 70000 | 10000 | 10000 | 80700 | 79700 | 106 | 97 | 75-125 | 1 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 1 | 20 | |
| Iron | ug/L | 1580 | 10000 | 10000 | 12100 | 11900 | 105 | 103 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 942 | 934 | 94 | 93 | 75-125 | 1 | 20 | |
| Lithium | ug/L | 84.5 | 1000 | 1000 | 1140 | 1130 | 106 | 104 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 19400 | 10000 | 10000 | 29400 | 29000 | 100 | 96 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 316 | 1000 | 1000 | 1280 | 1270 | 97 | 96 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 104 | 1000 | 1000 | 1170 | 1160 | 106 | 105 | 75-125 | 1 | 20 | |
| Potassium | ug/L | 7390 | 10000 | 10000 | 18200 | 17800 | 108 | 105 | 75-125 | 2 | 20 | |
| Silica | ug/L | 9130 | 10700 | 10700 | 19700 | 19700 | 99 | 99 | 75-125 | 0 | 20 | N2 |
| Sodium | ug/L | 75700 | 10000 | 10000 | 87400 | 85500 | 117 | 99 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 677433
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3119294 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/22/22 02:16 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/22/22 02:16 | |

LABORATORY CONTROL SAMPLE: 3119295

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 971 | 97 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1000 | 100 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3119296 3119297

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 309 | 1000 | 1000 | 1290 | 1220 | 98 | 91 | 75-125 | 6 | 20 | |
| Molybdenum, Dissolved | ug/L | 102 | 1000 | 1000 | 1120 | 1060 | 102 | 95 | 75-125 | 6 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676262
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3114075 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Arsenic | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Cobalt | ug/L | ND | 1.0 | 05/16/22 14:41 | |
| Selenium | ug/L | ND | 1.0 | 05/16/22 14:41 | |

LABORATORY CONTROL SAMPLE: 3114076

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 43.2 | 108 | 80-120 | |
| Arsenic | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Cobalt | ug/L | 40 | 40.8 | 102 | 80-120 | |
| Selenium | ug/L | 40 | 40.6 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114077 3114078

| Parameter | Units | 50315619003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 0.14J | 40 | 40 | 43.7 | 44.8 | 109 | 112 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 38.7 | 38.3 | 96 | 95 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | 0.10J | 40 | 40 | 38.2 | 39.0 | 95 | 97 | 75-125 | 2 | 20 | |
| Selenium | ug/L | 2.8 | 40 | 40 | 40.8 | 40.2 | 95 | 93 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676828
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3116149 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/18/22 16:09 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/18/22 16:09 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/18/22 16:09 | |

LABORATORY CONTROL SAMPLE: 3116150

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 51.5 | 103 | 90-110 | |

SAMPLE DUPLICATE: 3116151

| Parameter | Units | 50316224003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 235 | 236 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 235 | 236 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3116152

| Parameter | Units | 50316329004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 274 | 274 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 266 | 264 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | 8.0 | 9.4 | 16 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676814 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3116097 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/18/22 09:32 | |

LABORATORY CONTROL SAMPLE: 3116098

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 284 | 95 | 80-120 | |

SAMPLE DUPLICATE: 3116099

| Parameter | Units | 50316227001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 468 | 474 | 1 | 10 | |

SAMPLE DUPLICATE: 3116100

| Parameter | Units | 50316227002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1070 | 1130 | 6 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676461
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

SAMPLE DUPLICATE: 3114761

| Parameter | Units | 50316227003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.8 | 6.8 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3114762

| Parameter | Units | 50315436001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.9 | 8.1 | 3 | 2 | H3,R1 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676048
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3112808 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/13/22 09:09 | |

LABORATORY CONTROL SAMPLE: 3112809

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.54 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112810 3112811

| Parameter | Units | 50315982002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.19 | 0.20 | 37 | 39 | 90-110 | 4 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3112812

| Parameter | Units | 50315982003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.47 | 95 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 678174
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233004

METHOD BLANK: 3122311 Matrix: Water
Associated Lab Samples: 50316233001, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/24/22 20:10 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3122312

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 102 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122313 3122314

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 107 | 107 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3122315

| Parameter | Units | 50316152006 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 5.7 | 10 | 16.0 | 103 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 678187
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233002, 50316233003

METHOD BLANK: 3122392 Matrix: Water
Associated Lab Samples: 50316233002, 50316233003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/24/22 21:40 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3122393

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 0.99 | 99 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122394 3122395

| Parameter | Units | 50316356002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 102 | 102 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3122396

| Parameter | Units | 50316334005 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 0.98 | 98 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 675779
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233004

METHOD BLANK: 3111592 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/12/22 08:38 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/12/22 08:38 | |

LABORATORY CONTROL SAMPLE: 3111593

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.97 | 97 | 90-110 | |

MATRIX SPIKE SAMPLE: 3111594

| Parameter | Units | 50316224002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 0.99 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.96 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111595 3111596

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 96 | 96 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 95 | 95 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 675780
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233003

METHOD BLANK: 3111597 Matrix: Water
Associated Lab Samples: 50316233003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/12/22 09:51 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/12/22 09:51 | |

LABORATORY CONTROL SAMPLE: 3111598

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.97 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111599 3111600

| Parameter | Units | 50316216005 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.95 | 0.95 | 95 | 95 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3112544

| Parameter | Units | 50316291001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1.0 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.96 | 96 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 676061
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3112885 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 16:03 | |

LABORATORY CONTROL SAMPLE: 3112886

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112887 3112888

| Parameter | Units | 50316227002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.63 | | | 2.1 | 2.2 | | | | 4 | | |

MATRIX SPIKE SAMPLE: 3112889

| Parameter | Units | 50316233001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.4 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 677564 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3120257 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/21/22 21:56 | |

LABORATORY CONTROL SAMPLE: 3120258

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.2 | 102 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120259 3120260

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 11.2 | 11.1 | 104 | 102 | 80-120 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3120261

| Parameter | Units | 50316233001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.3 | 10 | 11.8 | 105 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 677651 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 3120505 — Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/22/22 22:11 | |

LABORATORY CONTROL SAMPLE: 3120506

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.3 | 103 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120507 3120508

| Parameter | Units | 50316224003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.2 | 10 | 10 | 11.8 | 11.8 | 107 | 107 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3120509

| Parameter | Units | 50316227001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.0 | 10 | 12.4 | 104 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105S** **Lab ID: 50316233001** Collected: 05/11/22 10:10 Received: 05/11/22 15:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.436 ± 0.262 (0.107) C:NA T:93%** | pCi/L | 06/21/22 15:49 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.945 ± 0.396 (0.623) C:81% T:93%** | pCi/L | 06/07/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.38 ± 0.658 (0.730)** | pCi/L | 06/27/22 17:40 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105I** **Lab ID: 50316233002** Collected: 05/11/22 11:45 Received: 05/11/22 15:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.0380 ± 0.268 (0.570) C:NA T:94%** | pCi/L | 06/21/22 16:08 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.668 ± 0.420 (0.785) C:66% T:94%** | pCi/L | 06/07/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.668 ± 0.688 (1.36)** | pCi/L | 06/27/22 17:40 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: MW-105D** **Lab ID: 50316233003** Collected: 05/11/22 13:50 Received: 05/11/22 15:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.73 ± 0.561 (0.112) C:NA T:88%** | pCi/L | 06/21/22 16:23 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.09 ± 0.545 (0.933) C:55% T:88%** | pCi/L | 06/07/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **2.82 ± 1.11 (1.05)** | pCi/L | 06/27/22 17:40 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

**Sample: DUP 4** **Lab ID: 50316233004** Collected: 05/11/22 08:00 Received: 05/11/22 15:30 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **1.01 ± 0.397 (0.101) C:NA T:88%** | pCi/L | 06/21/22 16:23 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.720 ± 0.414 (0.742) C:67% T:88%** | pCi/L | 06/07/22 15:03 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.73 ± 0.811 (0.843)** | pCi/L | 06/27/22 17:40 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 506532
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 2453874 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0795 ± 0.292 (0.631) C:NA T:92% | pCi/L | 06/21/22 15:18 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

QC Batch: 506533
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

METHOD BLANK: 2453877 Matrix: Water
Associated Lab Samples: 50316233001, 50316233002, 50316233003, 50316233004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.331 ± 0.336 (0.694) C:79% T:92% | pCi/L | 06/07/22 14:59 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| R1 | RPD value was outside control limits. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316233001** | **MW-105S** | EPA 9056 | 677373 | | |
| **50316233002** | **MW-105I** | EPA 9056 | 677373 | | |
| **50316233003** | **MW-105D** | EPA 9056 | 677373 | | |
| **50316233004** | **DUP 4** | EPA 9056 | 677373 | | |
| **50316233001** | **MW-105S** | EPA 3010 | 676914 | EPA 6010 | 677629 |
| **50316233002** | **MW-105I** | EPA 3010 | 676914 | EPA 6010 | 677629 |
| **50316233003** | **MW-105D** | EPA 3010 | 676914 | EPA 6010 | 677629 |
| **50316233004** | **DUP 4** | EPA 3010 | 676914 | EPA 6010 | 677629 |
| **50316233001** | **MW-105S** | EPA 3010 | 677433 | EPA 6010 | 677617 |
| **50316233002** | **MW-105I** | EPA 3010 | 677433 | EPA 6010 | 677617 |
| **50316233003** | **MW-105D** | EPA 3010 | 677433 | EPA 6010 | 677617 |
| **50316233004** | **DUP 4** | EPA 3010 | 677433 | EPA 6010 | 677617 |
| **50316233001** | **MW-105S** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316233002** | **MW-105I** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316233003** | **MW-105D** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316233004** | **DUP 4** | EPA 200.2 | 676262 | EPA 6020 | 676349 |
| **50316233001** | **MW-105S** | EPA 903.1 | 506532 | | |
| **50316233002** | **MW-105I** | EPA 903.1 | 506532 | | |
| **50316233003** | **MW-105D** | EPA 903.1 | 506532 | | |
| **50316233004** | **DUP 4** | EPA 903.1 | 506532 | | |
| **50316233001** | **MW-105S** | EPA 904.0 | 506533 | | |
| **50316233002** | **MW-105I** | EPA 904.0 | 506533 | | |
| **50316233003** | **MW-105D** | EPA 904.0 | 506533 | | |
| **50316233004** | **DUP 4** | EPA 904.0 | 506533 | | |
| **50316233001** | **MW-105S** | Total Radium Calculation | 514744 | | |
| **50316233002** | **MW-105I** | Total Radium Calculation | 514744 | | |
| **50316233003** | **MW-105D** | Total Radium Calculation | 514744 | | |
| **50316233004** | **DUP 4** | Total Radium Calculation | 514744 | | |
| **50316233001** | **MW-105S** | SM 2320B | 676828 | | |
| **50316233002** | **MW-105I** | SM 2320B | 676828 | | |
| **50316233003** | **MW-105D** | SM 2320B | 676828 | | |
| **50316233004** | **DUP 4** | SM 2320B | 676828 | | |
| **50316233001** | **MW-105S** | SM 2540C | 676814 | | |
| **50316233002** | **MW-105I** | SM 2540C | 676814 | | |
| **50316233003** | **MW-105D** | SM 2540C | 676814 | | |
| **50316233004** | **DUP 4** | SM 2540C | 676814 | | |
| **50316233001** | **MW-105S** | SM 4500-H+B | 676461 | | |
| **50316233002** | **MW-105I** | SM 4500-H+B | 676461 | | |
| **50316233003** | **MW-105D** | SM 4500-H+B | 676461 | | |
| **50316233004** | **DUP 4** | SM 4500-H+B | 676461 | | |
| **50316233001** | **MW-105S** | SM 4500-S2-D | 676048 | | |
| **50316233002** | **MW-105I** | SM 4500-S2-D | 676048 | | |
| **50316233003** | **MW-105D** | SM 4500-S2-D | 676048 | | |
| **50316233004** | **DUP 4** | SM 4500-S2-D | 676048 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316233

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316233001** | **MW-105S** | HACH 8146 | 678174 | | |
| **50316233002** | **MW-105I** | HACH 8146 | 678187 | | |
| **50316233003** | **MW-105D** | HACH 8146 | 678187 | | |
| **50316233004** | **DUP 4** | HACH 8146 | 678174 | | |
| **50316233001** | **MW-105S** | EPA 353.2 | 675779 | | |
| **50316233002** | **MW-105I** | EPA 353.2 | 675779 | | |
| **50316233003** | **MW-105D** | EPA 353.2 | 675780 | | |
| **50316233004** | **DUP 4** | EPA 353.2 | 675779 | | |
| **50316233001** | **MW-105S** | EPA 365.1 | 676061 | EPA 365.1 | 676409 |
| **50316233002** | **MW-105I** | EPA 365.1 | 676061 | EPA 365.1 | 676409 |
| **50316233003** | **MW-105D** | EPA 365.1 | 676061 | EPA 365.1 | 676409 |
| **50316233004** | **DUP 4** | EPA 365.1 | 676061 | EPA 365.1 | 676409 |
| **50316233001** | **MW-105S** | SM 5310C | 677564 | | |
| **50316233002** | **MW-105I** | SM 5310C | 677564 | | |
| **50316233003** | **MW-105D** | SM 5310C | 677564 | | |
| **50316233004** | **DUP 4** | SM 5310C | 677564 | | |
| **50316233001** | **MW-105S** | SM 5310C | 677651 | | |
| **50316233002** | **MW-105I** | SM 5310C | 677651 | | |
| **50316233003** | **MW-105D** | SM 5310C | 677651 | | |
| **50316233004** | **DUP 4** | SM 5310C | 677651 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

# CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical® WWW.PACELABS.COM

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://...

**WO# : 50316233**

50316233

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indi |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 2 | Pace Project Manager: | Ha |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/16 |

IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | |
| 13 | MW-105S | WT | | 5/11 | 1010 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 001 |
| 14 | MW-105I | WT | | 5/11 | 1145 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 002 |
| 15 | MW-105D | WT | | 5/11 | 1350 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | 003 |
| 16 | ~~MW-106S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 17 | ~~MW-106I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 18 | ~~MW-106D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 19 | ~~MW-107S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 20 | ~~MW-107I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 21 | ~~MW-107D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 22 | ~~MW-108S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 23 | ~~MW-108D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 24 | ~~DUP-3~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 5/11 | 1530 | | 5-11-22 | 15:30 | 3.2 | y | N | y |
| 6020 (Co, As, Se, Sb) | | | | | | | 1.4 | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | | |
|---|---|---|---|---|
| PRINT Name of SAMPLER: | P. Gies Hoppe | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| SIGNATURE of SAMPLER: | DATE Signed: 5/11 | | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A – Required Client Information: | | Section B – Required Project Information: | | Section C – Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 2 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/16 |

Regulatory Agency

State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | | |
| 25 | DUP 4 | WT | G | 5/11 | — | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 004 |
| 26 | ~~Field Blank 2~~ | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | | | |
| 27 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 29 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 30 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 5/11 | 1530 | | 5-11-22 | 15:30 | 3,2 | Y | N | Y |
| 6020 (Co, As, Se, Sb) | | | | | | | 1,4 | Y | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | |
|---|---|---|---|
| PRINT Name of SAMPLER: | P. Grey Hopper | TEMP in C | Received on Ice (Y/N) |
| SIGNATURE of SAMPLER: | DATE Signed: 5/11 | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** RC 5-11-22 17:00

1. **Courier:** ☐ FED EX ☐ UPS ☑ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** 3.8/3.2 | 2.0/1.4 | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** Circle: **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** $NO_3$, $NO_2$ | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | ✓ | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

**COC PAGE 1 of 2**

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | 1 | 1 | | | 1 | 1 | 1 | 1 | 1 | 1 | | 1 | | | | | 1 | 1 | 1 | |
| 3 | | | | | | | | | | | | 1 | 1 | | | 1 | 1 | 1 | 1 | 1 | 1 | | 1 | | | | | 1 | 1 | 1 | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE** 2 **of** 2

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 12, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316356001** | **MW-15D** | Water | 05/11/22 13:30 | 05/12/22 13:45 |
| **50316356002** | **MW-14D** | Water | 05/11/22 10:40 | 05/12/22 13:45 |
| **50316356003** | **MW-11S** | Water | 05/11/22 11:20 | 05/12/22 13:45 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316356001** | **MW-15D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316356002** | **MW-14D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | WDB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316356003** | **MW-11S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | JPK | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | WDB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316356001** | **MW-15D** | | | | | |
| EPA 9056 | Chloride | 29.1 | mg/L | 2.5 | 05/26/22 02:52 | |
| EPA 9056 | Fluoride | 0.12 | mg/L | 0.10 | 05/26/22 02:34 | |
| EPA 9056 | Sulfate | 73.2 | mg/L | 2.5 | 05/26/22 02:52 | |
| EPA 6010 | Barium | 75.1 | ug/L | 10.0 | 05/25/22 03:31 | |
| EPA 6010 | Boron | 157 | ug/L | 100 | 05/25/22 03:31 | |
| EPA 6010 | Calcium | 106000 | ug/L | 1000 | 05/25/22 03:31 | |
| EPA 6010 | Iron | 1220 | ug/L | 100 | 05/25/22 03:31 | |
| EPA 6010 | Magnesium | 31300 | ug/L | 1000 | 05/25/22 03:31 | |
| EPA 6010 | Manganese | 115 | ug/L | 10.0 | 05/25/22 03:31 | |
| EPA 6010 | Potassium | 2280 | ug/L | 1000 | 05/25/22 03:31 | |
| EPA 6010 | Silica | 12600 | ug/L | 450 | 05/25/22 03:31 | N2 |
| EPA 6010 | Sodium | 22800 | ug/L | 1000 | 05/25/22 03:31 | |
| EPA 6010 | Manganese, Dissolved | 117 | ug/L | 10.0 | 05/24/22 03:15 | |
| EPA 6020 | Arsenic | 1.2 | ug/L | 1.0 | 05/18/22 18:41 | |
| EPA 903.1 | Radium-226 | 0.134 ± 0.651 (1.12) C:NA T:84% | pCi/L | | 06/21/22 11:56 | |
| EPA 904.0 | Radium-228 | 0.631 ± 0.506 (1.01) C:69% T:86% | pCi/L | | 06/14/22 18:01 | |
| Total Radium Calculation | Total Radium | 0.765 ± 1.16 (2.13) | pCi/L | | 06/21/22 18:15 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 339 | mg/L | 2.0 | 05/19/22 11:13 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 339 | mg/L | 2.0 | 05/19/22 11:13 | |
| SM 2540C | Total Dissolved Solids | 512 | mg/L | 10.0 | 05/18/22 11:45 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/20/22 15:03 | H3 |
| SM 5310C | Total Organic Carbon | 1.1 | mg/L | 1.0 | 05/22/22 05:17 | |
| **50316356002** | **MW-14D** | | | | | |
| EPA 9056 | Chloride | 171 | mg/L | 25.0 | 05/26/22 04:06 | |
| EPA 9056 | Fluoride | 0.33 | mg/L | 0.10 | 05/26/22 03:29 | |
| EPA 9056 | Sulfate | 2190 | mg/L | 25.0 | 05/26/22 04:06 | |
| EPA 6010 | Barium | 44.3 | ug/L | 10.0 | 05/25/22 03:33 | |
| EPA 6010 | Boron | 54100 | ug/L | 100 | 05/25/22 03:33 | |
| EPA 6010 | Calcium | 383000 | ug/L | 3000 | 05/25/22 03:41 | |
| EPA 6010 | Iron | 2610 | ug/L | 100 | 05/25/22 03:33 | |
| EPA 6010 | Lithium | 768 | ug/L | 20.0 | 05/25/22 03:33 | |
| EPA 6010 | Magnesium | 216000 | ug/L | 1000 | 05/25/22 03:33 | |
| EPA 6010 | Manganese | 320 | ug/L | 10.0 | 05/25/22 03:33 | |
| EPA 6010 | Molybdenum | 203 | ug/L | 10.0 | 05/25/22 03:33 | |
| EPA 6010 | Potassium | 61200 | ug/L | 1000 | 05/25/22 03:33 | |
| EPA 6010 | Silica | 11900 | ug/L | 450 | 05/25/22 03:33 | N2 |
| EPA 6010 | Sodium | 357000 | ug/L | 3000 | 05/25/22 03:41 | |
| EPA 6010 | Manganese, Dissolved | 329 | ug/L | 10.0 | 05/24/22 03:17 | |
| EPA 6010 | Molybdenum, Dissolved | 205 | ug/L | 10.0 | 05/24/22 03:17 | |
| EPA 6020 | Arsenic | 127 | ug/L | 1.0 | 05/18/22 18:45 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316356002** | **MW-14D** | | | | | |
| EPA 903.1 | Radium-226 | -0.0383 ± 0.338 (0.736) C:NA T:95% | pCi/L | | 06/21/22 11:56 | |
| EPA 904.0 | Radium-228 | 1.03 ± 0.527 (0.925) C:66% T:93% | pCi/L | | 06/14/22 17:51 | |
| Total Radium Calculation | Total Radium | 1.03 ± 0.865 (1.66) | pCi/L | | 06/21/22 18:15 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 276 | mg/L | 2.0 | 05/19/22 16:29 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 276 | mg/L | 2.0 | 05/19/22 16:29 | |
| SM 2540C | Total Dissolved Solids | 3610 | mg/L | 40.0 | 05/18/22 11:45 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 05/20/22 15:04 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.71 | mg/L | 0.15 | 05/15/22 19:20 | |
| SM 5310C | Total Organic Carbon | 2.1 | mg/L | 1.0 | 05/22/22 05:37 | |
| SM 5310C | Dissolved Organic Carbon | 2.6 | mg/L | 1.0 | 05/23/22 08:27 | |
| **50316356003** | **MW-11S** | | | | | |
| EPA 9056 | Chloride | 25.5 | mg/L | 2.5 | 05/26/22 04:43 | |
| EPA 9056 | Fluoride | 1.8 | mg/L | 0.10 | 05/26/22 04:25 | |
| EPA 9056 | Sulfate | 108 | mg/L | 2.5 | 05/26/22 04:43 | |
| EPA 6010 | Aluminum | 10100 | ug/L | 200 | 05/25/22 03:35 | |
| EPA 6010 | Barium | 175 | ug/L | 10.0 | 05/25/22 03:35 | |
| EPA 6010 | Boron | 712 | ug/L | 100 | 05/25/22 03:35 | |
| EPA 6010 | Calcium | 108000 | ug/L | 1000 | 05/25/22 03:35 | |
| EPA 6010 | Chromium | 14.8 | ug/L | 10.0 | 05/25/22 03:35 | |
| EPA 6010 | Iron | 12800 | ug/L | 100 | 05/25/22 03:35 | |
| EPA 6010 | Lithium | 25.1 | ug/L | 20.0 | 05/25/22 03:35 | |
| EPA 6010 | Magnesium | 49500 | ug/L | 1000 | 05/25/22 03:35 | |
| EPA 6010 | Manganese | 281 | ug/L | 10.0 | 05/25/22 03:35 | |
| EPA 6010 | Molybdenum | 82.5 | ug/L | 10.0 | 05/25/22 03:35 | |
| EPA 6010 | Potassium | 5580 | ug/L | 1000 | 05/25/22 03:35 | |
| EPA 6010 | Silica | 49100 | ug/L | 450 | 05/25/22 03:35 | N2 |
| EPA 6010 | Sodium | 21300 | ug/L | 1000 | 05/25/22 03:35 | |
| EPA 6010 | Manganese, Dissolved | 34.3 | ug/L | 10.0 | 05/24/22 03:19 | |
| EPA 6010 | Molybdenum, Dissolved | 79.8 | ug/L | 10.0 | 05/24/22 03:19 | |
| EPA 6020 | Arsenic | 10.5 | ug/L | 1.0 | 05/18/22 21:09 | |
| EPA 6020 | Beryllium | 0.40 | ug/L | 0.20 | 05/18/22 21:09 | |
| EPA 6020 | Cobalt | 4.9 | ug/L | 1.0 | 05/18/22 21:09 | |
| EPA 6020 | Selenium | 1.1 | ug/L | 1.0 | 05/18/22 21:09 | |
| EPA 903.1 | Radium-226 | 0.218 ± 0.574 (1.03) C:NA T:91% | pCi/L | | 06/21/22 11:56 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316356003** | **MW-11S** | | | | | |
| EPA 904.0 | Radium-228 | 0.529 ± 0.410 (0.801) C:71% T:88% | pCi/L | | 06/14/22 17:51 | |
| Total Radium Calculation | Total Radium | 0.747 ± 0.984 (1.83) | pCi/L | | 06/21/22 18:15 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 309 | mg/L | 2.0 | 05/19/22 16:29 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 309 | mg/L | 2.0 | 05/19/22 16:29 | |
| SM 2540C | Total Dissolved Solids | 440 | mg/L | 10.0 | 05/18/22 12:31 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.9 | Std. Units | 0.10 | 05/20/22 15:04 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.61 | mg/L | 0.15 | 05/15/22 19:55 | |
| SM 5310C | Dissolved Organic Carbon | 1.1 | mg/L | 1.0 | 05/23/22 08:38 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-15D** **Lab ID: 50316356001** Collected: 05/11/22 13:30 Received: 05/12/22 13:45 Matrix: Water

Comments: • Upon receipt at the laboratory, 2.5 mls of nitric acid were added to the sample to meet the sample preservation requirement of pH <2 for radiochemistry analysis. The samples were not preserved <2 within the required 5 days of collection.

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **29.1** | mg/L | 2.5 | 10 | | 05/26/22 02:52 | 16887-00-6 | |
| Fluoride | **0.12** | mg/L | 0.10 | 1 | | 05/26/22 02:34 | 16984-48-8 | |
| Sulfate | **73.2** | mg/L | 2.5 | 10 | | 05/26/22 02:52 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7429-90-5 | |
| Barium | **75.1** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-39-3 | |
| Boron | **157** | ug/L | 100 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-43-9 | |
| Calcium | **106000** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-47-3 | |
| Iron | **1220** | ug/L | 100 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7439-93-2 | |
| Magnesium | **31300** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7439-95-4 | |
| Manganese | **115** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7439-98-7 | |
| Potassium | **2280** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-09-7 | |
| Silica | **12600** | ug/L | 450 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7631-86-9 | N2 |
| Sodium | **22800** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:31 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **117** | ug/L | 10.0 | 1 | 05/21/22 15:00 | 05/24/22 03:15 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/21/22 15:00 | 05/24/22 03:15 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:41 | 7440-36-0 | |
| Arsenic | **1.2** | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:41 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/17/22 14:40 | 05/18/22 18:41 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:41 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:41 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:41 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/19/22 10:59 | 05/19/22 21:10 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **339** | mg/L | 2.0 | 1 | | 05/19/22 11:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-15D** **Lab ID: 50316356001** Collected: 05/11/22 13:30 Received: 05/12/22 13:45 Matrix: Water

Comments: • Upon receipt at the laboratory, 2.5 mls of nitric acid were added to the sample to meet the sample preservation requirement of pH <2 for radiochemistry analysis. The samples were not preserved <2 within the required 5 days of collection.

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2320B Alkalinity** | Analytical Method: SM 2320B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity,Bicarbonate (CaCO3) | **339** | mg/L | 2.0 | 1 | | 05/19/22 11:13 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/19/22 11:13 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **512** | mg/L | 10.0 | 1 | | 05/18/22 11:45 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/20/22 15:03 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 13:06 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 21:45 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 17:50 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 17:50 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/13/22 11:00 | 05/15/22 19:20 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 05/22/22 05:17 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/23/22 08:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-14D** **Lab ID: 50316356002** Collected: 05/11/22 10:40 Received: 05/12/22 13:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **171** | mg/L | 25.0 | 100 | | 05/26/22 04:06 | 16887-00-6 | |
| Fluoride | **0.33** | mg/L | 0.10 | 1 | | 05/26/22 03:29 | 16984-48-8 | |
| Sulfate | **2190** | mg/L | 25.0 | 100 | | 05/26/22 04:06 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7429-90-5 | |
| Barium | **44.3** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7440-39-3 | |
| Boron | **54100** | ug/L | 100 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7440-43-9 | |
| Calcium | **383000** | ug/L | 3000 | 3 | 05/24/22 14:38 | 05/25/22 03:41 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7440-47-3 | |
| Iron | **2610** | ug/L | 100 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7439-92-1 | |
| Lithium | **768** | ug/L | 20.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7439-93-2 | |
| Magnesium | **216000** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7439-95-4 | |
| Manganese | **320** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7439-96-5 | |
| Molybdenum | **203** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7439-98-7 | |
| Potassium | **61200** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7440-09-7 | |
| Silica | **11900** | ug/L | 450 | 1 | 05/24/22 14:38 | 05/25/22 03:33 | 7631-86-9 | N2 |
| Sodium | **357000** | ug/L | 3000 | 3 | 05/24/22 14:38 | 05/25/22 03:41 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **329** | ug/L | 10.0 | 1 | 05/21/22 15:00 | 05/24/22 03:17 | 7439-96-5 | |
| Molybdenum, Dissolved | **205** | ug/L | 10.0 | 1 | 05/21/22 15:00 | 05/24/22 03:17 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:45 | 7440-36-0 | |
| Arsenic | **127** | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:45 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/17/22 14:40 | 05/18/22 18:45 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:45 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:45 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 18:45 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/19/22 10:59 | 05/19/22 21:12 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **276** | mg/L | 2.0 | 1 | | 05/19/22 16:29 | | |
| Alkalinity,Bicarbonate (CaCO3) | **276** | mg/L | 2.0 | 1 | | 05/19/22 16:29 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/19/22 16:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-14D** **Lab ID: 50316356002** Collected: 05/11/22 10:40 Received: 05/12/22 13:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **3610** | mg/L | 40.0 | 1 | | 05/18/22 11:45 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 1 | | 05/20/22 15:04 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 13:06 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 21:40 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 17:24 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 17:24 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.71** | mg/L | 0.15 | 1 | 05/13/22 11:00 | 05/15/22 19:20 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.1** | mg/L | 1.0 | 1 | | 05/22/22 05:37 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.6** | mg/L | 1.0 | 1 | | 05/23/22 08:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-11S** **Lab ID: 50316356003** Collected: 05/11/22 11:20 Received: 05/12/22 13:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **25.5** | mg/L | 2.5 | 10 | | 05/26/22 04:43 | 16887-00-6 | |
| Fluoride | **1.8** | mg/L | 0.10 | 1 | | 05/26/22 04:25 | 16984-48-8 | |
| Sulfate | **108** | mg/L | 2.5 | 10 | | 05/26/22 04:43 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **10100** | ug/L | 200 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7429-90-5 | |
| Barium | **175** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-39-3 | |
| Boron | **712** | ug/L | 100 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-43-9 | |
| Calcium | **108000** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-70-2 | |
| Chromium | **14.8** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-47-3 | |
| Iron | **12800** | ug/L | 100 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7439-92-1 | |
| Lithium | **25.1** | ug/L | 20.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7439-93-2 | |
| Magnesium | **49500** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7439-95-4 | |
| Manganese | **281** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7439-96-5 | |
| Molybdenum | **82.5** | ug/L | 10.0 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7439-98-7 | |
| Potassium | **5580** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-09-7 | |
| Silica | **49100** | ug/L | 450 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7631-86-9 | N2 |
| Sodium | **21300** | ug/L | 1000 | 1 | 05/24/22 14:38 | 05/25/22 03:35 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **34.3** | ug/L | 10.0 | 1 | 05/21/22 15:00 | 05/24/22 03:19 | 7439-96-5 | |
| Molybdenum, Dissolved | **79.8** | ug/L | 10.0 | 1 | 05/21/22 15:00 | 05/24/22 03:19 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 21:09 | 7440-36-0 | |
| Arsenic | **10.5** | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 21:09 | 7440-38-2 | |
| Beryllium | **0.40** | ug/L | 0.20 | 1 | 05/17/22 14:40 | 05/18/22 21:09 | 7440-41-7 | |
| Cobalt | **4.9** | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 21:09 | 7440-48-4 | |
| Selenium | **1.1** | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 21:09 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/17/22 14:40 | 05/18/22 21:09 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/19/22 10:59 | 05/19/22 21:15 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **309** | mg/L | 2.0 | 1 | | 05/19/22 16:29 | | |
| Alkalinity,Bicarbonate (CaCO3) | **309** | mg/L | 2.0 | 1 | | 05/19/22 16:29 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/19/22 16:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-11S** **Lab ID: 50316356003** Collected: 05/11/22 11:20 Received: 05/12/22 13:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **440** | mg/L | 10.0 | 1 | | 05/18/22 12:31 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.9** | Std. Units | 0.10 | 1 | | 05/20/22 15:04 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/13/22 13:06 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/24/22 21:42 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/12/22 17:29 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/12/22 17:29 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.61** | mg/L | 0.15 | 1 | 05/14/22 04:00 | 05/15/22 19:55 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/22/22 06:02 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.1** | mg/L | 1.0 | 1 | | 05/23/22 08:38 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677934
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3121412 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/25/22 11:50 | |
| Fluoride | mg/L | ND | 0.10 | 05/25/22 11:50 | |
| Sulfate | mg/L | ND | 0.25 | 05/25/22 11:50 | |

LABORATORY CONTROL SAMPLE: 3121413

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 94 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.55 | 110 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.5 | 100 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3121414 3121415

| Parameter | Units | 50316333004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 160 | 125 | 125 | 274 | 278 | 91 | 94 | 80-120 | 2 | 15 | |
| Fluoride | mg/L | 0.61 | 0.5 | 0.5 | 1.2 | 1.2 | 112 | 112 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 475 | 250 | 250 | 699 | 705 | 90 | 92 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677003
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3117049 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/19/22 21:05 | |

LABORATORY CONTROL SAMPLE: 3117050

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 5.0 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117051 3117052

| Parameter | Units | 50316357014 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | <0.12 | 5 | 5 | 5.3 | 5.5 | 106 | 110 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677577
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3120315 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/25/22 02:43 | |
| Barium | ug/L | ND | 10.0 | 05/25/22 02:43 | |
| Boron | ug/L | ND | 100 | 05/25/22 02:43 | |
| Cadmium | ug/L | ND | 2.0 | 05/25/22 02:43 | |
| Calcium | ug/L | ND | 1000 | 05/25/22 02:43 | |
| Chromium | ug/L | ND | 10.0 | 05/25/22 02:43 | |
| Iron | ug/L | ND | 100 | 05/25/22 02:43 | |
| Lead | ug/L | ND | 10.0 | 05/25/22 02:43 | |
| Lithium | ug/L | ND | 20.0 | 05/25/22 02:43 | |
| Magnesium | ug/L | ND | 1000 | 05/25/22 02:43 | |
| Manganese | ug/L | ND | 10.0 | 05/25/22 02:43 | |
| Molybdenum | ug/L | ND | 10.0 | 05/25/22 02:43 | |
| Potassium | ug/L | ND | 1000 | 05/25/22 02:43 | |
| Silica | ug/L | ND | 450 | 05/25/22 02:43 | N2 |
| Sodium | ug/L | ND | 1000 | 05/25/22 02:43 | |

LABORATORY CONTROL SAMPLE: 3120316

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9670 | 97 | 80-120 | |
| Barium | ug/L | 1000 | 959 | 96 | 80-120 | |
| Boron | ug/L | 1000 | 966 | 97 | 80-120 | |
| Cadmium | ug/L | 1000 | 965 | 97 | 80-120 | |
| Calcium | ug/L | 10000 | 9790 | 98 | 80-120 | |
| Chromium | ug/L | 1000 | 972 | 97 | 80-120 | |
| Iron | ug/L | 10000 | 9650 | 97 | 80-120 | |
| Lead | ug/L | 1000 | 927 | 93 | 80-120 | |
| Lithium | ug/L | 1000 | 1040 | 104 | 80-120 | |
| Magnesium | ug/L | 10000 | 9450 | 95 | 80-120 | |
| Manganese | ug/L | 1000 | 944 | 94 | 80-120 | |
| Molybdenum | ug/L | 1000 | 990 | 99 | 80-120 | |
| Potassium | ug/L | 10000 | 9900 | 99 | 80-120 | |
| Silica | ug/L | 10700 | 10200 | 95 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9900 | 99 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120317 3120318

| Parameter | Units | 50316334004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10400 | 10100 | 103 | 101 | 75-125 | 2 | 20 | |
| Barium | ug/L | 141 | 1000 | 1000 | 1160 | 1140 | 102 | 100 | 75-125 | 1 | 20 | |
| Boron | ug/L | 766 | 1000 | 1000 | 1830 | 1800 | 106 | 103 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 1040 | 1010 | 104 | 101 | 75-125 | 2 | 20 | |
| Calcium | ug/L | 137000 | 10000 | 10000 | 149000 | 149000 | 122 | 120 | 75-125 | 0 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 1020 | 991 | 102 | 99 | 75-125 | 3 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 10100 | 9820 | 100 | 97 | 75-125 | 3 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 945 | 926 | 94 | 93 | 75-125 | 2 | 20 | |
| Lithium | ug/L | 24.7 | 1000 | 1000 | 1200 | 1180 | 117 | 116 | 75-125 | 1 | 20 | |
| Magnesium | ug/L | 30700 | 10000 | 10000 | 41000 | 40800 | 103 | 100 | 75-125 | 1 | 20 | |
| Manganese | ug/L | 2170 | 1000 | 1000 | 3160 | 3110 | 99 | 94 | 75-125 | 1 | 20 | |
| Molybdenum | ug/L | 52.6 | 1000 | 1000 | 1100 | 1080 | 105 | 102 | 75-125 | 2 | 20 | |
| Potassium | ug/L | 6340 | 10000 | 10000 | 17400 | 17200 | 110 | 109 | 75-125 | 1 | 20 | |
| Silica | ug/L | 15100 | 10700 | 10700 | 26200 | 26000 | 104 | 102 | 75-125 | 1 | 20 | N2 |
| Sodium | ug/L | 60700 | 10000 | 10000 | 72600 | 72900 | 118 | 121 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677435
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3119311 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/24/22 03:13 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/24/22 03:13 | |

LABORATORY CONTROL SAMPLE: 3119312

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 988 | 99 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1020 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3119313 3119314

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 20.8 | 1000 | 1000 | 988 | 993 | 97 | 97 | 75-125 | 0 | 20 | |
| Molybdenum, Dissolved | ug/L | 27.4 | 1000 | 1000 | 1050 | 1050 | 102 | 102 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676599
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3115176 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/18/22 14:06 | |
| Arsenic | ug/L | ND | 1.0 | 05/18/22 14:06 | |
| Beryllium | ug/L | ND | 0.20 | 05/18/22 14:06 | |
| Cobalt | ug/L | ND | 1.0 | 05/18/22 14:06 | |
| Selenium | ug/L | ND | 1.0 | 05/18/22 14:06 | |
| Thallium | ug/L | ND | 1.0 | 05/18/22 14:06 | |

LABORATORY CONTROL SAMPLE: 3115177

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 42.3 | 106 | 80-120 | |
| Arsenic | ug/L | 40 | 37.7 | 94 | 80-120 | |
| Beryllium | ug/L | 40 | 39.3 | 98 | 80-120 | |
| Cobalt | ug/L | 40 | 41.1 | 103 | 80-120 | |
| Selenium | ug/L | 40 | 38.5 | 96 | 80-120 | |
| Thallium | ug/L | 40 | 40.9 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115178 3115179

| Parameter | Units | 50315449001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 42.5 | 43.6 | 106 | 109 | 75-125 | 3 | 20 | |
| Arsenic | ug/L | 0.076 mg/L | 40 | 40 | 116 | 112 | 100 | 91 | 75-125 | 3 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 41.0 | 41.8 | 102 | 105 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.2 | 39.8 | 94 | 98 | 75-125 | 4 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 39.7 | 37.8 | 99 | 94 | 75-125 | 5 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 40.8 | 42.4 | 102 | 106 | 75-125 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676934
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001

METHOD BLANK: 3116615 Matrix: Water
Associated Lab Samples: 50316356001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/19/22 11:13 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/19/22 11:13 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/19/22 11:13 | |

LABORATORY CONTROL SAMPLE: 3116616

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 48.8 | 98 | 90-110 | |

SAMPLE DUPLICATE: 3116617

| Parameter | Units | 50316481001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 150 | 149 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 150 | 149 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3116618

| Parameter | Units | 50316334004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 432 | 435 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 432 | 435 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677051
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356002, 50316356003

METHOD BLANK: 3117327 Matrix: Water
Associated Lab Samples: 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/19/22 16:29 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/19/22 16:29 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/19/22 16:29 | |

LABORATORY CONTROL SAMPLE: 3117328

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 51.7 | 103 | 90-110 | |

SAMPLE DUPLICATE: 3117329

| Parameter | Units | 50316356003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 309 | 320 | 4 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 309 | 320 | 4 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3117330

| Parameter | Units | 50316481007 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 188 | 194 | 3 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 188 | 194 | 3 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676817
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002

METHOD BLANK: 3116109 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/18/22 11:38 | |

LABORATORY CONTROL SAMPLE: 3116110

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 293 | 98 | 80-120 | |

SAMPLE DUPLICATE: 3116111

| Parameter | Units | 50316329021 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 416 | 417 | 0 | 10 | |

SAMPLE DUPLICATE: 3116112

| Parameter | Units | 50316332004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1850 | 1830 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676818
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356003

METHOD BLANK: 3116113 Matrix: Water
Associated Lab Samples: 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/18/22 12:30 | |

LABORATORY CONTROL SAMPLE: 3116114

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 297 | 99 | 80-120 | |

SAMPLE DUPLICATE: 3116115

| Parameter | Units | 50316356003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 440 | 469 | 6 | 10 | |

SAMPLE DUPLICATE: 3116116

| Parameter | Units | 50316391001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2090 | 2020 | 4 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677437
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

SAMPLE DUPLICATE: 3119326

| Parameter | Units | 50316352004 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 8.4 | 8.4 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3119327

| Parameter | Units | 50315564008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.1 | 7.1 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676128
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3113215 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/13/22 13:06 | |

LABORATORY CONTROL SAMPLE: 3113216

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.54 | 107 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113217 3113218

| Parameter | Units | 50316227002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.39 | 0.39 | 77 | 77 | 90-110 | 0 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3113219

| Parameter | Units | 50316356001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.52 | 105 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 678187 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3122392 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/24/22 21:40 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3122393

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 0.99 | 99 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122394 3122395

| Parameter | Units | 50316356002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 102 | 102 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3122396

| Parameter | Units | 50316334005 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 0.98 | 98 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 675982
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3112539 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/12/22 17:14 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/12/22 17:14 | |

LABORATORY CONTROL SAMPLE: 3112540

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.98 | 98 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.97 | 97 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112541 3112542

| Parameter | Units | 50316334001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 2.0 | 1 | 1 | 3.0 | 3.0 | 98 | 98 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.95 | 0.94 | 95 | 94 | 90-110 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3112543

| Parameter | Units | 50316328002 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1.0 | 99 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.98 | 98 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676062
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002

METHOD BLANK: 3112890 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/15/22 18:41 | |

LABORATORY CONTROL SAMPLE: 3112891

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3112892 3112893

| Parameter | Units | 50316328001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.5 | | | | 1 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 676233
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356003

METHOD BLANK: 3113987 Matrix: Water
Associated Lab Samples: 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/15/22 19:46 | |

LABORATORY CONTROL SAMPLE: 3113988

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113989 3113990

| Parameter | Units | 50316276001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 14.7 | | | 85.1 | 88.5 | | | | 4 | | |

MATRIX SPIKE SAMPLE: 3113991

| Parameter | Units | 50316368003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.39 | | 1.9 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677569 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3120284 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/22/22 04:32 | |

LABORATORY CONTROL SAMPLE: 3120285

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120286 3120287

| Parameter | Units | 50316376011 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 3.5 | 10 | 10 | 13.8 | 13.8 | 103 | 104 | 80-120 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3120288

| Parameter | Units | 50316387001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 9390 ug/L | 10 | 19.1 | 97 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 677652 | Analysis Method: SM 5310C
QC Batch Method: SM 5310C | Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 3120510 Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/23/22 03:53 | |

LABORATORY CONTROL SAMPLE: 3120511

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.2 | 102 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120512 3120513

| Parameter | Units | 50316227002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 7.6 | 10 | 10 | 18.3 | 17.8 | 107 | 102 | 80-120 | 2 | 20 | |

MATRIX SPIKE SAMPLE: 3120514

| Parameter | Units | 50316328001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 11.7 | 108 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-15D** **Lab ID: 50316356001** Collected: 05/11/22 13:30 Received: 05/12/22 13:45 Matrix: Water
PWS: Site ID: Sample Type:

Comments: • Upon receipt at the laboratory, 2.5 mls of nitric acid were added to the sample to meet the sample preservation requirement of pH <2 for radiochemistry analysis. The samples were not preserved <2 within the required 5 days of collection.

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-226 | EPA 903.1 | **0.134 ± 0.651 (1.12) C:NA T:84%** | pCi/L | 06/21/22 11:56 | 13982-63-3 | |
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-228 | EPA 904.0 | **0.631 ± 0.506 (1.01) C:69% T:86%** | pCi/L | 06/14/22 18:01 | 15262-20-1 | |
| | | Pace Analytical Services - Greensburg | | | | |
| Total Radium | Total Radium Calculation | **0.765 ± 1.16 (2.13)** | pCi/L | 06/21/22 18:15 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-14D** **Lab ID: 50316356002** Collected: 05/11/22 10:40 Received: 05/12/22 13:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.0383 ± 0.338 (0.736) C:NA T:95%** | pCi/L | 06/21/22 11:56 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.03 ± 0.527 (0.925) C:66% T:93%** | pCi/L | 06/14/22 17:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.03 ± 0.865 (1.66)** | pCi/L | 06/21/22 18:15 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

**Sample: MW-11S** **Lab ID: 50316356003** Collected: 05/11/22 11:20 Received: 05/12/22 13:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.218 ± 0.574 (1.03) C:NA T:91%** | pCi/L | 06/21/22 11:56 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.529 ± 0.410 (0.801) C:71% T:88%** | pCi/L | 06/14/22 17:51 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.747 ± 0.984 (1.83)** | pCi/L | 06/21/22 18:15 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 507538
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 2459214
Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0820 ± 0.253 (0.591) C:NA T:99% | pCi/L | 06/21/22 11:30 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

QC Batch: 507539
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316356001, 50316356002, 50316356003

METHOD BLANK: 2459215
Matrix: Water
Associated Lab Samples: 50316356001, 50316356002, 50316356003

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.312 ± 0.358 (0.753) C:73% T:97% | pCi/L | 06/14/22 13:26 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| 50316356001 | MW-15D | EPA 9056 | 677934 | | |
| 50316356002 | MW-14D | EPA 9056 | 677934 | | |
| 50316356003 | MW-11S | EPA 9056 | 677934 | | |
| 50316356001 | MW-15D | EPA 3010 | 677577 | EPA 6010 | 678211 |
| 50316356002 | MW-14D | EPA 3010 | 677577 | EPA 6010 | 678211 |
| 50316356003 | MW-11S | EPA 3010 | 677577 | EPA 6010 | 678211 |
| 50316356001 | MW-15D | EPA 3010 | 677435 | EPA 6010 | 677903 |
| 50316356002 | MW-14D | EPA 3010 | 677435 | EPA 6010 | 677903 |
| 50316356003 | MW-11S | EPA 3010 | 677435 | EPA 6010 | 677903 |
| 50316356001 | MW-15D | EPA 200.2 | 676599 | EPA 6020 | 676771 |
| 50316356002 | MW-14D | EPA 200.2 | 676599 | EPA 6020 | 676771 |
| 50316356003 | MW-11S | EPA 200.2 | 676599 | EPA 6020 | 676771 |
| 50316356001 | MW-15D | EPA 7470 | 677003 | EPA 7470 | 677235 |
| 50316356002 | MW-14D | EPA 7470 | 677003 | EPA 7470 | 677235 |
| 50316356003 | MW-11S | EPA 7470 | 677003 | EPA 7470 | 677235 |
| 50316356001 | MW-15D | EPA 903.1 | 507538 | | |
| 50316356002 | MW-14D | EPA 903.1 | 507538 | | |
| 50316356003 | MW-11S | EPA 903.1 | 507538 | | |
| 50316356001 | MW-15D | EPA 904.0 | 507539 | | |
| 50316356002 | MW-14D | EPA 904.0 | 507539 | | |
| 50316356003 | MW-11S | EPA 904.0 | 507539 | | |
| 50316356001 | MW-15D | Total Radium Calculation | 513453 | | |
| 50316356002 | MW-14D | Total Radium Calculation | 513453 | | |
| 50316356003 | MW-11S | Total Radium Calculation | 513453 | | |
| 50316356001 | MW-15D | SM 2320B | 676934 | | |
| 50316356002 | MW-14D | SM 2320B | 677051 | | |
| 50316356003 | MW-11S | SM 2320B | 677051 | | |
| 50316356001 | MW-15D | SM 2540C | 676817 | | |
| 50316356002 | MW-14D | SM 2540C | 676817 | | |
| 50316356003 | MW-11S | SM 2540C | 676818 | | |
| 50316356001 | MW-15D | SM 4500-H+B | 677437 | | |
| 50316356002 | MW-14D | SM 4500-H+B | 677437 | | |
| 50316356003 | MW-11S | SM 4500-H+B | 677437 | | |
| 50316356001 | MW-15D | SM 4500-S2-D | 676128 | | |
| 50316356002 | MW-14D | SM 4500-S2-D | 676128 | | |
| 50316356003 | MW-11S | SM 4500-S2-D | 676128 | | |
| 50316356001 | MW-15D | HACH 8146 | 678187 | | |
| 50316356002 | MW-14D | HACH 8146 | 678187 | | |
| 50316356003 | MW-11S | HACH 8146 | 678187 | | |
| 50316356001 | MW-15D | EPA 353.2 | 675982 | | |
| 50316356002 | MW-14D | EPA 353.2 | 675982 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316356

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316356003** | **MW-11S** | EPA 353.2 | 675982 | | |
| **50316356001** | **MW-15D** | EPA 365.1 | 676062 | EPA 365.1 | 676410 |
| **50316356002** | **MW-14D** | EPA 365.1 | 676062 | EPA 365.1 | 676410 |
| **50316356003** | **MW-11S** | EPA 365.1 | 676233 | EPA 365.1 | 676451 |
| **50316356001** | **MW-15D** | SM 5310C | 677569 | | |
| **50316356002** | **MW-14D** | SM 5310C | 677569 | | |
| **50316356003** | **MW-11S** | SM 5310C | 677569 | | |
| **50316356001** | **MW-15D** | SM 5310C | 677652 | | |
| **50316356002** | **MW-14D** | SM 5310C | 677652 | | |
| **50316356003** | **MW-11S** | SM 5310C | 677652 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50316356

50316356

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Re

The Chain-of-Custody is a LEGAL DOCUMENT. All relev



| Section A | Section B | Section C |
|---|---|---|
| Required Client Information: | Required Project Information: | Invoice Information: |
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: Atlas Indianapolis |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 10498/15 |

Regulatory Agency

State / Location: IN

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analysis Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Matrix Codes: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | | Y | | | | | | Y | | | | | | |
| 13 | MW-9S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 14 | MW-9I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 15 | MW-9D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 16 | MW-10S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 17 | MW-10D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 18 | MW-11D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 19 | MW-12S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 20 | MW-11S | WT | G | | | 5/11/22 | 1120 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 21 | MW-12D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 22 | MW-13S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 23 | MW-13D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 24 | MW-14D | WT | G | | | 5/11/22 | 1040 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / Atlas | | | | 5/12/22 | 13:45 | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | | | | | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Kendra Reininga

SIGNATURE of SAMPLER: Mark Breting for Kendra Reininga

DATE Signed: 5/13/22

| TEMP In C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical
www.pacelabs.com

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page : 3 Of 3

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

Regulatory Agency:

State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Y/N | Analyses Test: TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | Residual Chlorine (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Requested Analysis Filtered (Y/N) | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | |
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 27 | MW-15D | WT | G | | | 5/11/22 | 1330 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | |
| 30 | Field Blank 1 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | X | |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

MATRIX CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / Atlas | | | Alan Boyle | 5/04/22 | 13:45 | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | | | | | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Kendra Reininga

SIGNATURE of SAMPLER: Mark Breting / for Kendra Reininga

DATE Signed: 5/13/22

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

F-IN-Q-290-rev.22, 22Apr2022

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** DMP 5/12/22 15:02

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** (Initial/Corrected) RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

| 3.2/3.2 | 2.2/2.2 | | |
|---|---|---|---|

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☑ Other Plastic Bags

DMP 5/12/22

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | |
| **Short Hold Time Analysis (48 hours or less)? Analysis:** | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | |
| **Rush TAT Requested (4 days or less):** | | |
| Custody Signatures Present? | | |
| Containers Intact?: | | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | | |
| Extra labels on Terracore Vials? (soils only) | | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** Circle: **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | |
| Headspace Wisconsin Sulfide? | | | |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | |
| Trip Blank Present? | | | |
| Trip Blank Custody Seals?: | | | |

COMMENTS: MW-15D rcvd, not on COC or COC not rcvd. MW14D + MW15 rcvd without a COC. Samples were received by Pace 5/12/22 1345.

**COC PAGE __/__ of __/__**

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | MW-15D | | S/11 1330 | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | | ✓ |
| 2 | | | | | | | MW-14D | | S/11,22, 1040 | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | | ↓ |
| 3 | | | | | | | MW-11S | | S-11, 1120 | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | | ↓ |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 13, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316495001** | **M-4** | Water | 05/12/22 17:10 | 05/13/22 14:45 |
| **50316495002** | **MW-106I** | Water | 05/12/22 15:00 | 05/13/22 14:45 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316495001** | **M-4** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316495002** | **MW-106I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316495001** | **M-4** | | | | | |
| EPA 9056 | Chloride | 121 | mg/L | 2.5 | 05/27/22 00:54 | |
| EPA 9056 | Sulfate | 1080 | mg/L | 25.0 | 05/27/22 01:11 | |
| EPA 6010 | Barium | 159 | ug/L | 10.0 | 05/26/22 12:16 | |
| EPA 6010 | Boron | 28200 | ug/L | 100 | 05/26/22 12:16 | |
| EPA 6010 | Calcium | 367000 | ug/L | 2000 | 05/26/22 14:33 | |
| EPA 6010 | Iron | 6630 | ug/L | 100 | 05/26/22 12:16 | |
| EPA 6010 | Lithium | 367 | ug/L | 20.0 | 05/26/22 12:16 | |
| EPA 6010 | Magnesium | 58600 | ug/L | 1000 | 05/26/22 12:16 | |
| EPA 6010 | Manganese | 1050 | ug/L | 10.0 | 05/26/22 12:16 | |
| EPA 6010 | Molybdenum | 300 | ug/L | 10.0 | 05/26/22 12:16 | |
| EPA 6010 | Potassium | 24400 | ug/L | 1000 | 05/26/22 12:16 | |
| EPA 6010 | Silica | 13100 | ug/L | 450 | 05/26/22 12:16 | N2 |
| EPA 6010 | Sodium | 131000 | ug/L | 1000 | 05/26/22 12:16 | |
| EPA 6010 | Manganese, Dissolved | 1220 | ug/L | 10.0 | 05/21/22 02:52 | |
| EPA 6010 | Molybdenum, Dissolved | 293 | ug/L | 10.0 | 05/21/22 02:52 | |
| EPA 6020 | Arsenic | 926 | ug/L | 10.0 | 05/23/22 10:31 | |
| EPA 903.1 | Radium-226 | 0.571 ± 0.379 (0.442) C:NA T:81% | pCi/L | | 06/27/22 16:44 | |
| EPA 904.0 | Radium-228 | 1.39 ± 0.561 (0.896) C:74% T:81% | pCi/L | | 06/21/22 16:00 | |
| Total Radium Calculation | Total Radium | 1.96 ± 0.940 (1.34) | pCi/L | | 07/01/22 17:37 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 291 | mg/L | 2.0 | 05/20/22 14:02 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 291 | mg/L | 2.0 | 05/20/22 14:02 | |
| SM 2540C | Total Dissolved Solids | 2060 | mg/L | 20.0 | 05/19/22 14:54 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/20/22 18:40 | H3 |
| EPA 365.1 | Phosphate as P04 | 2.2 | mg/L | 0.15 | 05/21/22 09:38 | |
| SM 5310C | Total Organic Carbon | 2.9 | mg/L | 1.0 | 05/24/22 06:51 | |
| SM 5310C | Dissolved Organic Carbon | 3.2 | mg/L | 1.0 | 05/23/22 16:35 | |
| **50316495002** | **MW-106I** | | | | | |
| EPA 9056 | Chloride | 263 | mg/L | 25.0 | 05/26/22 22:21 | |
| EPA 9056 | Fluoride | 0.20 | mg/L | 0.10 | 05/27/22 01:28 | |
| EPA 9056 | Sulfate | 710 | mg/L | 25.0 | 05/26/22 22:21 | |
| EPA 6010 | Aluminum | 487 | ug/L | 200 | 05/26/22 12:18 | |
| EPA 6010 | Barium | 69.3 | ug/L | 10.0 | 05/26/22 12:18 | |
| EPA 6010 | Boron | 12100 | ug/L | 100 | 05/26/22 12:18 | |
| EPA 6010 | Calcium | 240000 | ug/L | 2000 | 05/26/22 14:35 | |
| EPA 6010 | Iron | 6500 | ug/L | 100 | 05/26/22 12:18 | |
| EPA 6010 | Lithium | 101 | ug/L | 20.0 | 05/26/22 12:18 | |
| EPA 6010 | Magnesium | 47600 | ug/L | 1000 | 05/26/22 12:18 | |
| EPA 6010 | Manganese | 432 | ug/L | 10.0 | 05/26/22 12:18 | |
| EPA 6010 | Molybdenum | 320 | ug/L | 10.0 | 05/26/22 12:18 | |
| EPA 6010 | Potassium | 15800 | ug/L | 1000 | 05/26/22 12:18 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316495002** | **MW-106I** | | | | | |
| EPA 6010 | Silica | 14800 | ug/L | 450 | 05/26/22 12:18 | N2 |
| EPA 6010 | Sodium | 183000 | ug/L | 1000 | 05/26/22 12:18 | |
| EPA 6010 | Manganese, Dissolved | 432 | ug/L | 10.0 | 05/21/22 02:54 | |
| EPA 6010 | Molybdenum, Dissolved | 342 | ug/L | 10.0 | 05/21/22 02:54 | |
| EPA 6020 | Arsenic | 117 | ug/L | 1.0 | 05/23/22 10:39 | |
| EPA 903.1 | Radium-226 | 0.999 ± 0.451 (0.334) C:NA T:90% | pCi/L | | 06/27/22 16:44 | |
| EPA 904.0 | Radium-228 | 0.731 ± 0.369 (0.624) C:75% T:90% | pCi/L | | 06/21/22 16:00 | |
| Total Radium Calculation | Total Radium | 1.73 ± 0.820 (0.958) | pCi/L | | 07/01/22 17:37 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 238 | mg/L | 2.0 | 05/20/22 19:54 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 238 | mg/L | 2.0 | 05/20/22 19:54 | |
| SM 2540C | Total Dissolved Solids | 1730 | mg/L | 20.0 | 05/19/22 14:54 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/20/22 18:41 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.75 | mg/L | 0.15 | 05/21/22 09:39 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Sample: M-4** **Lab ID: 50316495001** Collected: 05/12/22 17:10 Received: 05/13/22 14:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **121** | mg/L | 2.5 | 10 | | 05/27/22 00:54 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 05/27/22 00:37 | 16984-48-8 | |
| Sulfate | **1080** | mg/L | 25.0 | 100 | | 05/27/22 01:11 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7429-90-5 | |
| Barium | **159** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7440-39-3 | |
| Boron | **28200** | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7440-43-9 | |
| Calcium | **367000** | ug/L | 2000 | 2 | 05/25/22 08:57 | 05/26/22 14:33 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7440-47-3 | |
| Iron | **6630** | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7439-92-1 | |
| Lithium | **367** | ug/L | 20.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7439-93-2 | |
| Magnesium | **58600** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7439-95-4 | |
| Manganese | **1050** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7439-96-5 | |
| Molybdenum | **300** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7439-98-7 | |
| Potassium | **24400** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7440-09-7 | |
| Silica | **13100** | ug/L | 450 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7631-86-9 | N2 |
| Sodium | **131000** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 12:16 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **1220** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:52 | 7439-96-5 | |
| Molybdenum, Dissolved | **293** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:52 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:35 | 7440-36-0 | |
| Arsenic | **926** | ug/L | 10.0 | 10 | 05/18/22 08:45 | 05/23/22 10:31 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:35 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:35 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **291** | mg/L | 2.0 | 1 | | 05/20/22 14:02 | | |
| Alkalinity,Bicarbonate (CaCO3) | **291** | mg/L | 2.0 | 1 | | 05/20/22 14:02 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/20/22 14:02 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **2060** | mg/L | 20.0 | 1 | | 05/19/22 14:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Sample: M-4** **Lab ID: 50316495001** Collected: 05/12/22 17:10 Received: 05/13/22 14:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/20/22 18:40 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 08:43 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:16 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/14/22 09:28 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:28 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **2.2** | mg/L | 0.15 | 1 | 05/17/22 13:00 | 05/21/22 09:38 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.9** | mg/L | 1.0 | 1 | | 05/24/22 06:51 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **3.2** | mg/L | 1.0 | 1 | | 05/23/22 16:35 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Sample: MW-106I** **Lab ID: 50316495002** Collected: 05/12/22 15:00 Received: 05/13/22 14:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **263** | mg/L | 25.0 | 100 | | 05/26/22 22:21 | 16887-00-6 | |
| Fluoride | **0.20** | mg/L | 0.10 | 1 | | 05/27/22 01:28 | 16984-48-8 | |
| Sulfate | **710** | mg/L | 25.0 | 100 | | 05/26/22 22:21 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **487** | ug/L | 200 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7429-90-5 | |
| Barium | **69.3** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7440-39-3 | |
| Boron | **12100** | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7440-43-9 | |
| Calcium | **240000** | ug/L | 2000 | 2 | 05/25/22 08:57 | 05/26/22 14:35 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7440-47-3 | |
| Iron | **6500** | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7439-92-1 | |
| Lithium | **101** | ug/L | 20.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7439-93-2 | |
| Magnesium | **47600** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7439-95-4 | |
| Manganese | **432** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7439-96-5 | |
| Molybdenum | **320** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7439-98-7 | |
| Potassium | **15800** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7440-09-7 | |
| Silica | **14800** | ug/L | 450 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7631-86-9 | N2 |
| Sodium | **183000** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 12:18 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **432** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:54 | 7439-96-5 | |
| Molybdenum, Dissolved | **342** | ug/L | 10.0 | 1 | 05/20/22 06:45 | 05/21/22 02:54 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:39 | 7440-36-0 | |
| Arsenic | **117** | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:39 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:39 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/18/22 08:45 | 05/23/22 10:39 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **238** | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| Alkalinity,Bicarbonate (CaCO3) | **238** | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1730** | mg/L | 20.0 | 1 | | 05/19/22 14:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Sample: MW-106I** **Lab ID: 50316495002** Collected: 05/12/22 15:00 Received: 05/13/22 14:45 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/20/22 18:41 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 08:43 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:15 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/14/22 09:19 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:19 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.75** | mg/L | 0.15 | 1 | 05/17/22 13:00 | 05/21/22 09:39 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 4.0 | 4 | | 05/26/22 13:48 | 7440-44-0 | D3 |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 4.0 | 4 | | 05/24/22 14:30 | | D3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 678022
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3121706 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/26/22 03:35 | |
| Fluoride | mg/L | ND | 0.10 | 05/26/22 03:35 | |
| Sulfate | mg/L | ND | 0.25 | 05/26/22 03:35 | |

LABORATORY CONTROL SAMPLE: 3121707

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 89 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 96 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 98 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3121708 3121709

| Parameter | Units | 50316445001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 144 | 125 | 125 | 246 | 245 | 82 | 81 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.37 | 0.36 | 74 | 72 | 80-120 | 3 | 15 | M0 |
| Sulfate | mg/L | 1080 | 250 | 250 | 1260 | 1260 | 73 | 73 | 80-120 | 0 | 15 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677583
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3120339 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/26/22 12:03 | |
| Barium | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Boron | ug/L | ND | 100 | 05/26/22 12:03 | |
| Cadmium | ug/L | ND | 2.0 | 05/26/22 12:03 | |
| Calcium | ug/L | ND | 1000 | 05/26/22 12:03 | |
| Chromium | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Iron | ug/L | ND | 100 | 05/26/22 12:03 | |
| Lead | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Lithium | ug/L | ND | 20.0 | 05/26/22 12:03 | |
| Magnesium | ug/L | ND | 1000 | 05/26/22 12:03 | |
| Manganese | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Molybdenum | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Potassium | ug/L | ND | 1000 | 05/26/22 12:03 | |
| Silica | ug/L | ND | 450 | 05/26/22 12:03 | N2 |
| Sodium | ug/L | ND | 1000 | 05/26/22 12:03 | |

LABORATORY CONTROL SAMPLE: 3120340

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9430 | 94 | 80-120 | |
| Barium | ug/L | 1000 | 976 | 98 | 80-120 | |
| Boron | ug/L | 1000 | 929 | 93 | 80-120 | |
| Cadmium | ug/L | 1000 | 942 | 94 | 80-120 | |
| Calcium | ug/L | 10000 | 9690 | 97 | 80-120 | |
| Chromium | ug/L | 1000 | 967 | 97 | 80-120 | |
| Iron | ug/L | 10000 | 9430 | 94 | 80-120 | |
| Lead | ug/L | 1000 | 919 | 92 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 10000 | 9240 | 92 | 80-120 | |
| Manganese | ug/L | 1000 | 936 | 94 | 80-120 | |
| Molybdenum | ug/L | 1000 | 983 | 98 | 80-120 | |
| Potassium | ug/L | 10000 | 9460 | 95 | 80-120 | |
| Silica | ug/L | 10700 | 9950 | 93 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9710 | 97 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120341 3120342

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9740 | 10200 | 97 | 102 | 75-125 | 5 | 20 | |
| Barium | ug/L | 127 | 1000 | 1000 | 1120 | 1170 | 99 | 104 | 75-125 | 4 | 20 | |
| Boron | ug/L | 723 | 1000 | 1000 | 1690 | 1760 | 97 | 103 | 75-125 | 4 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 986 | 1020 | 99 | 102 | 75-125 | 4 | 20 | |
| Calcium | ug/L | 174000 | 10000 | 10000 | 188000 | 193000 | 137 | 184 | 75-125 | 2 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 961 | 1000 | 96 | 100 | 75-125 | 4 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9270 | 9680 | 93 | 97 | 75-125 | 4 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 901 | 934 | 90 | 93 | 75-125 | 4 | 20 | |
| Lithium | ug/L | 26.2 | 1000 | 1000 | 1140 | 1180 | 111 | 116 | 75-125 | 4 | 20 | |
| Magnesium | ug/L | 45400 | 10000 | 10000 | 55000 | 56100 | 96 | 107 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 17.3 | 1000 | 1000 | 943 | 981 | 93 | 96 | 75-125 | 4 | 20 | |
| Molybdenum | ug/L | 25.6 | 1000 | 1000 | 1040 | 1080 | 102 | 105 | 75-125 | 3 | 20 | |
| Potassium | ug/L | 5970 | 10000 | 10000 | 16500 | 17200 | 106 | 112 | 75-125 | 4 | 20 | |
| Silica | ug/L | 15100 | 10700 | 10700 | 25500 | 26200 | 97 | 104 | 75-125 | 3 | 20 | N2 |
| Sodium | ug/L | 97800 | 10000 | 10000 | 111000 | 114000 | 134 | 164 | 75-125 | 3 | 20 | P6 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120343 3120344

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 9820 | 101 | 98 | 75-125 | 2 | 20 | |
| Barium | ug/L | 36.8 | 1000 | 1000 | 1020 | 1020 | 98 | 99 | 75-125 | 0 | 20 | |
| Boron | ug/L | 8280 | 1000 | 1000 | 10200 | 9760 | 190 | 148 | 75-125 | 4 | 20 | P6 |
| Cadmium | ug/L | ND | 1000 | 1000 | 998 | 986 | 100 | 99 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 232000 | 10000 | 10000 | 258000 | 258000 | 262 | 262 | 75-125 | 0 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 964 | 963 | 96 | 96 | 75-125 | 0 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9500 | 9220 | 95 | 92 | 75-125 | 3 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 900 | 889 | 90 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | 101 | 1000 | 1000 | 1230 | 1220 | 113 | 112 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 70800 | 10000 | 10000 | 86800 | 82800 | 160 | 121 | 75-125 | 5 | 20 | P6 |
| Manganese | ug/L | 18.3 | 1000 | 1000 | 969 | 940 | 95 | 92 | 75-125 | 3 | 20 | |
| Molybdenum | ug/L | 165 | 1000 | 1000 | 1200 | 1180 | 104 | 102 | 75-125 | 2 | 20 | |
| Potassium | ug/L | 15300 | 10000 | 10000 | 27000 | 26800 | 117 | 116 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12200 | 10700 | 10700 | 23800 | 23100 | 109 | 102 | 75-125 | 3 | 20 | N2 |
| Sodium | ug/L | 89200 | 10000 | 10000 | 106000 | 105000 | 166 | 154 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677124
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3117566 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/21/22 01:56 | |

LABORATORY CONTROL SAMPLE: 3117567

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 951 | 95 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1030 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117568 3117569

| Parameter | Units | 50316088002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 1000 | 1000 | 944 | 934 | 94 | 93 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 676701
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3115572 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/19/22 01:15 | |
| Arsenic | ug/L | ND | 1.0 | 05/19/22 01:15 | |
| Cobalt | ug/L | ND | 1.0 | 05/19/22 01:15 | |
| Selenium | ug/L | ND | 1.0 | 05/19/22 01:15 | |

LABORATORY CONTROL SAMPLE: 3115573

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.0 | 103 | 80-120 | |
| Arsenic | ug/L | 40 | 37.8 | 94 | 80-120 | |
| Cobalt | ug/L | 40 | 40.9 | 102 | 80-120 | |
| Selenium | ug/L | 40 | 39.9 | 100 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115574 3115575

| Parameter | Units | 50316357014 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | <2.0 | 40 | 40 | 41.7 | 41.7 | 104 | 104 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | <5.0 | 40 | 40 | 38.6 | 38.6 | 94 | 94 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | <20.0 | 40 | 40 | 38.8 | 38.8 | 95 | 95 | 75-125 | 0 | 20 | |
| Selenium | ug/L | <5.0 | 40 | 40 | 43.1 | 44.6 | 96 | 100 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677185
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001

METHOD BLANK: 3117826 Matrix: Water
Associated Lab Samples: 50316495001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 4.0 | 2.0 | 05/20/22 13:54 | B |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/20/22 13:54 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/20/22 13:54 | |

LABORATORY CONTROL SAMPLE: 3117827

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 53.1 | 106 | 90-110 | |

SAMPLE DUPLICATE: 3117828

| Parameter | Units | 50316481012 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 206 | 206 | 0 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 206 | 206 | 0 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3117829

| Parameter | Units | 50316481022 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 170 | 176 | 3 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 170 | 176 | 3 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677381
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495002

METHOD BLANK: 3118900 Matrix: Water
Associated Lab Samples: 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/20/22 19:54 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/20/22 19:54 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/20/22 19:54 | |

LABORATORY CONTROL SAMPLE: 3118901

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 53.0 | 106 | 90-110 | |

SAMPLE DUPLICATE: 3118903

| Parameter | Units | 50316506002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 289 | 296 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 289 | 296 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3118904

| Parameter | Units | 50316507001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 436 | 442 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 436 | 442 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677048
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3117317 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/19/22 14:49 | |

LABORATORY CONTROL SAMPLE: 3117318

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 299 | 100 | 80-120 | |

SAMPLE DUPLICATE: 3117319

| Parameter | Units | 50316448002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2530 | 2520 | 0 | 10 | |

SAMPLE DUPLICATE: 3117320

| Parameter | Units | 50316481022 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 588 | 584 | 1 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677473
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

SAMPLE DUPLICATE: 3119836

| Parameter | Units | 50316343003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.9 | 7.0 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3119837

| Parameter | Units | 50316499001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 676794
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3116023 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/18/22 08:43 | |

LABORATORY CONTROL SAMPLE: 3116024

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.46 | 92 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116025 3116026

| Parameter | Units | 50316445001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.42 | 0.43 | 85 | 85 | 90-110 | 0 | 20 | M3 |

MATRIX SPIKE SAMPLE: 3116027

| Parameter | Units | 50316495001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.40 | 63 | 90-110 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 678396
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3123107 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/25/22 21:41 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3123108

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 101 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3123109 3123110

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 0.97 | 102 | 97 | 90-110 | 5 | 20 | H3,N2 |

MATRIX SPIKE SAMPLE: 3123111

| Parameter | Units | 50316499003 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 0.98 | 98 | 90-110 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 676251
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3114048 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/14/22 09:04 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/14/22 09:04 | |

LABORATORY CONTROL SAMPLE: 3114049

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.97 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114050 3114051

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.84 | 1 | 1 | 1.9 | 1.9 | 102 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.97 | 0.97 | 97 | 97 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114052 3114053

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.98 | 0.98 | 98 | 98 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 676638
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3115299 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/21/22 09:26 | |

LABORATORY CONTROL SAMPLE: 3115300

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115301 3115302

| Parameter | Units | 50316481022 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.38 | | | 1.8 | 1.8 | | | | 2 | | |

MATRIX SPIKE SAMPLE: 3115303

| Parameter | Units | 50316499001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | 1.5 | | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 678177
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001

METHOD BLANK: 3122323 Matrix: Water
Associated Lab Samples: 50316495001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/24/22 21:03 | |

LABORATORY CONTROL SAMPLE: 3122324

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.1 | 101 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122325 3122326

| Parameter | Units | 50316481022 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 4.0 | 10 | 10 | 14.1 | 14.2 | 101 | 102 | 80-120 | 1 | 20 | |

MATRIX SPIKE SAMPLE: 3122327

| Parameter | Units | 50316495001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.9 | 10 | 13.2 | 103 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 678321
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495002

METHOD BLANK: 3122816 Matrix: Water
Associated Lab Samples: 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/25/22 21:37 | |

LABORATORY CONTROL SAMPLE: 3122817

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122818 3122819

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.4 | 10 | 10 | 11.6 | 11.5 | 102 | 102 | 80-120 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122820 3122821

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.2 | 10 | 10 | 11.5 | 11.5 | 103 | 102 | 80-120 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 677653
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 3120515 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/23/22 09:11 | |

LABORATORY CONTROL SAMPLE: 3120516

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120517 3120518

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.2 | 10 | 10 | 12.3 | 12.5 | 101 | 103 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120519 3120520

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.6 | 10 | 10 | 11.9 | 12.1 | 103 | 104 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Sample: M-4** **Lab ID: 50316495001** Collected: 05/12/22 17:10 Received: 05/13/22 14:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.571 ± 0.379 (0.442) C:NA T:81%** | pCi/L | 06/27/22 16:44 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **1.39 ± 0.561 (0.896) C:74% T:81%** | pCi/L | 06/21/22 16:00 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.96 ± 0.940 (1.34)** | pCi/L | 07/01/22 17:37 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

**Sample: MW-106I** **Lab ID: 50316495002** Collected: 05/12/22 15:00 Received: 05/13/22 14:45 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.999 ± 0.451 (0.334) C:NA T:90%** | pCi/L | 06/27/22 16:44 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.731 ± 0.369 (0.624) C:75% T:90%** | pCi/L | 06/21/22 16:00 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.73 ± 0.820 (0.958)** | pCi/L | 07/01/22 17:37 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 510560
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 2474591 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.140 ± 0.281 (0.619) C:75% T:91% | pCi/L | 06/21/22 16:01 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

QC Batch: 510558
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316495001, 50316495002

METHOD BLANK: 2474589 Matrix: Water
Associated Lab Samples: 50316495001, 50316495002

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.0499 ± 0.228 (0.135) C:NA T:91% | pCi/L | 06/27/22 17:13 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| B | Analyte was detected in the associated method blank. |
| D3 | Sample was diluted due to the presence of high levels of non-target analytes or other matrix interference. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| M3 | Matrix spike recovery was outside laboratory control limits due to matrix interferences. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316495

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316495001** | **M-4** | EPA 9056 | 678022 | | |
| **50316495002** | **MW-106I** | EPA 9056 | 678022 | | |
| **50316495001** | **M-4** | EPA 3010 | 677583 | EPA 6010 | 678550 |
| **50316495002** | **MW-106I** | EPA 3010 | 677583 | EPA 6010 | 678550 |
| **50316495001** | **M-4** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316495002** | **MW-106I** | EPA 3010 | 677124 | EPA 6010 | 677492 |
| **50316495001** | **M-4** | EPA 200.2 | 676701 | EPA 6020 | 676994 |
| **50316495002** | **MW-106I** | EPA 200.2 | 676701 | EPA 6020 | 676994 |
| **50316495001** | **M-4** | EPA 903.1 | 510558 | | |
| **50316495002** | **MW-106I** | EPA 903.1 | 510558 | | |
| **50316495001** | **M-4** | EPA 904.0 | 510560 | | |
| **50316495002** | **MW-106I** | EPA 904.0 | 510560 | | |
| **50316495001** | **M-4** | Total Radium Calculation | 515968 | | |
| **50316495002** | **MW-106I** | Total Radium Calculation | 515968 | | |
| **50316495001** | **M-4** | SM 2320B | 677185 | | |
| **50316495002** | **MW-106I** | SM 2320B | 677381 | | |
| **50316495001** | **M-4** | SM 2540C | 677048 | | |
| **50316495002** | **MW-106I** | SM 2540C | 677048 | | |
| **50316495001** | **M-4** | SM 4500-H+B | 677473 | | |
| **50316495002** | **MW-106I** | SM 4500-H+B | 677473 | | |
| **50316495001** | **M-4** | SM 4500-S2-D | 676794 | | |
| **50316495002** | **MW-106I** | SM 4500-S2-D | 676794 | | |
| **50316495001** | **M-4** | HACH 8146 | 678396 | | |
| **50316495002** | **MW-106I** | HACH 8146 | 678396 | | |
| **50316495001** | **M-4** | EPA 353.2 | 676251 | | |
| **50316495002** | **MW-106I** | EPA 353.2 | 676251 | | |
| **50316495001** | **M-4** | EPA 365.1 | 676638 | EPA 365.1 | 677704 |
| **50316495002** | **MW-106I** | EPA 365.1 | 676638 | EPA 365.1 | 677704 |
| **50316495001** | **M-4** | SM 5310C | 678177 | | |
| **50316495002** | **MW-106I** | SM 5310C | 678321 | | |
| **50316495001** | **M-4** | SM 5310C | 677653 | | |
| **50316495002** | **MW-106I** | SM 5310C | 677653 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelab

**WO# : 50316495**

50316495

| Section A | Section B | Section C |
|---|---|---|
| **Required Client Information:** | **Required Project Information:** | **Invoice Information:** |
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: Atlas Indianapolis |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 2 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 10498/16 |

**State / Location:** IN

**Requested Analysis Filtered (Y/N)**

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | | | | | Y | | | | | Y | | | | | |
| 1 | M-4 | WT | G | 5/12 | 1710 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 001 |
| 2 | ~~PZ-100S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 3 | ~~PZ-100D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 4 | ~~PZ-101S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 5 | ~~PZ-101D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 6 | ~~MW-102S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 7 | ~~MW-102D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 8 | ~~MW-103S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 9 | ~~MW-103L~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 10 | ~~MW-103D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 11 | ~~MW-104S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 12 | ~~MW-104D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 5/13 | 0600 | | | |
| 6020 (Co, As, Se, Sb) | | | | M. Nunez | 5/13/22 | 1445 |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| 2.3 | Y | N | Y |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: P. Gregg Hopper

SIGNATURE of SAMPLER:

DATE Signed: 5/12/22

# CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical® WWW.PACELABS.COM

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.



| Section A | Section B | Section C |
|---|---|---|
| **Required Client Information:** | **Required Project Information:** | **Invoice Information:** |
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: Atlas Indianapolis |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 2 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 10498/16 |

**Regulatory Agency**

**State / Location**: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

**Requested Analysis Filtered (Y/N)**

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | | | |
| 13 | ~~MW-105S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 14 | ~~MW-105I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 15 | ~~MW-105D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 16 | ~~MW-106S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 17 | MW-106I | WT | G | 5/12 | 1500 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | 502 |
| 18 | ~~MW-106D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 19 | ~~MW-107S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 20 | ~~MW-107I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 21 | ~~MW-107D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 22 | ~~MW-108S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 23 | ~~MW-108D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 24 | ~~DUP 3~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 5/13 | 0800 | | 5/13/22 | 1335 | | | | |
| 6020 (Co, As, Se, Sb) | | 5/13/22 | 0445 | M. Nunez | 5/13/22 | 1440 | 2.3 | Y | N | Y |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: P. Greg Hopper

SIGNATURE of SAMPLER: [signature] DATE Signed: 5/12/22

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

F-IN-Q-290-rev.22, 22Apr2022

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** MW 5/13/22 1628

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☒ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☒ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** 2.7 | 2.3 **(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☒ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☒ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** Nitrates | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 16:38 | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

COC PAGE 1 of 1

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

COC PAGE 2 of 2

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | SBS / DI / MeOH (only) / BK / Kit R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | |
|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass |
| GN | General | AG3C | 250mL NaOH amber glass |

### Plastic / Misc.

| | |
|---|---|
| BP1B | 1L NaOH plastic |
| BP1N | 1L HNO3 plastic |
| BP1S | 1L H2SO4 plastic |
| BP1U | 1L unpreserved plastic |
| BP1Z | 1L NaOH, Zn, Ac |
| BP2N | 500mL HNO3 plastic |
| BP2C | 500mL NaOH plastic |
| BP2S | 500mL H2SO4 plastic |
| BP2U | 500mL unpreserved plastic |
| BP2Z | 500mL NaOH, Zn Ac |
| BP3B | 250mL NaOH plastic |
| BP3N | 250mL HNO3 plastic |
| BP3F | 250mL HNO3 plastic-field filtered |
| BP3U | 250mL unpreserved plastic |
| BP3S | 250mL H2SO4 plastic |
| BP3Z | 250mL NaOH, ZnAc plastic |

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 13, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316507001** | **MW-8S** | Water | 05/13/22 13:35 | 05/13/22 16:00 |
| **50316507002** | **MW-8S MS** | Water | 05/13/22 13:35 | 05/13/22 16:00 |
| **50316507003** | **MW-8S MSD** | Water | 05/13/22 13:35 | 05/13/22 16:00 |
| **50316507004** | **Field Blank 1** | Water | 05/13/22 14:45 | 05/13/22 16:00 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316507001** | **MW-8S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316507002** | **MW-8S MS** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50316507003** | **MW-8S MSD** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50316507004** | **Field Blank 1** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | ILP | 1 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316507001** | **MW-8S** | | | | | |
| EPA 9056 | Chloride | 96.8 | mg/L | 2.5 | 05/27/22 03:27 | |
| EPA 9056 | Sulfate | 571 | mg/L | 25.0 | 05/27/22 04:18 | |
| EPA 6010 | Barium | 36.8 | ug/L | 10.0 | 05/26/22 13:00 | |
| EPA 6010 | Boron | 8280 | ug/L | 100 | 05/26/22 13:00 | |
| EPA 6010 | Calcium | 232000 | ug/L | 2000 | 05/26/22 14:37 | |
| EPA 6010 | Lithium | 101 | ug/L | 20.0 | 05/26/22 13:00 | |
| EPA 6010 | Magnesium | 70800 | ug/L | 1000 | 05/26/22 13:00 | |
| EPA 6010 | Manganese | 18.3 | ug/L | 10.0 | 05/26/22 13:00 | |
| EPA 6010 | Molybdenum | 165 | ug/L | 10.0 | 05/26/22 13:00 | |
| EPA 6010 | Potassium | 15300 | ug/L | 1000 | 05/26/22 13:00 | |
| EPA 6010 | Silica | 12200 | ug/L | 450 | 05/26/22 13:00 | N2 |
| EPA 6010 | Sodium | 89200 | ug/L | 1000 | 05/26/22 13:00 | |
| EPA 6010 | Manganese, Dissolved | 19.1 | ug/L | 10.0 | 05/26/22 00:53 | |
| EPA 6010 | Molybdenum, Dissolved | 177 | ug/L | 10.0 | 05/26/22 00:53 | |
| EPA 6020 | Selenium | 5.2 | ug/L | 1.0 | 05/21/22 05:08 | |
| EPA 903.1 | Radium-226 | 0.0805 ± 0.250 (0.483) C:NA T:98% | pCi/L | | 06/27/22 11:09 | |
| EPA 904.0 | Radium-228 | 0.514 ± 0.334 (0.621) C:69% T:98% | pCi/L | | 06/21/22 11:42 | |
| Total Radium Calculation | Total Radium | 0.595 ± 0.584 (1.10) | pCi/L | | 06/27/22 17:40 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 436 | mg/L | 2.0 | 05/20/22 19:54 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 436 | mg/L | 2.0 | 05/20/22 19:54 | |
| SM 2540C | Total Dissolved Solids | 1440 | mg/L | 20.0 | 05/19/22 15:32 | |
| SM 4500-H+B | pH at 25 Degrees C | 6.9 | Std. Units | 0.10 | 05/20/22 19:55 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.84 | mg/L | 0.10 | 05/14/22 09:41 | |
| SM 5310C | Total Organic Carbon | 1.2 | mg/L | 1.0 | 05/26/22 00:57 | |
| SM 5310C | Dissolved Organic Carbon | 1.6 | mg/L | 1.0 | 05/23/22 20:36 | |
| **50316507002** | **MW-8S MS** | | | | | |
| EPA 903.1 | Radium-226 | 74.98 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 06/27/22 11:09 | |
| EPA 904.0 | Radium-228 | 89.84 %REC ± NA (NA) C:NA T:NA | pCi/L | | 06/21/22 11:42 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316507003** | **MW-8S MSD** | | | | | |
| EPA 903.1 | Radium-226 | 102.14 %REC 30.66 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 06/27/22 11:09 | |
| EPA 904.0 | Radium-228 | 102.05 %REC 12.72 RPD ± NA (NA) C:NA T:NA | pCi/L | | 06/21/22 11:42 | |
| **50316507004** | **Field Blank 1** | | | | | |
| EPA 903.1 | Radium-226 | -0.0457 ± 0.208 (0.491) C:NA T:93% | pCi/L | | 06/27/22 11:09 | |
| EPA 904.0 | Radium-228 | 0.392 ± 0.311 (0.612) C:78% T:93% | pCi/L | | 06/21/22 11:42 | |
| Total Radium Calculation | Total Radium | 0.392 ± 0.519 (1.10) | pCi/L | | 06/27/22 17:40 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 7.6 | mg/L | 2.0 | 05/20/22 19:54 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 7.6 | mg/L | 2.0 | 05/20/22 19:54 | |
| SM 4500-H+B | pH at 25 Degrees C | 5.6 | Std. Units | 0.10 | 05/20/22 19:57 | H3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: MW-8S** **Lab ID: 50316507001** Collected: 05/13/22 13:35 Received: 05/13/22 16:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **96.8** | mg/L | 2.5 | 10 | | 05/27/22 03:27 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 05/27/22 02:36 | 16984-48-8 | |
| Sulfate | **571** | mg/L | 25.0 | 100 | | 05/27/22 04:18 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7429-90-5 | |
| Barium | **36.8** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7440-39-3 | |
| Boron | **8280** | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7440-43-9 | |
| Calcium | **232000** | ug/L | 2000 | 2 | 05/25/22 08:57 | 05/26/22 14:37 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7439-92-1 | |
| Lithium | **101** | ug/L | 20.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7439-93-2 | |
| Magnesium | **70800** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7439-95-4 | |
| Manganese | **18.3** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7439-96-5 | |
| Molybdenum | **165** | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7439-98-7 | |
| Potassium | **15300** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7440-09-7 | |
| Silica | **12200** | ug/L | 450 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7631-86-9 | N2 |
| Sodium | **89200** | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:00 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **19.1** | ug/L | 10.0 | 1 | 05/24/22 09:09 | 05/26/22 00:53 | 7439-96-5 | |
| Molybdenum, Dissolved | **177** | ug/L | 10.0 | 1 | 05/24/22 09:09 | 05/26/22 00:53 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:08 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:08 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/19/22 08:05 | 05/21/22 05:08 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:08 | 7440-48-4 | |
| Selenium | **5.2** | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:08 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:08 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/19/22 21:17 | 05/20/22 16:37 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **436** | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| Alkalinity,Bicarbonate (CaCO3) | **436** | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: MW-8S** **Lab ID: 50316507001** Collected: 05/13/22 13:35 Received: 05/13/22 16:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1440** | mg/L | 20.0 | 1 | | 05/19/22 15:32 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **6.9** | Std. Units | 0.10 | 1 | | 05/20/22 19:55 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:45 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.84** | mg/L | 0.10 | 1 | | 05/14/22 09:41 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:41 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 09:56 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.2** | mg/L | 1.0 | 1 | | 05/26/22 00:57 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/23/22 20:36 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: Field Blank 1** **Lab ID: 50316507004** Collected: 05/13/22 14:45 Received: 05/13/22 16:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | ND | mg/L | 0.25 | 1 | | 05/27/22 05:43 | 16887-00-6 | |
| Fluoride | ND | mg/L | 0.10 | 1 | | 05/27/22 05:43 | 16984-48-8 | |
| Sulfate | ND | mg/L | 0.25 | 1 | | 05/27/22 05:43 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7429-90-5 | |
| Barium | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-39-3 | |
| Boron | ND | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-43-9 | |
| Calcium | ND | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7439-93-2 | |
| Magnesium | ND | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7439-98-7 | |
| Potassium | ND | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-09-7 | |
| Silica | ND | ug/L | 450 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7631-86-9 | N2 |
| Sodium | ND | ug/L | 1000 | 1 | 05/25/22 08:57 | 05/26/22 13:06 | 7440-23-5 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:32 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:32 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/19/22 08:05 | 05/21/22 05:32 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:32 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:32 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/19/22 08:05 | 05/21/22 05:32 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/19/22 21:17 | 05/20/22 16:44 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **7.6** | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| Alkalinity,Bicarbonate (CaCO3) | **7.6** | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/20/22 19:54 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | ND | mg/L | 10.0 | 1 | | 05/19/22 15:16 | | PL |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: Field Blank 1** **Lab ID: 50316507004** Collected: 05/13/22 14:45 Received: 05/13/22 16:00 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **5.6** | Std. Units | 0.10 | 1 | | 05/20/22 19:57 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:47 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/14/22 09:58 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:58 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 09:58 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/26/22 01:33 | 7440-44-0 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 678028
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3121716 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/27/22 14:46 | |
| Fluoride | mg/L | ND | 0.10 | 05/27/22 14:46 | |
| Sulfate | mg/L | ND | 0.25 | 05/27/22 14:46 | |

LABORATORY CONTROL SAMPLE: 3121717

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 93 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.51 | 102 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.5 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3121718 3121719

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 96.8 | 12.5 | 12.5 | 99.9 | 99.6 | 25 | 22 | 80-120 | 0 | 15 | M0 |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.40 | 0.41 | 77 | 79 | 80-120 | 3 | 15 | M0 |
| Sulfate | mg/L | 571 | 250 | 250 | 762 | 764 | 77 | 77 | 80-120 | 0 | 15 | M0 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677141
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3117622 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/20/22 15:51 | |

LABORATORY CONTROL SAMPLE: 3117623

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 4.9 | 98 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117624 3117625

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 4.7 | 4.8 | 95 | 96 | 75-125 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117626 3117627

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 4.9 | 5.0 | 99 | 99 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677583
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3120339 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/26/22 12:03 | |
| Barium | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Boron | ug/L | ND | 100 | 05/26/22 12:03 | |
| Cadmium | ug/L | ND | 2.0 | 05/26/22 12:03 | |
| Calcium | ug/L | ND | 1000 | 05/26/22 12:03 | |
| Chromium | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Iron | ug/L | ND | 100 | 05/26/22 12:03 | |
| Lead | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Lithium | ug/L | ND | 20.0 | 05/26/22 12:03 | |
| Magnesium | ug/L | ND | 1000 | 05/26/22 12:03 | |
| Manganese | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Molybdenum | ug/L | ND | 10.0 | 05/26/22 12:03 | |
| Potassium | ug/L | ND | 1000 | 05/26/22 12:03 | |
| Silica | ug/L | ND | 450 | 05/26/22 12:03 | N2 |
| Sodium | ug/L | ND | 1000 | 05/26/22 12:03 | |

LABORATORY CONTROL SAMPLE: 3120340

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9430 | 94 | 80-120 | |
| Barium | ug/L | 1000 | 976 | 98 | 80-120 | |
| Boron | ug/L | 1000 | 929 | 93 | 80-120 | |
| Cadmium | ug/L | 1000 | 942 | 94 | 80-120 | |
| Calcium | ug/L | 10000 | 9690 | 97 | 80-120 | |
| Chromium | ug/L | 1000 | 967 | 97 | 80-120 | |
| Iron | ug/L | 10000 | 9430 | 94 | 80-120 | |
| Lead | ug/L | 1000 | 919 | 92 | 80-120 | |
| Lithium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Magnesium | ug/L | 10000 | 9240 | 92 | 80-120 | |
| Manganese | ug/L | 1000 | 936 | 94 | 80-120 | |
| Molybdenum | ug/L | 1000 | 983 | 98 | 80-120 | |
| Potassium | ug/L | 10000 | 9460 | 95 | 80-120 | |
| Silica | ug/L | 10700 | 9950 | 93 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9710 | 97 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120341 3120342

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 9740 | 10200 | 97 | 102 | 75-125 | 5 | 20 | |
| Barium | ug/L | 127 | 1000 | 1000 | 1120 | 1170 | 99 | 104 | 75-125 | 4 | 20 | |
| Boron | ug/L | 723 | 1000 | 1000 | 1690 | 1760 | 97 | 103 | 75-125 | 4 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 986 | 1020 | 99 | 102 | 75-125 | 4 | 20 | |
| Calcium | ug/L | 174000 | 10000 | 10000 | 188000 | 193000 | 137 | 184 | 75-125 | 2 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 961 | 1000 | 96 | 100 | 75-125 | 4 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9270 | 9680 | 93 | 97 | 75-125 | 4 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 901 | 934 | 90 | 93 | 75-125 | 4 | 20 | |
| Lithium | ug/L | 26.2 | 1000 | 1000 | 1140 | 1180 | 111 | 116 | 75-125 | 4 | 20 | |
| Magnesium | ug/L | 45400 | 10000 | 10000 | 55000 | 56100 | 96 | 107 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 17.3 | 1000 | 1000 | 943 | 981 | 93 | 96 | 75-125 | 4 | 20 | |
| Molybdenum | ug/L | 25.6 | 1000 | 1000 | 1040 | 1080 | 102 | 105 | 75-125 | 3 | 20 | |
| Potassium | ug/L | 5970 | 10000 | 10000 | 16500 | 17200 | 106 | 112 | 75-125 | 4 | 20 | |
| Silica | ug/L | 15100 | 10700 | 10700 | 25500 | 26200 | 97 | 104 | 75-125 | 3 | 20 | N2 |
| Sodium | ug/L | 97800 | 10000 | 10000 | 111000 | 114000 | 134 | 164 | 75-125 | 3 | 20 | P6 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120343 3120344

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 9820 | 101 | 98 | 75-125 | 2 | 20 | |
| Barium | ug/L | 36.8 | 1000 | 1000 | 1020 | 1020 | 98 | 99 | 75-125 | 0 | 20 | |
| Boron | ug/L | 8280 | 1000 | 1000 | 10200 | 9760 | 190 | 148 | 75-125 | 4 | 20 | P6 |
| Cadmium | ug/L | ND | 1000 | 1000 | 998 | 986 | 100 | 99 | 75-125 | 1 | 20 | |
| Calcium | ug/L | 232000 | 10000 | 10000 | 258000 | 258000 | 262 | 262 | 75-125 | 0 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 964 | 963 | 96 | 96 | 75-125 | 0 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9500 | 9220 | 95 | 92 | 75-125 | 3 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 900 | 889 | 90 | 89 | 75-125 | 1 | 20 | |
| Lithium | ug/L | 101 | 1000 | 1000 | 1230 | 1220 | 113 | 112 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 70800 | 10000 | 10000 | 86800 | 82800 | 160 | 121 | 75-125 | 5 | 20 | P6 |
| Manganese | ug/L | 18.3 | 1000 | 1000 | 969 | 940 | 95 | 92 | 75-125 | 3 | 20 | |
| Molybdenum | ug/L | 165 | 1000 | 1000 | 1200 | 1180 | 104 | 102 | 75-125 | 2 | 20 | |
| Potassium | ug/L | 15300 | 10000 | 10000 | 27000 | 26800 | 117 | 116 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12200 | 10700 | 10700 | 23800 | 23100 | 109 | 102 | 75-125 | 3 | 20 | N2 |
| Sodium | ug/L | 89200 | 10000 | 10000 | 106000 | 105000 | 166 | 154 | 75-125 | 1 | 20 | P6 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677438
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001

METHOD BLANK: 3119328 Matrix: Water
Associated Lab Samples: 50316507001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/26/22 00:51 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/26/22 00:51 | |

LABORATORY CONTROL SAMPLE: 3119329

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 981 | 98 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1030 | 103 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3119330 3119331

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 19.1 | 1000 | 1000 | 938 | 973 | 92 | 95 | 75-125 | 4 | 20 | |
| Molybdenum, Dissolved | ug/L | 177 | 1000 | 1000 | 1170 | 1220 | 100 | 104 | 75-125 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 676951
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3116738 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/21/22 04:10 | |
| Arsenic | ug/L | ND | 1.0 | 05/21/22 04:10 | |
| Beryllium | ug/L | ND | 0.20 | 05/21/22 04:10 | |
| Cobalt | ug/L | ND | 1.0 | 05/21/22 04:10 | |
| Selenium | ug/L | ND | 1.0 | 05/21/22 04:10 | |
| Thallium | ug/L | ND | 1.0 | 05/21/22 04:10 | |

LABORATORY CONTROL SAMPLE: 3116739

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.7 | 104 | 80-120 | |
| Arsenic | ug/L | 40 | 38.9 | 97 | 80-120 | |
| Beryllium | ug/L | 40 | 40.6 | 102 | 80-120 | |
| Cobalt | ug/L | 40 | 40.7 | 102 | 80-120 | |
| Selenium | ug/L | 40 | 39.7 | 99 | 80-120 | |
| Thallium | ug/L | 40 | 41.9 | 105 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116740 3116741

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.2 | 42.5 | 108 | 106 | 75-125 | 2 | 20 | |
| Arsenic | ug/L | 2.0 | 40 | 40 | 39.7 | 40.4 | 94 | 96 | 75-125 | 2 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 42.7 | 42.5 | 107 | 106 | 75-125 | 0 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.6 | 39.4 | 96 | 98 | 75-125 | 2 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 38.7 | 38.7 | 95 | 95 | 75-125 | 0 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 43.3 | 43.0 | 108 | 108 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116742 3116743

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 44.1 | 42.8 | 110 | 107 | 75-125 | 3 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 39.6 | 38.5 | 98 | 96 | 75-125 | 3 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 44.8 | 44.1 | 112 | 110 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 40.2 | 38.6 | 100 | 96 | 75-125 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116742 3116743

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Selenium | ug/L | 5.2 | 40 | 40 | 45.6 | 43.9 | 101 | 97 | 75-125 | 4 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 44.4 | 43.3 | 111 | 108 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677381
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3118900 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/20/22 19:54 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/20/22 19:54 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/20/22 19:54 | |

LABORATORY CONTROL SAMPLE: 3118901

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 53.0 | 106 | 90-110 | |

SAMPLE DUPLICATE: 3118903

| Parameter | Units | 50316506002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 289 | 296 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 289 | 296 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3118904

| Parameter | Units | 50316507001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 436 | 442 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 436 | 442 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677049
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507004

METHOD BLANK: 3117321 Matrix: Water
Associated Lab Samples: 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/19/22 15:11 | |

LABORATORY CONTROL SAMPLE: 3117326

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 304 | 101 | 80-120 | |

SAMPLE DUPLICATE: 3117322

| Parameter | Units | 50316506002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1100 | 1110 | 1 | 10 | |

SAMPLE DUPLICATE: 3117323

| Parameter | Units | 50316478003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 828 | 800 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677053
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001

METHOD BLANK: 3117336 Matrix: Water
Associated Lab Samples: 50316507001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/19/22 15:32 | |

LABORATORY CONTROL SAMPLE: 3117337

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 298 | 99 | 80-120 | |

SAMPLE DUPLICATE: 3117338

| Parameter | Units | 50316507001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1440 | 1440 | 0 | 10 | |

SAMPLE DUPLICATE: 3117339

| Parameter | Units | 50316511002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1490 | 1460 | 2 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677484
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

SAMPLE DUPLICATE: 3119900

| Parameter | Units | 50316506002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3119901

| Parameter | Units | 50316507001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.9 | 7.0 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 676796
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3116034 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/18/22 09:54 | |

LABORATORY CONTROL SAMPLE: 3116035

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.46 | 92 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116036 3116037

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.53 | 0.52 | 106 | 105 | 90-110 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116038 3116039

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.50 | 103 | 100 | 90-110 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 678397
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3123112 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/25/22 22:41 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3123113

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 102 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3123114 3123115

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 0.97 | 0.96 | 97 | 96 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3123116 3123117

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 0.98 | 0.99 | 98 | 99 | 90-110 | 1 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 676251
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3114048 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/14/22 09:04 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/14/22 09:04 | |

LABORATORY CONTROL SAMPLE: 3114049

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.97 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114050 3114051

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.84 | 1 | 1 | 1.9 | 1.9 | 102 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.97 | 0.97 | 97 | 97 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114052 3114053

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.98 | 0.98 | 98 | 98 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 676640
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3115309 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/21/22 09:53 | |

LABORATORY CONTROL SAMPLE: 3115310

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115311 3115312

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.5 | | | | 1 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115313 3115314

| Parameter | Units | 50316478003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.28 | | | 1.7 | 1.6 | | | | 10 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115315 3115316

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.59 | | | 1.9 | 1.9 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 678321
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001, 50316507004

METHOD BLANK: 3122816 Matrix: Water
Associated Lab Samples: 50316507001, 50316507004

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/25/22 21:37 | |

LABORATORY CONTROL SAMPLE: 3122817

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122818 3122819

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.4 | 10 | 10 | 11.6 | 11.5 | 102 | 102 | 80-120 | 0 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122820 3122821

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.2 | 10 | 10 | 11.5 | 11.5 | 103 | 102 | 80-120 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 677653
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316507001

METHOD BLANK: 3120515 Matrix: Water
Associated Lab Samples: 50316507001

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/23/22 09:11 | |

LABORATORY CONTROL SAMPLE: 3120516

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120517 3120518

| Parameter | Units | 50316506002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.2 | 10 | 10 | 12.3 | 12.5 | 101 | 103 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120519 3120520

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 1.6 | 10 | 10 | 11.9 | 12.1 | 103 | 104 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: MW-8S** **Lab ID: 50316507001** Collected: 05/13/22 13:35 Received: 05/13/22 16:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.0805 ± 0.250 (0.483) C:NA T:98%** | pCi/L | 06/27/22 11:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.514 ± 0.334 (0.621) C:69% T:98%** | pCi/L | 06/21/22 11:42 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.595 ± 0.584 (1.10)** | pCi/L | 06/27/22 17:40 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: MW-8S MS** **Lab ID: 50316507002** Collected: 05/13/22 13:35 Received: 05/13/22 16:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-226 | EPA 903.1 | **74.98 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 06/27/22 11:09 | 13982-63-3 | |
| | | Pace Analytical Services - Greensburg | | | | |
| Radium-228 | EPA 904.0 | **89.84 %REC ± NA (NA) C:NA T:NA** | pCi/L | 06/21/22 11:42 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: MW-8S MSD** **Lab ID: 50316507003** Collected: 05/13/22 13:35 Received: 05/13/22 16:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **102.14 %REC 30.66 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 06/27/22 11:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **102.05 %REC 12.72 RPD ± NA (NA) C:NA T:NA** | pCi/L | 06/21/22 11:42 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

**Sample: Field Blank 1** **Lab ID: 50316507004** Collected: 05/13/22 14:45 Received: 05/13/22 16:00 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **-0.0457 ± 0.208 (0.491) C:NA T:93%** | pCi/L | 06/27/22 11:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.392 ± 0.311 (0.612) C:78% T:93%** | pCi/L | 06/21/22 11:42 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.392 ± 0.519 (1.10)** | pCi/L | 06/27/22 17:40 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 510549
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316507001, 50316507002, 50316507003, 50316507004

METHOD BLANK: 2474573 Matrix: Water
Associated Lab Samples: 50316507001, 50316507002, 50316507003, 50316507004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.0450 ± 0.265 (0.590) C:NA T:95% | pCi/L | 06/27/22 11:09 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

QC Batch: 510550
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316507001, 50316507002, 50316507003, 50316507004

METHOD BLANK: 2474574 Matrix: Water
Associated Lab Samples: 50316507001, 50316507002, 50316507003, 50316507004

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | -0.144 ± 0.223 (0.568) C:75% T:95% | pCi/L | 06/21/22 11:42 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| PL | The minimum mass of dried residue of 2.5 mg could not be obtained using the routine sample volume of 100 mL. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50316507

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316507001** | **MW-8S** | EPA 9056 | 678028 | | |
| **50316507004** | **Field Blank 1** | EPA 9056 | 678028 | | |
| **50316507001** | **MW-8S** | EPA 3010 | 677583 | EPA 6010 | 678550 |
| **50316507004** | **Field Blank 1** | EPA 3010 | 677583 | EPA 6010 | 678550 |
| **50316507001** | **MW-8S** | EPA 3010 | 677438 | EPA 6010 | 678437 |
| **50316507001** | **MW-8S** | EPA 200.2 | 676951 | EPA 6020 | 677119 |
| **50316507004** | **Field Blank 1** | EPA 200.2 | 676951 | EPA 6020 | 677119 |
| **50316507001** | **MW-8S** | EPA 7470 | 677141 | EPA 7470 | 677300 |
| **50316507004** | **Field Blank 1** | EPA 7470 | 677141 | EPA 7470 | 677300 |
| **50316507001** | **MW-8S** | EPA 903.1 | 510549 | | |
| **50316507002** | **MW-8S MS** | EPA 903.1 | 510549 | | |
| **50316507003** | **MW-8S MSD** | EPA 903.1 | 510549 | | |
| **50316507004** | **Field Blank 1** | EPA 903.1 | 510549 | | |
| **50316507001** | **MW-8S** | EPA 904.0 | 510550 | | |
| **50316507002** | **MW-8S MS** | EPA 904.0 | 510550 | | |
| **50316507003** | **MW-8S MSD** | EPA 904.0 | 510550 | | |
| **50316507004** | **Field Blank 1** | EPA 904.0 | 510550 | | |
| **50316507001** | **MW-8S** | Total Radium Calculation | 514741 | | |
| **50316507004** | **Field Blank 1** | Total Radium Calculation | 514741 | | |
| **50316507001** | **MW-8S** | SM 2320B | 677381 | | |
| **50316507004** | **Field Blank 1** | SM 2320B | 677381 | | |
| **50316507001** | **MW-8S** | SM 2540C | 677053 | | |
| **50316507004** | **Field Blank 1** | SM 2540C | 677049 | | |
| **50316507001** | **MW-8S** | SM 4500-H+B | 677484 | | |
| **50316507004** | **Field Blank 1** | SM 4500-H+B | 677484 | | |
| **50316507001** | **MW-8S** | SM 4500-S2-D | 676796 | | |
| **50316507004** | **Field Blank 1** | SM 4500-S2-D | 676796 | | |
| **50316507001** | **MW-8S** | HACH 8146 | 678397 | | |
| **50316507004** | **Field Blank 1** | HACH 8146 | 678397 | | |
| **50316507001** | **MW-8S** | EPA 353.2 | 676251 | | |
| **50316507004** | **Field Blank 1** | EPA 353.2 | 676251 | | |
| **50316507001** | **MW-8S** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316507004** | **Field Blank 1** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316507001** | **MW-8S** | SM 5310C | 678321 | | |
| **50316507004** | **Field Blank 1** | SM 5310C | 678321 | | |
| **50316507001** | **MW-8S** | SM 5310C | 677653 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Doc

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must

**WO# : 50316507**

50316507

| Section A | Section B | Section C |
|---|---|---|
| **Required Client Information:** | **Required Project Information:** | **Invoice Information:** |
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: Atlas Indianapolis |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 1 | Pace Project Manager: Hayden Putt |
| Requested Due Date: | Project #: | Pace Profile #: 10498/15 |

**State / Location:** IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | | | | Requested Analysis Filtered (Y/N) | | | | Y | | | | | Y | | | | | | |
| 1 | MW-1S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 2 | MW-1D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 3 | MW-2S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 4 | MW-2D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 5 | MW-3S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 6 | MW-3D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 7 | MW-4S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 8 | MW-5S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 9 | MW-6S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 10 | MW-7S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 11 | MW-7D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | | |
| 12 | MW-8S | WT | G | | | 5/13/22 | 1335 | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | | MS/MSD | |

001
002
003

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME |
|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting/Atlas | 5/13/22 | 1600 | | 5/13/22 | 1600 |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | | | | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | |

| SAMPLE CONDITIONS | | | |
|---|---|---|---|
| See Sciv | Y | N | Y |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: MARK BRETING

SIGNATURE of SAMPLER: Mark Breting DATE Signed: 5/13/22

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page : 3 Of 3

| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

Regulatory Agency

State / Location: IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

Requested Analysis Filtered (Y/N)

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** (Y) | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C (Y) | Sulfide | Phosphate | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 25 | MW-15S | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 26 | MW-15I | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | |
| 30 | Field Blank 1 | WT | G | | | 5/13/22 | 1445 | | 9 | 3 | 2 | 3 | | 1 | | | | | X | X | X | | X | X | X | X | | X | X | | 004 |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting / Atlas | 5/13/22 | 1600 | | 5/13/22 | 1600 | Ice/Cool | Y | N | Y |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | | | | | | | | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: MARK BRETING

SIGNATURE of SAMPLER: Mark Breting

DATE Signed: 5/13/22

TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N)

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** MCS 5/13/22 1730

1. **Courier:** ☐ FED EX ☐ UPS ☑ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 (5) 6 A B (C) D E F

4. **Cooler Temperature(s):** 4.7 / 4.3 | 5.4 / 5.1 | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH(ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

**COC PAGE 1 of 2**

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | SW | ✓ | ✓ | |

Container Codes

### Glass

| | | | | |
|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | |
| GN | General | AG3C | 250mL NaOH amber glass | |

### Plastic / Misc.

| | |
|---|---|
| BP1B | 1L NaOH plastic |
| BP1N | 1L HNO3 plastic |
| BP1S | 1L H2SO4 plastic |
| BP1U | 1L unpreserved plastic |
| BP1Z | 1L NaOH, Zn, Ac |
| BP2N | 500mL HNO3 plastic |
| BP2C | 500mL NaOH plastic |
| BP2S | 500mL H2SO4 plastic |
| BP2U | 500mL unpreserved plastic |
| BP2Z | 500mL NaOH, Zn Ac |
| BP3B | 250mL NaOH plastic |
| BP3N | 250mL HNO3 plastic |
| BP3F | 250mL HNO3 plastic-field filtered |
| BP3U | 250mL unpreserved plastic |
| BP3S | 250mL H2SO4 plastic |
| BP3Z | 250mL NaOH, ZnAc plastic |

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**COC PAGE 2 of 2**

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | 1 | | | | 2 | 1 | 2 | 1 | | 1 | | 1 | | | | | 5G | ✓ | ✓ | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 13, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50316511001** | **PZ-100S** | Water | 05/13/22 13:55 | 05/13/22 17:10 |
| **50316511002** | **PZ-100D** | Water | 05/13/22 13:55 | 05/13/22 17:10 |
| **50316511003** | **MW-102S** | Water | 05/13/22 10:45 | 05/13/22 17:10 |
| **50316511004** | **MW-104S** | Water | 05/13/22 11:45 | 05/13/22 17:10 |
| **50316511005** | **MW-104D** | Water | 05/13/22 10:25 | 05/13/22 17:10 |
| **50316511006** | **MW-102D** | Water | 05/13/22 11:55 | 05/13/22 17:10 |
| **50316511007** | **PZ-100D RAD MS** | Water | 05/13/22 13:55 | 05/13/22 17:10 |
| **50316511008** | **PZ-100D RAD MSD** | Water | 05/13/22 13:55 | 05/13/22 17:10 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316511001** | **PZ-100S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316511002** | **PZ-100D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316511003** | **MW-102S** | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316511004** | **MW-104S** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316511005** | **MW-104D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | MMS | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50316511006** | **MW-102D** | EPA 9056 | BK1 | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | DMT | 4 | PASI-I |
| | | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | TAY | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TRK | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | ZM | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50316511007** | **PZ-100D RAD MS** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |
| **50316511008** | **PZ-100D RAD MSD** | EPA 903.1 | SLC | 1 | PASI-PA |
| | | EPA 904.0 | VAL | 1 | PASI-PA |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316511001** | **PZ-100S** | | | | | |
| EPA 9056 | Chloride | 267 | mg/L | 25.0 | 05/27/22 07:34 | |
| EPA 9056 | Fluoride | 2.0 | mg/L | 0.10 | 05/27/22 06:57 | |
| EPA 9056 | Sulfate | 455 | mg/L | 25.0 | 05/27/22 07:34 | |
| EPA 6010 | Barium | 34.4 | ug/L | 10.0 | 05/27/22 09:58 | |
| EPA 6010 | Boron | 2160 | ug/L | 100 | 05/27/22 09:58 | |
| EPA 6010 | Calcium | 176000 | ug/L | 1000 | 05/27/22 09:58 | |
| EPA 6010 | Iron | 1800 | ug/L | 100 | 05/27/22 09:58 | |
| EPA 6010 | Lithium | 61.2 | ug/L | 20.0 | 05/27/22 09:58 | |
| EPA 6010 | Magnesium | 59900 | ug/L | 1000 | 05/27/22 09:58 | |
| EPA 6010 | Manganese | 359 | ug/L | 10.0 | 05/27/22 09:58 | |
| EPA 6010 | Molybdenum | 113 | ug/L | 10.0 | 05/27/22 09:58 | |
| EPA 6010 | Potassium | 10700 | ug/L | 1000 | 05/27/22 09:58 | |
| EPA 6010 | Silica | 15300 | ug/L | 450 | 05/27/22 09:58 | N2 |
| EPA 6010 | Sodium | 230000 | ug/L | 2000 | 05/27/22 12:10 | |
| EPA 6010 | Manganese, Dissolved | 373 | ug/L | 10.0 | 05/27/22 03:53 | |
| EPA 6010 | Molybdenum, Dissolved | 115 | ug/L | 10.0 | 05/27/22 03:53 | |
| EPA 6020 | Arsenic | 2.6 | ug/L | 1.0 | 05/20/22 08:16 | |
| EPA 903.1 | Radium-226 | 0.810 ± 0.495 (0.608) C:NA T:84% | pCi/L | | 06/29/22 12:09 | |
| EPA 904.0 | Radium-228 | 0.451 ± 0.351 (0.686) C:78% T:84% | pCi/L | | 06/23/22 15:15 | |
| Total Radium Calculation | Total Radium | 1.26 ± 0.846 (1.29) | pCi/L | | 06/30/22 15:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 335 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 335 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2540C | Total Dissolved Solids | 1530 | mg/L | 20.0 | 05/19/22 15:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/21/22 08:51 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.13 | mg/L | 0.10 | 05/14/22 09:50 | |
| **50316511002** | **PZ-100D** | | | | | |
| EPA 9056 | Chloride | 211 | mg/L | 25.0 | 05/27/22 08:29 | |
| EPA 9056 | Fluoride | 0.60 | mg/L | 0.10 | 05/27/22 07:52 | |
| EPA 9056 | Sulfate | 579 | mg/L | 25.0 | 05/27/22 08:29 | |
| EPA 6010 | Barium | 59.5 | ug/L | 10.0 | 05/27/22 10:01 | |
| EPA 6010 | Boron | 6770 | ug/L | 100 | 05/27/22 10:01 | |
| EPA 6010 | Calcium | 232000 | ug/L | 2000 | 05/27/22 12:12 | |
| EPA 6010 | Iron | 3270 | ug/L | 100 | 05/27/22 10:01 | |
| EPA 6010 | Lithium | 81.1 | ug/L | 20.0 | 05/27/22 10:01 | |
| EPA 6010 | Magnesium | 58600 | ug/L | 1000 | 05/27/22 10:01 | |
| EPA 6010 | Manganese | 230 | ug/L | 10.0 | 05/27/22 10:01 | |
| EPA 6010 | Molybdenum | 152 | ug/L | 10.0 | 05/27/22 10:01 | |
| EPA 6010 | Potassium | 11900 | ug/L | 1000 | 05/27/22 10:01 | |
| EPA 6010 | Silica | 12800 | ug/L | 450 | 05/27/22 10:01 | N2 |
| EPA 6010 | Sodium | 156000 | ug/L | 1000 | 05/27/22 10:01 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316511002** | **PZ-100D** | | | | | |
| EPA 6010 | Manganese, Dissolved | 232 | ug/L | 10.0 | 05/27/22 03:55 | |
| EPA 6010 | Molybdenum, Dissolved | 150 | ug/L | 10.0 | 05/27/22 03:55 | |
| EPA 6020 | Arsenic | 81.3 | ug/L | 1.0 | 05/20/22 08:20 | |
| EPA 903.1 | Radium-226 | 0.655 ± 0.407 (0.402) C:NA T:77% | pCi/L | | 06/29/22 12:09 | |
| EPA 904.0 | Radium-228 | 0.587 ± 0.456 (0.897) C:71% T:77% | pCi/L | | 06/23/22 15:15 | |
| Total Radium Calculation | Total Radium | 1.24 ± 0.863 (1.30) | pCi/L | | 06/30/22 15:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 260 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 260 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2540C | Total Dissolved Solids | 1490 | mg/L | 20.0 | 05/19/22 15:33 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 05/21/22 08:52 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.59 | mg/L | 0.15 | 05/21/22 10:07 | |
| SM 5310C | Total Organic Carbon | 1.6 | mg/L | 1.0 | 05/26/22 08:41 | |
| SM 5310C | Dissolved Organic Carbon | 2.0 | mg/L | 1.0 | 05/24/22 06:27 | |
| **50316511003** | **MW-102S** | | | | | |
| EPA 6010 | Aluminum | 5320 | ug/L | 200 | 05/27/22 10:11 | |
| EPA 6010 | Barium | 74.3 | ug/L | 10.0 | 05/27/22 10:11 | |
| EPA 6010 | Boron | 5710 | ug/L | 100 | 05/27/22 10:11 | |
| EPA 6010 | Calcium | 256000 | ug/L | 2000 | 05/27/22 12:18 | |
| EPA 6010 | Chromium | 13.7 | ug/L | 10.0 | 05/27/22 10:11 | |
| EPA 6010 | Iron | 23800 | ug/L | 100 | 05/27/22 10:11 | |
| EPA 6010 | Lithium | 62.9 | ug/L | 20.0 | 05/27/22 10:11 | |
| EPA 6010 | Magnesium | 83900 | ug/L | 1000 | 05/27/22 10:11 | |
| EPA 6010 | Manganese | 631 | ug/L | 10.0 | 05/27/22 10:11 | |
| EPA 6010 | Molybdenum | 44.9 | ug/L | 10.0 | 05/27/22 10:11 | |
| EPA 6010 | Potassium | 12000 | ug/L | 1000 | 05/27/22 10:11 | |
| EPA 6010 | Silica | 32500 | ug/L | 450 | 05/27/22 10:11 | N2 |
| EPA 6010 | Sodium | 162000 | ug/L | 1000 | 05/27/22 10:11 | |
| EPA 6010 | Manganese, Dissolved | 550 | ug/L | 10.0 | 05/27/22 04:08 | |
| EPA 6010 | Molybdenum, Dissolved | 40.3 | ug/L | 10.0 | 05/27/22 04:08 | |
| EPA 6020 | Arsenic | 83.6 | ug/L | 1.0 | 05/20/22 08:49 | |
| EPA 6020 | Cobalt | 2.8 | ug/L | 1.0 | 05/20/22 08:49 | |
| EPA 6020 | Selenium | 1.1 | ug/L | 1.0 | 05/20/22 08:49 | |
| EPA 903.1 | Radium-226 | 0.270 ± 0.319 (0.502) C:NA T:75% | pCi/L | | 06/29/22 12:09 | |
| EPA 904.0 | Radium-228 | 0.587 ± 0.436 (0.843) C:71% T:75% | pCi/L | | 06/23/22 15:15 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316511003** | **MW-102S** | | | | | |
| Total Radium Calculation | Total Radium | 0.857 ± 0.755 (1.35) | pCi/L | | 06/30/22 15:17 | |
| EPA 365.1 | Phosphate as P04 | 0.23 | mg/L | 0.15 | 05/21/22 10:10 | |
| SM 5310C | Total Organic Carbon | 2.2 | mg/L | 2.0 | 05/26/22 09:23 | |
| SM 5310C | Dissolved Organic Carbon | 10.9 | mg/L | 1.0 | 05/24/22 07:29 | |
| **50316511004** | **MW-104S** | | | | | |
| EPA 9056 | Chloride | 58.2 | mg/L | 2.5 | 05/27/22 11:52 | |
| EPA 9056 | Fluoride | 0.22 | mg/L | 0.10 | 05/27/22 11:34 | |
| EPA 9056 | Sulfate | 748 | mg/L | 25.0 | 05/27/22 12:11 | |
| EPA 6010 | Barium | 28.8 | ug/L | 10.0 | 05/27/22 10:14 | |
| EPA 6010 | Boron | 1270 | ug/L | 100 | 05/27/22 10:14 | |
| EPA 6010 | Calcium | 302000 | ug/L | 2000 | 05/27/22 12:20 | |
| EPA 6010 | Lithium | 26.3 | ug/L | 20.0 | 05/27/22 10:14 | |
| EPA 6010 | Magnesium | 79300 | ug/L | 1000 | 05/27/22 10:14 | |
| EPA 6010 | Potassium | 6800 | ug/L | 1000 | 05/27/22 10:14 | |
| EPA 6010 | Silica | 10700 | ug/L | 450 | 05/27/22 10:14 | N2 |
| EPA 6010 | Sodium | 62100 | ug/L | 1000 | 05/27/22 10:14 | |
| EPA 6020 | Selenium | 3.9 | ug/L | 1.0 | 05/20/22 08:53 | |
| EPA 903.1 | Radium-226 | 0.469 ± 0.454 (0.704) C:NA T:85% | pCi/L | | 06/29/22 12:09 | |
| EPA 904.0 | Radium-228 | 0.391 ± 0.331 (0.655) C:78% T:85% | pCi/L | | 06/23/22 15:15 | |
| Total Radium Calculation | Total Radium | 0.860 ± 0.785 (1.36) | pCi/L | | 06/30/22 15:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 377 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 377 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2540C | Total Dissolved Solids | 1670 | mg/L | 20.0 | 05/19/22 15:16 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 05/21/22 08:53 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.60 | mg/L | 0.10 | 05/14/22 09:37 | |
| SM 5310C | Dissolved Organic Carbon | 2.2 | mg/L | 1.0 | 05/24/22 07:48 | |
| **50316511005** | **MW-104D** | | | | | |
| EPA 9056 | Chloride | 116 | mg/L | 2.5 | 05/27/22 12:48 | |
| EPA 9056 | Fluoride | 0.14 | mg/L | 0.10 | 05/27/22 12:29 | |
| EPA 9056 | Sulfate | 738 | mg/L | 25.0 | 05/27/22 13:06 | |
| EPA 6010 | Barium | 66.2 | ug/L | 10.0 | 05/27/22 10:20 | |
| EPA 6010 | Boron | 2720 | ug/L | 100 | 05/27/22 10:20 | |
| EPA 6010 | Calcium | 305000 | ug/L | 2000 | 05/27/22 12:22 | |
| EPA 6010 | Iron | 6720 | ug/L | 100 | 05/27/22 10:20 | |
| EPA 6010 | Lithium | 23.0 | ug/L | 20.0 | 05/27/22 10:20 | |
| EPA 6010 | Magnesium | 78400 | ug/L | 1000 | 05/27/22 10:20 | |
| EPA 6010 | Manganese | 1220 | ug/L | 10.0 | 05/27/22 10:20 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316511005** | **MW-104D** | | | | | |
| EPA 6010 | Potassium | 9540 | ug/L | 1000 | 05/27/22 10:20 | |
| EPA 6010 | Silica | 11200 | ug/L | 450 | 05/27/22 10:20 | N2 |
| EPA 6010 | Sodium | 90000 | ug/L | 1000 | 05/27/22 10:20 | |
| EPA 6010 | Manganese, Dissolved | 425 | ug/L | 10.0 | 05/27/22 04:16 | |
| EPA 6020 | Arsenic | 6.6 | ug/L | 1.0 | 05/20/22 08:57 | |
| EPA 6020 | Cobalt | 1.1 | ug/L | 1.0 | 05/20/22 08:57 | |
| EPA 6020 | Selenium | 1.5 | ug/L | 1.0 | 05/20/22 08:57 | |
| EPA 903.1 | Radium-226 | 0.409 ± 0.465 (0.756) C:NA T:91% | pCi/L | | 06/29/22 12:30 | |
| EPA 904.0 | Radium-228 | 0.273 ± 0.329 (0.694) C:77% T:91% | pCi/L | | 06/23/22 15:15 | |
| Total Radium Calculation | Total Radium | 0.682 ± 0.794 (1.45) | pCi/L | | 06/30/22 15:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 370 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 370 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2540C | Total Dissolved Solids | 1630 | mg/L | 20.0 | 05/19/22 15:17 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.0 | Std. Units | 0.10 | 05/21/22 08:54 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 0.26 | mg/L | 0.10 | 05/14/22 09:34 | |
| SM 5310C | Total Organic Carbon | 1.2 | mg/L | 1.0 | 05/26/22 10:16 | |
| SM 5310C | Dissolved Organic Carbon | 1.7 | mg/L | 1.0 | 05/24/22 08:47 | |
| **50316511006** | **MW-102D** | | | | | |
| EPA 9056 | Chloride | 183 | mg/L | 25.0 | 05/27/22 14:38 | |
| EPA 9056 | Fluoride | 0.21 | mg/L | 0.10 | 05/27/22 14:01 | |
| EPA 9056 | Sulfate | 1190 | mg/L | 25.0 | 05/27/22 14:38 | |
| EPA 6010 | Barium | 55.2 | ug/L | 10.0 | 05/27/22 10:23 | |
| EPA 6010 | Boron | 20300 | ug/L | 100 | 05/27/22 10:23 | |
| EPA 6010 | Calcium | 364000 | ug/L | 2000 | 05/27/22 12:24 | |
| EPA 6010 | Iron | 5210 | ug/L | 100 | 05/27/22 10:23 | |
| EPA 6010 | Lithium | 63.1 | ug/L | 20.0 | 05/27/22 10:23 | |
| EPA 6010 | Magnesium | 62600 | ug/L | 1000 | 05/27/22 10:23 | |
| EPA 6010 | Manganese | 476 | ug/L | 10.0 | 05/27/22 10:23 | |
| EPA 6010 | Molybdenum | 448 | ug/L | 10.0 | 05/27/22 10:23 | |
| EPA 6010 | Potassium | 16000 | ug/L | 1000 | 05/27/22 10:23 | |
| EPA 6010 | Silica | 13800 | ug/L | 450 | 05/27/22 10:23 | N2 |
| EPA 6010 | Sodium | 174000 | ug/L | 1000 | 05/27/22 10:23 | |
| EPA 6010 | Manganese, Dissolved | 484 | ug/L | 10.0 | 05/27/22 04:18 | |
| EPA 6010 | Molybdenum, Dissolved | 444 | ug/L | 10.0 | 05/27/22 04:18 | |
| EPA 6020 | Arsenic | 51.3 | ug/L | 1.0 | 05/20/22 09:09 | |
| EPA 903.1 | Radium-226 | 18.2 ± 2.83 (0.469) C:NA T:84% | pCi/L | | 06/29/22 12:30 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50316511006** | **MW-102D** | | | | | |
| EPA 904.0 | Radium-228 | 0.637 ± 0.403 (0.754) C:80% T:84% | pCi/L | | 06/23/22 15:15 | |
| Total Radium Calculation | Total Radium | 18.8 ± 3.23 (1.22) | pCi/L | | 06/30/22 15:17 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 107 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 107 | mg/L | 2.0 | 05/21/22 13:35 | |
| SM 2540C | Total Dissolved Solids | 2070 | mg/L | 40.0 | 05/19/22 15:33 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.2 | Std. Units | 0.10 | 05/21/22 08:55 | H3 |
| EPA 365.1 | Phosphate as P04 | 0.71 | mg/L | 0.15 | 05/21/22 10:12 | |
| SM 5310C | Total Organic Carbon | 1.9 | mg/L | 1.0 | 05/25/22 22:45 | |
| SM 5310C | Dissolved Organic Carbon | 2.7 | mg/L | 1.0 | 05/24/22 09:14 | |
| **50316511007** | **PZ-100D RAD MS** | | | | | |
| EPA 903.1 | Radium-226 | 89.53 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 06/29/22 12:30 | |
| EPA 904.0 | Radium-228 | 63.57 %REC ± NA (NA) C:NA T:NA | pCi/L | | 06/23/22 15:15 | |
| **50316511008** | **PZ-100D RAD MSD** | | | | | |
| EPA 903.1 | Radium-226 | 67.35 %REC 28.28 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 06/29/22 14:20 | 1d |
| EPA 904.0 | Radium-228 | 73.44 %REC 14.4RPD ± NA (NA) C:NA T:NA | pCi/L | | 06/23/22 15:16 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100S** **Lab ID: 50316511001** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **267** | mg/L | 25.0 | 100 | | 05/27/22 07:34 | 16887-00-6 | |
| Fluoride | **2.0** | mg/L | 0.10 | 1 | | 05/27/22 06:57 | 16984-48-8 | |
| Sulfate | **455** | mg/L | 25.0 | 100 | | 05/27/22 07:34 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7429-90-5 | |
| Barium | **34.4** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7440-39-3 | |
| Boron | **2160** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7440-43-9 | |
| Calcium | **176000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7440-47-3 | |
| Iron | **1800** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7439-92-1 | |
| Lithium | **61.2** | ug/L | 20.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7439-93-2 | |
| Magnesium | **59900** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7439-95-4 | |
| Manganese | **359** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7439-96-5 | |
| Molybdenum | **113** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7439-98-7 | |
| Potassium | **10700** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7440-09-7 | |
| Silica | **15300** | ug/L | 450 | 1 | 05/25/22 16:16 | 05/27/22 09:58 | 7631-86-9 | N2 |
| Sodium | **230000** | ug/L | 2000 | 2 | 05/25/22 16:16 | 05/27/22 12:10 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **373** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 03:53 | 7439-96-5 | |
| Molybdenum, Dissolved | **115** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 03:53 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:16 | 7440-36-0 | |
| Arsenic | **2.6** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:16 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:16 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:16 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **335** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Bicarbonate (CaCO3) | **335** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1530** | mg/L | 20.0 | 1 | | 05/19/22 15:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100S** **Lab ID: 50316511001** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/21/22 08:51 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:46 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.13** | mg/L | 0.10 | 1 | | 05/14/22 09:50 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:50 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 10:06 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 4.0 | 4 | | 05/26/22 15:03 | 7440-44-0 | D3 |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 4.0 | 4 | | 05/24/22 15:29 | | D3 |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100D** **Lab ID: 50316511002** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **211** | mg/L | 25.0 | 100 | | 05/27/22 08:29 | 16887-00-6 | |
| Fluoride | **0.60** | mg/L | 0.10 | 1 | | 05/27/22 07:52 | 16984-48-8 | |
| Sulfate | **579** | mg/L | 25.0 | 100 | | 05/27/22 08:29 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7429-90-5 | |
| Barium | **59.5** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7440-39-3 | |
| Boron | **6770** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7440-43-9 | |
| Calcium | **232000** | ug/L | 2000 | 2 | 05/25/22 16:16 | 05/27/22 12:12 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7440-47-3 | |
| Iron | **3270** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7439-92-1 | |
| Lithium | **81.1** | ug/L | 20.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7439-93-2 | |
| Magnesium | **58600** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7439-95-4 | |
| Manganese | **230** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7439-96-5 | |
| Molybdenum | **152** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7439-98-7 | |
| Potassium | **11900** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7440-09-7 | |
| Silica | **12800** | ug/L | 450 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7631-86-9 | N2 |
| Sodium | **156000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:01 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **232** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 03:55 | 7439-96-5 | |
| Molybdenum, Dissolved | **150** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 03:55 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:20 | 7440-36-0 | |
| Arsenic | **81.3** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:20 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:20 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:20 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **260** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Bicarbonate (CaCO3) | **260** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1490** | mg/L | 20.0 | 1 | | 05/19/22 15:33 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100D** **Lab ID: 50316511002** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 1 | | 05/21/22 08:52 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:47 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/14/22 09:52 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:52 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.59** | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 10:07 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.6** | mg/L | 1.0 | 1 | | 05/26/22 08:41 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.0** | mg/L | 1.0 | 1 | | 05/24/22 06:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-102S** **Lab ID: 50316511003** Collected: 05/13/22 10:45 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | **5320** | ug/L | 200 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7429-90-5 | |
| Barium | **74.3** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7440-39-3 | |
| Boron | **5710** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7440-43-9 | |
| Calcium | **256000** | ug/L | 2000 | 2 | 05/25/22 16:16 | 05/27/22 12:18 | 7440-70-2 | |
| Chromium | **13.7** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7440-47-3 | |
| Iron | **23800** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7439-92-1 | |
| Lithium | **62.9** | ug/L | 20.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7439-93-2 | |
| Magnesium | **83900** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7439-95-4 | |
| Manganese | **631** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7439-96-5 | |
| Molybdenum | **44.9** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7439-98-7 | |
| Potassium | **12000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7440-09-7 | |
| Silica | **32500** | ug/L | 450 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7631-86-9 | N2 |
| Sodium | **162000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:11 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **550** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:08 | 7439-96-5 | |
| Molybdenum, Dissolved | **40.3** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:08 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:49 | 7440-36-0 | |
| Arsenic | **83.6** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:49 | 7440-38-2 | |
| Cobalt | **2.8** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:49 | 7440-48-4 | |
| Selenium | **1.1** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:49 | 7782-49-2 | |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.23** | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 10:10 | | |
| **5310C TOC** | Analytical Method: SM 5310C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **2.2** | mg/L | 2.0 | 2 | | 05/26/22 09:23 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **10.9** | mg/L | 1.0 | 1 | | 05/24/22 07:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-104S** **Lab ID: 50316511004** Collected: 05/13/22 11:45 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **58.2** | mg/L | 2.5 | 10 | | 05/27/22 11:52 | 16887-00-6 | |
| Fluoride | **0.22** | mg/L | 0.10 | 1 | | 05/27/22 11:34 | 16984-48-8 | |
| Sulfate | **748** | mg/L | 25.0 | 100 | | 05/27/22 12:11 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7429-90-5 | |
| Barium | **28.8** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7440-39-3 | |
| Boron | **1270** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7440-43-9 | |
| Calcium | **302000** | ug/L | 2000 | 2 | 05/25/22 16:16 | 05/27/22 12:20 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7439-92-1 | |
| Lithium | **26.3** | ug/L | 20.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7439-93-2 | |
| Magnesium | **79300** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7439-95-4 | |
| Manganese | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7439-98-7 | |
| Potassium | **6800** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7440-09-7 | |
| Silica | **10700** | ug/L | 450 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7631-86-9 | N2 |
| Sodium | **62100** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:14 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:14 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:14 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:53 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:53 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:53 | 7440-48-4 | |
| Selenium | **3.9** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:53 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **377** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Bicarbonate (CaCO3) | **377** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1670** | mg/L | 20.0 | 1 | | 05/19/22 15:16 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-104S** **Lab ID: 50316511004** Collected: 05/13/22 11:45 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 05/21/22 08:53 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.60** | mg/L | 0.10 | 1 | | 05/14/22 09:37 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:37 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 10:11 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/26/22 10:05 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.2** | mg/L | 1.0 | 1 | | 05/24/22 07:48 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-104D** **Lab ID: 50316511005** Collected: 05/13/22 10:25 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **116** | mg/L | 2.5 | 10 | | 05/27/22 12:48 | 16887-00-6 | |
| Fluoride | **0.14** | mg/L | 0.10 | 1 | | 05/27/22 12:29 | 16984-48-8 | |
| Sulfate | **738** | mg/L | 25.0 | 100 | | 05/27/22 13:06 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7429-90-5 | |
| Barium | **66.2** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7440-39-3 | |
| Boron | **2720** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7440-43-9 | |
| Calcium | **305000** | ug/L | 2000 | 2 | 05/25/22 16:16 | 05/27/22 12:22 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7440-47-3 | |
| Iron | **6720** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7439-92-1 | |
| Lithium | **23.0** | ug/L | 20.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7439-93-2 | |
| Magnesium | **78400** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7439-95-4 | |
| Manganese | **1220** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7439-98-7 | |
| Potassium | **9540** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7440-09-7 | |
| Silica | **11200** | ug/L | 450 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7631-86-9 | N2 |
| Sodium | **90000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:20 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **425** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:16 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:16 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:57 | 7440-36-0 | |
| Arsenic | **6.6** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:57 | 7440-38-2 | |
| Cobalt | **1.1** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:57 | 7440-48-4 | |
| Selenium | **1.5** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 08:57 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **370** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Bicarbonate (CaCO3) | **370** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **1630** | mg/L | 20.0 | 1 | | 05/19/22 15:17 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-104D** **Lab ID: 50316511005** Collected: 05/13/22 10:25 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.0** | Std. Units | 0.10 | 1 | | 05/21/22 08:54 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **0.26** | mg/L | 0.10 | 1 | | 05/14/22 09:34 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:34 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 10:11 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.2** | mg/L | 1.0 | 1 | | 05/26/22 10:16 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **1.7** | mg/L | 1.0 | 1 | | 05/24/22 08:47 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-102D** **Lab ID: 50316511006** Collected: 05/13/22 11:55 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **183** | mg/L | 25.0 | 100 | | 05/27/22 14:38 | 16887-00-6 | |
| Fluoride | **0.21** | mg/L | 0.10 | 1 | | 05/27/22 14:01 | 16984-48-8 | |
| Sulfate | **1190** | mg/L | 25.0 | 100 | | 05/27/22 14:38 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7429-90-5 | |
| Barium | **55.2** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7440-39-3 | |
| Boron | **20300** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7440-43-9 | |
| Calcium | **364000** | ug/L | 2000 | 2 | 05/25/22 16:16 | 05/27/22 12:24 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7440-47-3 | |
| Iron | **5210** | ug/L | 100 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7439-92-1 | |
| Lithium | **63.1** | ug/L | 20.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7439-93-2 | |
| Magnesium | **62600** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7439-95-4 | |
| Manganese | **476** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7439-96-5 | |
| Molybdenum | **448** | ug/L | 10.0 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7439-98-7 | |
| Potassium | **16000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7440-09-7 | |
| Silica | **13800** | ug/L | 450 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7631-86-9 | N2 |
| Sodium | **174000** | ug/L | 1000 | 1 | 05/25/22 16:16 | 05/27/22 10:23 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **484** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:18 | 7439-96-5 | |
| Molybdenum, Dissolved | **444** | ug/L | 10.0 | 1 | 05/25/22 15:30 | 05/27/22 04:18 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 09:09 | 7440-36-0 | |
| Arsenic | **51.3** | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 09:09 | 7440-38-2 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 09:09 | 7440-48-4 | |
| Selenium | ND | ug/L | 1.0 | 1 | 05/19/22 15:10 | 05/20/22 09:09 | 7782-49-2 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **107** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Bicarbonate (CaCO3) | **107** | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/21/22 13:35 | | |
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **2070** | mg/L | 40.0 | 1 | | 05/19/22 15:33 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-102D** **Lab ID: 50316511006** Collected: 05/13/22 11:55 Received: 05/13/22 17:10 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.2** | Std. Units | 0.10 | 1 | | 05/21/22 08:55 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/18/22 09:54 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/25/22 22:44 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | ND | mg/L | 0.10 | 1 | | 05/14/22 09:39 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/14/22 09:39 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | **0.71** | mg/L | 0.15 | 1 | 05/17/22 14:30 | 05/21/22 10:12 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | **1.9** | mg/L | 1.0 | 1 | | 05/25/22 22:45 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | **2.7** | mg/L | 1.0 | 1 | | 05/24/22 09:14 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 678196
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3122419 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/27/22 06:20 | |
| Fluoride | mg/L | ND | 0.10 | 05/27/22 06:20 | |
| Sulfate | mg/L | ND | 0.25 | 05/27/22 06:20 | |

LABORATORY CONTROL SAMPLE: 3122420

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.2 | 94 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.54 | 109 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.5 | 102 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122421 3122422

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 211 | 125 | 125 | 320 | 319 | 87 | 87 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.60 | 0.5 | 0.5 | 1.2 | 1.1 | 109 | 109 | 80-120 | 0 | 15 | |
| Sulfate | mg/L | 579 | 250 | 250 | 791 | 791 | 85 | 85 | 80-120 | 0 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677587
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3120361 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/27/22 09:56 | |
| Barium | ug/L | ND | 10.0 | 05/27/22 09:56 | |
| Boron | ug/L | ND | 100 | 05/27/22 09:56 | |
| Cadmium | ug/L | ND | 2.0 | 05/27/22 09:56 | |
| Calcium | ug/L | ND | 1000 | 05/27/22 09:56 | |
| Chromium | ug/L | ND | 10.0 | 05/27/22 09:56 | |
| Iron | ug/L | ND | 100 | 05/27/22 09:56 | |
| Lead | ug/L | ND | 10.0 | 05/27/22 09:56 | |
| Lithium | ug/L | ND | 20.0 | 05/27/22 09:56 | |
| Magnesium | ug/L | ND | 1000 | 05/27/22 09:56 | |
| Manganese | ug/L | ND | 10.0 | 05/27/22 09:56 | |
| Molybdenum | ug/L | ND | 10.0 | 05/27/22 09:56 | |
| Potassium | ug/L | ND | 1000 | 05/27/22 09:56 | |
| Silica | ug/L | ND | 450 | 05/27/22 09:56 | N2 |
| Sodium | ug/L | ND | 1000 | 05/27/22 09:56 | |

LABORATORY CONTROL SAMPLE: 3120362

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Barium | ug/L | 1000 | 1040 | 104 | 80-120 | |
| Boron | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Cadmium | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Calcium | ug/L | 10000 | 10500 | 105 | 80-120 | |
| Chromium | ug/L | 1000 | 1040 | 104 | 80-120 | |
| Iron | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Lead | ug/L | 1000 | 983 | 98 | 80-120 | |
| Lithium | ug/L | 1000 | 1090 | 109 | 80-120 | |
| Magnesium | ug/L | 10000 | 10000 | 100 | 80-120 | |
| Manganese | ug/L | 1000 | 999 | 100 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1070 | 107 | 80-120 | |
| Potassium | ug/L | 10000 | 10200 | 102 | 80-120 | |
| Silica | ug/L | 10700 | 11000 | 102 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 10400 | 104 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120363 3120364

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10600 | 10500 | 106 | 105 | 75-125 | 1 | 20 | |
| Barium | ug/L | 59.5 | 1000 | 1000 | 1080 | 1060 | 102 | 100 | 75-125 | 2 | 20 | |
| Boron | ug/L | 6770 | 1000 | 1000 | 7890 | 7730 | 111 | 95 | 75-125 | 2 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 1050 | 1030 | 105 | 103 | 75-125 | 2 | 20 | |
| Calcium | ug/L | 232000 | 10000 | 10000 | 252000 | 247000 | 206 | 152 | 75-125 | 2 | 20 | P6 |
| Chromium | ug/L | ND | 1000 | 1000 | 1040 | 1010 | 104 | 101 | 75-125 | 3 | 20 | |
| Iron | ug/L | 3270 | 10000 | 10000 | 13100 | 12800 | 98 | 95 | 75-125 | 2 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 948 | 926 | 95 | 93 | 75-125 | 2 | 20 | |
| Lithium | ug/L | 81.1 | 1000 | 1000 | 1250 | 1230 | 117 | 115 | 75-125 | 2 | 20 | |
| Magnesium | ug/L | 58600 | 10000 | 10000 | 68700 | 67500 | 100 | 88 | 75-125 | 2 | 20 | |
| Manganese | ug/L | 230 | 1000 | 1000 | 1210 | 1190 | 98 | 96 | 75-125 | 2 | 20 | |
| Molybdenum | ug/L | 152 | 1000 | 1000 | 1220 | 1190 | 107 | 104 | 75-125 | 2 | 20 | |
| Potassium | ug/L | 11900 | 10000 | 10000 | 23000 | 22800 | 111 | 108 | 75-125 | 1 | 20 | |
| Silica | ug/L | 12800 | 10700 | 10700 | 24000 | 23600 | 105 | 102 | 75-125 | 1 | 20 | N2 |
| Sodium | ug/L | 156000 | 10000 | 10000 | 166000 | 164000 | 97 | 77 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677439
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3119333 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/27/22 04:06 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/27/22 04:06 | |

LABORATORY CONTROL SAMPLE: 3119334

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 999 | 100 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1040 | 104 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3119335 3119336

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 232 | 1000 | 1000 | 1210 | 1240 | 98 | 101 | 75-125 | 2 | 20 | |
| Molybdenum, Dissolved | ug/L | 150 | 1000 | 1000 | 1190 | 1220 | 104 | 107 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677057 | Analysis Method: EPA 6020
QC Batch Method: EPA 200.2 | Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3117353 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/20/22 07:43 | |
| Arsenic | ug/L | ND | 1.0 | 05/20/22 07:43 | |
| Cobalt | ug/L | ND | 1.0 | 05/20/22 07:43 | |
| Selenium | ug/L | ND | 1.0 | 05/20/22 07:43 | |

LABORATORY CONTROL SAMPLE: 3117354

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 42.2 | 105 | 80-120 | |
| Arsenic | ug/L | 40 | 39.7 | 99 | 80-120 | |
| Cobalt | ug/L | 40 | 41.2 | 103 | 80-120 | |
| Selenium | ug/L | 40 | 39.3 | 98 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3117355 3117356

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.7 | 43.5 | 109 | 109 | 75-125 | 0 | 20 | |
| Arsenic | ug/L | 81.3 | 40 | 40 | 121 | 122 | 99 | 102 | 75-125 | 1 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 38.4 | 38.0 | 95 | 94 | 75-125 | 1 | 20 | |
| Selenium | ug/L | ND | 40 | 40 | 44.5 | 41.5 | 111 | 103 | 75-125 | 7 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677430 | Analysis Method: SM 2320B
QC Batch Method: SM 2320B | Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3119272 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/21/22 13:35 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/21/22 13:35 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/21/22 13:35 | |

LABORATORY CONTROL SAMPLE: 3119273

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 52.4 | 105 | 90-110 | |

SAMPLE DUPLICATE: 3119274

| Parameter | Units | 50316511002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 260 | 264 | 1 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 260 | 264 | 1 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3119275

| Parameter | Units | 50316601001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 339 | 348 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 339 | 348 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677049 | Analysis Method: SM 2540C
QC Batch Method: SM 2540C | Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511004, 50316511005

METHOD BLANK: 3117321 Matrix: Water
Associated Lab Samples: 50316511001, 50316511004, 50316511005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/19/22 15:11 | |

LABORATORY CONTROL SAMPLE: 3117326

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 304 | 101 | 80-120 | |

SAMPLE DUPLICATE: 3117322

| Parameter | Units | 50316506002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1100 | 1110 | 1 | 10 | |

SAMPLE DUPLICATE: 3117323

| Parameter | Units | 50316478003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 828 | 800 | 3 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677053
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511002, 50316511006

METHOD BLANK: 3117336 Matrix: Water
Associated Lab Samples: 50316511002, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/19/22 15:32 | |

LABORATORY CONTROL SAMPLE: 3117337

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 298 | 99 | 80-120 | |

SAMPLE DUPLICATE: 3117338

| Parameter | Units | 50316507001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1440 | 1440 | 0 | 10 | |

SAMPLE DUPLICATE: 3117339

| Parameter | Units | 50316511002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 1490 | 1460 | 2 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677510
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

SAMPLE DUPLICATE: 3120004

| Parameter | Units | 50316478003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.1 | 7.2 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3120005

| Parameter | Units | 50316511002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.4 | 7.5 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 676796
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3116034 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/18/22 09:54 | |

LABORATORY CONTROL SAMPLE: 3116035

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.46 | 92 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116036 3116037

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.53 | 0.52 | 106 | 105 | 90-110 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116038 3116039

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.52 | 0.50 | 103 | 100 | 90-110 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 678397 | Analysis Method: HACH 8146
QC Batch Method: HACH 8146 | Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3123112 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/25/22 22:41 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3123113

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 102 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3123114 3123115

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 0.97 | 0.96 | 97 | 96 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3123116 3123117

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 0.98 | 0.99 | 98 | 99 | 90-110 | 1 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 676251
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3114048 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/14/22 09:04 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/14/22 09:04 | |

LABORATORY CONTROL SAMPLE: 3114049

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 0.97 | 97 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.98 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114050 3114051

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 0.84 | 1 | 1 | 1.9 | 1.9 | 102 | 102 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.97 | 0.97 | 97 | 97 | 90-110 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114052 3114053

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 1 | 1 | 0.98 | 0.98 | 98 | 98 | 90-110 | 0 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.96 | 0.96 | 96 | 96 | 90-110 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 676640 — Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 — Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3115309 — Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/21/22 09:53 | |

LABORATORY CONTROL SAMPLE: 3115310

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.4 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115311 — 3115312

| Parameter | Units | 50316507001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.5 | 1.5 | | | | 1 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115313 — 3115314

| Parameter | Units | 50316478003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.28 | | | 1.7 | 1.6 | | | | 10 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3115315 — 3115316

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 0.59 | | | 1.9 | 1.9 | | | | 2 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 678322 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005

METHOD BLANK: 3122822 — Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/26/22 03:31 | |

LABORATORY CONTROL SAMPLE: 3122823

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.2 | 102 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122824 — 3122825

| Parameter | Units | 50316478003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 2.3 | 10 | 10 | 12.4 | 12.8 | 101 | 105 | 80-120 | 3 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122826 — 3122827

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 1.6 | 10 | 10 | 11.6 | 11.6 | 101 | 101 | 80-120 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 678323
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511006

METHOD BLANK: 3122828 Matrix: Water
Associated Lab Samples: 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/25/22 22:06 | |

LABORATORY CONTROL SAMPLE: 3122829

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122830 3122831

| Parameter | Units | 50316593001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 0.62J | 10 | 10 | 10.5 | 10.4 | 99 | 98 | 80-120 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3122837 3122838

| Parameter | Units | 50316595006 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 9.5 | 10 | 10 | 18.6 | 18.7 | 90 | 92 | 80-120 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 677654 — Analysis Method: SM 5310C
QC Batch Method: SM 5310C — Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

METHOD BLANK: 3120521 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/23/22 21:35 | |

LABORATORY CONTROL SAMPLE: 3120522

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120523 3120524

| Parameter | Units | 50316478003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.9 | 10 | 10 | 13.3 | 13.0 | 103 | 100 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3120525 3120526

| Parameter | Units | 50316511002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 2.0 | 10 | 10 | 12.1 | 12.3 | 100 | 103 | 80-120 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100S** **Lab ID: 50316511001** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.810 ± 0.495 (0.608) C:NA T:84%** | pCi/L | 06/29/22 12:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.451 ± 0.351 (0.686) C:78% T:84%** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.26 ± 0.846 (1.29)** | pCi/L | 06/30/22 15:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100D** **Lab ID: 50316511002** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.655 ± 0.407 (0.402) C:NA T:77%** | pCi/L | 06/29/22 12:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.587 ± 0.456 (0.897) C:71% T:77%** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **1.24 ± 0.863 (1.30)** | pCi/L | 06/30/22 15:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-102S** **Lab ID: 50316511003** Collected: 05/13/22 10:45 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.270 ± 0.319 (0.502) C:NA T:75%** | pCi/L | 06/29/22 12:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.587 ± 0.436 (0.843) C:71% T:75%** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.857 ± 0.755 (1.35)** | pCi/L | 06/30/22 15:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-104S** **Lab ID: 50316511004** Collected: 05/13/22 11:45 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.469 ± 0.454 (0.704) C:NA T:85%** | pCi/L | 06/29/22 12:09 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.391 ± 0.331 (0.655) C:78% T:85%** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.860 ± 0.785 (1.36)** | pCi/L | 06/30/22 15:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-104D** **Lab ID: 50316511005** Collected: 05/13/22 10:25 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.409 ± 0.465 (0.756) C:NA T:91%** | pCi/L | 06/29/22 12:30 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.273 ± 0.329 (0.694) C:77% T:91%** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.682 ± 0.794 (1.45)** | pCi/L | 06/30/22 15:17 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: MW-102D** **Lab ID: 50316511006** Collected: 05/13/22 11:55 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **18.2 ± 2.83 (0.469) C:NA T:84%** | pCi/L | 06/29/22 12:30 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.637 ± 0.403 (0.754) C:80% T:84%** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **18.8 ± 3.23 (1.22)** | pCi/L | 06/30/22 15:17 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100D RAD MS** **Lab ID: 50316511007** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **89.53 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 06/29/22 12:30 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **63.57 %REC ± NA (NA) C:NA T:NA** | pCi/L | 06/23/22 15:15 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

**Sample: PZ-100D RAD MSD** **Lab ID: 50316511008** Collected: 05/13/22 13:55 Received: 05/13/22 17:10 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **67.35 %REC 28.28 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 06/29/22 14:20 | 13982-63-3 | 1d |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **73.44 %REC 14.4RPD ± NA (NA) C:NA T:NA** | pCi/L | 06/23/22 15:16 | 15262-20-1 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 510562 Analysis Method: EPA 903.1
QC Batch Method: EPA 903.1 Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006, 50316511007, 50316511008

METHOD BLANK: 2474597 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006, 50316511007, 50316511008

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | 0.342 ± 0.290 (0.360) C:NA T:89% | pCi/L | 06/29/22 11:52 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

QC Batch: 510564
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006, 50316511007, 50316511008

METHOD BLANK: 2474601 Matrix: Water
Associated Lab Samples: 50316511001, 50316511002, 50316511003, 50316511004, 50316511005, 50316511006, 50316511007, 50316511008

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.179 ± 0.271 (0.584) C:76% T:89% | pCi/L | 06/23/22 15:25 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| 1d | The Ra-226 Matrix Spike duplicate recovery was below the default acceptance limit for MS recovery. The results have been reported baased on acceptable RPD between the RQS set. |
| D3 | Sample was diluted due to the presence of high levels of non-target analytes or other matrix interference. |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316511001** | **PZ-100S** | EPA 9056 | 678196 | | |
| **50316511002** | **PZ-100D** | EPA 9056 | 678196 | | |
| **50316511004** | **MW-104S** | EPA 9056 | 678196 | | |
| **50316511005** | **MW-104D** | EPA 9056 | 678196 | | |
| **50316511006** | **MW-102D** | EPA 9056 | 678196 | | |
| **50316511001** | **PZ-100S** | EPA 3010 | 677587 | EPA 6010 | 678791 |
| **50316511002** | **PZ-100D** | EPA 3010 | 677587 | EPA 6010 | 678791 |
| **50316511003** | **MW-102S** | EPA 3010 | 677587 | EPA 6010 | 678791 |
| **50316511004** | **MW-104S** | EPA 3010 | 677587 | EPA 6010 | 678791 |
| **50316511005** | **MW-104D** | EPA 3010 | 677587 | EPA 6010 | 678791 |
| **50316511006** | **MW-102D** | EPA 3010 | 677587 | EPA 6010 | 678791 |
| **50316511001** | **PZ-100S** | EPA 3010 | 677439 | EPA 6010 | 678728 |
| **50316511002** | **PZ-100D** | EPA 3010 | 677439 | EPA 6010 | 678728 |
| **50316511003** | **MW-102S** | EPA 3010 | 677439 | EPA 6010 | 678728 |
| **50316511004** | **MW-104S** | EPA 3010 | 677439 | EPA 6010 | 678728 |
| **50316511005** | **MW-104D** | EPA 3010 | 677439 | EPA 6010 | 678728 |
| **50316511006** | **MW-102D** | EPA 3010 | 677439 | EPA 6010 | 678728 |
| **50316511001** | **PZ-100S** | EPA 200.2 | 677057 | EPA 6020 | 677279 |
| **50316511002** | **PZ-100D** | EPA 200.2 | 677057 | EPA 6020 | 677279 |
| **50316511003** | **MW-102S** | EPA 200.2 | 677057 | EPA 6020 | 677279 |
| **50316511004** | **MW-104S** | EPA 200.2 | 677057 | EPA 6020 | 677279 |
| **50316511005** | **MW-104D** | EPA 200.2 | 677057 | EPA 6020 | 677279 |
| **50316511006** | **MW-102D** | EPA 200.2 | 677057 | EPA 6020 | 677279 |
| **50316511001** | **PZ-100S** | EPA 903.1 | 510562 | | |
| **50316511002** | **PZ-100D** | EPA 903.1 | 510562 | | |
| **50316511003** | **MW-102S** | EPA 903.1 | 510562 | | |
| **50316511004** | **MW-104S** | EPA 903.1 | 510562 | | |
| **50316511005** | **MW-104D** | EPA 903.1 | 510562 | | |
| **50316511006** | **MW-102D** | EPA 903.1 | 510562 | | |
| **50316511007** | **PZ-100D RAD MS** | EPA 903.1 | 510562 | | |
| **50316511008** | **PZ-100D RAD MSD** | EPA 903.1 | 510562 | | |
| **50316511001** | **PZ-100S** | EPA 904.0 | 510564 | | |
| **50316511002** | **PZ-100D** | EPA 904.0 | 510564 | | |
| **50316511003** | **MW-102S** | EPA 904.0 | 510564 | | |
| **50316511004** | **MW-104S** | EPA 904.0 | 510564 | | |
| **50316511005** | **MW-104D** | EPA 904.0 | 510564 | | |
| **50316511006** | **MW-102D** | EPA 904.0 | 510564 | | |
| **50316511007** | **PZ-100D RAD MS** | EPA 904.0 | 510564 | | |
| **50316511008** | **PZ-100D RAD MSD** | EPA 904.0 | 510564 | | |
| **50316511001** | **PZ-100S** | Total Radium Calculation | 515618 | | |
| **50316511002** | **PZ-100D** | Total Radium Calculation | 515618 | | |
| **50316511003** | **MW-102S** | Total Radium Calculation | 515618 | | |
| **50316511004** | **MW-104S** | Total Radium Calculation | 515618 | | |
| **50316511005** | **MW-104D** | Total Radium Calculation | 515618 | | |
| **50316511006** | **MW-102D** | Total Radium Calculation | 515618 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316511001** | **PZ-100S** | SM 2320B | 677430 | | |
| **50316511002** | **PZ-100D** | SM 2320B | 677430 | | |
| **50316511004** | **MW-104S** | SM 2320B | 677430 | | |
| **50316511005** | **MW-104D** | SM 2320B | 677430 | | |
| **50316511006** | **MW-102D** | SM 2320B | 677430 | | |
| **50316511001** | **PZ-100S** | SM 2540C | 677049 | | |
| **50316511002** | **PZ-100D** | SM 2540C | 677053 | | |
| **50316511004** | **MW-104S** | SM 2540C | 677049 | | |
| **50316511005** | **MW-104D** | SM 2540C | 677049 | | |
| **50316511006** | **MW-102D** | SM 2540C | 677053 | | |
| **50316511001** | **PZ-100S** | SM 4500-H+B | 677510 | | |
| **50316511002** | **PZ-100D** | SM 4500-H+B | 677510 | | |
| **50316511004** | **MW-104S** | SM 4500-H+B | 677510 | | |
| **50316511005** | **MW-104D** | SM 4500-H+B | 677510 | | |
| **50316511006** | **MW-102D** | SM 4500-H+B | 677510 | | |
| **50316511001** | **PZ-100S** | SM 4500-S2-D | 676796 | | |
| **50316511002** | **PZ-100D** | SM 4500-S2-D | 676796 | | |
| **50316511003** | **MW-102S** | SM 4500-S2-D | 676796 | | |
| **50316511004** | **MW-104S** | SM 4500-S2-D | 676796 | | |
| **50316511005** | **MW-104D** | SM 4500-S2-D | 676796 | | |
| **50316511006** | **MW-102D** | SM 4500-S2-D | 676796 | | |
| **50316511001** | **PZ-100S** | HACH 8146 | 678397 | | |
| **50316511002** | **PZ-100D** | HACH 8146 | 678397 | | |
| **50316511004** | **MW-104S** | HACH 8146 | 678397 | | |
| **50316511005** | **MW-104D** | HACH 8146 | 678397 | | |
| **50316511006** | **MW-102D** | HACH 8146 | 678397 | | |
| **50316511001** | **PZ-100S** | EPA 353.2 | 676251 | | |
| **50316511002** | **PZ-100D** | EPA 353.2 | 676251 | | |
| **50316511004** | **MW-104S** | EPA 353.2 | 676251 | | |
| **50316511005** | **MW-104D** | EPA 353.2 | 676251 | | |
| **50316511006** | **MW-102D** | EPA 353.2 | 676251 | | |
| **50316511001** | **PZ-100S** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316511002** | **PZ-100D** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316511003** | **MW-102S** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316511004** | **MW-104S** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316511005** | **MW-104D** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316511006** | **MW-102D** | EPA 365.1 | 676640 | EPA 365.1 | 677706 |
| **50316511001** | **PZ-100S** | SM 5310C | 678322 | | |
| **50316511002** | **PZ-100D** | SM 5310C | 678322 | | |
| **50316511003** | **MW-102S** | SM 5310C | 678322 | | |
| **50316511004** | **MW-104S** | SM 5310C | 678322 | | |
| **50316511005** | **MW-104D** | SM 5310C | 678322 | | |
| **50316511006** | **MW-102D** | SM 5310C | 678323 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 2
Pace Project No.: 50316511

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50316511001** | **PZ-100S** | SM 5310C | 677654 | | |
| **50316511002** | **PZ-100D** | SM 5310C | 677654 | | |
| **50316511003** | **MW-102S** | SM 5310C | 677654 | | |
| **50316511004** | **MW-104S** | SM 5310C | 677654 | | |
| **50316511005** | **MW-104D** | SM 5310C | 677654 | | |
| **50316511006** | **MW-102D** | SM 5310C | 677654 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

# CHAIN-OF-CUSTODY / Analytical Request Document

Pace Analytical® WWW.PACELABS.COM

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.

WO# : 50316511

50316511

Page: 1 Of

| Section A | Section B | Section C |
|---|---|---|
| **Required Client Information:** | **Required Project Information:** | **Invoice Information:** |
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: |
| Address: 7988 Centerpoint Drive Suite 100 | Copy To: | Company Name: |
| Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: |
| Phone: (317)579-4082 Fax: | Project Name: Harding St Profile 1 Report 2 | Pace Project Manager: |
| Requested Due Date: | Project #: | Pace Profile #: |

Regulatory Agency

State / Location IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4) by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX: Drinking Water DW, Water WT, Waste Water WW, Product P, Soil/Solid SL, Oil OL, Wipe WP, Air AR, Other OT, Tissue TS | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | | | | | |
| 1 | ~~M-4~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 2 | PZ-100S | WT | G | 5/13 | 1355 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | 001 |
| 3 | PZ-100D (MS/MSD-3) | WT | G | 5/13 | 1355 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | 002 007 008 |
| 4 | ~~PZ-101S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 5 | ~~PZ-101D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 6 | MW-102S | WT | G | 5/13 | 1045 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | 003 |
| 7 | MW-102D | WT | G | 5/13 | 1155 | | | | 7 | 3 | 3 | | | 1 | | | | | | | X | X | X | X | | X | X | X | | | | ~~004~~ 006 |
| 8 | ~~MW-103S~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 9 | ~~MW-103I~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 10 | ~~MW-103D~~ | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | |
| 11 | MW-104S | WT | G | 5/13 | 1145 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | ~~005~~ 004 |
| 12 | MW-104D | WT | G | 5/13 | 1025 | | | | 11 | 3 | 3 | 4 | | 1 | | | | | X | X | X | X | X | X | X | X | X | X | X | | | ~~004~~ 005 |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | | 5/13/22 | 1710 | | 5/13/22 | 1710 | See Rem | Y | N | Y |
| 6020 (Co, As, Se, Sb) | | | | | | | | | | |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | | | | |

| SAMPLER NAME AND SIGNATURE | | | | | |
|---|---|---|---|---|---|
| PRINT Name of SAMPLER: | P. Greg Hoppe | | TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
| SIGNATURE of SAMPLER: | DATE Signed: 5/13/22 | | | | | |

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** 05/13/22 1810 SMC

1. **Courier:** ☐ FED EX ☐ UPS ☒ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____
2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☒ No
   **(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**
3. **Thermometer:** 1 2 3 4 5 6 7 A B C D E F
4. **Cooler Temperature(s):** 19.4/19.4 | 09/0.9 | 6.2/6.2 | 1.5/1.5
   **(Initial/Corrected)** **RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)**
5. **Packing Material:** ☐ Bubble Wrap ☒ Bubble Bags ☐ None ☐ Other _____
6. **Ice Type:** ☒ Wet ☐ Blue ☐ None
7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☒ No
   Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1840 | |
| **Rush TAT Requested (4 days or less):** | | ✓ |
| Custody Signatures Present? | ✓ | |
| Containers Intact?: | ✓ | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | ✓ |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2)** **H2SO4 (<2)** **NaOH (>10)** **NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Headspace Wisconsin Sulfide? | | | ✓ |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | ✓ |
| Trip Blank Present? | | — | |
| Trip Blank Custody Seals?: | | | — |

COMMENTS:

**COC PAGE** 1 **of** ~~2~~ 1

SML
5/13/22

## Sample Container Count

SBS
DI
MeOH (only)
BK
Kit

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 3 | | | | | | | | | | | | 2 | 2 | | 1 | 4 | | 4 | 2 | 2 | 2 | | 2 | | | | | ↓ | ↓ | ↓ | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | 1 | 1 | | | 1 | | | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 7 | | | | | | | | | | | | ↓ | ↓ | | | 2 | 1 | 2 | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | WT | ✓ | ✓ | |
| 12 | | | | | | | | | | | | ↓ | ↓ | | | ↓ | ↓ | ↓ | ↓ | ↓ | ↓ | | ↓ | | | | | ↓ | ↓ | ↓ | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

August 01, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on May 06, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Indianapolis
- Pace Analytical Services - Greensburg

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Pace Analytical Services Pennsylvania**

1638 Roseytown Rd Suites 2,3&4, Greensburg, PA 15601
ANAB DOD-ELAP Rad Accreditation #: L2417
Alabama Certification #: 41590
Arizona Certification #: AZ0734
Arkansas Certification
California Certification #: 04222CA
Colorado Certification #: PA01547
Connecticut Certification #: PH-0694
Delaware Certification
EPA Region 4 DW Rad
Florida/TNI Certification #: E87683
Georgia Certification #: C040
Florida: Cert E871149 SEKS WET
Guam Certification
Hawaii Certification
Idaho Certification
Illinois Certification
Indiana Certification
Iowa Certification #: 391
Kansas/TNI Certification #: E-10358
Kentucky Certification #: KY90133
KY WW Permit #: KY0098221
KY WW Permit #: KY0000221
Louisiana DHH/TNI Certification #: LA180012
Louisiana DEQ/TNI Certification #: 4086
Maine Certification #: 2017020
Maryland Certification #: 308
Massachusetts Certification #: M-PA1457
Michigan/PADEP Certification #: 9991
Missouri Certification #: 235
Montana Certification #: Cert0082
Nebraska Certification #: NE-OS-29-14
Nevada Certification #: PA014572018-1
New Hampshire/TNI Certification #: 297617
New Jersey/TNI Certification #: PA051
New Mexico Certification #: PA01457
New York/TNI Certification #: 10888
North Carolina Certification #: 42706
North Dakota Certification #: R-190
Ohio EPA Rad Approval: #41249
Oregon/TNI Certification #: PA200002-010
Pennsylvania/TNI Certification #: 65-00282
Puerto Rico Certification #: PA01457
Rhode Island Certification #: 65-00282
South Dakota Certification
Tennessee Certification #: 02867
Texas/TNI Certification #: T104704188-17-3
Utah/TNI Certification #: PA014572017-9
USDA Soil Permit #: P330-17-00091
Vermont Dept. of Health: ID# VT-0282
Virgin Island/PADEP Certification
Virginia/VELAP Certification #: 460198
Washington Certification #: C868
West Virginia DEP Certification #: 143
West Virginia DHHR Certification #: 9964C
Wisconsin Approve List for Rad
Wyoming Certification #: 8TMS-L

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50315836007** | **MW-15S** | Water | 05/05/22 10:14 | 05/06/22 13:20 |
| **50315836008** | **MW-15I** | Water | 05/05/22 11:32 | 05/06/22 13:20 |
| **50315836009** | **MW-15I MS** | Water | 05/05/22 11:32 | 05/06/22 13:20 |
| **50315836010** | **MW-15I MSD** | Water | 05/05/22 11:32 | 05/06/22 13:20 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50315836007** | **MW-15S** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836008** | **MW-15I** | EPA 9056 | RMR | 3 | PASI-I |
| | | EPA 6010 | MTM | 15 | PASI-I |
| | | EPA 6010 | JPK | 2 | PASI-I |
| | | EPA 6020 | CAW | 6 | PASI-I |
| | | EPA 7470 | EAE | 1 | PASI-I |
| | | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| | | Total Radium Calculation | JAL | 1 | PASI-PA |
| | | SM 2320B | SLB | 3 | PASI-I |
| | | SM 2540C | BSW | 1 | PASI-I |
| | | SM 4500-H+B | TKG | 1 | PASI-I |
| | | SM 4500-S2-D | SWJ | 1 | PASI-I |
| | | HACH 8146 | SWJ | 1 | PASI-I |
| | | EPA 353.2 | OAS | 2 | PASI-I |
| | | EPA 365.1 | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| | | SM 5310C | ZM | 1 | PASI-I |
| **50315836009** | **MW-15I MS** | EPA 903.1 | RPS | 1 | PASI-PA |
| | | EPA 904.0 | JSM | 1 | PASI-PA |
| **50315836010** | **MW-15I MSD** | EPA 903.1 | RPS | 1 | PASI-PA |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| | | EPA 904.0 | JSM | 1 | PASI-PA |

PASI-I = Pace Analytical Services - Indianapolis
PASI-PA = Pace Analytical Services - Greensburg



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836007** | **MW-15S** | | | | | |
| EPA 9056 | Chloride | 28.1 | mg/L | 2.5 | 05/20/22 14:21 | |
| EPA 9056 | Fluoride | 0.12 | mg/L | 0.10 | 05/20/22 14:02 | |
| EPA 9056 | Sulfate | 48.8 | mg/L | 2.5 | 05/20/22 14:21 | |
| EPA 6010 | Barium | 49.0 | ug/L | 10.0 | 05/19/22 10:15 | |
| EPA 6010 | Boron | 120 | ug/L | 100 | 05/19/22 10:15 | |
| EPA 6010 | Calcium | 106000 | ug/L | 1000 | 05/19/22 10:15 | |
| EPA 6010 | Iron | 101 | ug/L | 100 | 05/19/22 10:15 | |
| EPA 6010 | Magnesium | 27600 | ug/L | 1000 | 05/19/22 10:15 | |
| EPA 6010 | Manganese | 12.1 | ug/L | 10.0 | 05/19/22 10:15 | |
| EPA 6010 | Potassium | 1550 | ug/L | 1000 | 05/19/22 10:15 | |
| EPA 6010 | Silica | 11300 | ug/L | 450 | 05/19/22 10:15 | N2 |
| EPA 6010 | Sodium | 21500 | ug/L | 1000 | 05/19/22 10:15 | |
| EPA 6020 | Selenium | 1.1 | ug/L | 1.0 | 05/14/22 07:09 | |
| EPA 903.1 | Radium-226 | 0.200 ± 0.278 (0.464) C:NA T:95% | pCi/L | | 06/15/22 13:00 | |
| EPA 904.0 | Radium-228 | 0.395 ± 0.371 (0.754) C:73% T:85% | pCi/L | | 06/08/22 16:08 | |
| Total Radium Calculation | Total Radium | 0.595 ± 0.649 (1.22) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 326 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 326 | mg/L | 2.0 | 05/16/22 18:42 | |
| SM 2540C | Total Dissolved Solids | 446 | mg/L | 10.0 | 05/12/22 16:02 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/14/22 17:06 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 3.8 | mg/L | 0.10 | 05/06/22 17:17 | |
| **50315836008** | **MW-15I** | | | | | |
| EPA 9056 | Chloride | 15.8 | mg/L | 2.5 | 05/20/22 12:46 | |
| EPA 9056 | Fluoride | 0.12 | mg/L | 0.10 | 05/20/22 14:39 | |
| EPA 9056 | Sulfate | 49.0 | mg/L | 2.5 | 05/20/22 12:46 | |
| EPA 6010 | Barium | 56.0 | ug/L | 10.0 | 05/19/22 10:27 | |
| EPA 6010 | Boron | 110 | ug/L | 100 | 05/19/22 10:27 | |
| EPA 6010 | Calcium | 99900 | ug/L | 1000 | 05/19/22 10:27 | |
| EPA 6010 | Magnesium | 26000 | ug/L | 1000 | 05/19/22 10:27 | |
| EPA 6010 | Manganese | 13.9 | ug/L | 10.0 | 05/19/22 10:27 | |
| EPA 6010 | Potassium | 1270 | ug/L | 1000 | 05/19/22 10:27 | |
| EPA 6010 | Silica | 12300 | ug/L | 450 | 05/19/22 10:27 | N2 |
| EPA 6010 | Sodium | 8210 | ug/L | 1000 | 05/19/22 10:27 | |
| EPA 6010 | Manganese, Dissolved | 14.4 | ug/L | 10.0 | 05/17/22 03:21 | |
| EPA 6020 | Selenium | 1.9 | ug/L | 1.0 | 05/14/22 05:58 | |
| EPA 903.1 | Radium-226 | 0.160 ± 0.368 (0.666) C:NA T:88% | pCi/L | | 06/15/22 12:00 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50315836008** | **MW-15I** | | | | | |
| EPA 904.0 | Radium-228 | 0.155 ± 0.338 (0.748) C:78% T:87% | pCi/L | | 06/08/22 16:09 | |
| Total Radium Calculation | Total Radium | 0.315 ± 0.706 (1.41) | pCi/L | | 06/16/22 18:09 | |
| SM 2320B | Alkalinity, Total as CaCO3 | 301 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2320B | Alkalinity,Bicarbonate (CaCO3) | 301 | mg/L | 2.0 | 05/16/22 17:27 | |
| SM 2540C | Total Dissolved Solids | 399 | mg/L | 10.0 | 05/12/22 16:02 | |
| SM 4500-H+B | pH at 25 Degrees C | 7.5 | Std. Units | 0.10 | 05/14/22 17:06 | H3 |
| EPA 353.2 | Nitrogen, Nitrate | 2.7 | mg/L | 0.10 | 05/06/22 17:33 | |
| **50315836009** | **MW-15I MS** | | | | | |
| EPA 903.1 | Radium-226 | 86.57 %REC ± NA (NA) C:NA T:NA% | pCi/L | | 06/15/22 13:00 | |
| EPA 904.0 | Radium-228 | 102.28 %REC ± NA (NA) C:NA T:NA | pCi/L | | 06/08/22 16:09 | |
| **50315836010** | **MW-15I MSD** | | | | | |
| EPA 903.1 | Radium-226 | 114.92 %REC 28.14 RPD ± NA (NA) C:NA T:NA% | pCi/L | | 06/15/22 13:00 | |
| EPA 904.0 | Radium-228 | 95.30 %REC 7.07 RPD ± NA (NA) C:NA T:NA | pCi/L | | 06/08/22 16:09 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15S** **Lab ID: 50315836007** Collected: 05/05/22 10:14 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **28.1** | mg/L | 2.5 | 10 | | 05/20/22 14:21 | 16887-00-6 | |
| Fluoride | **0.12** | mg/L | 0.10 | 1 | | 05/20/22 14:02 | 16984-48-8 | |
| Sulfate | **48.8** | mg/L | 2.5 | 10 | | 05/20/22 14:21 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7429-90-5 | |
| Barium | **49.0** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-39-3 | |
| Boron | **120** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-43-9 | |
| Calcium | **106000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-47-3 | |
| Iron | **101** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7439-93-2 | |
| Magnesium | **27600** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7439-95-4 | |
| Manganese | **12.1** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7439-98-7 | |
| Potassium | **1550** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-09-7 | |
| Silica | **11300** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7631-86-9 | N2 |
| Sodium | **21500** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:15 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:19 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:19 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:09 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:09 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/14/22 07:09 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:09 | 7440-48-4 | |
| Selenium | **1.1** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:09 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 07:09 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/11/22 10:47 | 05/11/22 17:54 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **326** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Bicarbonate (CaCO3) | **326** | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 18:42 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15S** **Lab ID: 50315836007** Collected: 05/05/22 10:14 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **446** | mg/L | 10.0 | 1 | | 05/12/22 16:02 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/14/22 17:06 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:19 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **3.8** | mg/L | 0.10 | 1 | | 05/06/22 17:17 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 17:17 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:39 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/14/22 04:50 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/17/22 17:13 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15I** **Lab ID: 50315836008** Collected: 05/05/22 11:32 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **9056 IC Anions** | Analytical Method: EPA 9056 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Chloride | **15.8** | mg/L | 2.5 | 10 | | 05/20/22 12:46 | 16887-00-6 | |
| Fluoride | **0.12** | mg/L | 0.10 | 1 | | 05/20/22 14:39 | 16984-48-8 | |
| Sulfate | **49.0** | mg/L | 2.5 | 10 | | 05/20/22 12:46 | 14808-79-8 | |
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Aluminum | ND | ug/L | 200 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7429-90-5 | |
| Barium | **56.0** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-39-3 | |
| Boron | **110** | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-42-8 | |
| Cadmium | ND | ug/L | 2.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-43-9 | |
| Calcium | **99900** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-70-2 | |
| Chromium | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-47-3 | |
| Iron | ND | ug/L | 100 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7439-89-6 | |
| Lead | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7439-92-1 | |
| Lithium | ND | ug/L | 20.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7439-93-2 | |
| Magnesium | **26000** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7439-95-4 | |
| Manganese | **13.9** | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7439-96-5 | |
| Molybdenum | ND | ug/L | 10.0 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7439-98-7 | |
| Potassium | **1270** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-09-7 | |
| Silica | **12300** | ug/L | 450 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7631-86-9 | N2 |
| Sodium | **8210** | ug/L | 1000 | 1 | 05/14/22 14:28 | 05/19/22 10:27 | 7440-23-5 | |
| **6010 MET ICP, Dissolved** | Analytical Method: EPA 6010 Preparation Method: EPA 3010 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Manganese, Dissolved | **14.4** | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:21 | 7439-96-5 | |
| Molybdenum, Dissolved | ND | ug/L | 10.0 | 1 | 05/13/22 14:37 | 05/17/22 03:21 | 7439-98-7 | |
| **6020 MET ICPMS** | Analytical Method: EPA 6020 Preparation Method: EPA 200.2 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Antimony | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 05:58 | 7440-36-0 | |
| Arsenic | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 05:58 | 7440-38-2 | |
| Beryllium | ND | ug/L | 0.20 | 1 | 05/12/22 14:20 | 05/14/22 05:58 | 7440-41-7 | |
| Cobalt | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 05:58 | 7440-48-4 | |
| Selenium | **1.9** | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 05:58 | 7782-49-2 | |
| Thallium | ND | ug/L | 1.0 | 1 | 05/12/22 14:20 | 05/14/22 05:58 | 7440-28-0 | |
| **7470 Mercury** | Analytical Method: EPA 7470 Preparation Method: EPA 7470 | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Mercury | ND | ug/L | 0.20 | 1 | 05/11/22 10:47 | 05/11/22 17:57 | 7439-97-6 | |
| **2320B Alkalinity** | Analytical Method: SM 2320B | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | |
| Alkalinity, Total as CaCO3 | **301** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Bicarbonate (CaCO3) | **301** | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |
| Alkalinity,Carbonate (CaCO3) | ND | mg/L | 2.0 | 1 | | 05/16/22 17:27 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15I** **Lab ID: 50315836008** Collected: 05/05/22 11:32 Received: 05/06/22 13:20 Matrix: Water

| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|
| **2540C Total Dissolved Solids** | Analytical Method: SM 2540C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Dissolved Solids | **399** | mg/L | 10.0 | 1 | | 05/12/22 16:02 | | |
| **4500H+ pH, Electrometric** | Analytical Method: SM 4500-H+B<br>Pace Analytical Services - Indianapolis | | | | | | | |
| pH at 25 Degrees C | **7.5** | Std. Units | 0.10 | 1 | | 05/14/22 17:06 | | H3 |
| **4500S2D Sulfide Water** | Analytical Method: SM 4500-S2-D<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Sulfide | ND | mg/L | 0.10 | 1 | | 05/07/22 09:45 | 18496-25-8 | |
| **Iron, Ferrous** | Analytical Method: HACH 8146<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Iron, Ferrous | ND | mg/L | 0.20 | 1 | | 05/10/22 15:19 | 15438-31-0 | H3,N2 |
| **353.2 Nitrogen, NO2/NO3 unpres** | Analytical Method: EPA 353.2<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Nitrogen, Nitrate | **2.7** | mg/L | 0.10 | 1 | | 05/06/22 17:33 | 14797-55-8 | |
| Nitrogen, Nitrite | ND | mg/L | 0.10 | 1 | | 05/06/22 17:33 | 14797-65-0 | |
| **365.1 Total Phosphorus** | Analytical Method: EPA 365.1 Preparation Method: EPA 365.1<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Phosphate as P04 | ND | mg/L | 0.15 | 1 | 05/11/22 10:00 | 05/14/22 08:41 | | |
| **5310C TOC** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Total Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/14/22 16:08 | 7440-44-0 | |
| **5310C Dissolved Organic Carbon** | Analytical Method: SM 5310C<br>Pace Analytical Services - Indianapolis | | | | | | | |
| Dissolved Organic Carbon | ND | mg/L | 1.0 | 1 | | 05/17/22 17:29 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676962
QC Batch Method: EPA 9056
Analysis Method: EPA 9056
Analysis Description: 9056 IC Anions
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3116809 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Chloride | mg/L | ND | 0.25 | 05/20/22 12:15 | |
| Fluoride | mg/L | ND | 0.10 | 05/20/22 12:15 | |
| Sulfate | mg/L | ND | 0.25 | 05/20/22 12:15 | |

LABORATORY CONTROL SAMPLE: 3116810

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Chloride | mg/L | 1.2 | 1.1 | 90 | 80-120 | |
| Fluoride | mg/L | 0.5 | 0.48 | 97 | 80-120 | |
| Sulfate | mg/L | 2.5 | 2.4 | 96 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116811 3116812

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 15.8 | 12.5 | 12.5 | 27.4 | 27.4 | 93 | 93 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | 0.12 | 0.5 | 0.5 | 0.50 | 0.49 | 74 | 73 | 80-120 | 1 | 15 | M0 |
| Sulfate | mg/L | 49.0 | 25 | 25 | 77.4 | 72.9 | 113 | 95 | 80-120 | 6 | 15 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116813 3116814

| Parameter | Units | 50315985002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 50.3 | 12.5 | 12.5 | 63.0 | 64.1 | 102 | 110 | 80-120 | 2 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.41 | 0.41 | 75 | 77 | 80-120 | 2 | 15 | M0 |
| Sulfate | mg/L | 1620 | 250 | 250 | 1780 | 1800 | 64 | 70 | 80-120 | 1 | 15 | M0 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3116815 3116816

| Parameter | Units | 50315986002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Chloride | mg/L | 60.8 | 12.5 | 12.5 | 71.9 | 72.1 | 89 | 90 | 80-120 | 0 | 15 | |
| Fluoride | mg/L | ND | 0.5 | 0.5 | 0.39 | 0.40 | 76 | 78 | 80-120 | 2 | 15 | M0 |
| Sulfate | mg/L | 1530 | 250 | 250 | 1770 | 1750 | 96 | 86 | 80-120 | 1 | 15 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675562
QC Batch Method: EPA 7470
Analysis Method: EPA 7470
Analysis Description: 7470 Mercury
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3110534 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Mercury | ug/L | ND | 0.20 | 05/11/22 17:49 | |

LABORATORY CONTROL SAMPLE: 3110535

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mercury | ug/L | 5 | 5.1 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110536 3110537

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 4.9 | 5.0 | 98 | 99 | 75-125 | 1 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110538 3110539

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mercury | ug/L | ND | 5 | 5 | 5.2 | 5.2 | 104 | 102 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675195
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3109105 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 200 | 05/19/22 09:50 | |
| Barium | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Boron | ug/L | ND | 100 | 05/19/22 09:50 | |
| Cadmium | ug/L | ND | 2.0 | 05/19/22 09:50 | |
| Calcium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Chromium | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Iron | ug/L | ND | 100 | 05/19/22 09:50 | |
| Lead | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Lithium | ug/L | ND | 20.0 | 05/19/22 09:50 | |
| Magnesium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Manganese | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Molybdenum | ug/L | ND | 10.0 | 05/19/22 09:50 | |
| Potassium | ug/L | ND | 1000 | 05/19/22 09:50 | |
| Silica | ug/L | ND | 450 | 05/19/22 09:50 | N2 |
| Sodium | ug/L | ND | 1000 | 05/19/22 09:50 | |

LABORATORY CONTROL SAMPLE: 3109106

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Aluminum | ug/L | 10000 | 9890 | 99 | 80-120 | |
| Barium | ug/L | 1000 | 982 | 98 | 80-120 | |
| Boron | ug/L | 1000 | 983 | 98 | 80-120 | |
| Cadmium | ug/L | 1000 | 972 | 97 | 80-120 | |
| Calcium | ug/L | 10000 | 10100 | 101 | 80-120 | |
| Chromium | ug/L | 1000 | 997 | 100 | 80-120 | |
| Iron | ug/L | 10000 | 9670 | 97 | 80-120 | |
| Lead | ug/L | 1000 | 954 | 95 | 80-120 | |
| Lithium | ug/L | 1000 | 1050 | 105 | 80-120 | |
| Magnesium | ug/L | 10000 | 9600 | 96 | 80-120 | |
| Manganese | ug/L | 1000 | 975 | 97 | 80-120 | |
| Molybdenum | ug/L | 1000 | 1020 | 102 | 80-120 | |
| Potassium | ug/L | 10000 | 9870 | 99 | 80-120 | |
| Silica | ug/L | 10700 | 10200 | 96 | 80-120 | N2 |
| Sodium | ug/L | 10000 | 9930 | 99 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109107 3109108

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Aluminum | ug/L | ND | 10000 | 10000 | 10100 | 10000 | 101 | 100 | 75-125 | 0 | 20 | |
| Barium | ug/L | 56.0 | 1000 | 1000 | 1070 | 1060 | 101 | 101 | 75-125 | 1 | 20 | |
| Boron | ug/L | 110 | 1000 | 1000 | 1140 | 1140 | 103 | 103 | 75-125 | 0 | 20 | |
| Cadmium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 0 | 20 | |
| Calcium | ug/L | 99900 | 10000 | 10000 | 110000 | 112000 | 106 | 120 | 75-125 | 1 | 20 | |
| Chromium | ug/L | ND | 1000 | 1000 | 1020 | 1010 | 102 | 101 | 75-125 | 0 | 20 | |
| Iron | ug/L | ND | 10000 | 10000 | 9810 | 9760 | 98 | 98 | 75-125 | 1 | 20 | |
| Lead | ug/L | ND | 1000 | 1000 | 956 | 956 | 96 | 96 | 75-125 | 0 | 20 | |
| Lithium | ug/L | ND | 1000 | 1000 | 1120 | 1120 | 112 | 112 | 75-125 | 0 | 20 | |
| Magnesium | ug/L | 26000 | 10000 | 10000 | 35800 | 36100 | 98 | 101 | 75-125 | 1 | 20 | |
| Manganese | ug/L | 13.9 | 1000 | 1000 | 1000 | 1000 | 99 | 99 | 75-125 | 0 | 20 | |
| Molybdenum | ug/L | ND | 1000 | 1000 | 1050 | 1050 | 105 | 105 | 75-125 | 0 | 20 | |
| Potassium | ug/L | 1270 | 10000 | 10000 | 11700 | 11700 | 104 | 104 | 75-125 | 0 | 20 | |
| Silica | ug/L | 12300 | 10700 | 10700 | 22900 | 23000 | 99 | 100 | 75-125 | 0 | 20 | N2 |
| Sodium | ug/L | 8210 | 10000 | 10000 | 18600 | 18600 | 104 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675145
QC Batch Method: EPA 3010
Analysis Method: EPA 6010
Analysis Description: 6010 MET Dissolved
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3108904 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | ND | 10.0 | 05/17/22 03:02 | |
| Molybdenum, Dissolved | ug/L | ND | 10.0 | 05/17/22 03:02 | |

LABORATORY CONTROL SAMPLE: 3108905

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 1000 | 1000 | 100 | 80-120 | |
| Molybdenum, Dissolved | ug/L | 1000 | 1040 | 104 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108906 3108907

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Manganese, Dissolved | ug/L | 14.4 | 1000 | 1000 | 1010 | 1000 | 100 | 99 | 75-125 | 1 | 20 | |
| Molybdenum, Dissolved | ug/L | ND | 1000 | 1000 | 1050 | 1040 | 105 | 104 | 75-125 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675800
QC Batch Method: EPA 200.2
Analysis Method: EPA 6020
Analysis Description: 6020 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3111670 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Antimony | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Arsenic | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Beryllium | ug/L | ND | 0.20 | 05/14/22 05:38 | |
| Cobalt | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Selenium | ug/L | ND | 1.0 | 05/14/22 05:38 | |
| Thallium | ug/L | ND | 1.0 | 05/14/22 05:38 | |

LABORATORY CONTROL SAMPLE: 3111671

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Antimony | ug/L | 40 | 41.2 | 103 | 80-120 | |
| Arsenic | ug/L | 40 | 36.8 | 92 | 80-120 | |
| Beryllium | ug/L | 40 | 39.3 | 98 | 80-120 | |
| Cobalt | ug/L | 40 | 40.4 | 101 | 80-120 | |
| Selenium | ug/L | 40 | 38.0 | 95 | 80-120 | |
| Thallium | ug/L | 40 | 40.5 | 101 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111672 3111673

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | ND | 40 | 40 | 43.7 | 41.3 | 109 | 103 | 75-125 | 6 | 20 | |
| Arsenic | ug/L | ND | 40 | 40 | 37.2 | 38.9 | 93 | 97 | 75-125 | 4 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 41.4 | 39.8 | 103 | 99 | 75-125 | 4 | 20 | |
| Cobalt | ug/L | ND | 40 | 40 | 39.9 | 38.1 | 98 | 94 | 75-125 | 5 | 20 | |
| Selenium | ug/L | 1.9 | 40 | 40 | 39.0 | 41.2 | 93 | 98 | 75-125 | 5 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 43.0 | 40.7 | 107 | 102 | 75-125 | 6 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111684 3111685

| Parameter | Units | 50315953004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony | ug/L | 0.090J | 40 | 40 | 43.4 | 42.2 | 108 | 105 | 75-125 | 3 | 20 | |
| Arsenic | ug/L | 0.27J | 40 | 40 | 38.6 | 38.1 | 96 | 95 | 75-125 | 1 | 20 | |
| Beryllium | ug/L | ND | 40 | 40 | 41.0 | 40.0 | 102 | 100 | 75-125 | 2 | 20 | |
| Cobalt | ug/L | 0.13J | 40 | 40 | 38.5 | 37.2 | 96 | 93 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3111684 3111685

| Parameter | Units | 50315953004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Selenium | ug/L | 0.39J | 40 | 40 | 39.6 | 39.5 | 98 | 98 | 75-125 | 0 | 20 | |
| Thallium | ug/L | ND | 40 | 40 | 43.0 | 41.6 | 107 | 104 | 75-125 | 3 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676431
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007

METHOD BLANK: 3114685 Matrix: Water
Associated Lab Samples: 50315836007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/16/22 18:42 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 18:42 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 18:42 | |

LABORATORY CONTROL SAMPLE: 3114686

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.2 | 98 | 90-110 | |

SAMPLE DUPLICATE: 3114688

| Parameter | Units | 50315792009 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 628 | 528 | 17 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 628 | 528 | 17 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676456
QC Batch Method: SM 2320B
Analysis Method: SM 2320B
Analysis Description: 2320B Alkalinity
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836008

METHOD BLANK: 3114738 Matrix: Water
Associated Lab Samples: 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | ND | 2.0 | 05/16/22 17:27 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 17:27 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | 2.0 | 05/16/22 17:27 | |

LABORATORY CONTROL SAMPLE: 3114739

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 50 | 49.8 | 100 | 90-110 | |

SAMPLE DUPLICATE: 3114740

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 301 | 310 | 3 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 301 | 310 | 3 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

SAMPLE DUPLICATE: 3114741

| Parameter | Units | 50315769003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Alkalinity, Total as CaCO3 | mg/L | 289 | 297 | 2 | 20 | |
| Alkalinity,Bicarbonate (CaCO3) | mg/L | 289 | 297 | 2 | 20 | |
| Alkalinity,Carbonate (CaCO3) | mg/L | ND | ND | | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675790
QC Batch Method: SM 2540C
Analysis Method: SM 2540C
Analysis Description: 2540C Total Dissolved Solids
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3111641 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | ND | 10.0 | 05/12/22 15:57 | |

LABORATORY CONTROL SAMPLE: 3111642

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 300 | 295 | 98 | 80-120 | |

SAMPLE DUPLICATE: 3111643

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 399 | 410 | 3 | 10 | |

SAMPLE DUPLICATE: 3111644

| Parameter | Units | 50315848011 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Total Dissolved Solids | mg/L | 2590 | 2590 | 0 | 10 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676299
QC Batch Method: SM 4500-H+B
Analysis Method: SM 4500-H+B
Analysis Description: 4500H+B pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

SAMPLE DUPLICATE: 3114316

| Parameter | Units | 50315836001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.6 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3114317

| Parameter | Units | 50315836008 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.5 | 7.5 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 674957
QC Batch Method: SM 4500-S2-D
Analysis Method: SM 4500-S2-D
Analysis Description: 4500S2D Sulfide Water
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3108158 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.10 | 05/07/22 09:45 | |

LABORATORY CONTROL SAMPLE: 3108159

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Sulfide | mg/L | 0.5 | 0.53 | 106 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108160 3108161

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.54 | 0.53 | 109 | 107 | 90-110 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3108162 3108163

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Sulfide | mg/L | ND | 0.5 | 0.5 | 0.54 | 0.52 | 109 | 103 | 90-110 | 5 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675312
QC Batch Method: HACH 8146
Analysis Method: HACH 8146
Analysis Description: Iron, Ferrous
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3109491 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 0.20 | 05/10/22 15:13 | H3,N2 |

LABORATORY CONTROL SAMPLE: 3109492

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | 1 | 1.0 | 100 | 90-110 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109493 3109494

| Parameter | Units | 50315733002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.1 | 1.1 | 101 | 103 | 90-110 | 1 | 20 | H3,N2 |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3109495 3109496

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Iron, Ferrous | mg/L | ND | 1 | 1 | 1.0 | 1.0 | 103 | 104 | 90-110 | 1 | 20 | H3,N2 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 674902
QC Batch Method: EPA 353.2
Analysis Method: EPA 353.2
Analysis Description: 353.2 Nitrate + Nitrite, Unpres.
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3107776 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | ND | 0.10 | 05/06/22 17:00 | |
| Nitrogen, Nitrite | mg/L | ND | 0.10 | 05/06/22 17:00 | |

LABORATORY CONTROL SAMPLE: 3107777

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 1 | 1.0 | 103 | 90-110 | |
| Nitrogen, Nitrite | mg/L | 1 | 0.96 | 96 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3107778 3107779

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 2.7 | 1 | 1 | 3.7 | 3.7 | 99 | 97 | 90-110 | 1 | 20 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 1 | 0.98 | 0.99 | 96 | 97 | 90-110 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3107782

| Parameter | Units | 50315836007 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Nitrogen, Nitrate | mg/L | 3.8 | 1 | 4.6 | 85 | 90-110 | |
| Nitrogen, Nitrite | mg/L | ND | 1 | 0.97 | 97 | 90-110 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 675566
QC Batch Method: EPA 365.1
Analysis Method: EPA 365.1
Analysis Description: 365.1 Total Phosphorus
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3110550 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | 0.15 | 05/14/22 08:33 | |

LABORATORY CONTROL SAMPLE: 3110551

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | | 1.5 | | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110552 3110553

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | ND | | | 1.4 | 1.4 | | | | 4 | | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3110554 3110555

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Phosphate as P04 | mg/L | 1.5 | | | 3.1 | 2.9 | | | | 7 | | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676189
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007

METHOD BLANK: 3113658 Matrix: Water
Associated Lab Samples: 50315836007

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/13/22 23:42 | |

LABORATORY CONTROL SAMPLE: 3113659

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 9.9 | 99 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113660 3113661

| Parameter | Units | 50315748001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 0.86 | 10 | 10 | 10.8 | 10.8 | 100 | 100 | 80-120 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 3113662

| Parameter | Units | 50315838001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 11.1 | 104 | 80-120 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676192
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Total Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836008

METHOD BLANK: 3113670 Matrix: Water
Associated Lab Samples: 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 1.0 | 05/14/22 15:48 | |

LABORATORY CONTROL SAMPLE: 3113671

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 10 | 10.0 | 100 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113672 3113673

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | ND | 10 | 10 | 10.1 | 9.7 | 97 | 93 | 80-120 | 3 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3113674 3113675

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Organic Carbon | mg/L | 11.2 | 20 | 20 | 30.3 | 28.8 | 95 | 88 | 80-120 | 5 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 676499
QC Batch Method: SM 5310C
Analysis Method: SM 5310C
Analysis Description: 5310C Dissolved Organic Carbon
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50315836007, 50315836008

METHOD BLANK: 3114861 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 1.0 | 05/17/22 14:37 | |

LABORATORY CONTROL SAMPLE: 3114862

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 10 | 9.8 | 98 | 90-110 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114863 3114864

| Parameter | Units | 50315836008 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | ND | 10 | 10 | 10.6 | 10.8 | 103 | 105 | 80-120 | 2 | 20 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3114865 3114866

| Parameter | Units | 50315883004 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Dissolved Organic Carbon | mg/L | 11.8 | 100 | 100 | 111 | 106 | 99 | 94 | 80-120 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15S** **Lab ID: 50315836007** Collected: 05/05/22 10:14 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.200 ± 0.278 (0.464) C:NA T:95%** | pCi/L | 06/15/22 13:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.395 ± 0.371 (0.754) C:73% T:85%** | pCi/L | 06/08/22 16:08 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.595 ± 0.649 (1.22)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15I** **Lab ID: 50315836008** Collected: 05/05/22 11:32 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **0.160 ± 0.368 (0.666) C:NA T:88%** | pCi/L | 06/15/22 12:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **0.155 ± 0.338 (0.748) C:78% T:87%** | pCi/L | 06/08/22 16:09 | 15262-20-1 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Total Radium | Total Radium Calculation | **0.315 ± 0.706 (1.41)** | pCi/L | 06/16/22 18:09 | 7440-14-4 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15I MS** **Lab ID: 50315836009** Collected: 05/05/22 11:32 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **86.57 %REC ± NA (NA) C:NA T:NA%** | pCi/L | 06/15/22 13:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **102.28 %REC ± NA (NA) C:NA T:NA** | pCi/L | 06/08/22 16:09 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

**Sample: MW-15I MSD** **Lab ID: 50315836010** Collected: 05/05/22 11:32 Received: 05/06/22 13:20 Matrix: Water
PWS: Site ID: Sample Type:

| Parameters | Method | Act ± Unc (MDC) Carr Trac | Units | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-226 | EPA 903.1 | **114.92 %REC 28.14 RPD ± NA (NA) C:NA T:NA%** | pCi/L | 06/15/22 13:00 | 13982-63-3 | |
| | Pace Analytical Services - Greensburg | | | | | |
| Radium-228 | EPA 904.0 | **95.30 %REC 7.07 RPD ± NA (NA) C:NA T:NA** | pCi/L | 06/08/22 16:09 | 15262-20-1 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 505241
QC Batch Method: EPA 904.0
Analysis Method: EPA 904.0
Analysis Description: 904.0 Radium 228
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315836007, 50315836008, 50315836009, 50315836010

METHOD BLANK: 2447182 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008, 50315836009, 50315836010

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-228 | 0.235 ± 0.296 (0.628) C:85% T:87% | pCi/L | 06/08/22 16:06 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL - RADIOCHEMISTRY

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

QC Batch: 505239
QC Batch Method: EPA 903.1
Analysis Method: EPA 903.1
Analysis Description: 903.1 Radium-226
Laboratory: Pace Analytical Services - Greensburg
Associated Lab Samples: 50315836007, 50315836008, 50315836009, 50315836010

METHOD BLANK: 2447174 Matrix: Water
Associated Lab Samples: 50315836007, 50315836008, 50315836009, 50315836010

| Parameter | Act ± Unc (MDC) Carr Trac | Units | Analyzed | Qualifiers |
|---|---|---|---|---|
| Radium-226 | -0.190 ± 0.249 (0.604) C:NA T:96% | pCi/L | 06/15/22 12:00 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Act - Activity

Unc - Uncertainty: SDWA = 1.96 sigma count uncertainty, all other matrices = Expanded Uncertainty (95% confidence interval). Gamma Spec = Expanded Uncertainty (95.4% Confidence Interval)

(MDC) - Minimum Detectable Concentration

Trac - Tracer Recovery (%)

Carr - Carrier Recovery (%)

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Profile 1 Report 1
Pace Project No.: 50317428

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50315836007** | **MW-15S** | EPA 9056 | 676962 | | |
| **50315836008** | **MW-15I** | EPA 9056 | 676962 | | |
| **50315836007** | **MW-15S** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836008** | **MW-15I** | EPA 3010 | 675195 | EPA 6010 | 677074 |
| **50315836007** | **MW-15S** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836008** | **MW-15I** | EPA 3010 | 675145 | EPA 6010 | 676545 |
| **50315836007** | **MW-15S** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836008** | **MW-15I** | EPA 200.2 | 675800 | EPA 6020 | 676024 |
| **50315836007** | **MW-15S** | EPA 7470 | 675562 | EPA 7470 | 675669 |
| **50315836008** | **MW-15I** | EPA 7470 | 675562 | EPA 7470 | 675669 |
| **50315836007** | **MW-15S** | EPA 903.1 | 505239 | | |
| **50315836008** | **MW-15I** | EPA 903.1 | 505239 | | |
| **50315836009** | **MW-15I MS** | EPA 903.1 | 505239 | | |
| **50315836010** | **MW-15I MSD** | EPA 903.1 | 505239 | | |
| **50315836007** | **MW-15S** | EPA 904.0 | 505241 | | |
| **50315836008** | **MW-15I** | EPA 904.0 | 505241 | | |
| **50315836009** | **MW-15I MS** | EPA 904.0 | 505241 | | |
| **50315836010** | **MW-15I MSD** | EPA 904.0 | 505241 | | |
| **50315836007** | **MW-15S** | Total Radium Calculation | 512513 | | |
| **50315836008** | **MW-15I** | Total Radium Calculation | 512513 | | |
| **50315836007** | **MW-15S** | SM 2320B | 676431 | | |
| **50315836008** | **MW-15I** | SM 2320B | 676456 | | |
| **50315836007** | **MW-15S** | SM 2540C | 675790 | | |
| **50315836008** | **MW-15I** | SM 2540C | 675790 | | |
| **50315836007** | **MW-15S** | SM 4500-H+B | 676299 | | |
| **50315836008** | **MW-15I** | SM 4500-H+B | 676299 | | |
| **50315836007** | **MW-15S** | SM 4500-S2-D | 674957 | | |
| **50315836008** | **MW-15I** | SM 4500-S2-D | 674957 | | |
| **50315836007** | **MW-15S** | HACH 8146 | 675312 | | |
| **50315836008** | **MW-15I** | HACH 8146 | 675312 | | |
| **50315836007** | **MW-15S** | EPA 353.2 | 674902 | | |
| **50315836008** | **MW-15I** | EPA 353.2 | 674902 | | |
| **50315836007** | **MW-15S** | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| **50315836008** | **MW-15I** | EPA 365.1 | 675566 | EPA 365.1 | 676272 |
| **50315836007** | **MW-15S** | SM 5310C | 676189 | | |
| **50315836008** | **MW-15I** | SM 5310C | 676192 | | |
| **50315836007** | **MW-15S** | SM 5310C | 676499 | | |
| **50315836008** | **MW-15I** | SM 5310C | 676499 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical
WWW.PACELABS.COM

# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



| Section A Required Client Information: | | Section B Required Project Information: | | Section C Invoice Information: | |
|---|---|---|---|---|---|
| Company: | Atlas Indianapolis | Report To: | Mark Breting | Attention: | Accounts Payable - Paula Sedam |
| Address: | 7988 Centerpoint Drive Suite 100 | Copy To: | | Company Name: | Atlas Indianapolis |
| | Indianapolis, IN 46256 | | | Address: | |
| Email: | mark.breting@oneatlas.com | Purchase Order #: | | Pace Quote: | |
| Phone: | (317)579-4082 Fax: | Project Name: | Harding St Profile 1 Report 1 | Pace Project Manager: | Hayden Putt |
| Requested Due Date: | | Project #: | | Pace Profile #: | 10498/15 |

Regulatory Agency: | State / Location: IN

| ITEM # | SAMPLE ID (One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique) | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH + ZnAcetate | Na2S2O3 | Methanol | Other | Analyses Test Y/N | TDS/ NO3,NO2-Wet | (Cl, F, SO4 by IC | Metals, Total* | Metals Diss. Field Filtered** | Rad-228 | Rad-226 | Alkalinity, Ferrous Iron, pH | TOC by 5310C | DOC by 5310C | Sulfide | Phosphate | | Residual Chlorine (Y/N) | 50317428 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | MATRIX CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS | | | | | | | | | | | | | | | | | | | | | Y | | | | Y | | | | | | |
| 25 | MW-15S | WT | G | | | 5/5/22 | 1014 | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | x | | | 007 |
| 26 | MW-15I | WT | G | | | 5/5/22 | 1132 | | ~~33~~ 11 | ~~9~~ 3 | ~~9~~ 3 | ~~12~~ 4 | | ~~3~~ 1 | | | | | x | x | x | x | x | x | x | x | x | x | x | | | MS/MSD 008/009 |
| 27 | MW-15D | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | x | | | 010 |
| 28 | DUP 1 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | x | | | |
| 29 | DUP 2 | WT | | | | | | | 11 | 3 | 3 | 4 | | 1 | | | | | x | x | x | x | x | x | x | x | x | x | x | | | |
| 30 | Field Blank 1 | WT | | | | | | | 9 | 3 | 2 | 3 | | 1 | | | | | x | x | x | | x | x | x | x | | x | x | | | |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| * Metals: 6010 (Al, Ba, B, Cd, Cr, Fe, Pb, Mn, Mo, Ca, Mg, Na, K, Li, SiO2) | Mark Breting /ATLAS | 5/6/22 | 0945 | [illegible] Pace | 5/6/22 | 945 | |
| 6020 (Be, Co, As, Se, Sb, Tl) 7470 Hg | [illegible] Pace | 5/6/22 | 1320 | [illegible] | 5/6/22 | 1320 | SEE Sample |
| ** Dissolved FF 6010 (Mo, Mn) | | | | | | | |
| Alkalinity = (Total , Bicarb & Carb) | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: P. Greg Hopper, Somanta Lab

SIGNATURE of SAMPLER: Mark Breting /ATL DATE Signed: 5/6/22

P. Greg Hopper, Somanta Lab.

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|
| | | | |

F-IN-Q-290-rev.22, 22Apr2022

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** [illegible] 5/6/22 1405

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☒ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** | | | | |

**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☒ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☒ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No |
|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ |
| **Short Hold Time Analysis (48 hours or less)?** **Analysis:** NO3 | ✓ | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: 1500 | |
| **Rush TAT Requested (4 days or less):** | | ✓ |
| Custody Signatures Present? | ✓ | |
| Containers Intact?: | ✓ | |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | |

| | Yes | No | N/A |
|---|---|---|---|
| All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** ~~HNO3 (<2)~~ ~~H2SO4 (<2)~~ NaOH (>10) ~~NaOH/ZnAc (>9)~~ Any non-conformance to pH recommendations will be noted on the container count form | ✓ | | |
| | Present | Absent | N/A |
| Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Headspace Wisconsin Sulfide? | | | ✓ |
| | Present | Absent | No VOA Vials Sent |
| Headspace in VOA Vials (>6mm): See Containter Count form for details | | | |
| Trip Blank Present? | | ✓ | |
| Trip Blank Custody Seals?: | | ✓ | |

COMMENTS: 1.8/1.6 0.6/0.4 0.8/0.6 0.7/0.5 1.6/1.4

Samples 007-010 moved to 50317428. hrp 5/26/22

**COC PAGE ____ of ____**

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | SBS / DI / MeOH (only) / BK / Kit R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | Syringe Kit | | | Matrix | HNO3/ H2SO4 pH <2 | NaOH/ ZNAc pH >9 | NaOH pH>10 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | 1 | 1 | | | 2 | 1 | 2 | 1 | 1 | 1 | | 1 | | | | | SL | ✓ | ✓ | |
| 2 | | | | | | | | | | | | 3 | 3 | | | 6 | 3 | 6 | 3 | 3 | 3 | | 3 | | | | | SL | ✓ | ✓ | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| BG1H | 1L HCl clear glass | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1S | 1L H2SO4 clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| GN | General | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic / Misc.

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |

| | |
|---|---|
| AF | Air Filter |
| C | Air Cassettes |
| R | Terracore kit |
| SP5T | 120mL Coliform Na Thiosulfate |
| U | Summa Can |
| ZPLC | Ziploc Bag |

| | | | |
|---|---|---|---|
| WT | | Water | |
| SL | | Solid | |
| NAL | OL | Non-aqueous liquid | Oil |
| WP | | Wipe | |

## SOIL ANALYTICAL DATA

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

November 17, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Ash Pond System
Pace Project No.: 50330483

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 08, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Green Bay
- Pace Analytical Services - Indianapolis

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Pace Analytical Services Green Bay**

1241 Bellevue Street, Green Bay, WI 54302
Florida/NELAP Certification #: E87948
Illinois Certification #: 200050
Kentucky UST Certification #: 82
Louisiana Certification #: 04168
Minnesota Certification #: 055-999-334
New York Certification #: 12064
North Dakota Certification #: R-150
South Carolina Certification #: 83006001
Texas Certification #: T104704529-21-8
Virginia VELAP Certification ID: 11873
Wisconsin Certification #: 405132750
Wisconsin DATCP Certification #: 105-444
USDA Soil Permit #: P330-21-00008
Federal Fish & Wildlife Permit #: 51774A

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50330483001** | **MW-109S (31-33)** | Solid | 11/08/22 08:45 | 11/08/22 14:35 |
| **50330483002** | **MW-109I (54-56)** | Solid | 11/08/22 09:05 | 11/08/22 14:35 |
| **50330483003** | **MW-109D (82-84)** | Solid | 11/08/22 08:47 | 11/08/22 14:35 |
| **50330483004** | **MW-110S (52-54)** | Solid | 11/08/22 08:50 | 11/08/22 14:35 |
| **50330483005** | **MW-110I (68-70)** | Solid | 11/08/22 08:52 | 11/08/22 14:35 |
| **50330483006** | **MW-110D (96-98)** | Solid | 11/08/22 08:55 | 11/08/22 14:35 |
| **50330483007** | **MW-4I (60-62)** | Solid | 11/08/22 08:58 | 11/08/22 14:35 |
| **50330483008** | **MW-4D (78-80)** | Solid | 11/08/22 09:00 | 11/08/22 14:35 |
| **50330483009** | **DUP-1** | Solid | 11/08/22 09:15 | 11/08/22 14:35 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50330483001** | **MW-109S (31-33)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483002** | **MW-109I (54-56)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483003** | **MW-109D (82-84)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483004** | **MW-110S (52-54)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483005** | **MW-110I (68-70)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483006** | **MW-110D (96-98)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483007** | **MW-4I (60-62)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483008** | **MW-4D (78-80)** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50330483009** | **DUP-1** | EPA 6010 | DJS | 5 | PASI-I |
| | | SM 2540G | BAL1 | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|

PASI-G = Pace Analytical Services - Green Bay
PASI-I = Pace Analytical Services - Indianapolis



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50330483001** | **MW-109S (31-33)** | | | | | |
| EPA 6010 | Arsenic | 3.4 | mg/kg | 0.90 | 11/16/22 12:22 | |
| EPA 6010 | Iron | 6090 | mg/kg | 45.1 | 11/16/22 12:22 | |
| EPA 6010 | Manganese | 212 | mg/kg | 0.90 | 11/16/22 12:22 | |
| EPA 6010 | Molybdenum | 1.0 | mg/kg | 0.90 | 11/16/22 12:22 | |
| SM 2540G | Percent Moisture | 2.8 | % | 0.10 | 11/14/22 18:41 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.9 | Std. Units | 0.10 | 11/09/22 14:28 | H3 |
| EPA 9060 | Total Organic Carbon | 19100 | mg/kg | 4500 | 11/16/22 06:10 | |
| EPA 9060 | Total Organic Carbon | 15200 | mg/kg | 4560 | 11/16/22 06:15 | |
| EPA 9060 | Total Organic Carbon | 14100 | mg/kg | 4560 | 11/16/22 06:21 | |
| EPA 9060 | Total Organic Carbon | 11000 | mg/kg | 4540 | 11/16/22 06:26 | |
| EPA 9060 | Mean Total Organic Carbon | 14800 | mg/kg | 4540 | 11/16/22 06:10 | |
| EPA 9060 | RSD% | 22.8 | % | | 11/16/22 06:10 | |
| **50330483002** | **MW-109I (54-56)** | | | | | |
| EPA 6010 | Arsenic | 3.6 | mg/kg | 1.1 | 11/16/22 12:24 | |
| EPA 6010 | Iron | 5320 | mg/kg | 54.6 | 11/16/22 12:24 | |
| EPA 6010 | Manganese | 216 | mg/kg | 1.1 | 11/16/22 12:24 | |
| EPA 6010 | Molybdenum | 1.5 | mg/kg | 1.1 | 11/16/22 12:24 | |
| SM 2540G | Percent Moisture | 12.1 | % | 0.10 | 11/14/22 18:41 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 11/09/22 14:37 | H3 |
| EPA 9060 | Total Organic Carbon | 9130 | mg/kg | 3030 | 11/16/22 06:32 | |
| EPA 9060 | Total Organic Carbon | 9320 | mg/kg | 3010 | 11/16/22 06:37 | |
| EPA 9060 | Total Organic Carbon | 6480 | mg/kg | 2990 | 11/16/22 06:43 | |
| EPA 9060 | Total Organic Carbon | 11100 | mg/kg | 3050 | 11/16/22 06:49 | |
| EPA 9060 | Mean Total Organic Carbon | 9000 | mg/kg | 3020 | 11/16/22 06:32 | |
| EPA 9060 | RSD% | 21.0 | % | | 11/16/22 06:32 | |
| **50330483003** | **MW-109D (82-84)** | | | | | |
| EPA 6010 | Arsenic | 6.1 | mg/kg | 0.93 | 11/16/22 12:44 | |
| EPA 6010 | Iron | 8420 | mg/kg | 46.4 | 11/16/22 12:44 | |
| EPA 6010 | Manganese | 286 | mg/kg | 0.93 | 11/16/22 12:44 | |
| EPA 6010 | Molybdenum | 2.5 | mg/kg | 0.93 | 11/16/22 12:44 | |
| SM 2540G | Percent Moisture | 4.7 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 8.0 | Std. Units | 0.10 | 11/09/22 14:29 | H3 |
| EPA 9060 | Total Organic Carbon | 33800 | mg/kg | 1990 | 11/16/22 07:46 | |
| EPA 9060 | Total Organic Carbon | 41900 | mg/kg | 1990 | 11/16/22 07:54 | |
| EPA 9060 | Total Organic Carbon | 28100 | mg/kg | 2010 | 11/16/22 08:00 | |
| EPA 9060 | Total Organic Carbon | 31600 | mg/kg | 2020 | 11/16/22 08:07 | |
| EPA 9060 | Mean Total Organic Carbon | 33900 | mg/kg | 2000 | 11/16/22 07:46 | |
| EPA 9060 | RSD% | 17.3 | % | | 11/16/22 07:46 | |
| **50330483004** | **MW-110S (52-54)** | | | | | |
| EPA 6010 | Arsenic | 3.8 | mg/kg | 1.2 | 11/16/22 12:47 | |
| EPA 6010 | Iron | 7780 | mg/kg | 58.8 | 11/16/22 12:47 | |
| EPA 6010 | Manganese | 287 | mg/kg | 1.2 | 11/16/22 12:47 | |
| EPA 6010 | Molybdenum | 1.7 | mg/kg | 1.2 | 11/16/22 12:47 | |
| SM 2540G | Percent Moisture | 15.3 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 8.0 | Std. Units | 0.10 | 11/09/22 14:30 | H3 |
| EPA 9060 | Total Organic Carbon | 14100 | mg/kg | 1420 | 11/16/22 08:15 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50330483004** | **MW-110S (52-54)** | | | | | |
| EPA 9060 | Total Organic Carbon | 15800 | mg/kg | 1450 | 11/16/22 08:22 | |
| EPA 9060 | Total Organic Carbon | 13000 | mg/kg | 1440 | 11/16/22 08:30 | |
| EPA 9060 | Total Organic Carbon | 11700 | mg/kg | 1430 | 11/16/22 08:39 | |
| EPA 9060 | Mean Total Organic Carbon | 13600 | mg/kg | 1430 | 11/16/22 08:15 | |
| EPA 9060 | RSD% | 12.7 | % | | 11/16/22 08:15 | |
| **50330483005** | **MW-110I (68-70)** | | | | | |
| EPA 6010 | Arsenic | 2.3 | mg/kg | 1.0 | 11/16/22 12:50 | |
| EPA 6010 | Iron | 5500 | mg/kg | 50.3 | 11/16/22 12:50 | |
| EPA 6010 | Manganese | 101 | mg/kg | 1.0 | 11/16/22 12:50 | |
| SM 2540G | Percent Moisture | 3.4 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 8.0 | Std. Units | 0.10 | 11/09/22 14:31 | H3 |
| EPA 9060 | Total Organic Carbon | 5520 | mg/kg | 622 | 11/16/22 11:10 | |
| EPA 9060 | Total Organic Carbon | 5550 | mg/kg | 627 | 11/16/22 11:16 | |
| EPA 9060 | Total Organic Carbon | 5330 | mg/kg | 624 | 11/16/22 11:23 | |
| EPA 9060 | Total Organic Carbon | 4880 | mg/kg | 626 | 11/16/22 11:28 | |
| EPA 9060 | Mean Total Organic Carbon | 5320 | mg/kg | 625 | 11/16/22 11:10 | |
| EPA 9060 | RSD% | 5.8 | % | | 11/16/22 11:10 | |
| **50330483006** | **MW-110D (96-98)** | | | | | |
| EPA 6010 | Arsenic | 4.1 | mg/kg | 1.1 | 11/16/22 12:53 | |
| EPA 6010 | Iron | 6310 | mg/kg | 54.7 | 11/16/22 12:53 | |
| EPA 6010 | Manganese | 325 | mg/kg | 1.1 | 11/16/22 12:53 | |
| EPA 6010 | Molybdenum | 1.6 | mg/kg | 1.1 | 11/16/22 12:53 | |
| SM 2540G | Percent Moisture | 10.3 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.9 | Std. Units | 0.10 | 11/09/22 14:32 | H3 |
| EPA 9060 | Total Organic Carbon | 7670 | mg/kg | 1530 | 11/16/22 09:22 | |
| EPA 9060 | Total Organic Carbon | 8980 | mg/kg | 1520 | 11/16/22 09:27 | |
| EPA 9060 | Total Organic Carbon | 7200 | mg/kg | 1530 | 11/16/22 09:34 | |
| EPA 9060 | Total Organic Carbon | 9420 | mg/kg | 1550 | 11/16/22 09:39 | |
| EPA 9060 | Mean Total Organic Carbon | 8320 | mg/kg | 1530 | 11/16/22 09:22 | |
| EPA 9060 | RSD% | 12.7 | % | | 11/16/22 09:22 | |
| **50330483007** | **MW-4I (60-62)** | | | | | |
| EPA 6010 | Arsenic | 5.3 | mg/kg | 1.0 | 11/16/22 12:56 | |
| EPA 6010 | Iron | 6980 | mg/kg | 51.0 | 11/16/22 12:56 | |
| EPA 6010 | Manganese | 231 | mg/kg | 1.0 | 11/16/22 12:56 | |
| EPA 6010 | Molybdenum | 2.4 | mg/kg | 1.0 | 11/16/22 12:56 | |
| SM 2540G | Percent Moisture | 9.0 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.6 | Std. Units | 0.10 | 11/09/22 14:35 | H3 |
| EPA 9060 | Total Organic Carbon | 21300 | mg/kg | 2000 | 11/16/22 09:56 | |
| EPA 9060 | Total Organic Carbon | 36500 | mg/kg | 2010 | 11/16/22 10:03 | |
| EPA 9060 | Total Organic Carbon | 25000 | mg/kg | 2040 | 11/16/22 10:09 | |
| EPA 9060 | Total Organic Carbon | 21300 | mg/kg | 2000 | 11/16/22 10:15 | |
| EPA 9060 | Mean Total Organic Carbon | 26000 | mg/kg | 2010 | 11/16/22 09:56 | |
| EPA 9060 | RSD% | 27.8 | % | | 11/16/22 09:56 | |
| **50330483008** | **MW-4D (78-80)** | | | | | |
| EPA 6010 | Arsenic | 4.9 | mg/kg | 1.1 | 11/16/22 12:59 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50330483008** | **MW-4D (78-80)** | | | | | |
| EPA 6010 | Iron | 6610 | mg/kg | 55.0 | 11/16/22 12:59 | |
| EPA 6010 | Manganese | 216 | mg/kg | 1.1 | 11/16/22 12:59 | |
| EPA 6010 | Molybdenum | 3.3 | mg/kg | 1.1 | 11/16/22 12:59 | |
| SM 2540G | Percent Moisture | 12.5 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.4 | Std. Units | 0.10 | 11/09/22 14:36 | H3 |
| EPA 9060 | Total Organic Carbon | 3500 | mg/kg | 2340 | 11/16/22 10:22 | |
| EPA 9060 | Total Organic Carbon | 8140 | mg/kg | 2330 | 11/16/22 10:28 | |
| EPA 9060 | Total Organic Carbon | 8130 | mg/kg | 2300 | 11/16/22 10:35 | |
| EPA 9060 | Total Organic Carbon | 4440 | mg/kg | 2310 | 11/16/22 10:41 | |
| EPA 9060 | Mean Total Organic Carbon | 6050 | mg/kg | 2320 | 11/16/22 10:22 | |
| EPA 9060 | RSD% | 40.2 | % | | 11/16/22 10:22 | 1d |
| **50330483009** | **DUP-1** | | | | | |
| EPA 6010 | Arsenic | 4.3 | mg/kg | 1.2 | 11/16/22 13:01 | |
| EPA 6010 | Iron | 8350 | mg/kg | 58.3 | 11/16/22 13:01 | |
| EPA 6010 | Manganese | 319 | mg/kg | 1.2 | 11/16/22 13:01 | |
| EPA 6010 | Molybdenum | 1.8 | mg/kg | 1.2 | 11/16/22 13:01 | |
| SM 2540G | Percent Moisture | 15.6 | % | 0.10 | 11/14/22 18:42 | N2 |
| EPA 9045 | pH at 25 Degrees C | 8.1 | Std. Units | 0.10 | 11/09/22 14:39 | H3 |
| EPA 9060 | Total Organic Carbon | 11500 | mg/kg | 2120 | 11/16/22 10:46 | |
| EPA 9060 | Total Organic Carbon | 10900 | mg/kg | 2150 | 11/16/22 10:52 | |
| EPA 9060 | Total Organic Carbon | 9510 | mg/kg | 2130 | 11/16/22 10:59 | |
| EPA 9060 | Total Organic Carbon | 7480 | mg/kg | 2160 | 11/16/22 11:05 | |
| EPA 9060 | Mean Total Organic Carbon | 9860 | mg/kg | 2140 | 11/16/22 10:46 | |
| EPA 9060 | RSD% | 18.3 | % | | 11/16/22 10:46 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-109S (31-33)** **Lab ID: 50330483001** Collected: 11/08/22 08:45 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **3.4** | mg/kg | 0.90 | 0.15 | 1 | 11/15/22 10:57 | 11/16/22 12:22 | 7440-38-2 | |
| Iron | **6090** | mg/kg | 45.1 | 11.5 | 1 | 11/15/22 10:57 | 11/16/22 12:22 | 7439-89-6 | |
| Lithium | ND | mg/kg | 4.5 | 0.31 | 1 | 11/15/22 10:57 | 11/16/22 12:22 | 7439-93-2 | N2 |
| Manganese | **212** | mg/kg | 0.90 | 0.60 | 1 | 11/15/22 10:57 | 11/16/22 12:22 | 7439-96-5 | |
| Molybdenum | **1.0** | mg/kg | 0.90 | 0.053 | 1 | 11/15/22 10:57 | 11/16/22 12:22 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **2.8** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:41 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.9** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:28 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **19100** | mg/kg | 4500 | 1460 | 1 | | 11/16/22 06:10 | 7440-44-0 | |
| Total Organic Carbon | **15200** | mg/kg | 4560 | 1470 | 1 | | 11/16/22 06:15 | 7440-44-0 | |
| Total Organic Carbon | **14100** | mg/kg | 4560 | 1470 | 1 | | 11/16/22 06:21 | 7440-44-0 | |
| Total Organic Carbon | **11000** | mg/kg | 4540 | 1470 | 1 | | 11/16/22 06:26 | 7440-44-0 | |
| Mean Total Organic Carbon | **14800** | mg/kg | 4540 | 1470 | 1 | | 11/16/22 06:10 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **22.8** | % | | | 1 | | 11/16/22 06:10 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-109I (54-56)** **Lab ID: 50330483002** Collected: 11/08/22 09:05 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **3.6** | mg/kg | 1.1 | 0.18 | 1 | 11/15/22 10:57 | 11/16/22 12:24 | 7440-38-2 | |
| Iron | **5320** | mg/kg | 54.6 | 13.9 | 1 | 11/15/22 10:57 | 11/16/22 12:24 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.5 | 0.37 | 1 | 11/15/22 10:57 | 11/16/22 12:24 | 7439-93-2 | N2 |
| Manganese | **216** | mg/kg | 1.1 | 0.73 | 1 | 11/15/22 10:57 | 11/16/22 12:24 | 7439-96-5 | |
| Molybdenum | **1.5** | mg/kg | 1.1 | 0.064 | 1 | 11/15/22 10:57 | 11/16/22 12:24 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **12.1** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:41 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:37 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **9130** | mg/kg | 3030 | 980 | 1 | | 11/16/22 06:32 | 7440-44-0 | |
| Total Organic Carbon | **9320** | mg/kg | 3010 | 974 | 1 | | 11/16/22 06:37 | 7440-44-0 | |
| Total Organic Carbon | **6480** | mg/kg | 2990 | 967 | 1 | | 11/16/22 06:43 | 7440-44-0 | |
| Total Organic Carbon | **11100** | mg/kg | 3050 | 987 | 1 | | 11/16/22 06:49 | 7440-44-0 | |
| Mean Total Organic Carbon | **9000** | mg/kg | 3020 | 977 | 1 | | 11/16/22 06:32 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **21.0** | % | | | 1 | | 11/16/22 06:32 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-109D (82-84)** **Lab ID: 50330483003** Collected: 11/08/22 08:47 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **6.1** | mg/kg | 0.93 | 0.15 | 1 | 11/15/22 10:57 | 11/16/22 12:44 | 7440-38-2 | |
| Iron | **8420** | mg/kg | 46.4 | 11.8 | 1 | 11/15/22 10:57 | 11/16/22 12:44 | 7439-89-6 | |
| Lithium | ND | mg/kg | 4.6 | 0.31 | 1 | 11/15/22 10:57 | 11/16/22 12:44 | 7439-93-2 | N2 |
| Manganese | **286** | mg/kg | 0.93 | 0.62 | 1 | 11/15/22 10:57 | 11/16/22 12:44 | 7439-96-5 | |
| Molybdenum | **2.5** | mg/kg | 0.93 | 0.055 | 1 | 11/15/22 10:57 | 11/16/22 12:44 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **4.7** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **8.0** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:29 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **33800** | mg/kg | 1990 | 643 | 1 | | 11/16/22 07:46 | 7440-44-0 | |
| Total Organic Carbon | **41900** | mg/kg | 1990 | 643 | 1 | | 11/16/22 07:54 | 7440-44-0 | |
| Total Organic Carbon | **28100** | mg/kg | 2010 | 649 | 1 | | 11/16/22 08:00 | 7440-44-0 | |
| Total Organic Carbon | **31600** | mg/kg | 2020 | 654 | 1 | | 11/16/22 08:07 | 7440-44-0 | |
| Mean Total Organic Carbon | **33900** | mg/kg | 2000 | 647 | 1 | | 11/16/22 07:46 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **17.3** | % | | | 1 | | 11/16/22 07:46 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-110S (52-54)** **Lab ID: 50330483004** Collected: 11/08/22 08:50 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **3.8** | mg/kg | 1.2 | 0.20 | 1 | 11/15/22 10:57 | 11/16/22 12:47 | 7440-38-2 | |
| Iron | **7780** | mg/kg | 58.8 | 14.9 | 1 | 11/15/22 10:57 | 11/16/22 12:47 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.9 | 0.40 | 1 | 11/15/22 10:57 | 11/16/22 12:47 | 7439-93-2 | N2 |
| Manganese | **287** | mg/kg | 1.2 | 0.78 | 1 | 11/15/22 10:57 | 11/16/22 12:47 | 7439-96-5 | |
| Molybdenum | **1.7** | mg/kg | 1.2 | 0.069 | 1 | 11/15/22 10:57 | 11/16/22 12:47 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **15.3** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **8.0** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:30 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **14100** | mg/kg | 1420 | 459 | 1 | | 11/16/22 08:15 | 7440-44-0 | |
| Total Organic Carbon | **15800** | mg/kg | 1450 | 467 | 1 | | 11/16/22 08:22 | 7440-44-0 | |
| Total Organic Carbon | **13000** | mg/kg | 1440 | 465 | 1 | | 11/16/22 08:30 | 7440-44-0 | |
| Total Organic Carbon | **11700** | mg/kg | 1430 | 462 | 1 | | 11/16/22 08:39 | 7440-44-0 | |
| Mean Total Organic Carbon | **13600** | mg/kg | 1430 | 464 | 1 | | 11/16/22 08:15 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **12.7** | % | | | 1 | | 11/16/22 08:15 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-110I (68-70)** **Lab ID: 50330483005** Collected: 11/08/22 08:52 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **2.3** | mg/kg | 1.0 | 0.17 | 1 | 11/15/22 10:57 | 11/16/22 12:50 | 7440-38-2 | |
| Iron | **5500** | mg/kg | 50.3 | 12.8 | 1 | 11/15/22 10:57 | 11/16/22 12:50 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.0 | 0.34 | 1 | 11/15/22 10:57 | 11/16/22 12:50 | 7439-93-2 | N2 |
| Manganese | **101** | mg/kg | 1.0 | 0.67 | 1 | 11/15/22 10:57 | 11/16/22 12:50 | 7439-96-5 | |
| Molybdenum | ND | mg/kg | 1.0 | 0.059 | 1 | 11/15/22 10:57 | 11/16/22 12:50 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **3.4** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **8.0** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:31 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **5520** | mg/kg | 622 | 201 | 1 | | 11/16/22 11:10 | 7440-44-0 | |
| Total Organic Carbon | **5550** | mg/kg | 627 | 203 | 1 | | 11/16/22 11:16 | 7440-44-0 | |
| Total Organic Carbon | **5330** | mg/kg | 624 | 202 | 1 | | 11/16/22 11:23 | 7440-44-0 | |
| Total Organic Carbon | **4880** | mg/kg | 626 | 202 | 1 | | 11/16/22 11:28 | 7440-44-0 | |
| Mean Total Organic Carbon | **5320** | mg/kg | 625 | 202 | 1 | | 11/16/22 11:10 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **5.8** | % | | | 1 | | 11/16/22 11:10 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-110D (96-98)** **Lab ID: 50330483006** Collected: 11/08/22 08:55 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **4.1** | mg/kg | 1.1 | 0.18 | 1 | 11/15/22 10:57 | 11/16/22 12:53 | 7440-38-2 | |
| Iron | **6310** | mg/kg | 54.7 | 13.9 | 1 | 11/15/22 10:57 | 11/16/22 12:53 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.5 | 0.37 | 1 | 11/15/22 10:57 | 11/16/22 12:53 | 7439-93-2 | N2 |
| Manganese | **325** | mg/kg | 1.1 | 0.73 | 1 | 11/15/22 10:57 | 11/16/22 12:53 | 7439-96-5 | |
| Molybdenum | **1.6** | mg/kg | 1.1 | 0.065 | 1 | 11/15/22 10:57 | 11/16/22 12:53 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **10.3** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.9** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:32 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **7670** | mg/kg | 1530 | 494 | 1 | | 11/16/22 09:22 | 7440-44-0 | |
| Total Organic Carbon | **8980** | mg/kg | 1520 | 492 | 1 | | 11/16/22 09:27 | 7440-44-0 | |
| Total Organic Carbon | **7200** | mg/kg | 1530 | 495 | 1 | | 11/16/22 09:34 | 7440-44-0 | |
| Total Organic Carbon | **9420** | mg/kg | 1550 | 501 | 1 | | 11/16/22 09:39 | 7440-44-0 | |
| Mean Total Organic Carbon | **8320** | mg/kg | 1530 | 496 | 1 | | 11/16/22 09:22 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **12.7** | % | | | 1 | | 11/16/22 09:22 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-4I (60-62)** **Lab ID: 50330483007** Collected: 11/08/22 08:58 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **5.3** | mg/kg | 1.0 | 0.17 | 1 | 11/15/22 10:57 | 11/16/22 12:56 | 7440-38-2 | |
| Iron | **6980** | mg/kg | 51.0 | 13.0 | 1 | 11/15/22 10:57 | 11/16/22 12:56 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.1 | 0.35 | 1 | 11/15/22 10:57 | 11/16/22 12:56 | 7439-93-2 | N2 |
| Manganese | **231** | mg/kg | 1.0 | 0.68 | 1 | 11/15/22 10:57 | 11/16/22 12:56 | 7439-96-5 | |
| Molybdenum | **2.4** | mg/kg | 1.0 | 0.060 | 1 | 11/15/22 10:57 | 11/16/22 12:56 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **9.0** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.6** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:35 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **21300** | mg/kg | 2000 | 647 | 1 | | 11/16/22 09:56 | 7440-44-0 | |
| Total Organic Carbon | **36500** | mg/kg | 2010 | 648 | 1 | | 11/16/22 10:03 | 7440-44-0 | |
| Total Organic Carbon | **25000** | mg/kg | 2040 | 660 | 1 | | 11/16/22 10:09 | 7440-44-0 | |
| Total Organic Carbon | **21300** | mg/kg | 2000 | 647 | 1 | | 11/16/22 10:15 | 7440-44-0 | |
| Mean Total Organic Carbon | **26000** | mg/kg | 2010 | 650 | 1 | | 11/16/22 09:56 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **27.8** | % | | | 1 | | 11/16/22 09:56 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: MW-4D (78-80)** **Lab ID: 50330483008** Collected: 11/08/22 09:00 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **4.9** | mg/kg | 1.1 | 0.18 | 1 | 11/15/22 10:57 | 11/16/22 12:59 | 7440-38-2 | |
| Iron | **6610** | mg/kg | 55.0 | 14.0 | 1 | 11/15/22 10:57 | 11/16/22 12:59 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.5 | 0.37 | 1 | 11/15/22 10:57 | 11/16/22 12:59 | 7439-93-2 | N2 |
| Manganese | **216** | mg/kg | 1.1 | 0.73 | 1 | 11/15/22 10:57 | 11/16/22 12:59 | 7439-96-5 | |
| Molybdenum | **3.3** | mg/kg | 1.1 | 0.065 | 1 | 11/15/22 10:57 | 11/16/22 12:59 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **12.5** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.4** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:36 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **3500** | mg/kg | 2340 | 757 | 1 | | 11/16/22 10:22 | 7440-44-0 | |
| Total Organic Carbon | **8140** | mg/kg | 2330 | 755 | 1 | | 11/16/22 10:28 | 7440-44-0 | |
| Total Organic Carbon | **8130** | mg/kg | 2300 | 745 | 1 | | 11/16/22 10:35 | 7440-44-0 | |
| Total Organic Carbon | **4440** | mg/kg | 2310 | 746 | 1 | | 11/16/22 10:41 | 7440-44-0 | |
| Mean Total Organic Carbon | **6050** | mg/kg | 2320 | 751 | 1 | | 11/16/22 10:22 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **40.2** | % | | | 1 | | 11/16/22 10:22 | | 1d |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

**Sample: DUP-1** **Lab ID: 50330483009** Collected: 11/08/22 09:15 Received: 11/08/22 14:35 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **4.3** | mg/kg | 1.2 | 0.19 | 1 | 11/15/22 10:57 | 11/16/22 13:01 | 7440-38-2 | |
| Iron | **8350** | mg/kg | 58.3 | 14.8 | 1 | 11/15/22 10:57 | 11/16/22 13:01 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.8 | 0.40 | 1 | 11/15/22 10:57 | 11/16/22 13:01 | 7439-93-2 | N2 |
| Manganese | **319** | mg/kg | 1.2 | 0.78 | 1 | 11/15/22 10:57 | 11/16/22 13:01 | 7439-96-5 | |
| Molybdenum | **1.8** | mg/kg | 1.2 | 0.069 | 1 | 11/15/22 10:57 | 11/16/22 13:01 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **15.6** | % | 0.10 | 0.10 | 1 | | 11/14/22 18:42 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **8.1** | Std. Units | 0.10 | 0.10 | 1 | | 11/09/22 14:39 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **11500** | mg/kg | 2120 | 686 | 1 | | 11/16/22 10:46 | 7440-44-0 | |
| Total Organic Carbon | **10900** | mg/kg | 2150 | 694 | 1 | | 11/16/22 10:52 | 7440-44-0 | |
| Total Organic Carbon | **9510** | mg/kg | 2130 | 690 | 1 | | 11/16/22 10:59 | 7440-44-0 | |
| Total Organic Carbon | **7480** | mg/kg | 2160 | 697 | 1 | | 11/16/22 11:05 | 7440-44-0 | |
| Mean Total Organic Carbon | **9860** | mg/kg | 2140 | 692 | 1 | | 11/16/22 10:46 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **18.3** | % | | | 1 | | 11/16/22 10:46 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50330483

QC Batch: 705250
QC Batch Method: EPA 3050
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50330483001, 50330483002, 50330483003, 50330483004, 50330483005, 50330483006, 50330483007, 50330483008, 50330483009

METHOD BLANK: 3241948 Matrix: Solid
Associated Lab Samples: 50330483001, 50330483002, 50330483003, 50330483004, 50330483005, 50330483006, 50330483007, 50330483008, 50330483009

| Parameter | Units | Blank Result | Reporting Limit | MDL | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| Arsenic | mg/kg | ND | 1.0 | 0.17 | 11/16/22 09:55 | |
| Iron | mg/kg | ND | 50.0 | 12.7 | 11/16/22 09:55 | |
| Lithium | mg/kg | ND | 5.0 | 0.34 | 11/16/22 09:55 | N2 |
| Manganese | mg/kg | ND | 1.0 | 0.66 | 11/16/22 09:55 | |
| Molybdenum | mg/kg | ND | 1.0 | 0.059 | 11/16/22 09:55 | |

LABORATORY CONTROL SAMPLE: 3241949

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Arsenic | mg/kg | 50 | 51.2 | 102 | 80-120 | |
| Iron | mg/kg | 500 | 528 | 106 | 80-120 | |
| Lithium | mg/kg | 50 | 53.2 | 106 | 80-120 | N2 |
| Manganese | mg/kg | 50 | 52.8 | 106 | 80-120 | |
| Molybdenum | mg/kg | 50 | 54.8 | 110 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3241950 3241951

| Parameter | Units | 50330483002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Arsenic | mg/kg | 3.6 | 51.9 | 51.6 | 57.6 | 56.7 | 104 | 103 | 75-125 | 2 | 20 | |
| Iron | mg/kg | 5320 | 519 | 516 | 6140 | 5590 | 158 | 53 | 75-125 | 9 | 20 | P6 |
| Lithium | mg/kg | ND | 51.9 | 51.6 | 61.2 | 60.3 | 113 | 111 | 75-125 | 1 | 20 | N2 |
| Manganese | mg/kg | 216 | 51.9 | 51.6 | 250 | 248 | 66 | 62 | 75-125 | 1 | 20 | P6 |
| Molybdenum | mg/kg | 1.5 | 51.9 | 51.6 | 53.9 | 53.3 | 101 | 100 | 75-125 | 1 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50330483

QC Batch: 706288
QC Batch Method: SM 2540G
Analysis Method: SM 2540G
Analysis Description: Dry Weight/Percent Moisture
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50330483001, 50330483002, 50330483003, 50330483004, 50330483005, 50330483006, 50330483007, 50330483008, 50330483009

SAMPLE DUPLICATE: 3246910

| Parameter | Units | 50330483002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Percent Moisture | % | 12.1 | 12.3 | 2 | 5 | N2 |

SAMPLE DUPLICATE: 3246967

| Parameter | Units | 50330483003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Percent Moisture | % | 4.7 | 5.5 | 16 | 5 | N2,R1 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50330483

QC Batch: 705205
QC Batch Method: EPA 9045
Analysis Method: EPA 9045
Analysis Description: 9045 pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50330483001, 50330483002, 50330483003, 50330483004, 50330483005, 50330483006, 50330483007, 50330483008, 50330483009

SAMPLE DUPLICATE: 3241730

| Parameter | Units | 50330390001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 6.0 | 6.1 | 1 | 2 | H3 |

SAMPLE DUPLICATE: 3241731

| Parameter | Units | 50330483002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.8 | 2 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50330483

QC Batch: 431472 — Analysis Method: EPA 9060
QC Batch Method: EPA 9060 — Analysis Description: 9060 TOC Average
Laboratory: Pace Analytical Services - Green Bay
Associated Lab Samples: 50330483001, 50330483002, 50330483003, 50330483004, 50330483005, 50330483006, 50330483007, 50330483008, 50330483009

METHOD BLANK: 2484842 — Matrix: Solid
Associated Lab Samples: 50330483001, 50330483002, 50330483003, 50330483004, 50330483005, 50330483006, 50330483007, 50330483008, 50330483009

| Parameter | Units | Blank Result | Reporting Limit | MDL | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | ND | 600 | 194 | 11/16/22 05:26 | |

LABORATORY CONTROL SAMPLE: 2484843

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | 120000 | 120000 | 100 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2484844 2484845

| Parameter | Units | 50330483002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | 9000 | 30100 | 30400 | 43100 | 44900 | 113 | 118 | 50-152 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Ash Pond System
Pace Project No.: 50330483

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| 1d | % RSD > 40 |
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| R1 | RPD value was outside control limits. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50330483001** | **MW-109S (31-33)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483002** | **MW-109I (54-56)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483003** | **MW-109D (82-84)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483004** | **MW-110S (52-54)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483005** | **MW-110I (68-70)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483006** | **MW-110D (96-98)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483007** | **MW-4I (60-62)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483008** | **MW-4D (78-80)** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483009** | **DUP-1** | EPA 3050 | 705250 | EPA 6010 | 706609 |
| **50330483001** | **MW-109S (31-33)** | SM 2540G | 706288 | | |
| **50330483002** | **MW-109I (54-56)** | SM 2540G | 706288 | | |
| **50330483003** | **MW-109D (82-84)** | SM 2540G | 706288 | | |
| **50330483004** | **MW-110S (52-54)** | SM 2540G | 706288 | | |
| **50330483005** | **MW-110I (68-70)** | SM 2540G | 706288 | | |
| **50330483006** | **MW-110D (96-98)** | SM 2540G | 706288 | | |
| **50330483007** | **MW-4I (60-62)** | SM 2540G | 706288 | | |
| **50330483008** | **MW-4D (78-80)** | SM 2540G | 706288 | | |
| **50330483009** | **DUP-1** | SM 2540G | 706288 | | |
| **50330483001** | **MW-109S (31-33)** | EPA 9045 | 705205 | | |
| **50330483002** | **MW-109I (54-56)** | EPA 9045 | 705205 | | |
| **50330483003** | **MW-109D (82-84)** | EPA 9045 | 705205 | | |
| **50330483004** | **MW-110S (52-54)** | EPA 9045 | 705205 | | |
| **50330483005** | **MW-110I (68-70)** | EPA 9045 | 705205 | | |
| **50330483006** | **MW-110D (96-98)** | EPA 9045 | 705205 | | |
| **50330483007** | **MW-4I (60-62)** | EPA 9045 | 705205 | | |
| **50330483008** | **MW-4D (78-80)** | EPA 9045 | 705205 | | |
| **50330483009** | **DUP-1** | EPA 9045 | 705205 | | |
| **50330483001** | **MW-109S (31-33)** | EPA 9060 | 431472 | | |
| **50330483001** | **MW-109S (31-33)** | EPA 9060 | 431473 | | |
| **50330483002** | **MW-109I (54-56)** | EPA 9060 | 431472 | | |
| **50330483002** | **MW-109I (54-56)** | EPA 9060 | 431473 | | |
| **50330483003** | **MW-109D (82-84)** | EPA 9060 | 431472 | | |
| **50330483003** | **MW-109D (82-84)** | EPA 9060 | 431473 | | |
| **50330483004** | **MW-110S (52-54)** | EPA 9060 | 431472 | | |
| **50330483004** | **MW-110S (52-54)** | EPA 9060 | 431473 | | |
| **50330483005** | **MW-110I (68-70)** | EPA 9060 | 431472 | | |
| **50330483005** | **MW-110I (68-70)** | EPA 9060 | 431473 | | |
| **50330483006** | **MW-110D (96-98)** | EPA 9060 | 431472 | | |
| **50330483006** | **MW-110D (96-98)** | EPA 9060 | 431473 | | |
| **50330483007** | **MW-4I (60-62)** | EPA 9060 | 431472 | | |
| **50330483007** | **MW-4I (60-62)** | EPA 9060 | 431473 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Ash Pond System
Pace Project No.: 50330483

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50330483008** | **MW-4D (78-80)** | EPA 9060 | 431472 | | |
| **50330483008** | **MW-4D (78-80)** | EPA 9060 | 431473 | | |
| **50330483009** | **DUP-1** | EPA 9060 | 431472 | | |
| **50330483009** | **DUP-1** | EPA 9060 | 431473 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

# CHAIN-OF-CUSTODY / Analytical Request D

(2)

**WO# : 50330483**

50330483

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields mu

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at https://info.pac

| Section A<br>Required Client Information: | Section B<br>Required Project Information: | Section C<br>Invoice Information: | |
|---|---|---|---|
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam | |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: Atlas Indianapolis | Regulatory Agency |
| Suite 100, Indianapolis, IN 46256 | | Address: | |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: | |
| Phone: 317-313-8306 Fax: | Project Name: Harding St Ash Pond System | Pace Project Manager: hayden.putt@pacelabs.com, | State / Location |
| Requested Due Date: | Project #: | Pace Profile #: 10498/34 | IN |

| ITEM # | SAMPLE ID<br>One Character per box.<br>(A-Z, 0-9 / , -)<br>Sample Ids must be unique | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH | Na2S2O3 | Methanol | Other | Analyses Test Y/N | As, Mo, Mn, Fe, Li by 6010 | pH by 9045 | TOC by 9060 to Pace GB | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | MW-109S (~~30-32~~) (31-33) | SL | | | | 11/8/22 | ~~936~~ 836 | | 2 | 2 | | | | | | | | | X | X | X | | 001 |
| 2 | MW-109I (54-56) MS/MSD | | | | | | 905 | | 6 | 6 | | | | | | | | | X | X | X | | 002 |
| 3 | MW-109D (~~84~~ 82-84) | | | | | | 847 | | 2 | 2 | | | | | | | | | X | X | X | | 003 |
| 4 | MW-110S (52-54) | | | | | | 850 | | 2 | 2 | | | | | | | | | X | X | X | | 004 |
| 5 | MW-110I (68-70) | | | | | | 852 | | 2 | 2 | | | | | | | | | X | X | X | | 005 |
| 6 | MW-110D (96-98) | | | | | | 855 | | 2 | 2 | | | | | | | | | X | X | X | | 006 |
| 7 | MW-4I (60-62) | | | | | | 858 | | 2 | 2 | | | | | | | | | X | X | X | | 007 |
| 8 | MW-4D (78-80) | | | | | | 900 | | 2 | 2 | | | | | | | | | X | X | X | | 008 |
| 9 | DUP-1 | ↓ | | | | ↓ | 915 | | 2 | 2 | | | | | | | | | X | X | X | | 009 |
| 10 | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | |

MATRIX CODE: Drinking Water DW; Water WT; Waste Water WW; Product P; Soil/Solid SL; Oil OL; Wipe WP; Air AR; Other OT; Tissue TS

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS |
|---|---|---|---|---|---|---|---|
| | Kendra Reininga | 11/8/22 | 935 | | 11/8/22 | 1355 | |
| | | 11/8/22 | 1435 | | 11/8/22 | 1435 | 2.8 Y N Y |
| | | | | | | | |
| | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Kendra Reininga

SIGNATURE of SAMPLER: Kendra Reininga DATE Signed: 11/8/22

TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N)

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** MR 11/8/22 1615

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E F

4. **Cooler Temperature(s):** 2.8/2.8 | | | |
**(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)

5. **Packing Material:** ☐ Bubble Wrap ☐ Bubble Bags ☑ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | | | ✓ |
| **Short Hold Time Analysis (48 hours or less)? Analysis:** | | ✓ | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | | | Present | Absent | N/A ✓ |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | ✓ | |

COMMENTS:

**COC PAGE ____ of ____**

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| COC Line Item | WGFU | MeOH (only) / SBS / DI / R | VIALS: DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AMBER GLASS: AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | PLASTIC: BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | OTHER: CG3H | CG3F | Syringe Kit | | Matrix |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | SC |
| 2 | 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| Nitric | Sulfuric | Sodium Hydroxide | Sodium Hydroxide/ ZnAc |
|---|---|---|---|
| Red | Yellow | Green | Black |
| HNO3 <2 | H2SO4 <2 | NaOH >10 | NaOH/Zn Ac >9 |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| CG3F | 250mL clear glass HCl, Field Filter | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1H | 1L HCl clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| BG1S | 1L H2SO4 clear glass | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

### Miscellaneous

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |
| ZPLC | Ziploc Bag |
| R | Terracore Kit |
| SP5T | 120mL Coliform Sodium Thiosulfate |
| GN | General Container |
| U | Summa Can (air sample) |
| WT | Water |
| SL | Solid Solid |
| OL: | Oil |
| NAL | Non-aqueous liquid |
| WP | Wipe |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

December 05, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Ash Pond System
Pace Project No.: 50332045

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on November 28, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Green Bay
- Pace Analytical Services - Indianapolis

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Ash Pond System
Pace Project No.: 50332045

**Pace Analytical Services Green Bay**

1241 Bellevue Street, Green Bay, WI 54302
Florida/NELAP Certification #: E87948
Illinois Certification #: 200050
Kentucky UST Certification #: 82
Louisiana Certification #: 04168
Minnesota Certification #: 055-999-334
New York Certification #: 12064
North Dakota Certification #: R-150
South Carolina Certification #: 83006001
Texas Certification #: T104704529-21-8
Virginia VELAP Certification ID: 11873
Wisconsin Certification #: 405132750
Wisconsin DATCP Certification #: 105-444
USDA Soil Permit #: P330-21-00008
Federal Fish & Wildlife Permit #: 51774A

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Ash Pond System
Pace Project No.: 50332045

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50332045001** | **MW-6I (62-64)** | Solid | 11/23/22 12:43 | 11/28/22 15:10 |
| **50332045002** | **MW-12D1 (78-80)** | Solid | 11/23/22 13:02 | 11/28/22 15:10 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Ash Pond System
Pace Project No.: 50332045

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50332045001** | **MW-6I (62-64)** | EPA 6010 | RAM | 5 | PASI-I |
| | | SM 2540G | MMS | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50332045002** | **MW-12D1 (78-80)** | EPA 6010 | RAM | 5 | PASI-I |
| | | SM 2540G | MMS | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |

PASI-G = Pace Analytical Services - Green Bay
PASI-I = Pace Analytical Services - Indianapolis



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Ash Pond System
Pace Project No.: 50332045

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50332045001** | **MW-6I (62-64)** | | | | | |
| EPA 6010 | Arsenic | 7.7 | mg/kg | 1.1 | 12/05/22 12:04 | |
| EPA 6010 | Iron | 12800 | mg/kg | 53.9 | 12/05/22 12:04 | |
| EPA 6010 | Lithium | 14.8 | mg/kg | 5.4 | 12/05/22 12:04 | N2 |
| EPA 6010 | Manganese | 342 | mg/kg | 1.1 | 12/05/22 12:04 | |
| EPA 6010 | Molybdenum | 4.3 | mg/kg | 1.1 | 12/05/22 12:04 | |
| SM 2540G | Percent Moisture | 14.0 | % | 0.10 | 12/02/22 22:12 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.1 | Std. Units | 0.10 | 11/29/22 13:41 | H3 |
| EPA 9060 | Total Organic Carbon | 30700 | mg/kg | 1590 | 12/02/22 06:42 | |
| EPA 9060 | Total Organic Carbon | 27500 | mg/kg | 1620 | 12/02/22 06:48 | |
| EPA 9060 | Total Organic Carbon | 31600 | mg/kg | 1610 | 12/02/22 06:54 | |
| EPA 9060 | Total Organic Carbon | 26500 | mg/kg | 1620 | 12/02/22 07:00 | |
| EPA 9060 | Mean Total Organic Carbon | 29100 | mg/kg | 1610 | 12/02/22 06:42 | |
| EPA 9060 | RSD% | 8.4 | % | | 12/02/22 06:42 | |
| **50332045002** | **MW-12D1 (78-80)** | | | | | |
| EPA 6010 | Arsenic | 3.3 | mg/kg | 1.2 | 12/05/22 12:07 | |
| EPA 6010 | Iron | 4660 | mg/kg | 61.4 | 12/05/22 12:07 | |
| EPA 6010 | Manganese | 36.6 | mg/kg | 1.2 | 12/05/22 12:07 | |
| SM 2540G | Percent Moisture | 23.3 | % | 0.10 | 12/02/22 22:12 | N2 |
| EPA 9045 | pH at 25 Degrees C | 6.4 | Std. Units | 0.10 | 11/29/22 13:42 | H3 |
| EPA 9060 | Total Organic Carbon | 36800 | mg/kg | 2860 | 12/02/22 07:05 | |
| EPA 9060 | Total Organic Carbon | 40200 | mg/kg | 2810 | 12/02/22 07:11 | |
| EPA 9060 | Total Organic Carbon | 41800 | mg/kg | 2870 | 12/02/22 07:17 | |
| EPA 9060 | Total Organic Carbon | 36200 | mg/kg | 2820 | 12/02/22 07:22 | |
| EPA 9060 | Mean Total Organic Carbon | 38800 | mg/kg | 2840 | 12/02/22 07:05 | |
| EPA 9060 | RSD% | 7.0 | % | | 12/02/22 07:05 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50332045

**Sample: MW-6I (62-64)** **Lab ID: 50332045001** Collected: 11/23/22 12:43 Received: 11/28/22 15:10 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **7.7** | mg/kg | 1.1 | 0.18 | 1 | 12/02/22 09:01 | 12/05/22 12:04 | 7440-38-2 | |
| Iron | **12800** | mg/kg | 53.9 | 13.7 | 1 | 12/02/22 09:01 | 12/05/22 12:04 | 7439-89-6 | |
| Lithium | **14.8** | mg/kg | 5.4 | 0.37 | 1 | 12/02/22 09:01 | 12/05/22 12:04 | 7439-93-2 | N2 |
| Manganese | **342** | mg/kg | 1.1 | 0.72 | 1 | 12/02/22 09:01 | 12/05/22 12:04 | 7439-96-5 | |
| Molybdenum | **4.3** | mg/kg | 1.1 | 0.064 | 1 | 12/02/22 09:01 | 12/05/22 12:04 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **14.0** | % | 0.10 | 0.10 | 1 | | 12/02/22 22:12 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.1** | Std. Units | 0.10 | 0.10 | 1 | | 11/29/22 13:41 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **30700** | mg/kg | 1590 | 514 | 1 | | 12/02/22 06:42 | 7440-44-0 | |
| Total Organic Carbon | **27500** | mg/kg | 1620 | 524 | 1 | | 12/02/22 06:48 | 7440-44-0 | |
| Total Organic Carbon | **31600** | mg/kg | 1610 | 522 | 1 | | 12/02/22 06:54 | 7440-44-0 | |
| Total Organic Carbon | **26500** | mg/kg | 1620 | 524 | 1 | | 12/02/22 07:00 | 7440-44-0 | |
| Mean Total Organic Carbon | **29100** | mg/kg | 1610 | 521 | 1 | | 12/02/22 06:42 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **8.4** | % | | | 1 | | 12/02/22 06:42 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50332045

**Sample: MW-12D1 (78-80)** **Lab ID: 50332045002** Collected: 11/23/22 13:02 Received: 11/28/22 15:10 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **3.3** | mg/kg | 1.2 | 0.20 | 1 | 12/02/22 09:01 | 12/05/22 12:07 | 7440-38-2 | |
| Iron | **4660** | mg/kg | 61.4 | 15.6 | 1 | 12/02/22 09:01 | 12/05/22 12:07 | 7439-89-6 | |
| Lithium | ND | mg/kg | 6.1 | 0.42 | 1 | 12/02/22 09:01 | 12/05/22 12:07 | 7439-93-2 | N2 |
| Manganese | **36.6** | mg/kg | 1.2 | 0.82 | 1 | 12/02/22 09:01 | 12/05/22 12:07 | 7439-96-5 | |
| Molybdenum | ND | mg/kg | 1.2 | 0.072 | 1 | 12/02/22 09:01 | 12/05/22 12:07 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **23.3** | % | 0.10 | 0.10 | 1 | | 12/02/22 22:12 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **6.4** | Std. Units | 0.10 | 0.10 | 1 | | 11/29/22 13:42 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **36800** | mg/kg | 2860 | 924 | 1 | | 12/02/22 07:05 | 7440-44-0 | |
| Total Organic Carbon | **40200** | mg/kg | 2810 | 908 | 1 | | 12/02/22 07:11 | 7440-44-0 | |
| Total Organic Carbon | **41800** | mg/kg | 2870 | 928 | 1 | | 12/02/22 07:17 | 7440-44-0 | |
| Total Organic Carbon | **36200** | mg/kg | 2820 | 913 | 1 | | 12/02/22 07:22 | 7440-44-0 | |
| Mean Total Organic Carbon | **38800** | mg/kg | 2840 | 918 | 1 | | 12/02/22 07:05 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **7.0** | % | | | 1 | | 12/02/22 07:05 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332045

QC Batch: 708363
QC Batch Method: EPA 3050
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50332045001, 50332045002

METHOD BLANK: 3255953 Matrix: Solid
Associated Lab Samples: 50332045001, 50332045002

| Parameter | Units | Blank Result | Reporting Limit | MDL | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| Arsenic | mg/kg | ND | 1.0 | 0.17 | 12/05/22 10:41 | |
| Iron | mg/kg | ND | 50.0 | 12.7 | 12/05/22 10:41 | |
| Lithium | mg/kg | ND | 5.0 | 0.34 | 12/05/22 10:41 | N2 |
| Manganese | mg/kg | ND | 1.0 | 0.66 | 12/05/22 10:41 | |
| Molybdenum | mg/kg | ND | 1.0 | 0.059 | 12/05/22 10:41 | |

LABORATORY CONTROL SAMPLE: 3255954

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Arsenic | mg/kg | 50 | 54.5 | 109 | 80-120 | |
| Iron | mg/kg | 500 | 528 | 106 | 80-120 | |
| Lithium | mg/kg | 50 | 51.4 | 103 | 80-120 | N2 |
| Manganese | mg/kg | 50 | 52.6 | 105 | 80-120 | |
| Molybdenum | mg/kg | 50 | 56.6 | 113 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3255955 3255956

| Parameter | Units | 50331598002 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Arsenic | mg/kg | 5.4 | 46.1 | 48.3 | 53.0 | 54.5 | 103 | 101 | 75-125 | 3 | 20 | |
| Iron | mg/kg | 11400 | 461 | 483 | 12600 | 11900 | 257 | 91 | 75-125 | 6 | 20 | P6 |
| Lithium | mg/kg | 12.9 | 46.1 | 48.3 | 59.0 | 60.0 | 100 | 97 | 75-125 | 2 | 20 | N2 |
| Manganese | mg/kg | 253 | 46.1 | 48.3 | 374 | 352 | 264 | 205 | 75-125 | 6 | 20 | P6 |
| Molybdenum | mg/kg | 1.5 | 46.1 | 48.3 | 44.2 | 45.3 | 93 | 90 | 75-125 | 2 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332045

QC Batch: 709301
QC Batch Method: SM 2540G
Analysis Method: SM 2540G
Analysis Description: Dry Weight/Percent Moisture
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50332045001, 50332045002

SAMPLE DUPLICATE: 3259729

| Parameter | Units | 50332045002 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Percent Moisture | % | 23.3 | 24.8 | 6 | 5 | N2,R1 |

SAMPLE DUPLICATE: 3259730

| Parameter | Units | 50332260005 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Percent Moisture | % | 10.9 | 10.3 | 6 | 5 | N2,R1 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332045

QC Batch: 708622
QC Batch Method: EPA 9045
Analysis Method: EPA 9045
Analysis Description: 9045 pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50332045001, 50332045002

SAMPLE DUPLICATE: 3256824

| Parameter | Units | 50332016001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.8 | 7.8 | 0 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332045

QC Batch: 432704
QC Batch Method: EPA 9060
Analysis Method: EPA 9060
Analysis Description: 9060 TOC Average
Laboratory: Pace Analytical Services - Green Bay
Associated Lab Samples: 50332045001, 50332045002

METHOD BLANK: 2490951 Matrix: Solid
Associated Lab Samples: 50332045001, 50332045002

| Parameter | Units | Blank Result | Reporting Limit | MDL | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | ND | 600 | 194 | 12/02/22 04:25 | |

LABORATORY CONTROL SAMPLE: 2490952

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | 120000 | 114000 | 95 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2490953 2490954

| Parameter | Units | 92636709001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | 3840 | 7990 | 7990 | 10200 | 10200 | 79 | 80 | 50-152 | 0 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Ash Pond System
Pace Project No.: 50332045

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| R1 | RPD value was outside control limits. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Ash Pond System
Pace Project No.: 50332045

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50332045001** | **MW-6I (62-64)** | EPA 3050 | 708363 | EPA 6010 | 709478 |
| **50332045002** | **MW-12D1 (78-80)** | EPA 3050 | 708363 | EPA 6010 | 709478 |
| **50332045001** | **MW-6I (62-64)** | SM 2540G | 709301 | | |
| **50332045002** | **MW-12D1 (78-80)** | SM 2540G | 709301 | | |
| **50332045001** | **MW-6I (62-64)** | EPA 9045 | 708622 | | |
| **50332045002** | **MW-12D1 (78-80)** | EPA 9045 | 708622 | | |
| **50332045001** | **MW-6I (62-64)** | EPA 9060 | 432704 | | |
| **50332045001** | **MW-6I (62-64)** | EPA 9060 | 432705 | | |
| **50332045002** | **MW-12D1 (78-80)** | EPA 9060 | 432704 | | |
| **50332045002** | **MW-12D1 (78-80)** | EPA 9060 | 432705 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50332045

50332045

# CHAIN-OF-CUSTODY / Analytical R

The Chain-of-Custody is a LEGAL DOCUMENT. All rele

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found a

| Section A<br>Required Client Information: | Section B<br>Required Project Information: | Section C<br>Invoice Information: |
|---|---|---|
| Company: Atlas Indianapolis | Report To: Mark Breting | Attention: Accounts Payable - Paula Sedam |
| Address: 7988 Centerpoint Drive | Copy To: | Company Name: Atlas Indianapolis |
| Suite 100, Indianapolis, IN 46256 | | Address: |
| Email: mark.breting@oneatlas.com | Purchase Order #: | Pace Quote: |
| Phone: 317-313-8306 Fax: | Project Name: Harding St Ash Pond System | Pace Project Manager: hayden.putt@pacelabs.com, |
| Requested Due Date: | Project #: | Pace Profile #: 10498/34 |

| Regulatory Agency |
|---|
| |
| **State / Location** |
| IN |

| ITEM # | SAMPLE ID<br>One Character per box.<br>(A-Z, 0-9 / , -)<br>Sample Ids must be unique | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH | Na2S2O3 | Methanol | Other | Y/N | Analyses Test: As, Mo, Mn, Fe, Li by 6010 | pH by 9045 | TOC by 9060 to Pace GB | Residual Chlorine (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | MW-6I (62-64) | | | | | 11-23-22 | 1243 | | 2 | 2 | | | | | | | | | X | X | X | |
| 2 | MW-12D1 (78-80) | | | | | 11-23-22 | 1302 | | 2 | 2 | | | | | | | | | X | X | X | |
| 3 | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS: TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|---|---|---|---|---|---|---|
| | | 11/28 | 1445 | | 11/28/22 | 1445 | | | | |
| | | 11/28/22 | 1510 | | 11/28/22 | 1510 | 1.2 | Y | N | Y |
| | | | | | | | | | | |
| | | | | | | | | | | |

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Colton Palmer

SIGNATURE of SAMPLER: Colton Palmer

DATE Signed: 11-23-22

Pace

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** DD 11/28/22 2046

1. **Courier:** ☐ FED EX ☐ UPS ☐ CLIENT ☑ PACE ☐ USPS ☐ OTHER _____

2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No

**(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**

3. **Thermometer:** 1 2 3 4 5 6 A B C D E (F)

4. **Cooler Temperature(s):** 1.2/1.2 | | | |

**(Initial/Corrected)** **RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)**

5. **Packing Material:** ☑ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____

6. **Ice Type:** ☑ Wet ☐ Blue ☐ None

7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No

Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle:** **HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | | | |
| **Short Hold Time Analysis (48 hours or less)? Analysis:** | | ✓ | | | | ✓ |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | | | Present | Absent | N/A |
| | | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | | | ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | ✓ | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | | ✓ |

COMMENTS:

**COC PAGE ____ of ____**

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| | | VIALS | | | | | | AMBER GLASS | | | | | | | PLASTIC | | | | | | | | | OTHER | | | | | Nitric | Sulfuric | Sodium Hydroxide | Sodium Hydroxide/ ZnAc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | MeOH (only) | SBS | DI | | | | | | | | | | | | | | | | | | | | | | | | | Red | Yellow | Green | Black |
| COC Line Item | WGFU | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | CG3F | Syringe Kit | | Matrix | HNO3 <2 | H2SO4 <2 | NaOH >10 | NaOH/Zn Ac >9 |
| 1 | / | | | | | | | / | | | | | | | | | | | | | | | | | | | | SL | | | | |
| 2 | / | | | | | | | / | | | | | | | | | | | | | | | | | | | | SL | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| CG3F | 250mL clear glass HCl, Field Filter | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1H | 1L HCl clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| BG1S | 1L H2SO4 clear glass | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

### Miscellaneous

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |
| ZPLC | Ziploc Bag |
| R | Terracore Kit |
| SP5T | 120mL Coliform Sodium Thiosulfate |
| GN | General Container |
| U | Summa Can (air sample) |
| WT | Water |
| SL | Solid Solid |
| OL: | Oil |
| NAL | Non-aqueous liquid |
| WP | Wipe |

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

December 15, 2022

Mr. Mark Breting
ATC Group Services
7988 Centerpoint Drive
Suite 100
Indianapolis, IN 46256

RE: Project: Harding St Ash Pond System
Pace Project No.: 50332961

Dear Mr. Breting:

Enclosed are the analytical results for sample(s) received by the laboratory on December 08, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Green Bay
- Pace Analytical Services - Indianapolis

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Hayden Putt
hayden.putt@pacelabs.com
(317)228-3145
Project Manager

Enclosures

cc: Mr. Robert Miller, Haley & Aldrich



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# CERTIFICATIONS

Project: Harding St Ash Pond System
Pace Project No.: 50332961

**Pace Analytical Services Green Bay**

1241 Bellevue Street, Green Bay, WI 54302
Florida/NELAP Certification #: E87948
Illinois Certification #: 200050
Kentucky UST Certification #: 82
Louisiana Certification #: 04168
Minnesota Certification #: 055-999-334
New York Certification #: 12064
North Dakota Certification #: R-150
South Carolina Certification #: 83006001
Texas Certification #: T104704529-21-8
Virginia VELAP Certification ID: 11873
Wisconsin Certification #: 405132750
Wisconsin DATCP Certification #: 105-444
USDA Soil Permit #: P330-21-00008
Federal Fish & Wildlife Permit #: 51774A

**Pace Analytical Services Indianapolis**

7726 Moller Road, Indianapolis, IN 46268
Illinois Accreditation #: 200074
Indiana Drinking Water Laboratory #: C-49-06
Kansas/TNI Certification #: E-10177
Kentucky UST Agency Interest #: 80226
Kentucky WW Laboratory ID #: 98019
Michigan Drinking Water Laboratory #9050
Ohio VAP Certified Laboratory #: CL0065
Oklahoma Laboratory #: 9204
Texas Certification #: T104704355
Wisconsin Laboratory #: 999788130
USDA Soil Permit #: P330-19-00257



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE SUMMARY

Project: Harding St Ash Pond System
Pace Project No.: 50332961

| Lab ID | Sample ID | Matrix | Date Collected | Date Received |
|---|---|---|---|---|
| **50332961001** | **MW-2D1 (77-79)** | Solid | 12/08/22 13:13 | 12/08/22 16:15 |
| **50332961002** | **MW-45R (34-36)** | Solid | 12/08/22 13:54 | 12/08/22 16:15 |
| **50332961003** | **MW-5D (74-76)** | Solid | 12/08/22 13:21 | 12/08/22 16:15 |
| **50332961004** | **MW-8D0 (34-36)** | Solid | 12/08/22 13:39 | 12/08/22 16:15 |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SAMPLE ANALYTE COUNT

Project: Harding St Ash Pond System
Pace Project No.: 50332961

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|---|---|---|---|---|---|
| **50332961001** | **MW-2D1 (77-79)** | EPA 6010 | MTM | 5 | PASI-I |
| | | SM 2540G | IRH | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50332961002** | **MW-45R (34-36)** | EPA 6010 | MTM | 5 | PASI-I |
| | | SM 2540G | IRH | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50332961003** | **MW-5D (74-76)** | EPA 6010 | MTM | 5 | PASI-I |
| | | SM 2540G | IRH | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |
| **50332961004** | **MW-8D0 (34-36)** | EPA 6010 | MTM | 5 | PASI-I |
| | | SM 2540G | IRH | 1 | PASI-I |
| | | EPA 9045 | TRK | 1 | PASI-I |
| | | EPA 9060 | TJJ | 6 | PASI-G |

PASI-G = Pace Analytical Services - Green Bay
PASI-I = Pace Analytical Services - Indianapolis



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Ash Pond System
Pace Project No.: 50332961

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50332961001** | **MW-2D1 (77-79)** | | | | | |
| EPA 6010 | Arsenic | 6.2 | mg/kg | 0.96 | 12/14/22 10:23 | |
| EPA 6010 | Iron | 8960 | mg/kg | 48.2 | 12/13/22 14:47 | |
| EPA 6010 | Lithium | 7.7 | mg/kg | 4.8 | 12/13/22 14:47 | N2 |
| EPA 6010 | Manganese | 73.2 | mg/kg | 0.96 | 12/13/22 14:47 | |
| EPA 6010 | Molybdenum | 2.4 | mg/kg | 0.96 | 12/13/22 14:47 | |
| SM 2540G | Percent Moisture | 12.8 | % | 0.10 | 12/09/22 19:28 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.8 | Std. Units | 0.10 | 12/09/22 19:05 | H3 |
| EPA 9060 | Total Organic Carbon | 9360 | mg/kg | 1550 | 12/14/22 07:07 | |
| EPA 9060 | Total Organic Carbon | 13300 | mg/kg | 1540 | 12/14/22 07:12 | |
| EPA 9060 | Total Organic Carbon | 10100 | mg/kg | 1540 | 12/14/22 07:18 | |
| EPA 9060 | Total Organic Carbon | 19300 | mg/kg | 1550 | 12/14/22 07:23 | |
| EPA 9060 | Mean Total Organic Carbon | 13000 | mg/kg | 1540 | 12/14/22 07:07 | |
| EPA 9060 | RSD% | 34.9 | % | | 12/14/22 07:07 | |
| **50332961002** | **MW-45R (34-36)** | | | | | |
| EPA 6010 | Arsenic | 2.4 | mg/kg | 1.0 | 12/14/22 10:25 | |
| EPA 6010 | Iron | 5610 | mg/kg | 49.8 | 12/13/22 14:49 | |
| EPA 6010 | Lithium | 5.6 | mg/kg | 5.0 | 12/13/22 14:49 | N2 |
| EPA 6010 | Manganese | 165 | mg/kg | 1.0 | 12/13/22 14:49 | |
| SM 2540G | Percent Moisture | 6.7 | % | 0.10 | 12/09/22 19:28 | N2 |
| EPA 9045 | pH at 25 Degrees C | 8.2 | Std. Units | 0.10 | 12/09/22 19:09 | H3 |
| EPA 9060 | Total Organic Carbon | 33400 | mg/kg | 3670 | 12/15/22 03:18 | |
| EPA 9060 | Total Organic Carbon | 36000 | mg/kg | 3630 | 12/15/22 03:23 | |
| EPA 9060 | Total Organic Carbon | 37100 | mg/kg | 3700 | 12/15/22 03:29 | |
| EPA 9060 | Total Organic Carbon | 35400 | mg/kg | 3680 | 12/15/22 03:34 | |
| EPA 9060 | Mean Total Organic Carbon | 35400 | mg/kg | 3670 | 12/15/22 03:18 | |
| EPA 9060 | RSD% | 4.4 | % | | 12/15/22 03:18 | |
| **50332961003** | **MW-5D (74-76)** | | | | | |
| EPA 6010 | Arsenic | 1.9 | mg/kg | 1.1 | 12/14/22 10:28 | |
| EPA 6010 | Iron | 10100 | mg/kg | 55.1 | 12/13/22 14:52 | |
| EPA 6010 | Manganese | 56.8 | mg/kg | 1.1 | 12/13/22 14:52 | |
| EPA 6010 | Molybdenum | 1.5 | mg/kg | 1.1 | 12/13/22 14:52 | |
| SM 2540G | Percent Moisture | 16.3 | % | 0.10 | 12/09/22 19:28 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 12/09/22 19:06 | H3 |
| EPA 9060 | RSD% | 11.9 | % | | 12/14/22 07:53 | |
| **50332961004** | **MW-8D0 (34-36)** | | | | | |
| EPA 6010 | Arsenic | 12.8 | mg/kg | 1.0 | 12/14/22 10:34 | |
| EPA 6010 | Iron | 14200 | mg/kg | 51.3 | 12/13/22 15:07 | |
| EPA 6010 | Lithium | 7.8 | mg/kg | 5.1 | 12/13/22 15:07 | N2 |
| EPA 6010 | Manganese | 346 | mg/kg | 1.0 | 12/13/22 15:07 | |
| EPA 6010 | Molybdenum | 2.6 | mg/kg | 1.0 | 12/13/22 15:07 | |
| SM 2540G | Percent Moisture | 14.2 | % | 0.10 | 12/09/22 19:28 | N2 |
| EPA 9045 | pH at 25 Degrees C | 7.7 | Std. Units | 0.10 | 12/09/22 19:08 | H3 |
| EPA 9060 | Total Organic Carbon | 888 | mg/kg | 699 | 12/14/22 09:00 | |
| EPA 9060 | Total Organic Carbon | 988 | mg/kg | 697 | 12/14/22 09:06 | |
| EPA 9060 | Total Organic Carbon | 959 | mg/kg | 694 | 12/14/22 09:12 | |
| EPA 9060 | Total Organic Carbon | 922 | mg/kg | 693 | 12/14/22 09:18 | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## SUMMARY OF DETECTION

Project: Harding St Ash Pond System
Pace Project No.: 50332961

| Lab Sample ID / Method | Client Sample ID / Parameters | Result | Units | Report Limit | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| **50332961004** | **MW-8D0 (34-36)** | | | | | |
| EPA 9060 | Mean Total Organic Carbon | 939 | mg/kg | 696 | 12/14/22 09:00 | |
| EPA 9060 | RSD% | 4.6 | % | | 12/14/22 09:00 | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50332961

**Sample: MW-2D1 (77-79)** **Lab ID: 50332961001** Collected: 12/08/22 13:13 Received: 12/08/22 16:15 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **6.2** | mg/kg | 0.96 | 0.16 | 1 | 12/13/22 08:59 | 12/14/22 10:23 | 7440-38-2 | |
| Iron | **8960** | mg/kg | 48.2 | 12.3 | 1 | 12/13/22 08:59 | 12/13/22 14:47 | 7439-89-6 | |
| Lithium | **7.7** | mg/kg | 4.8 | 0.20 | 1 | 12/13/22 08:59 | 12/13/22 14:47 | 7439-93-2 | N2 |
| Manganese | **73.2** | mg/kg | 0.96 | 0.50 | 1 | 12/13/22 08:59 | 12/13/22 14:47 | 7439-96-5 | |
| Molybdenum | **2.4** | mg/kg | 0.96 | 0.072 | 1 | 12/13/22 08:59 | 12/13/22 14:47 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **12.8** | % | 0.10 | 0.10 | 1 | | 12/09/22 19:28 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.8** | Std. Units | 0.10 | 0.10 | 1 | | 12/09/22 19:05 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **9360** | mg/kg | 1550 | 500 | 1 | | 12/14/22 07:07 | 7440-44-0 | |
| Total Organic Carbon | **13300** | mg/kg | 1540 | 498 | 1 | | 12/14/22 07:12 | 7440-44-0 | |
| Total Organic Carbon | **10100** | mg/kg | 1540 | 497 | 1 | | 12/14/22 07:18 | 7440-44-0 | |
| Total Organic Carbon | **19300** | mg/kg | 1550 | 500 | 1 | | 12/14/22 07:23 | 7440-44-0 | |
| Mean Total Organic Carbon | **13000** | mg/kg | 1540 | 499 | 1 | | 12/14/22 07:07 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **34.9** | % | | | 1 | | 12/14/22 07:07 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50332961

**Sample: MW-45R (34-36)** **Lab ID: 50332961002** Collected: 12/08/22 13:54 Received: 12/08/22 16:15 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **2.4** | mg/kg | 1.0 | 0.17 | 1 | 12/13/22 08:59 | 12/14/22 10:25 | 7440-38-2 | |
| Iron | **5610** | mg/kg | 49.8 | 12.7 | 1 | 12/13/22 08:59 | 12/13/22 14:49 | 7439-89-6 | |
| Lithium | **5.6** | mg/kg | 5.0 | 0.21 | 1 | 12/13/22 08:59 | 12/13/22 14:49 | 7439-93-2 | N2 |
| Manganese | **165** | mg/kg | 1.0 | 0.51 | 1 | 12/13/22 08:59 | 12/13/22 14:49 | 7439-96-5 | |
| Molybdenum | ND | mg/kg | 1.0 | 0.075 | 1 | 12/13/22 08:59 | 12/13/22 14:49 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **6.7** | % | 0.10 | 0.10 | 1 | | 12/09/22 19:28 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **8.2** | Std. Units | 0.10 | 0.10 | 1 | | 12/09/22 19:09 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **33400** | mg/kg | 3670 | 1190 | 1 | | 12/15/22 03:18 | 7440-44-0 | |
| Total Organic Carbon | **36000** | mg/kg | 3630 | 1170 | 1 | | 12/15/22 03:23 | 7440-44-0 | |
| Total Organic Carbon | **37100** | mg/kg | 3700 | 1200 | 1 | | 12/15/22 03:29 | 7440-44-0 | |
| Total Organic Carbon | **35400** | mg/kg | 3680 | 1190 | 1 | | 12/15/22 03:34 | 7440-44-0 | |
| Mean Total Organic Carbon | **35400** | mg/kg | 3670 | 1190 | 1 | | 12/15/22 03:18 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **4.4** | % | | | 1 | | 12/15/22 03:18 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50332961

**Sample: MW-5D (74-76)** **Lab ID: 50332961003** Collected: 12/08/22 13:21 Received: 12/08/22 16:15 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **1.9** | mg/kg | 1.1 | 0.19 | 1 | 12/13/22 08:59 | 12/14/22 10:28 | 7440-38-2 | |
| Iron | **10100** | mg/kg | 55.1 | 14.1 | 1 | 12/13/22 08:59 | 12/13/22 14:52 | 7439-89-6 | |
| Lithium | ND | mg/kg | 5.5 | 0.23 | 1 | 12/13/22 08:59 | 12/13/22 14:52 | 7439-93-2 | N2 |
| Manganese | **56.8** | mg/kg | 1.1 | 0.57 | 1 | 12/13/22 08:59 | 12/13/22 14:52 | 7439-96-5 | |
| Molybdenum | **1.5** | mg/kg | 1.1 | 0.083 | 1 | 12/13/22 08:59 | 12/13/22 14:52 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **16.3** | % | 0.10 | 0.10 | 1 | | 12/09/22 19:28 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 0.10 | 1 | | 12/09/22 19:06 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | ND | mg/kg | 723 | 234 | 1 | | 12/14/22 07:53 | 7440-44-0 | |
| Total Organic Carbon | ND | mg/kg | 722 | 233 | 1 | | 12/14/22 07:59 | 7440-44-0 | |
| Total Organic Carbon | ND | mg/kg | 718 | 232 | 1 | | 12/14/22 08:04 | 7440-44-0 | |
| Total Organic Carbon | ND | mg/kg | 719 | 233 | 1 | | 12/14/22 08:09 | 7440-44-0 | |
| Mean Total Organic Carbon | ND | mg/kg | 721 | 233 | 1 | | 12/14/22 07:53 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **11.9** | % | | | 1 | | 12/14/22 07:53 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## ANALYTICAL RESULTS

Project: Harding St Ash Pond System
Pace Project No.: 50332961

**Sample: MW-8D0 (34-36)** **Lab ID: 50332961004** Collected: 12/08/22 13:39 Received: 12/08/22 16:15 Matrix: Solid

***Results reported on a "dry weight" basis and are adjusted for percent moisture, sample size and any dilutions.***

| Parameters | Results | Units | Report Limit | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|---|---|---|---|---|---|---|---|---|---|
| **6010 MET ICP** | Analytical Method: EPA 6010 Preparation Method: EPA 3050 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Arsenic | **12.8** | mg/kg | 1.0 | 0.17 | 1 | 12/13/22 08:59 | 12/14/22 10:34 | 7440-38-2 | |
| Iron | **14200** | mg/kg | 51.3 | 13.1 | 1 | 12/13/22 08:59 | 12/13/22 15:07 | 7439-89-6 | |
| Lithium | **7.8** | mg/kg | 5.1 | 0.21 | 1 | 12/13/22 08:59 | 12/13/22 15:07 | 7439-93-2 | N2 |
| Manganese | **346** | mg/kg | 1.0 | 0.53 | 1 | 12/13/22 08:59 | 12/13/22 15:07 | 7439-96-5 | |
| Molybdenum | **2.6** | mg/kg | 1.0 | 0.077 | 1 | 12/13/22 08:59 | 12/13/22 15:07 | 7439-98-7 | |
| **Percent Moisture** | Analytical Method: SM 2540G | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| Percent Moisture | **14.2** | % | 0.10 | 0.10 | 1 | | 12/09/22 19:28 | | N2 |
| **9045 pH Soil** | Analytical Method: EPA 9045 | | | | | | | | |
| | Pace Analytical Services - Indianapolis | | | | | | | | |
| pH at 25 Degrees C | **7.7** | Std. Units | 0.10 | 0.10 | 1 | | 12/09/22 19:08 | | H3 |
| **Total Organic Carbon Quad** | Analytical Method: EPA 9060 | | | | | | | | |
| | Pace Analytical Services - Green Bay | | | | | | | | |
| Total Organic Carbon | **888** | mg/kg | 699 | 226 | 1 | | 12/14/22 09:00 | 7440-44-0 | |
| Total Organic Carbon | **988** | mg/kg | 697 | 225 | 1 | | 12/14/22 09:06 | 7440-44-0 | |
| Total Organic Carbon | **959** | mg/kg | 694 | 224 | 1 | | 12/14/22 09:12 | 7440-44-0 | |
| Total Organic Carbon | **922** | mg/kg | 693 | 224 | 1 | | 12/14/22 09:18 | 7440-44-0 | |
| Mean Total Organic Carbon | **939** | mg/kg | 696 | 225 | 1 | | 12/14/22 09:00 | 7440-44-0 | |
| ***Surrogates*** | | | | | | | | | |
| RSD% | **4.6** | % | | | 1 | | 12/14/22 09:00 | | |

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332961

QC Batch: 710615
QC Batch Method: EPA 3050
Analysis Method: EPA 6010
Analysis Description: 6010 MET
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50332961001, 50332961002, 50332961003, 50332961004

METHOD BLANK: 3265812 Matrix: Solid
Associated Lab Samples: 50332961001, 50332961002, 50332961003, 50332961004

| Parameter | Units | Blank Result | Reporting Limit | MDL | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| Arsenic | mg/kg | ND | 1.0 | 0.17 | 12/14/22 09:56 | |
| Iron | mg/kg | ND | 50.0 | 12.8 | 12/13/22 13:55 | |
| Lithium | mg/kg | ND | 5.0 | 0.21 | 12/13/22 13:55 | N2 |
| Manganese | mg/kg | ND | 1.0 | 0.52 | 12/13/22 13:55 | |
| Molybdenum | mg/kg | ND | 1.0 | 0.075 | 12/13/22 13:55 | |

LABORATORY CONTROL SAMPLE: 3265813

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Arsenic | mg/kg | 50 | 51.0 | 102 | 80-120 | |
| Iron | mg/kg | 500 | 508 | 102 | 80-120 | |
| Lithium | mg/kg | 50 | 51.1 | 102 | 80-120 | N2 |
| Manganese | mg/kg | 50 | 50.4 | 101 | 80-120 | |
| Molybdenum | mg/kg | 50 | 53.2 | 106 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 3265814 3265815

| Parameter | Units | 50332961003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Arsenic | mg/kg | 1.9 | 42.4 | 43.9 | 38.3 | 40.3 | 87 | 88 | 75-125 | 5 | 20 | |
| Iron | mg/kg | 10100 | 424 | 439 | 7450 | 9600 | -235 | 262 | 75-125 | 25 | 20 | P6,R1 |
| Lithium | mg/kg | ND | 42.4 | 43.9 | 40.7 | 43.3 | 87 | 90 | 75-125 | 6 | 20 | N2 |
| Manganese | mg/kg | 56.8 | 42.4 | 43.9 | 75.2 | 94.4 | 65 | 107 | 75-125 | 23 | 20 | M0,R1 |
| Molybdenum | mg/kg | 1.5 | 42.4 | 43.9 | 38.2 | 39.8 | 87 | 88 | 75-125 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332961

QC Batch: 710392
QC Batch Method: SM 2540G
Analysis Method: SM 2540G
Analysis Description: Dry Weight/Percent Moisture
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50332961001, 50332961002, 50332961003, 50332961004

SAMPLE DUPLICATE: 3264667

| Parameter | Units | 50332666001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Percent Moisture | % | 93.1 | 93.4 | 0 | 5 | N2 |

SAMPLE DUPLICATE: 3264668

| Parameter | Units | 50332961003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| Percent Moisture | % | 16.3 | 17.3 | 6 | 5 | N2,R1 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332961

QC Batch: 710289
QC Batch Method: EPA 9045
Analysis Method: EPA 9045
Analysis Description: 9045 pH
Laboratory: Pace Analytical Services - Indianapolis
Associated Lab Samples: 50332961001, 50332961002, 50332961003, 50332961004

SAMPLE DUPLICATE: 3264219

| Parameter | Units | 50332898001 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 8.4 | 8.4 | 0 | 2 | H3 |

SAMPLE DUPLICATE: 3264220

| Parameter | Units | 50332961003 Result | Dup Result | RPD | Max RPD | Qualifiers |
|---|---|---|---|---|---|---|
| pH at 25 Degrees C | Std. Units | 7.7 | 7.8 | 1 | 2 | H3 |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA

Project: Harding St Ash Pond System
Pace Project No.: 50332961

QC Batch: 433707 | Analysis Method: EPA 9060
QC Batch Method: EPA 9060 | Analysis Description: 9060 TOC Average
Laboratory: Pace Analytical Services - Green Bay
Associated Lab Samples: 50332961001, 50332961002, 50332961003, 50332961004

METHOD BLANK: 2496374 Matrix: Solid
Associated Lab Samples: 50332961001, 50332961002, 50332961003, 50332961004

| Parameter | Units | Blank Result | Reporting Limit | MDL | Analyzed | Qualifiers |
|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | ND | 600 | 194 | 12/14/22 06:03 | |

LABORATORY CONTROL SAMPLE: 2496375

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | 120000 | 116000 | 97 | 80-120 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2496376 2496377

| Parameter | Units | 50332961003 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Mean Total Organic Carbon | mg/kg | ND | 7200 | 7180 | 6630 | 6350 | 89 | 86 | 50-152 | 4 | 20 | |

**Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.**

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

# QUALIFIERS

Project: Harding St Ash Pond System
Pace Project No.: 50332961

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## ANALYTE QUALIFIERS

| | |
|---|---|
| H3 | Sample was received or analysis requested beyond the recognized method holding time. |
| M0 | Matrix spike recovery and/or matrix spike duplicate recovery was outside laboratory control limits. |
| N2 | The lab does not hold NELAC/TNI accreditation for this parameter but other accreditations/certifications may apply. A complete list of accreditations/certifications is available upon request. |
| P6 | Matrix spike recovery was outside laboratory control limits due to a parent sample concentration notably higher than the spike level. |
| R1 | RPD value was outside control limits. |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Pace Analytical Services, LLC**
7726 Moller Road
Indianapolis, IN 46268
(317)228-3100

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Harding St Ash Pond System
Pace Project No.: 50332961

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|---|---|---|---|---|---|
| **50332961001** | **MW-2D1 (77-79)** | EPA 3050 | 710615 | EPA 6010 | 710848 |
| **50332961002** | **MW-45R (34-36)** | EPA 3050 | 710615 | EPA 6010 | 710848 |
| **50332961003** | **MW-5D (74-76)** | EPA 3050 | 710615 | EPA 6010 | 710848 |
| **50332961004** | **MW-8D0 (34-36)** | EPA 3050 | 710615 | EPA 6010 | 710848 |
| **50332961001** | **MW-2D1 (77-79)** | SM 2540G | 710392 | | |
| **50332961002** | **MW-45R (34-36)** | SM 2540G | 710392 | | |
| **50332961003** | **MW-5D (74-76)** | SM 2540G | 710392 | | |
| **50332961004** | **MW-8D0 (34-36)** | SM 2540G | 710392 | | |
| **50332961001** | **MW-2D1 (77-79)** | EPA 9045 | 710289 | | |
| **50332961002** | **MW-45R (34-36)** | EPA 9045 | 710289 | | |
| **50332961003** | **MW-5D (74-76)** | EPA 9045 | 710289 | | |
| **50332961004** | **MW-8D0 (34-36)** | EPA 9045 | 710289 | | |
| **50332961001** | **MW-2D1 (77-79)** | EPA 9060 | 433707 | | |
| **50332961001** | **MW-2D1 (77-79)** | EPA 9060 | 433708 | | |
| **50332961002** | **MW-45R (34-36)** | EPA 9060 | 433707 | | |
| **50332961002** | **MW-45R (34-36)** | EPA 9060 | 433708 | | |
| **50332961003** | **MW-5D (74-76)** | EPA 9060 | 433707 | | |
| **50332961003** | **MW-5D (74-76)** | EPA 9060 | 433708 | | |
| **50332961004** | **MW-8D0 (34-36)** | EPA 9060 | 433707 | | |
| **50332961004** | **MW-8D0 (34-36)** | EPA 9060 | 433708 | | |



This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO# : 50332961

50332961

Pace

# ytical Request Document

Submitting a sample via this chain of custody con NT. All relevant fields must be completed accurately.

ons found at https://info.pacelabs.com/hubfs/pas-standard-terms.pdf.

Page : 1 Of 1

**Section A**
**Required Client Information:**

| | |
|---|---|
| Company: | Atlas Indianapolis |
| Address: | 7988 Centerpoint Drive |
| | Suite 100, Indianapolis, IN 46256 |
| Email: | mark.breting@oneatlas.com |
| Phone: | 317-313-8306 Fax: |
| Requested Due Date: | |

**Section B**
**Required Project Information:**

| | |
|---|---|
| Report To: | Mark Breting |
| Copy To: | |
| | |
| Purchase Order #: | |
| Project Name: | Harding St Ash Pond System |
| Project #: | |

| | |
|---|---|
| Attention: | Accounts Payable - Paula Sedam |
| Company Name: | Atlas Indianapolis |
| Address: | |
| Pace Quote: | |
| Pace Project Manager: | hayden.putt@pacelabs.com, |
| Pace Profile #: | 10498/34 |

**Regulatory Agency**

**State / Location**
IN

**SAMPLE ID**
One Character per box.
(A-Z, 0-9 / , -)
Sample Ids must be unique

| MATRIX | CODE |
|---|---|
| Drinking Water | DW |
| Water | WT |
| Waste Water | WW |
| Product | P |
| Soil/Solid | SL |
| Oil | OL |
| Wipe | WP |
| Air | AR |
| Other | OT |
| Tissue | TS |

| ITEM # | SAMPLE ID | MATRIX CODE (see valid codes to left) | SAMPLE TYPE (G=GRAB C=COMP) | COLLECTED START DATE | COLLECTED START TIME | COLLECTED END DATE | COLLECTED END TIME | SAMPLE TEMP AT COLLECTION | # OF CONTAINERS | Preservatives: Unpreserved | H2SO4 | HNO3 | HCl | NaOH | Na2S2O3 | Methanol | Other | Analyses Test Y/N | As, Mo, Mn, Fe, Li by 6010 | pH by 9045 | TOC by 9060 to Pace GB | Residual Chlorine (Y/N) | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | mw-2D1 (77-79) | SL | G | | | 12/8/22 | 1313 | | 2 | 2 | | | | | | | | | X | X | X | | 001 |
| 2 | mw-4SR (34-36) | ↓ | ↓ | | | ↓ | 1354 | | 2 | 2 | | | | | | | | | X | X | X | | 002 |
| 3 | mw-5D (74-76) MS/MSD | | | | | | 1321 | | 6 | 6 | | | | | | | | | X | X | X | | 003 |
| 4 | mw-8D0 (34-36) | | | | | | 1339 | | 2 | 2 | | | | | | | | | X | X | X | | 004 |
| 5 | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | |

| ADDITIONAL COMMENTS | RELINQUISHED BY / AFFILIATION | DATE | TIME | ACCEPTED BY / AFFILIATION | DATE | TIME | SAMPLE CONDITIONS | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| | | 12-8-22 | | | 12/8/22 | 1506 | | | | |
| | | 12/8/22 | 1615 | | 12/8/22 | 1615 | 0.1 | Y | N | Y |
| | | | | | | | | | | |
| | | | | | | | | | | |

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: Colton Palmer

SIGNATURE of SAMPLER: Colton Palmer

DATE Signed: 12-8-22

| TEMP in C | Received on Ice (Y/N) | Custody Sealed Cooler (Y/N) | Samples Intact (Y/N) |
|---|---|---|---|

# SAMPLE CONDITION UPON RECEIPT FORM

**Date/Time and Initials of person examining contents:** DD 12/8/22 1850

1. **Courier:** ☐ FED EX ☐ UPS ☑ CLIENT ☐ PACE ☐ USPS ☐ OTHER _____
2. **Custody Seal on Cooler/Box Present:** ☐ Yes ☑ No
   **(If yes)Seals Intact:** ☐ Yes ☐ No **(leave blank if no seals were present)**
3. **Thermometer:** 1 2 3 4 5 6 A B C D E F
4. **Cooler Temperature(s):** 1.0/0.1 | | | |
   **(Initial/Corrected)** RECORD TEMPS OF ALL COOLERS RECEIVED (use Comments below to add more)
5. **Packing Material:** ☐ Bubble Wrap ☑ Bubble Bags ☐ None ☐ Other _____
6. **Ice Type:** ☑ Wet ☐ Blue ☐ None
7. **If temp. is over 6°C or under 0°C, was the PM notified?:** ☐ Yes ☐ No
   Cooler temp should be above freezing to 6°C

**All discrepancies will be written out in the comments section below.**

| | Yes | No | | Yes | No | N/A |
|---|---|---|---|---|---|---|
| **USDA Regulated Soils?** (HI, ID, NY, WA, OR,CA, NM, TX, OK, AR, LA, TN, AL, MS, NC, SC, GA, FL, or Puerto Rico) | | ✓ | All containers needing acid/base preservation have been pH CHECKED?: **Exceptions: VOA, coliform, LLHg, O&G, RAD CHEM, and any container with a septum cap or preserved with HCl.** **Circle: HNO3 (<2) H2SO4 (<2) NaOH (>10) NaOH/ZnAc (>9)** Any non-conformance to pH recommendations will be noted on the container count form | | | ✓ |
| **Short Hold Time Analysis (48 hours or less)? Analysis:** | | ✓ | | | | |
| **Time 5035A TC placed in Freezer or Short Holds To Lab** | Time: | | Residual Chlorine Check (SVOC 625 Pest/PCB 608) | Present | Absent | N/A ✓ |
| **Rush TAT Requested (4 days or less):** | | ✓ | Residual Chlorine Check (Total/Amenable/Free Cyanide) | | | ✓ |
| Custody Signatures Present? | ✓ | | Headspace Wisconsin Sulfide? | | | ✓ |
| Containers Intact?: | ✓ | | Headspace in VOA Vials (>6mm): See Containter Count form for details | Present | Absent | No VOA Vials Sent ✓ |
| Sample Label (IDs/Dates/Times) Match COC?: Except TCs, which only require sample ID | ✓ | | Trip Blank Present? | | | |
| Extra labels on Terracore Vials? (soils only) | | | Trip Blank Custody Seals?: | | | |

COMMENTS:

**COC PAGE ____ of ____**

## Sample Container Count

** Place a RED dot on containers that are out of conformance **

| | | MeOH (only) | | VIALS | | | | | | AMBER GLASS | | | | | | | PLASTIC | | | | | | | | | OTHER | | | | | Nitric | Sulfuric | Sodium Hydroxide | Sodium Hydroxide/ ZnAc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | SBS | | | | | | | | | | | | | | | | | | | | | | | | | | | | | Red | Yellow | Green | Black |
| COC Line Item | WGFU | DI | R | DG9H VG9H | VOA VIAL HS (>6mm) | VG9U | DG9U | VG9T | AG0U | AG1H | AG1U | AG2U | AG3S | AG3SF | AG3C | BP1U | BP1N | BP2U | BP3U | BP3N | BP3F | BP3S | BP3B | BP3Z | CG3H | CG3F | Syringe Kit | | Matrix | HNO3 <2 | H2SO4 <2 | NaOH >10 | NaOH/Zn Ac >9 |
| 1 | / | | | | | | | | / | | | | | | | | | | | | | | | | | | | SL | | | | |
| 2 | / | | | | | | | | / | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | 3 | | | | | | | | 3 | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | / | | | | | | | | / | | | | | | | | | | | | | | | | | | | V | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Container Codes

### Glass

| | | | | | |
|---|---|---|---|---|---|
| DG9H | 40mL HCl amber voa vial | BG1T | 1L Na Thiosulfate clear glass | BP1B | 1L NaOH plastic |
| DG9P | 40mL TSP amber vial | BG1U | 1L unpreserved glass | BP1N | 1L HNO3 plastic |
| DG9S | 40mL H2SO4 amber vial | BG3H | 250mL HCl Clear Glass | BP1S | 1L H2SO4 plastic |
| DG9T | 40mL Na Thio amber vial | BG3U | 250mL Unpres Clear Glass | BP1U | 1L unpreserved plastic |
| DG9U | 40mL unpreserved amber vial | AG0U | 100mL unpres amber glass | BP1Z | 1L NaOH, Zn, Ac |
| VG9H | 40mL HCl clear vial | AG1H | 1L HCl amber glass | BP2N | 500mL HNO3 plastic |
| VG9T | 40mL Na Thio. clear vial | AG1S | 1L H2SO4 amber glass | BP2C | 500mL NaOH plastic |
| VG9U | 40mL unpreserved clear vial | AG1T | 1L Na Thiosulfate amber glass | BP2S | 500mL H2SO4 plastic |
| I | 40mL w/hexane wipe vial | AG1U | 1liter unpres amber glass | BP2U | 500mL unpreserved plastic |
| WGKU | 8oz unpreserved clear jar | AG2N | 500mL HNO3 amber glass | BP2Z | 500mL NaOH, Zn Ac |
| WGFU | 4oz clear soil jar | AG2S | 500mL H2SO4 amber glass | BP3B | 250mL NaOH plastic |
| JGFU | 4oz unpreserved amber wide | AG2U | 500mL unpres amber glass | BP3N | 250mL HNO3 plastic |
| CG3H | 250mL clear glass HCl | AG3S | 250mL H2SO4 amber glass | BP3F | 250mL HNO3 plastic-field filtered |
| CG3F | 250mL clear glass HCl, Field Filter | AG3SF | 250mL H2SO4 amb glass -field filtered | BP3U | 250mL unpreserved plastic |
| BG1H | 1L HCl clear glass | AG3U | 250mL unpres amber glass | BP3S | 250mL H2SO4 plastic |
| BG1S | 1L H2SO4 clear glass | AG3C | 250mL NaOH amber glass | BP3Z | 250mL NaOH, ZnAc plastic |

### Plastic

| | |
|---|---|
| BP4U | 125mL unpreserved plastic |
| BP4N | 125mL HNO3 plastic |
| BP4S | 125mL H2SO4 plastic |

### Miscellaneous

| | |
|---|---|
| Syringe Kit | LL Cr+6 sampling kit |
| ZPLC | Ziploc Bag |
| R | Terracore Kit |
| SP5T | 120mL Coliform Sodium Thiosulfate |
| GN | General Container |
| U | Summa Can (air sample) |
| WT | Water |
| SL | Solid Solid |
| OL: | Oil |
| NAL | Non-aqueous liquid |
| WP | Wipe |

ATTACHMENT C

# PREDICTION LIMITS DOCUMENTATION

**NOVEMBER 2021**

## Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/03/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/03/2021 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/03/2020 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/03/2021 | ND | 1.0000 | | |
| Barium, Total | ug/L | MW-15I | 09/18/2018 | | 62.1000 | | |
| Barium, Total | ug/L | MW-15I | 11/29/2018 | | 66.0000 | | |
| Barium, Total | ug/L | MW-15I | 02/04/2019 | | 77.1000 | | |
| Barium, Total | ug/L | MW-15I | 03/25/2019 | | 78.8000 | | |
| Barium, Total | ug/L | MW-15I | 05/14/2019 | | 78.1000 | | |
| Barium, Total | ug/L | MW-15I | 07/24/2019 | | 66.2000 | | |
| Barium, Total | ug/L | MW-15I | 11/05/2019 | | 59.0000 | | |
| Barium, Total | ug/L | MW-15I | 01/29/2020 | | 56.6000 | | |
| Barium, Total | ug/L | MW-15I | 05/27/2020 | | 72.8000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-15I | 11/03/2020 | | 61.9000 | | |
| Barium, Total | ug/L | MW-15I | 05/06/2021 | | 67.4000 | | |
| Barium, Total | ug/L | MW-15I | 11/03/2021 | | 67.9000 | | |
| Beryllium, Total | ug/L | MW-15I | 09/18/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 11/29/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 02/04/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 03/25/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/14/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 07/24/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 11/05/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 01/29/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/27/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 11/03/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/06/2021 | ND | 0.2000 | | |
| Cadmium, Total | ug/L | MW-15I | 09/18/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 11/29/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 02/04/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 03/25/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 05/14/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 07/24/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 11/05/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | 2.0000 | ** |
| Cadmium, Total | ug/L | MW-15I | 05/27/2020 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 05/06/2021 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 11/03/2021 | ND | 2.0000 | | |
| Chromium, Total | ug/L | MW-15I | 09/18/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/29/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 02/04/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 03/25/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 05/14/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 07/24/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/05/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 01/29/2020 | ND | 20.0000 | 10.0000 | ** |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-15I | 05/27/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/03/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 05/06/2021 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/03/2021 | ND | 10.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/03/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/03/2021 | ND | 1.0000 | | |
| Fluoride | mg/L | MW-15I | 09/18/2018 | | 0.1100 | | |
| Fluoride | mg/L | MW-15I | 11/29/2018 | | 0.1300 | | |
| Fluoride | mg/L | MW-15I | 02/04/2019 | | 0.1200 | | |
| Fluoride | mg/L | MW-15I | 03/25/2019 | | 0.1300 | | |
| Fluoride | mg/L | MW-15I | 05/14/2019 | | 0.1100 | | |
| Fluoride | mg/L | MW-15I | 07/24/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 11/05/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 01/29/2020 | | 0.1200 | | |
| Fluoride | mg/L | MW-15I | 05/27/2020 | | 0.1200 | | |
| Fluoride | mg/L | MW-15I | 11/03/2020 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 05/06/2021 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 11/03/2021 | ND | 0.1000 | | |
| Lead, Total | ug/L | MW-15I | 09/18/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/29/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 02/04/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 03/25/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/14/2019 | ND | 10.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Lead, Total | ug/L | MW-15I | 07/24/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/05/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 01/29/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/27/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/03/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/06/2021 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/03/2021 | ND | 10.0000 | | |
| Lithium, Total | ug/L | MW-15I | 09/18/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/29/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 02/04/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 03/25/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/14/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 07/24/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/05/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 01/29/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/27/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/03/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/06/2021 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/03/2021 | ND | 20.0000 | | |
| Mercury | ug/L | MW-15I | 09/18/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 11/29/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 02/04/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 03/25/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 05/14/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 07/24/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 11/05/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 01/29/2020 | ND | 0.2000 | 2.0000 | ** |
| Mercury | ug/L | MW-15I | 05/27/2020 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 05/06/2021 | ND | 2.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 09/18/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/29/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 02/04/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 03/25/2019 | ND | 10.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-15I | 05/14/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 07/24/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/05/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 01/29/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 05/27/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/03/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 05/06/2021 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/03/2021 | ND | 10.0000 | | |
| Selenium, Total | ug/L | MW-15I | 09/18/2018 | | 1.9000 | | |
| Selenium, Total | ug/L | MW-15I | 11/29/2018 | | 1.9000 | | |
| Selenium, Total | ug/L | MW-15I | 02/04/2019 | | 2.1000 | | |
| Selenium, Total | ug/L | MW-15I | 03/25/2019 | | 1.9000 | | |
| Selenium, Total | ug/L | MW-15I | 05/14/2019 | | 1.5000 | | |
| Selenium, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 01/29/2020 | | 1.7000 | | |
| Selenium, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 11/03/2020 | | 2.0000 | | |
| Selenium, Total | ug/L | MW-15I | 05/06/2021 | | 1.7000 | | |
| Selenium, Total | ug/L | MW-15I | 11/03/2021 | | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Total Radium | pCi/L | MW-15I | 09/18/2018 | | 0.7100 | | |
| Total Radium | pCi/L | MW-15I | 11/29/2018 | | 0.7930 | | |
| Total Radium | pCi/L | MW-15I | 02/04/2019 | | 0.8490 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-15I | 03/25/2019 | | 1.6500 | | |
| Total Radium | pCi/L | MW-15I | 05/14/2019 | | 1.6300 | | |
| Total Radium | pCi/L | MW-15I | 07/24/2019 | | 1.6200 | | |
| Total Radium | pCi/L | MW-15I | 11/05/2019 | ND | 1.4600 | | |
| Total Radium | pCi/L | MW-15I | 01/29/2020 | | 0.5700 | | |
| Total Radium | pCi/L | MW-15I | 05/27/2020 | | 1.0500 | | |
| Total Radium | pCi/L | MW-15I | 11/03/2020 | | 0.6830 | | |
| Total Radium | pCi/L | MW-15I | 05/06/2021 | | 0.9160 | | |
| Total Radium | pCi/L | MW-15I | 11/03/2021 | | 1.1800 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10S | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-11S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/01/2021 | | 2.8000 | *** | 1.0000 |
| Antimony, Total | ug/L | MW-13S | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 11/03/2021 | ND | 1.0000 | ** | 1.0000 |
| Antimony, Total | ug/L | MW-2S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/01/2021 | | 7.3000 | *** | 1.0000 |
| Antimony, Total | ug/L | MW-4S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-5S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-6S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-7S | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-8S | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 11/09/2020 | | 7.3000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/02/2021 | | 429.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/01/2021 | | 2.2000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/01/2021 | | 43.4000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/02/2021 | | 368.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/03/2021 | | 7.4000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/01/2021 | | 28.9000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/01/2021 | | 1.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/01/2021 | ND | 1.0000 | ** | 1.0000 |
| Arsenic, Total | ug/L | MW-5S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/01/2021 | | 11.8000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/02/2021 | | 376.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-8S | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 11/09/2020 | ND | 1.0000 | ** | 1.0000 |
| Barium, Total | ug/L | MW-10S | 11/02/2021 | | 73.3000 | | 88.9314 |
| Barium, Total | ug/L | MW-11S | 11/01/2021 | | 74.3000 | | 88.9314 |
| Barium, Total | ug/L | MW-12S | 11/01/2021 | | 31.6000 | | 88.9314 |
| Barium, Total | ug/L | MW-13S | 11/02/2021 | | 44.2000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 11/03/2021 | | 64.8000 | ** | 88.9314 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-2S | 11/01/2021 | | 103.0000 | *** | 88.9314 |
| Barium, Total | ug/L | MW-3S | 11/01/2021 | | 55.4000 | | 88.9314 |
| Barium, Total | ug/L | MW-4S | 11/01/2021 | | 80.8000 | ** | 88.9314 |
| Barium, Total | ug/L | MW-5S | 11/01/2021 | | 24.3000 | | 88.9314 |
| Barium, Total | ug/L | MW-6S | 11/01/2021 | | 117.0000 | *** | 88.9314 |
| Barium, Total | ug/L | MW-7S | 11/02/2021 | | 41.8000 | | 88.9314 |
| Barium, Total | ug/L | MW-8S | 11/04/2021 | | 32.2000 | | 88.9314 |
| Barium, Total | ug/L | MW-9S | 11/09/2020 | | 52.0000 | | 88.9314 |
| Beryllium, Total | ug/L | MW-10S | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-12S | 11/05/2020 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-13S | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-1S | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-2S | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-3S | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-4S | 11/03/2020 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-5S | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-6S | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-7S | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-8S | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-9S | 11/09/2020 | ND | 0.2000 | | 0.2000 |
| Cadmium, Total | ug/L | MW-10S | 11/02/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-11S | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-12S | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-13S | 11/02/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-1S | 11/03/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-2S | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-3S | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-4S | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-5S | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-6S | 11/01/2021 | ND | 2.0000 | | 2.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cadmium, Total | ug/L | MW-7S | 11/02/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-8S | 11/04/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-9S | 05/29/2020 | ND | 2.0000 | | 2.0000 |
| Chromium, Total | ug/L | MW-10S | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-12S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-13S | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-1S | 11/03/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-2S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-3S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-4S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-5S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-6S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-7S | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-8S | 11/04/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-9S | 11/09/2020 | ND | 10.0000 | | 10.0000 |
| Cobalt, Total | ug/L | MW-10S | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-12S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13S | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-1S | 11/03/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-2S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-3S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 11/01/2021 | ND | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 11/01/2021 | ND | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/01/2021 | | 1.6000 | *** | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 11/02/2021 | ND | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-8S | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-9S | 11/09/2020 | ND | 1.0000 | | 1.0000 |
| Fluoride | mg/L | MW-10S | 11/02/2021 | | 2.5000 | *** | 0.2453 |
| Fluoride | mg/L | MW-11S | 11/01/2021 | | 1.4000 | *** | 0.2453 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-12S | 11/01/2021 | | 1.8000 | *** | 0.2453 |
| Fluoride | mg/L | MW-13S | 11/02/2021 | | 0.8300 | *** | 0.2453 |
| Fluoride | mg/L | MW-1S | 11/03/2021 | | 0.3100 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 11/01/2021 | | 0.5000 | *** | 0.2453 |
| Fluoride | mg/L | MW-3S | 11/01/2021 | | 0.1400 | | 0.2453 |
| Fluoride | mg/L | MW-4S | 11/01/2021 | | 0.1000 | | 0.2453 |
| Fluoride | mg/L | MW-5S | 11/01/2021 | | 1.9000 | *** | 0.2453 |
| Fluoride | mg/L | MW-6S | 11/01/2021 | | 1.2000 | *** | 0.2453 |
| Fluoride | mg/L | MW-7S | 11/02/2021 | | 0.5000 | *** | 0.2453 |
| Fluoride | mg/L | MW-8S | 11/04/2021 | | 0.1200 | | 0.2453 |
| Fluoride | mg/L | MW-9S | 11/09/2020 | | 0.2100 | | 0.2453 |
| Lead, Total | ug/L | MW-10S | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-11S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-12S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-13S | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-1S | 11/03/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-2S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-3S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-4S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-5S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-6S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-7S | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-8S | 11/04/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-9S | 11/09/2020 | ND | 10.0000 | | 10.0000 |
| Lithium, Total | ug/L | MW-10S | 11/02/2021 | | 53.3000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 11/01/2021 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/01/2021 | | 73.2000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/02/2021 | | 73.3000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-1S | 11/03/2021 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-2S | 11/01/2021 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-3S | 11/01/2021 | ND | 20.0000 | | 20.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-4S | 11/01/2021 | | 23.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/01/2021 | | 46.2000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/01/2021 | | 73.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/02/2021 | | 85.8000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/04/2021 | | 137.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 11/09/2020 | | 72.7000 | *** | 20.0000 |
| Mercury | ug/L | MW-10S | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-11S | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-12S | 05/29/2020 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-13S | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-1S | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-2S | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-3S | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-4S | 06/05/2020 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-5S | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-6S | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-7S | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-8S | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-9S | 05/29/2020 | ND | 2.0000 | | 2.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/02/2021 | | 71.2000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/01/2021 | | 76.1000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/01/2021 | | 144.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/02/2021 | | 553.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/03/2021 | | 28.1000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/01/2021 | | 38.4000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/01/2021 | | 46.7000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-4S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 11/01/2021 | | 152.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/01/2021 | | 186.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/02/2021 | | 625.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/04/2021 | | 270.0000 | *** | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-9S | 11/09/2020 | | 201.0000 | *** | 10.0000 |
| Selenium, Total | ug/L | MW-10S | 11/02/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-11S | 11/01/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 11/01/2021 | | 10.7000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-13S | 11/02/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-1S | 11/03/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-2S | 11/01/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 11/01/2021 | | 3.6000 | ** | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 11/01/2021 | | 20.3000 | *** | 3.6792 |
| Selenium, Total | ug/L | MW-5S | 11/01/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 11/01/2021 | | 6.0000 | *** | 3.6792 |
| Selenium, Total | ug/L | MW-7S | 11/02/2021 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-8S | 11/04/2021 | | 1.3000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 11/09/2020 | | 15.9000 | *** | 3.6792 |
| Thallium, Total | ug/L | MW-10S | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-11S | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-12S | 05/29/2020 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-13S | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-1S | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-2S | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-3S | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-4S | 06/05/2020 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-5S | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-6S | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-7S | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-8S | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-9S | 05/29/2020 | ND | 1.0000 | | 1.0000 |
| Total Radium | pCi/L | MW-10S | 11/02/2021 | | 1.1600 | | 2.3657 |
| Total Radium | pCi/L | MW-11S | 11/01/2021 | | 1.0700 | | 2.3657 |
| Total Radium | pCi/L | MW-12S | 11/01/2021 | | 0.9120 | | 2.3657 |
| Total Radium | pCi/L | MW-13S | 11/02/2021 | | 2.0000 | | 2.3657 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-1S | 11/03/2021 | | 1.1100 | ** | 2.3657 |
| Total Radium | pCi/L | MW-2S | 11/01/2021 | | 2.2300 | | 2.3657 |
| Total Radium | pCi/L | MW-3S | 11/01/2021 | ND | 1.5000 | | 2.3657 |
| Total Radium | pCi/L | MW-4S | 11/01/2021 | ND | 1.6600 | | 2.3657 |
| Total Radium | pCi/L | MW-5S | 11/01/2021 | | 1.0200 | | 2.3657 |
| Total Radium | pCi/L | MW-6S | 11/01/2021 | ND | 1.6500 | | 2.3657 |
| Total Radium | pCi/L | MW-7S | 11/02/2021 | ND | 2.1100 | | 2.3657 |
| Total Radium | pCi/L | MW-8S | 11/04/2021 | ND | 2.0400 | | 2.3657 |
| Total Radium | pCi/L | MW-9S | 11/09/2020 | ND | 1.8600 | | 2.3657 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-3

## Detection Frequencies in Upgradient and Downgradient Wells

| Constituent | Upgradient Detect | Upgradient N | Upgradient Proportion | Downgradient Detect | Downgradient N | Downgradient Proportion |
|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 12 | 0.000 | 41 | 199 | 0.206 |
| Arsenic, Total | 0 | 12 | 0.000 | 125 | 199 | 0.628 |
| Barium, Total | 12 | 12 | 1.000 | 199 | 199 | 1.000 |
| Beryllium, Total | 0 | 11 | 0.000 | 1 | 174 | 0.006 |
| Cadmium, Total | 0 | 11 | 0.000 | 3 | 173 | 0.017 |
| Chromium, Total | 0 | 12 | 0.000 | 8 | 199 | 0.040 |
| Cobalt, Total | 0 | 12 | 0.000 | 15 | 186 | 0.081 |
| Fluoride | 7 | 12 | 0.583 | 197 | 212 | 0.929 |
| Lead, Total | 0 | 12 | 0.000 | 2 | 186 | 0.011 |
| Lithium, Total | 0 | 12 | 0.000 | 157 | 199 | 0.789 |
| Mercury | 0 | 10 | 0.000 | 0 | 161 | 0.000 |
| Molybdenum, Total | 0 | 12 | 0.000 | 185 | 199 | 0.930 |
| Selenium, Total | 9 | 12 | 0.750 | 39 | 199 | 0.196 |
| Thallium, Total | 0 | 10 | 0.000 | 0 | 161 | 0.000 |
| Total Radium | 11 | 12 | 0.917 | 158 | 197 | 0.802 |

N = Total number of measurements in all wells.
Detect = Total number of detections in all wells.
Proportion = Detect/N.

## Table C-4

## Shapiro-Wilk Multiple Group Test of Normality

| Constituent | Detect | N | Detect Freq | G raw | G log | G cbrt | G sqrt | G sqr | G cub | Crit Value | Dist Form | Model Type |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Arsenic, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Barium, Total | 12 | 12 | 1.000 | 0.204 | 0.010 | | | | | 2.326 | normal | normal |
| Beryllium, Total | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Cadmium, Total | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Chromium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Cobalt, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Fluoride | 7 | 12 | 0.583 | 1.998 | 2.016 | | | | | 2.326 | normal | normal |
| Lead, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Lithium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Mercury | 0 | 10 | 0.000 | 3.262 | 3.262 | | | | | 2.326 | non-norm | nonpar |
| Molybdenum, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Selenium, Total | 9 | 12 | 0.750 | 2.084 | 2.506 | | | | | 2.326 | normal | normal |
| Thallium, Total | 0 | 10 | 0.000 | 3.262 | 3.262 | | | | | 2.326 | non-norm | nonpar |
| Total Radium | 11 | 12 | 0.917 | 1.212 | 0.583 | | | | | 2.326 | normal | normal |

* - Distribution override for that constituent.
Fit to distribution is confirmed if G <= critical value.
Model type may not match distributional form when detection frequency < 50%.

## Table C-5

## Summary Statistics and Prediction Limits

| Constituent | Units | Detect | N | Mean | SD | alpha | Factor | Pred Limit | Type | | Conf |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | 0 | 12 | | | | | 1.0000 | nonpar | *** | 0.89 |
| Arsenic, Total | ug/L | 0 | 12 | | | | | 1.0000 | nonpar | *** | 0.89 |
| Barium, Total | ug/L | 12 | 12 | 67.8250 | 7.4756 | 0.0100 | 2.8234 | 88.9314 | normal | | |
| Beryllium, Total | ug/L | 0 | 11 | | | | | 0.2000 | nonpar | *** | 0.87 |
| Cadmium, Total | ug/L | 0 | 11 | | | | | 2.0000 | nonpar | *** | 0.87 |
| Chromium, Total | ug/L | 0 | 12 | | | | | 10.0000 | nonpar | *** | 0.89 |
| Cobalt, Total | ug/L | 0 | 12 | | | | | 1.0000 | nonpar | *** | 0.89 |
| Fluoride | mg/L | 7 | 12 | 0.0700 | 0.0621 | 0.0100 | 2.8234 | 0.2453 | normal | | |
| Lead, Total | ug/L | 0 | 12 | | | | | 10.0000 | nonpar | *** | 0.89 |
| Lithium, Total | ug/L | 0 | 12 | | | | | 20.0000 | nonpar | *** | 0.89 |
| Mercury | ug/L | 0 | 10 | | | | | 2.0000 | nonpar | *** | 0.86 |
| Molybdenum, Total | ug/L | 0 | 12 | | | | | 10.0000 | nonpar | *** | 0.89 |
| Selenium, Total | ug/L | 9 | 12 | 1.3083 | 0.8397 | 0.0100 | 2.8234 | 3.6792 | normal | | |
| Thallium, Total | ug/L | 0 | 10 | | | | | 1.0000 | nonpar | *** | 0.86 |
| Total Radium | pCi/L | 11 | 12 | 0.9709 | 0.4940 | 0.0100 | 2.8234 | 2.3657 | normal | | |

Conf = confidence level for passing initial test or one verification resample at all downgradient wells for a single constituent (nonparametric test only).
* - Insufficient Data.
** - Calculated limit raised to Manual Reporting Limit.
*** - Nonparametric limit based on ND value.
For transformed data, mean and SD in transformed units and prediction limit in original units.
All sample sizes and statistics are based on outlier free data.
For nonparametric limits, median reporting limits are substituted for extreme reporting limit values.

## Table C-6

## Dixon's Test Outliers
## 1% Significance Level

| Constituent | Units | Well | Date | Result | ND Qualifier | Date Range | N | Critical Value |
|---|---|---|---|---|---|---|---|---|

N = Total number of independent measurements in background at each well.
Date Range = Dates of the first and last measurements included in background at each well.
Critical Value depends on the significance level and on N-1 when the two most extreme values are tested or N for the most extreme value.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-12S | 04/06/2016 | | 6.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/25/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 08/09/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 09/27/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/29/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 01/25/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/23/2017 | | 7.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 08/08/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/30/2018 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 09/17/2018 | | 3.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/16/2019 | | 4.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/29/2020 | | 2.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/05/2020 | | 2.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/01/2021 | | 2.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 04/07/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/26/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 08/09/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 09/27/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 11/29/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 01/26/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/23/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 08/09/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/29/2018 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 09/17/2018 | | 1.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/15/2019 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 11/07/2019 | | 6.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/26/2020 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 11/06/2020 | | 3.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/05/2021 | | 2.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 11/03/2021 | ND | 1.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

### Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-3S | 04/05/2016 | | 9.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/25/2016 | | 8.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 08/08/2016 | | 8.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 09/26/2016 | | 10.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/28/2016 | | 8.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 01/24/2017 | | 6.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/22/2017 | | 9.6000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 08/07/2017 | | 7.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/29/2018 | | 8.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 09/17/2018 | | 9.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/14/2019 | | 7.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/05/2019 | | 8.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/18/2020 | | 7.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/03/2020 | | 7.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/03/2021 | | 5.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/01/2021 | | 7.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 04/06/2016 | | 14.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/25/2016 | | 14.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 08/08/2016 | | 13.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 09/27/2016 | | 14.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 11/28/2016 | | 11.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 01/25/2017 | | 12.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/23/2017 | | 12.6000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 08/08/2017 | | 8.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/30/2018 | | 11.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 09/17/2018 | | 11.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/16/2019 | | 9.2000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/29/2020 | | 8.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 11/09/2020 | | 7.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 04/06/2016 | | 455.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

### Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-10S | 05/25/2016 | | 440.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 08/09/2016 | | 484.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 09/27/2016 | | 492.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/29/2016 | | 545.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 01/25/2017 | | 507.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/23/2017 | | 440.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 08/08/2017 | | 494.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/30/2018 | | 444.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 09/18/2018 | | 343.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/16/2019 | | 349.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/05/2019 | | 385.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/19/2020 | | 358.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/05/2020 | | 349.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/06/2021 | | 413.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/02/2021 | | 429.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 04/07/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/26/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 08/10/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 09/28/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/30/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 01/26/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/24/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 08/09/2017 | | 12.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/29/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 09/14/2018 | | 2.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/15/2019 | | 3.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/07/2019 | | 2.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/27/2020 | | 13.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/05/2020 | | 2.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/05/2021 | | 2.4000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-11S | 11/01/2021 | | 2.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 04/06/2016 | | 15.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/25/2016 | | 14.7000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 08/09/2016 | | 15.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 09/27/2016 | | 15.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/29/2016 | | 14.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 01/25/2017 | | 18.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/23/2017 | | 19.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 08/08/2017 | | 16.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/30/2018 | | 43.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 09/17/2018 | | 38.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/16/2019 | | 30.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/29/2020 | | 64.7000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/05/2020 | | 46.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/01/2021 | | 43.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 04/06/2016 | | 365.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/25/2016 | | 369.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 08/09/2016 | | 376.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 09/27/2016 | | 416.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/29/2016 | | 426.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 01/25/2017 | | 397.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/23/2017 | | 386.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 08/08/2017 | | 371.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/30/2018 | | 375.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 09/18/2018 | | 320.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/15/2019 | | 324.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/07/2019 | | 352.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/19/2020 | | 311.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/05/2020 | | 433.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/06/2021 | | 321.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-13S | 11/02/2021 | | 368.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 04/07/2016 | | 49.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/26/2016 | | 22.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 08/09/2016 | | 34.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 09/27/2016 | | 10.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/29/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 01/26/2017 | | 35.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/23/2017 | | 23.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 08/09/2017 | | 14.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/29/2018 | | 168.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 09/17/2018 | | 33.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/15/2019 | | 13.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/07/2019 | | 50.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/26/2020 | | 12.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/06/2020 | | 21.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/05/2021 | | 24.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/03/2021 | | 7.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 04/05/2016 | | 26.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/24/2016 | | 22.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 08/08/2016 | | 27.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 09/26/2016 | | 22.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/28/2016 | | 21.7000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 01/24/2017 | | 17.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/22/2017 | | 27.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 08/07/2017 | | 19.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/29/2018 | | 18.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 09/17/2018 | | 14.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/14/2019 | | 12.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/05/2019 | | 14.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/19/2020 | | 9.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-2S | 11/04/2020 | | 16.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/03/2021 | | 6.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/01/2021 | | 28.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 04/05/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/25/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 08/08/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 09/26/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/28/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 01/24/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/22/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 08/07/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/29/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 09/17/2018 | | 2.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/14/2019 | | 2.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/05/2019 | | 1.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/18/2020 | | 1.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/03/2020 | | 1.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/01/2021 | | 1.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 04/05/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/25/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 08/08/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 09/26/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/29/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 01/24/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/22/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 08/07/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/29/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 09/14/2018 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/14/2019 | ND | 1.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-4S | 06/05/2020 | | 1.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/03/2020 | | 3.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 04/06/2016 | | 28.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/25/2016 | | 23.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 08/09/2016 | | 34.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 09/27/2016 | | 30.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/29/2016 | | 35.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 01/25/2017 | | 11.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/23/2017 | | 12.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 08/08/2017 | | 11.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/30/2018 | | 13.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 09/18/2018 | | 15.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/14/2019 | | 11.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/28/2020 | | 23.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/09/2020 | | 39.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/05/2021 | | 11.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/01/2021 | | 11.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 04/06/2016 | | 320.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/25/2016 | | 353.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 08/09/2016 | | 365.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 09/27/2016 | | 352.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/29/2016 | | 372.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 01/25/2017 | | 352.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/23/2017 | | 373.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 08/08/2017 | | 359.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/30/2018 | | 383.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 09/18/2018 | | 317.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/15/2019 | | 345.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/06/2019 | | 439.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-7S | 05/27/2020 | | 367.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/17/2020 | | 462.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/06/2021 | | 419.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/02/2021 | | 376.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/25/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 08/08/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 09/27/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 11/28/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 01/25/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/23/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 08/08/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/30/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 09/17/2018 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/16/2019 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/29/2020 | | 1.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 11/09/2020 | ND | 1.0000 | | 1.0000 |
| Barium, Total | ug/L | MW-1S | 04/07/2016 | | 100.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 05/26/2016 | | 76.4000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 08/09/2016 | | 97.3000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 09/27/2016 | | 67.8000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 11/29/2016 | | 43.3000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 01/26/2017 | | 127.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 05/23/2017 | | 72.5000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 08/09/2017 | | 62.2000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 05/29/2018 | | 279.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 09/17/2018 | | 95.8000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 05/15/2019 | | 63.5000 | | 88.9314 |
| Barium, Total | ug/L | MW-1S | 11/07/2019 | | 140.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 05/26/2020 | | 69.8000 | | 88.9314 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-1S | 11/06/2020 | | 112.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 05/05/2021 | | 125.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-1S | 11/03/2021 | | 64.8000 | | 88.9314 |
| Barium, Total | ug/L | MW-2S | 04/05/2016 | | 205.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 05/24/2016 | | 158.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 08/08/2016 | | 168.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 09/26/2016 | | 180.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 11/28/2016 | | 185.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 01/24/2017 | | 97.4000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 05/22/2017 | | 138.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 08/07/2017 | | 127.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 05/29/2018 | | 90.3000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 09/17/2018 | | 86.0000 | | 88.9314 |
| Barium, Total | ug/L | MW-2S | 05/14/2019 | | 123.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 11/05/2019 | | 195.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 05/19/2020 | | 86.1000 | | 88.9314 |
| Barium, Total | ug/L | MW-2S | 11/04/2020 | | 137.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 05/03/2021 | | 92.4000 | * | 88.9314 |
| Barium, Total | ug/L | MW-2S | 11/01/2021 | | 103.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 04/05/2016 | | 117.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 05/25/2016 | | 136.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 08/08/2016 | | 140.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 09/26/2016 | | 123.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 11/29/2016 | | 128.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 01/24/2017 | | 119.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 05/22/2017 | | 70.3000 | | 88.9314 |
| Barium, Total | ug/L | MW-4S | 08/07/2017 | | 93.8000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 05/29/2018 | | 49.4000 | | 88.9314 |
| Barium, Total | ug/L | MW-4S | 09/14/2018 | | 93.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 05/14/2019 | | 60.0000 | | 88.9314 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-4S | 06/05/2020 | | 86.0000 | | 88.9314 |
| Barium, Total | ug/L | MW-4S | 11/03/2020 | | 113.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-4S | 11/01/2021 | | 80.8000 | | 88.9314 |
| Barium, Total | ug/L | MW-6S | 04/06/2016 | | 150.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 05/25/2016 | | 112.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 08/09/2016 | | 166.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 09/27/2016 | | 160.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 11/29/2016 | | 189.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 01/25/2017 | | 105.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 05/23/2017 | | 80.5000 | | 88.9314 |
| Barium, Total | ug/L | MW-6S | 08/08/2017 | | 80.6000 | | 88.9314 |
| Barium, Total | ug/L | MW-6S | 05/30/2018 | | 116.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 09/18/2018 | | 132.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 05/14/2019 | | 103.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 05/28/2020 | | 141.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 11/09/2020 | | 121.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 05/05/2021 | | 113.0000 | * | 88.9314 |
| Barium, Total | ug/L | MW-6S | 11/01/2021 | | 117.0000 | * | 88.9314 |
| Cobalt, Total | ug/L | MW-4S | 04/05/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 08/08/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 09/26/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 01/24/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 05/22/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 08/07/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 05/29/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 05/14/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 06/05/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 11/03/2020 | | 1.1000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cobalt, Total | ug/L | MW-4S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 09/27/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/14/2019 | | 1.2000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/18/2020 | | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 11/05/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/06/2021 | | 1.3000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 09/27/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/14/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/28/2020 | | 2.4000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/09/2020 | | 1.6000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/05/2021 | | 1.8000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/01/2021 | | 1.6000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 04/06/2016 | ND | 10.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cobalt, Total | ug/L | MW-7S | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 09/27/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 05/15/2019 | | 1.1000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 11/06/2019 | | 1.6000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 05/27/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 11/17/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 05/06/2021 | | 1.5000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Fluoride | mg/L | MW-10S | 04/06/2016 | | 3.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 05/25/2016 | | 3.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 08/09/2016 | | 2.2000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 09/27/2016 | | 2.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 11/29/2016 | | 3.1000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 01/25/2017 | | 2.7000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 05/23/2017 | | 2.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 08/08/2017 | | 2.1000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 09/20/2017 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 05/30/2018 | | 2.2000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 09/18/2018 | | 2.7000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 05/16/2019 | | 2.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 11/05/2019 | | 2.1000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 05/19/2020 | | 2.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 11/05/2020 | | 2.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-10S | 05/06/2021 | | 2.5000 | * | 0.2453 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-10S | 11/02/2021 | | 2.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 04/07/2016 | | 1.2000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 05/26/2016 | | 1.3000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 08/10/2016 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 09/28/2016 | | 1.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 11/30/2016 | | 1.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 01/26/2017 | | 1.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 05/24/2017 | | 1.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 08/09/2017 | | 1.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 09/20/2017 | | 1.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 05/29/2018 | | 1.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 09/14/2018 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 05/15/2019 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 11/07/2019 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 05/27/2020 | | 1.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 11/05/2020 | | 1.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 05/05/2021 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-11S | 11/01/2021 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 04/06/2016 | | 0.3500 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 05/25/2016 | | 0.3700 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 08/09/2016 | | 0.3800 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 09/27/2016 | | 0.3800 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 11/29/2016 | | 0.4200 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 01/25/2017 | | 0.5200 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 05/23/2017 | | 0.5100 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 08/08/2017 | | 0.5700 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 09/20/2017 | | 0.7500 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 05/30/2018 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 09/17/2018 | | 1.7000 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 05/16/2019 | | 1.5000 | * | 0.2453 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-12S | 05/29/2020 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 11/05/2020 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-12S | 11/01/2021 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 04/06/2016 | | 0.5200 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 05/25/2016 | | 0.5200 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 08/09/2016 | | 0.4900 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 09/27/2016 | | 0.5200 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 11/29/2016 | | 0.5500 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 01/25/2017 | | 0.5700 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 05/23/2017 | | 0.6300 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 08/08/2017 | | 0.7200 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 09/20/2017 | | 0.6500 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 05/30/2018 | | 0.8600 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 09/18/2018 | | 0.8800 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 05/15/2019 | | 0.8300 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 11/07/2019 | | 0.7800 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 05/19/2020 | | 0.9300 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 11/05/2020 | | 0.9400 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 05/06/2021 | | 0.9200 | * | 0.2453 |
| Fluoride | mg/L | MW-13S | 11/02/2021 | | 0.8300 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 04/07/2016 | | 0.5200 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 05/26/2016 | | 0.5700 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 08/09/2016 | | 0.4900 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 09/27/2016 | | 0.5100 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 11/29/2016 | | 0.5800 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 01/26/2017 | | 0.6900 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 05/23/2017 | | 0.6900 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 08/09/2017 | | 0.7000 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 09/20/2017 | | 0.6200 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 05/29/2018 | | 0.6200 | * | 0.2453 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-1S | 09/17/2018 | | 0.6200 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 05/15/2019 | | 0.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 11/07/2019 | | 0.4200 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 05/26/2020 | | 0.3600 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 11/06/2020 | | 0.3500 | * | 0.2453 |
| Fluoride | mg/L | MW-1S | 05/05/2021 | | 0.2400 | | 0.2453 |
| Fluoride | mg/L | MW-1S | 11/03/2021 | | 0.3100 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 04/05/2016 | | 0.8400 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 05/24/2016 | | 1.1000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 08/08/2016 | | 1.2000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 09/26/2016 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 11/28/2016 | | 1.3000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 01/24/2017 | | 2.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 05/22/2017 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 08/07/2017 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 09/20/2017 | | 1.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 05/29/2018 | | 1.1000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 09/17/2018 | | 1.8000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 05/14/2019 | | 0.9600 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 11/05/2019 | | 0.7000 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 05/19/2020 | | 0.5800 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 11/04/2020 | | 0.2800 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 05/03/2021 | | 0.4600 | * | 0.2453 |
| Fluoride | mg/L | MW-2S | 11/01/2021 | | 0.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 04/06/2016 | | 4.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 05/25/2016 | | 4.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 08/09/2016 | | 3.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 09/27/2016 | | 3.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 11/29/2016 | | 3.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 01/25/2017 | | 3.4000 | * | 0.2453 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-5S | 05/23/2017 | | 3.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 08/08/2017 | | 3.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 09/20/2017 | | 3.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 05/30/2018 | | 2.6000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 09/18/2018 | | 3.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 05/14/2019 | | 2.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 05/18/2020 | | 2.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 11/05/2020 | | 2.3000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 05/06/2021 | | 1.7000 | * | 0.2453 |
| Fluoride | mg/L | MW-5S | 11/01/2021 | | 1.9000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 04/06/2016 | | 0.9300 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 05/25/2016 | | 0.9400 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 08/09/2016 | | 0.7600 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 09/27/2016 | | 0.8400 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 11/29/2016 | | 0.9100 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 01/25/2017 | | 0.7400 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 05/23/2017 | | 0.8300 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 08/08/2017 | | 1.1000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 09/20/2017 | | 0.9300 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 05/30/2018 | | 1.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 09/18/2018 | | 1.2000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 05/14/2019 | | 0.5500 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 05/28/2020 | | 1.0000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 11/09/2020 | | 1.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 05/05/2021 | | 1.3000 | * | 0.2453 |
| Fluoride | mg/L | MW-6S | 11/01/2021 | | 1.2000 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 04/06/2016 | | 0.3400 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 05/25/2016 | | 0.3800 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 08/09/2016 | | 0.3400 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 09/27/2016 | | 0.3600 | * | 0.2453 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-7S | 11/29/2016 | | 0.3600 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 01/25/2017 | | 0.3400 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 05/23/2017 | | 0.3700 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 08/08/2017 | | 0.4100 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 09/20/2017 | | 0.4000 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 05/30/2018 | | 0.4200 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 09/18/2018 | | 0.4500 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 05/15/2019 | | 0.5000 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 11/06/2019 | | 0.4600 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 05/27/2020 | | 0.5700 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 11/17/2020 | | 0.5400 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 05/06/2021 | | 0.5100 | * | 0.2453 |
| Fluoride | mg/L | MW-7S | 11/02/2021 | | 0.5000 | * | 0.2453 |
| Lithium, Total | ug/L | MW-10S | 04/06/2016 | | 106.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/25/2016 | | 94.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 08/09/2016 | | 98.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 09/27/2016 | | 79.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/29/2016 | | 96.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 01/25/2017 | | 95.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/23/2017 | | 72.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 08/08/2017 | | 93.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/30/2018 | | 57.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 09/18/2018 | | 59.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/16/2019 | | 69.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/05/2019 | | 60.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/19/2020 | | 75.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/05/2020 | | 49.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/06/2021 | | 45.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/02/2021 | | 53.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 04/06/2016 | | 215.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-12S | 05/25/2016 | | 196.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 08/09/2016 | | 193.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 09/27/2016 | | 176.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/29/2016 | | 189.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 01/25/2017 | | 158.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/23/2017 | | 155.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 08/08/2017 | | 160.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/30/2018 | | 106.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 09/17/2018 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/16/2019 | | 127.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/29/2020 | | 97.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/05/2020 | | 84.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/01/2021 | | 73.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 04/06/2016 | | 89.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/25/2016 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 08/09/2016 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 09/27/2016 | | 119.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/29/2016 | | 148.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 01/25/2017 | | 143.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/23/2017 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 08/08/2017 | | 107.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/30/2018 | | 91.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 09/18/2018 | | 84.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/15/2019 | | 99.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/07/2019 | | 75.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/19/2020 | | 83.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/05/2020 | | 69.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/06/2021 | | 62.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/02/2021 | | 73.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 04/05/2016 | | 23.9000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-4S | 05/25/2016 | | 21.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 08/08/2016 | | 20.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 09/26/2016 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 11/29/2016 | | 25.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 01/24/2017 | | 20.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/22/2017 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 08/07/2017 | | 22.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/29/2018 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 09/14/2018 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/14/2019 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 06/05/2020 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 11/03/2020 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 11/01/2021 | | 23.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 04/06/2016 | | 89.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/25/2016 | | 78.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 08/09/2016 | | 75.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 09/27/2016 | | 76.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/29/2016 | | 94.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 01/25/2017 | | 85.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/23/2017 | | 57.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 08/08/2017 | | 63.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/30/2018 | | 57.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 09/18/2018 | | 52.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/14/2019 | | 59.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/18/2020 | | 54.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/05/2020 | | 41.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/06/2021 | | 42.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/01/2021 | | 46.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 04/06/2016 | | 112.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/25/2016 | | 99.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-6S | 08/09/2016 | | 102.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 09/27/2016 | | 89.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/29/2016 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 01/25/2017 | | 114.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/23/2017 | | 99.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 08/08/2017 | | 86.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/30/2018 | | 75.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 09/18/2018 | | 58.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/14/2019 | | 117.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/28/2020 | | 84.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/09/2020 | | 61.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/05/2021 | | 62.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/01/2021 | | 73.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 04/06/2016 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/25/2016 | | 110.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 08/09/2016 | | 109.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 09/27/2016 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/29/2016 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 01/25/2017 | | 145.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/23/2017 | | 135.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 08/08/2017 | | 131.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/30/2018 | | 103.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 09/18/2018 | | 94.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/15/2019 | | 106.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/06/2019 | | 89.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/27/2020 | | 87.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/17/2020 | | 86.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/06/2021 | | 81.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/02/2021 | | 85.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 04/07/2016 | | 182.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-8S | 05/26/2016 | | 135.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 08/09/2016 | | 204.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 09/28/2016 | | 184.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/30/2016 | | 184.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 01/26/2017 | | 155.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/23/2017 | | 94.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 08/09/2017 | | 73.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/29/2018 | | 132.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 09/17/2018 | | 147.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/15/2019 | | 124.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/07/2019 | | 174.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/26/2020 | | 124.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/09/2020 | | 188.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/05/2021 | | 123.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/04/2021 | | 137.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 04/06/2016 | | 126.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/25/2016 | | 110.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 08/08/2016 | | 103.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 09/27/2016 | | 84.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 11/28/2016 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 01/25/2017 | | 114.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/23/2017 | | 86.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 08/08/2017 | | 90.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/30/2018 | | 93.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 09/17/2018 | | 89.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/16/2019 | | 70.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/29/2020 | | 86.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 11/09/2020 | | 72.7000 | * | 20.0000 |
| Molybdenum, Total | ug/L | MW-10S | 04/06/2016 | | 324.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/25/2016 | | 299.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-10S | 08/09/2016 | | 279.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 09/27/2016 | | 247.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/29/2016 | | 241.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 01/25/2017 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/23/2017 | | 219.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 08/08/2017 | | 166.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/30/2018 | | 138.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 09/18/2018 | | 117.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/16/2019 | | 93.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/05/2019 | | 93.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/19/2020 | | 82.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/05/2020 | | 77.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/06/2021 | | 72.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/02/2021 | | 71.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 04/07/2016 | | 77.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/26/2016 | | 81.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 08/10/2016 | | 82.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 09/28/2016 | | 80.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/30/2016 | | 82.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 01/26/2017 | | 83.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/24/2017 | | 78.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 08/09/2017 | | 73.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/29/2018 | | 73.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 09/14/2018 | | 74.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/15/2019 | | 73.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/07/2019 | | 75.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/27/2020 | | 83.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/05/2020 | | 80.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/05/2021 | | 77.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/01/2021 | | 76.1000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-12S | 04/06/2016 | | 256.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/25/2016 | | 274.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 08/09/2016 | | 279.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 09/27/2016 | | 265.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/29/2016 | | 269.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 01/25/2017 | | 227.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/23/2017 | | 273.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 08/08/2017 | | 283.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/30/2018 | | 287.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 09/17/2018 | | 294.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/16/2019 | | 241.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/29/2020 | | 198.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/05/2020 | | 196.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/01/2021 | | 144.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 04/06/2016 | | 577.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/25/2016 | | 563.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 08/09/2016 | | 552.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 09/27/2016 | | 517.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/29/2016 | | 517.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 01/25/2017 | | 481.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/23/2017 | | 508.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 08/08/2017 | | 511.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/30/2018 | | 720.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 09/18/2018 | | 770.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/15/2019 | | 782.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/07/2019 | | 809.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/19/2020 | | 746.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/05/2020 | | 722.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/06/2021 | | 692.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/02/2021 | | 553.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-1S | 04/07/2016 | | 456.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/26/2016 | | 309.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 08/09/2016 | | 199.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 09/27/2016 | | 167.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/29/2016 | | 151.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 01/26/2017 | | 247.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/23/2017 | | 106.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 08/09/2017 | | 88.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/29/2018 | | 57.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 09/17/2018 | | 51.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/15/2019 | | 50.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/07/2019 | | 28.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/26/2020 | | 37.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/06/2020 | | 25.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/05/2021 | | 24.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/03/2021 | | 28.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 04/05/2016 | | 458.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/24/2016 | | 352.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 08/08/2016 | | 248.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 09/26/2016 | | 179.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/28/2016 | | 190.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 01/24/2017 | | 214.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/22/2017 | | 135.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 08/07/2017 | | 141.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/29/2018 | | 78.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 09/17/2018 | | 85.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/14/2019 | | 36.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/05/2019 | | 31.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/19/2020 | | 27.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/04/2020 | | 36.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-2S | 05/03/2021 | | 35.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/01/2021 | | 38.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 04/05/2016 | | 139.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/25/2016 | | 124.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 08/08/2016 | | 97.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 09/26/2016 | | 77.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/28/2016 | | 98.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 01/24/2017 | | 88.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/22/2017 | | 63.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 08/07/2017 | | 64.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/29/2018 | | 78.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 09/17/2018 | | 52.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/14/2019 | | 43.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/05/2019 | | 41.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/18/2020 | | 49.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/03/2020 | | 40.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/03/2021 | | 36.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/01/2021 | | 46.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 04/06/2016 | | 251.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/25/2016 | | 266.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 08/09/2016 | | 266.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 09/27/2016 | | 275.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 11/29/2016 | | 321.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 01/25/2017 | | 313.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/23/2017 | | 319.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 08/08/2017 | | 307.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/30/2018 | | 265.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 09/18/2018 | | 254.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/14/2019 | | 231.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/18/2020 | | 218.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-5S | 11/05/2020 | | 182.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/06/2021 | | 131.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 11/01/2021 | | 152.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 04/06/2016 | | 309.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/25/2016 | | 261.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 08/09/2016 | | 240.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 09/27/2016 | | 226.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/29/2016 | | 243.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 01/25/2017 | | 166.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/23/2017 | | 142.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 08/08/2017 | | 185.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/30/2018 | | 150.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 09/18/2018 | | 157.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/14/2019 | | 65.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/28/2020 | | 146.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/09/2020 | | 211.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/05/2021 | | 216.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/01/2021 | | 186.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 04/06/2016 | | 435.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/25/2016 | | 448.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 08/09/2016 | | 477.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 09/27/2016 | | 468.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/29/2016 | | 486.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 01/25/2017 | | 439.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/23/2017 | | 429.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 08/08/2017 | | 425.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/30/2018 | | 528.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 09/18/2018 | | 518.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/15/2019 | | 575.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/06/2019 | | 608.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-7S | 05/27/2020 | | 705.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/17/2020 | | 681.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/06/2021 | | 676.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/02/2021 | | 625.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 04/07/2016 | | 258.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/26/2016 | | 210.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 08/09/2016 | | 329.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 09/28/2016 | | 331.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/30/2016 | | 389.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 01/26/2017 | | 294.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/23/2017 | | 208.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 08/09/2017 | | 150.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/29/2018 | | 419.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 09/17/2018 | | 311.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/15/2019 | | 329.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/07/2019 | | 530.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/26/2020 | | 306.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/09/2020 | | 532.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/05/2021 | | 354.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/04/2021 | | 270.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 04/06/2016 | | 519.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/25/2016 | | 438.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 08/08/2016 | | 374.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 09/27/2016 | | 344.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 11/28/2016 | | 368.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 01/25/2017 | | 290.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/23/2017 | | 217.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 08/08/2017 | | 191.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/30/2018 | | 116.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 09/17/2018 | | 98.4000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-9S | 05/16/2019 | | 118.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/29/2020 | | 93.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 11/09/2020 | | 201.0000 | * | 10.0000 |
| Selenium, Total | ug/L | MW-12S | 04/06/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 05/25/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 08/09/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 09/27/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 11/29/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 01/25/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 05/23/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 08/08/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 05/30/2018 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 09/17/2018 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 05/16/2019 | | 1.4000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 05/29/2020 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 11/05/2020 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-12S | 11/01/2021 | | 10.7000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 04/05/2016 | | 11.1000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 05/25/2016 | | 10.7000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 08/08/2016 | | 15.0000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 09/26/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 11/28/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 01/24/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 05/22/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 08/07/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 05/29/2018 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 09/17/2018 | | 3.4000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 05/14/2019 | | 16.5000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 11/05/2019 | ND | 1.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 05/18/2020 | | 8.2000 | * | 3.6792 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-3S | 11/03/2020 | | 1.5000 | | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 05/03/2021 | | 9.5000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-3S | 11/01/2021 | | 3.6000 | | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 04/05/2016 | | 50.8000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 05/25/2016 | | 31.5000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 08/08/2016 | | 35.6000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 09/26/2016 | | 13.4000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 11/29/2016 | | 39.0000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 01/24/2017 | | 19.6000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 05/22/2017 | | 20.5000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 08/07/2017 | | 19.9000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 05/29/2018 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 09/14/2018 | | 33.8000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 05/14/2019 | | 16.1000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 06/05/2020 | | 12.4000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 11/03/2020 | | 41.4000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-4S | 11/01/2021 | | 20.3000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 04/06/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 05/25/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 08/09/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 09/27/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 11/29/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 01/25/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 05/23/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 08/08/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 05/30/2018 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 09/18/2018 | | 2.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 05/14/2019 | | 1.7000 | | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 05/28/2020 | | 3.7000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 11/09/2020 | ND | 1.0000 | | 3.6792 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-6S | 05/05/2021 | | 3.9000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-6S | 11/01/2021 | | 6.0000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 04/06/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 05/25/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 08/08/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 09/27/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 11/28/2016 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 01/25/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 05/23/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 08/08/2017 | ND | 10.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 05/30/2018 | | 146.0000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 09/17/2018 | | 66.0000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 05/16/2019 | | 2.0000 | | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 05/29/2020 | | 120.0000 | * | 3.6792 |
| Selenium, Total | ug/L | MW-9S | 11/09/2020 | | 15.9000 | * | 3.6792 |
| Total Radium | pCi/L | MW-1S | 04/07/2016 | | 2.0400 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 05/26/2016 | | 1.5300 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 08/09/2016 | | 4.2400 | * | 2.3657 |
| Total Radium | pCi/L | MW-1S | 09/27/2016 | | 1.7500 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 11/29/2016 | | 1.3400 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 01/26/2017 | | 2.1400 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 05/23/2017 | | 2.4100 | * | 2.3657 |
| Total Radium | pCi/L | MW-1S | 08/09/2017 | | 1.2400 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 05/29/2018 | | 4.8400 | * | 2.3657 |
| Total Radium | pCi/L | MW-1S | 09/17/2018 | | 2.2700 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 05/15/2019 | | 1.7600 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 11/07/2019 | | 5.3800 | * | 2.3657 |
| Total Radium | pCi/L | MW-1S | 05/26/2020 | | 0.9380 | | 2.3657 |
| Total Radium | pCi/L | MW-1S | 11/06/2020 | | 3.0800 | * | 2.3657 |
| Total Radium | pCi/L | MW-1S | 05/05/2021 | | 3.5400 | * | 2.3657 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.


## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-1S | 11/03/2021 | | 1.1100 | | 2.3657 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

# False Positive and False Negative Rates for Current Upgradient vs. Downgradient Monitoring Program



# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/03/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/03/2021 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15D | 09/18/2018 | | 1.3000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/29/2018 | | 1.2000 | | |
| Arsenic, Total | ug/L | MW-15D | 02/04/2019 | | 1.3000 | | |
| Arsenic, Total | ug/L | MW-15D | 03/25/2019 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/14/2019 | | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15D | 07/24/2019 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/05/2019 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 01/29/2020 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/27/2020 | | 1.2000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/03/2020 | | 1.7000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/06/2021 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/03/2021 | | 1.2000 | | |
| Barium, Total | ug/L | MW-15D | 09/18/2018 | | 71.4000 | | |
| Barium, Total | ug/L | MW-15D | 11/29/2018 | | 67.8000 | | |
| Barium, Total | ug/L | MW-15D | 02/04/2019 | | 69.6000 | | |
| Barium, Total | ug/L | MW-15D | 03/25/2019 | | 68.4000 | | |
| Barium, Total | ug/L | MW-15D | 05/14/2019 | | 65.6000 | | |
| Barium, Total | ug/L | MW-15D | 07/24/2019 | | 64.6000 | | |
| Barium, Total | ug/L | MW-15D | 11/05/2019 | | 65.3000 | | |
| Barium, Total | ug/L | MW-15D | 01/29/2020 | | 65.2000 | | |
| Barium, Total | ug/L | MW-15D | 05/27/2020 | | 64.2000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-15D | 11/03/2020 | | 63.2000 | | |
| Barium, Total | ug/L | MW-15D | 05/06/2021 | | 68.9000 | | |
| Barium, Total | ug/L | MW-15D | 11/03/2021 | | 69.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 09/18/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 11/29/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 02/04/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 03/25/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/14/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 07/24/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 11/05/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 01/29/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/27/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 11/03/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/06/2021 | ND | 0.2000 | | |
| Cadmium, Total | ug/L | MW-15D | 09/18/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 11/29/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 02/04/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 03/25/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 05/14/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 07/24/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 11/05/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | 2.0000 | ** |
| Cadmium, Total | ug/L | MW-15D | 05/27/2020 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 05/06/2021 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 11/03/2021 | ND | 2.0000 | | |
| Chromium, Total | ug/L | MW-15D | 09/18/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/29/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 02/04/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 03/25/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 05/14/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 07/24/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/05/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 01/29/2020 | ND | 20.0000 | 10.0000 | ** |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-15D | 05/27/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/03/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 05/06/2021 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/03/2021 | ND | 10.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/03/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/03/2021 | ND | 1.0000 | | |
| Fluoride | mg/L | MW-15D | 09/18/2018 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 11/29/2018 | | 0.1200 | | |
| Fluoride | mg/L | MW-15D | 02/04/2019 | | 0.1200 | | |
| Fluoride | mg/L | MW-15D | 03/25/2019 | | 0.1300 | | |
| Fluoride | mg/L | MW-15D | 05/14/2019 | | 0.1100 | | |
| Fluoride | mg/L | MW-15D | 07/24/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 11/05/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 01/29/2020 | | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 05/27/2020 | | 0.1100 | | |
| Fluoride | mg/L | MW-15D | 11/03/2020 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 05/06/2021 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 11/03/2021 | ND | 0.1000 | | |
| Lead, Total | ug/L | MW-15D | 09/18/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/29/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 02/04/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 03/25/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/14/2019 | ND | 10.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Lead, Total | ug/L | MW-15D | 07/24/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/05/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 01/29/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/27/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/03/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/06/2021 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/03/2021 | ND | 10.0000 | | |
| Lithium, Total | ug/L | MW-15D | 09/18/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/29/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 02/04/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 03/25/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/14/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 07/24/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/05/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 01/29/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/27/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/03/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/06/2021 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/03/2021 | ND | 20.0000 | | |
| Mercury | ug/L | MW-15D | 09/18/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 11/29/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 02/04/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 03/25/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 05/14/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 07/24/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 11/05/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 01/29/2020 | ND | 0.2000 | 2.0000 | ** |
| Mercury | ug/L | MW-15D | 05/27/2020 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 05/06/2021 | ND | 2.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 09/18/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/29/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 02/04/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 03/25/2019 | ND | 10.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-15D | 05/14/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 07/24/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/05/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 01/29/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 05/27/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/03/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 05/06/2021 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/03/2021 | ND | 10.0000 | | |
| Selenium, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/03/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/03/2021 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Total Radium | pCi/L | MW-15D | 09/18/2018 | | 1.1700 | | |
| Total Radium | pCi/L | MW-15D | 11/29/2018 | | 1.6500 | | |
| Total Radium | pCi/L | MW-15D | 02/04/2019 | | 1.0600 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

## Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-15D | 03/25/2019 | | 1.4600 | | |
| Total Radium | pCi/L | MW-15D | 05/14/2019 | | 2.0600 | | |
| Total Radium | pCi/L | MW-15D | 07/24/2019 | | 1.4500 | | |
| Total Radium | pCi/L | MW-15D | 11/05/2019 | | 1.1000 | | |
| Total Radium | pCi/L | MW-15D | 01/29/2020 | | 0.8340 | | |
| Total Radium | pCi/L | MW-15D | 05/27/2020 | | 1.2100 | | |
| Total Radium | pCi/L | MW-15D | 11/03/2020 | | 1.4300 | | |
| Total Radium | pCi/L | MW-15D | 05/06/2021 | | 1.7400 | | |
| Total Radium | pCi/L | MW-15D | 11/03/2021 | | 1.1300 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10D | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-11D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-13D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-14D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1D | 11/03/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-2D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-3D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-7D | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-9D | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-9I | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-10D | 11/02/2021 | | 173.0000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 11/01/2021 | | 14.8000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 11/01/2021 | | 428.0000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 11/01/2021 | | 231.0000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 11/01/2021 | | 113.0000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 11/03/2021 | | 3.4000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 11/01/2021 | | 3.8000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 11/01/2021 | | 3.4000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 11/02/2021 | | 457.0000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 11/04/2021 | | 9.0000 | *** | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 11/04/2021 | | 5.2000 | *** | 1.7471 |
| Barium, Total | ug/L | MW-10D | 11/02/2021 | | 33.3000 | | 74.2368 |
| Barium, Total | ug/L | MW-11D | 11/01/2021 | | 23.6000 | | 74.2368 |
| Barium, Total | ug/L | MW-12D | 11/01/2021 | | 26.8000 | | 74.2368 |
| Barium, Total | ug/L | MW-13D | 11/01/2021 | | 30.7000 | | 74.2368 |
| Barium, Total | ug/L | MW-14D | 11/01/2021 | | 51.5000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 11/03/2021 | | 72.0000 | ** | 74.2368 |
| Barium, Total | ug/L | MW-2D | 11/01/2021 | | 57.4000 | | 74.2368 |
| Barium, Total | ug/L | MW-3D | 11/01/2021 | | 66.9000 | | 74.2368 |
| Barium, Total | ug/L | MW-7D | 11/02/2021 | | 53.9000 | | 74.2368 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-9D | 11/04/2021 | | 46.3000 | | 74.2368 |
| Barium, Total | ug/L | MW-9I | 11/04/2021 | | 73.4000 | | 74.2368 |
| Beryllium, Total | ug/L | MW-10D | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11D | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-12D | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-13D | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-14D | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-1D | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-2D | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-3D | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-7D | 05/06/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-9D | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-9I | 05/03/2021 | ND | 0.2000 | | 0.2000 |
| Cadmium, Total | ug/L | MW-10D | 11/02/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-11D | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-12D | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-13D | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-14D | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-1D | 11/03/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-2D | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-3D | 11/01/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 11/02/2021 | ND | 2.0000 | ** | 2.0000 |
| Cadmium, Total | ug/L | MW-9D | 11/04/2021 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-9I | 11/04/2021 | ND | 2.0000 | | 2.0000 |
| Chromium, Total | ug/L | MW-10D | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-12D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-13D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-14D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-1D | 11/03/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-2D | 11/01/2021 | ND | 10.0000 | | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

### Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-3D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-7D | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-9D | 11/04/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-9I | 11/04/2021 | ND | 10.0000 | | 10.0000 |
| Cobalt, Total | ug/L | MW-10D | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-12D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 11/01/2021 | ND | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 11/01/2021 | ND | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-1D | 11/03/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-2D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-3D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/02/2021 | | 1.8000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-9D | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-9I | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Fluoride | mg/L | MW-10D | 11/02/2021 | | 2.0000 | *** | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/01/2021 | | 0.3600 | *** | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/01/2021 | | 1.3000 | *** | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/01/2021 | | 0.5500 | *** | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/01/2021 | | 0.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/03/2021 | | 0.3100 | *** | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/01/2021 | | 0.8600 | *** | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/01/2021 | | 0.1500 | *** | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/02/2021 | | 0.3800 | *** | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/04/2021 | | 0.3600 | *** | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/04/2021 | | 0.9800 | *** | 0.1300 |
| Lead, Total | ug/L | MW-10D | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-11D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-12D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-13D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-14D | 11/01/2021 | ND | 10.0000 | | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lead, Total | ug/L | MW-1D | 11/03/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-2D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-3D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-7D | 11/02/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-9D | 11/04/2021 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-9I | 11/04/2021 | ND | 10.0000 | | 10.0000 |
| Lithium, Total | ug/L | MW-10D | 11/02/2021 | | 67.4000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/01/2021 | | 150.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/01/2021 | | 95.5000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/01/2021 | | 84.7000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/01/2021 | | 751.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/03/2021 | | 23.4000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/01/2021 | | 56.1000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-3D | 11/01/2021 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/02/2021 | | 103.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/04/2021 | | 23.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/04/2021 | | 28.5000 | *** | 20.0000 |
| Mercury | ug/L | MW-10D | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-11D | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-12D | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-13D | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-14D | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-1D | 05/05/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-2D | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-3D | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-7D | 05/06/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-9D | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Mercury | ug/L | MW-9I | 05/03/2021 | ND | 2.0000 | | 2.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/02/2021 | | 84.1000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-11D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/01/2021 | | 176.0000 | *** | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-13D | 11/01/2021 | | 599.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/01/2021 | | 257.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/03/2021 | | 33.6000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/01/2021 | | 56.4000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-3D | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/02/2021 | | 688.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/04/2021 | | 41.3000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/04/2021 | | 123.0000 | *** | 10.0000 |
| Selenium, Total | ug/L | MW-10D | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-11D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-12D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-13D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-14D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-1D | 11/03/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-2D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-3D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-7D | 11/02/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-9D | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-9I | 11/04/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-10D | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-11D | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-12D | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-13D | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-14D | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-1D | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-2D | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-3D | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-7D | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-9D | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-9I | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Total Radium | pCi/L | MW-10D | 11/02/2021 | | 1.2000 | | 2.3237 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-11D | 11/01/2021 | | 1.0900 | | 2.3237 |
| Total Radium | pCi/L | MW-12D | 11/01/2021 | | 0.9600 | | 2.3237 |
| Total Radium | pCi/L | MW-13D | 11/01/2021 | | 1.4600 | | 2.3237 |
| Total Radium | pCi/L | MW-14D | 11/01/2021 | | 1.4900 | | 2.3237 |
| Total Radium | pCi/L | MW-1D | 11/03/2021 | | 1.0300 | | 2.3237 |
| Total Radium | pCi/L | MW-2D | 11/01/2021 | | 1.5800 | | 2.3237 |
| Total Radium | pCi/L | MW-3D | 11/01/2021 | | 1.4800 | | 2.3237 |
| Total Radium | pCi/L | MW-7D | 11/02/2021 | | 1.0900 | | 2.3237 |
| Total Radium | pCi/L | MW-9D | 11/04/2021 | | 1.4200 | | 2.3237 |
| Total Radium | pCi/L | MW-9I | 11/04/2021 | | 1.8000 | | 2.3237 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-3

## Detection Frequencies in Upgradient and Downgradient Wells

| Constituent | Upgradient Detect | Upgradient N | Upgradient Proportion | Downgradient Detect | Downgradient N | Downgradient Proportion |
|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 12 | 0.000 | 1 | 176 | 0.006 |
| Arsenic, Total | 12 | 12 | 1.000 | 133 | 176 | 0.756 |
| Barium, Total | 12 | 12 | 1.000 | 176 | 176 | 1.000 |
| Beryllium, Total | 0 | 11 | 0.000 | 0 | 154 | 0.000 |
| Cadmium, Total | 0 | 11 | 0.000 | 5 | 154 | 0.032 |
| Chromium, Total | 0 | 12 | 0.000 | 4 | 176 | 0.023 |
| Cobalt, Total | 0 | 12 | 0.000 | 4 | 165 | 0.024 |
| Fluoride | 6 | 12 | 0.500 | 185 | 187 | 0.989 |
| Lead, Total | 0 | 12 | 0.000 | 0 | 165 | 0.000 |
| Lithium, Total | 0 | 12 | 0.000 | 168 | 176 | 0.955 |
| Mercury | 0 | 10 | 0.000 | 1 | 143 | 0.007 |
| Molybdenum, Total | 0 | 12 | 0.000 | 157 | 176 | 0.892 |
| Selenium, Total | 0 | 12 | 0.000 | 0 | 176 | 0.000 |
| Thallium, Total | 0 | 10 | 0.000 | 0 | 143 | 0.000 |
| Total Radium | 12 | 12 | 1.000 | 153 | 176 | 0.869 |

N = Total number of measurements in all wells.
Detect = Total number of detections in all wells.
Proportion = Detect/N.

## Table C-4

## Shapiro-Wilk Multiple Group Test of Normality

| Constituent | Detect | N | Detect Freq | G raw | G log | G cbrt | G sqrt | G sqr | G cub | Crit Value | Dist Form | Model Type |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Arsenic, Total | 12 | 12 | 1.000 | 2.752 | 2.124 | | | | | 2.326 | lognor | lognor |
| Barium, Total | 12 | 12 | 1.000 | 0.048 | 0.022 | | | | | 2.326 | normal | normal |
| Beryllium, Total | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Cadmium, Total | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Chromium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Cobalt, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Fluoride | 6 | 12 | 0.500 | 2.922 | 2.896 | | | | | 2.326 | non-norm | nonpar |
| Lead, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Lithium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Mercury | 0 | 10 | 0.000 | 3.262 | 3.262 | | | | | 2.326 | non-norm | nonpar |
| Molybdenum, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Selenium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Thallium, Total | 0 | 10 | 0.000 | 3.262 | 3.262 | | | | | 2.326 | non-norm | nonpar |
| Total Radium | 12 | 12 | 1.000 | 0.579 | 1.624 | | | | | 2.326 | normal | normal |

* - Distribution override for that constituent.
Fit to distribution is confirmed if G <= critical value.
Model type may not match distributional form when detection frequency < 50%.

## Table C-5

## Summary Statistics and Prediction Limits

| Constituent | Units | Detect | N | Mean | SD | alpha | Factor | Pred Limit | Type | | Conf |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | 0 | 12 | | | | | 1.0000 | nonpar | *** | 0.90 |
| Arsenic, Total | ug/L | 12 | 12 | 0.1732 | 0.1363 | 0.0100 | 2.8234 | 1.7471 | lognor | | |
| Barium, Total | ug/L | 12 | 12 | 66.9500 | 2.5809 | 0.0100 | 2.8234 | 74.2368 | normal | | |
| Beryllium, Total | ug/L | 0 | 11 | | | | | 0.2000 | nonpar | *** | 0.89 |
| Cadmium, Total | ug/L | 0 | 11 | | | | | 2.0000 | nonpar | *** | 0.89 |
| Chromium, Total | ug/L | 0 | 12 | | | | | 10.0000 | nonpar | *** | 0.90 |
| Cobalt, Total | ug/L | 0 | 12 | | | | | 1.0000 | nonpar | *** | 0.90 |
| Fluoride | mg/L | 6 | 12 | | | | | 0.1300 | nonpar | | 0.90 |
| Lead, Total | ug/L | 0 | 12 | | | | | 10.0000 | nonpar | *** | 0.90 |
| Lithium, Total | ug/L | 0 | 12 | | | | | 20.0000 | nonpar | *** | 0.90 |
| Mercury | ug/L | 0 | 10 | | | | | 2.0000 | nonpar | *** | 0.87 |
| Molybdenum, Total | ug/L | 0 | 12 | | | | | 10.0000 | nonpar | *** | 0.90 |
| Selenium, Total | ug/L | 0 | 12 | | | | | 1.0000 | nonpar | *** | 0.90 |
| Thallium, Total | ug/L | 0 | 10 | | | | | 1.0000 | nonpar | *** | 0.87 |
| Total Radium | pCi/L | 12 | 12 | 1.3578 | 0.3421 | 0.0100 | 2.8234 | 2.3237 | normal | | |

Conf = confidence level for passing initial test or one verification resample at all downgradient wells for a single constituent (nonparametric test only).
* - Insufficient Data.
** - Calculated limit raised to Manual Reporting Limit.
*** - Nonparametric limit based on ND value.
For transformed data, mean and SD in transformed units and prediction limit in original units.
All sample sizes and statistics are based on outlier free data.
For nonparametric limits, median reporting limits are substituted for extreme reporting limit values.

## Table C-6

## Dixon's Test Outliers
## 1% Significance Level

| Constituent | Units | Well | Date | Result | ND Qualifier | Date Range | N | Critical Value |
|---|---|---|---|---|---|---|---|---|

N = Total number of independent measurements in background at each well.
Date Range = Dates of the first and last measurements included in background at each well.
Critical Value depends on the significance level and on N-1 when the two most extreme values are tested or N for the most extreme value.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-10D | 04/06/2016 | | 412.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 05/25/2016 | | 440.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 08/09/2016 | | 464.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 09/27/2016 | | 488.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 11/29/2016 | | 406.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 01/25/2017 | | 433.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 05/23/2017 | | 399.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 08/08/2017 | | 447.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 05/30/2018 | | 396.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 09/18/2018 | | 323.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 05/16/2019 | | 313.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 11/05/2019 | | 275.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 05/19/2020 | | 268.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 11/05/2020 | | 265.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 05/06/2021 | | 250.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-10D | 11/02/2021 | | 173.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 04/07/2016 | | 10.6000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 05/26/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 08/10/2016 | | 14.4000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 09/28/2016 | | 14.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 11/30/2016 | | 12.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 01/26/2017 | | 10.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 05/24/2017 | | 14.4000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 08/09/2017 | | 14.5000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 05/29/2018 | | 18.2000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 09/14/2018 | | 14.6000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 05/14/2019 | | 14.3000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 11/07/2019 | | 15.4000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 05/27/2020 | | 15.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 11/05/2020 | | 14.4000 | * | 1.7471 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

### Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-11D | 05/05/2021 | | 15.4500 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-11D | 11/01/2021 | | 14.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 04/06/2016 | | 241.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 05/25/2016 | | 252.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 08/09/2016 | | 243.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 09/27/2016 | | 257.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 11/29/2016 | | 280.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 01/25/2017 | | 275.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 05/23/2017 | | 268.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 08/08/2017 | | 204.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 05/30/2018 | | 223.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 09/17/2018 | | 214.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 05/16/2019 | | 210.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 11/06/2019 | | 232.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 05/18/2020 | | 287.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 11/05/2020 | | 513.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 05/03/2021 | | 463.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-12D | 11/01/2021 | | 428.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 04/06/2016 | | 214.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 05/25/2016 | | 215.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 08/09/2016 | | 245.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 09/27/2016 | | 282.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 11/29/2016 | | 291.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 01/25/2017 | | 315.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 05/23/2017 | | 306.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 08/08/2017 | | 277.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 05/30/2018 | | 253.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 09/18/2018 | | 214.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 05/16/2019 | | 225.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 11/06/2019 | | 219.0000 | * | 1.7471 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-13D | 05/19/2020 | | 241.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 11/05/2020 | | 224.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 05/06/2021 | | 242.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-13D | 11/01/2021 | | 231.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 04/07/2016 | | 89.1000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 05/26/2016 | | 87.6000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 08/10/2016 | | 86.5000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 09/28/2016 | | 92.3000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 11/30/2016 | | 103.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 01/26/2017 | | 116.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 05/23/2017 | | 124.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 08/09/2017 | | 128.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 05/30/2018 | | 147.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 09/17/2018 | | 116.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 05/15/2019 | | 108.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 11/07/2019 | | 111.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 05/26/2020 | | 131.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 11/05/2020 | | 105.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 05/05/2021 | | 133.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-14D | 11/01/2021 | | 113.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 04/07/2016 | | 10.3000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 05/26/2016 | | 12.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 08/09/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 09/27/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 11/29/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 01/26/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 05/23/2017 | | 11.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 08/09/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 05/29/2018 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 09/17/2018 | | 4.2000 | * | 1.7471 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-1D | 05/15/2019 | | 4.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 11/07/2019 | | 5.2000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 05/26/2020 | | 7.4000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 11/06/2020 | | 50.6000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 05/05/2021 | | 5.9000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-1D | 11/03/2021 | | 3.4000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 04/05/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 05/24/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 08/08/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 09/26/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 11/28/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 01/24/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 05/22/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 08/07/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 05/29/2018 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 09/17/2018 | | 1.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 05/15/2019 | | 2.2000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 11/05/2019 | | 3.1000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 05/19/2020 | | 1.9000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 11/04/2020 | | 3.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 05/03/2021 | | 2.5000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-2D | 11/01/2021 | | 3.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 04/05/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 05/25/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 08/08/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 09/26/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 11/28/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 01/24/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 05/22/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 08/07/2017 | ND | 10.0000 | | 1.7471 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-3D | 05/29/2018 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 09/17/2018 | | 2.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 05/15/2019 | | 2.9000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 11/06/2019 | | 2.9000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 05/18/2020 | | 3.3000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 11/03/2020 | | 2.9000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 05/03/2021 | | 3.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-3D | 11/01/2021 | | 3.4000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 04/06/2016 | | 428.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 05/25/2016 | | 435.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 08/09/2016 | | 412.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 09/27/2016 | | 408.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 11/29/2016 | | 417.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 01/25/2017 | | 468.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 05/23/2017 | | 509.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 08/08/2017 | | 504.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 05/30/2018 | | 491.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 09/18/2018 | | 433.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 05/15/2019 | | 471.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 11/06/2019 | | 432.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 05/27/2020 | | 467.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 11/17/2020 | | 402.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 05/06/2021 | | 476.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-7D | 11/02/2021 | | 457.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 04/06/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 05/25/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 08/08/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 09/27/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 11/29/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 01/25/2017 | ND | 10.0000 | | 1.7471 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-9D | 05/23/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 08/08/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 05/30/2018 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 09/17/2018 | | 2.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 05/16/2019 | | 2.1000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 11/06/2019 | | 3.2000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 05/19/2020 | | 5.3000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 11/04/2020 | | 4.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 05/03/2021 | | 8.7000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9D | 11/04/2021 | | 9.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 04/06/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 05/25/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 08/08/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 09/27/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 11/28/2016 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 01/25/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 05/23/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 08/08/2017 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 05/30/2018 | ND | 10.0000 | | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 09/17/2018 | | 5.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 05/16/2019 | | 3.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 11/06/2019 | | 4.0000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 05/19/2020 | | 4.2000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 11/04/2020 | | 4.6000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 05/03/2021 | | 4.8000 | * | 1.7471 |
| Arsenic, Total | ug/L | MW-9I | 11/04/2021 | | 5.2000 | * | 1.7471 |
| Barium, Total | ug/L | MW-1D | 04/07/2016 | | 47.2000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 05/26/2016 | | 49.6000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 08/09/2016 | | 51.6000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 09/27/2016 | | 49.8000 | | 74.2368 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-1D | 11/29/2016 | | 39.3000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 01/26/2017 | | 44.2000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 05/23/2017 | | 48.4000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 08/09/2017 | | 51.3000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 05/29/2018 | | 49.8000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 09/17/2018 | | 51.7000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 05/15/2019 | | 61.8000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 11/07/2019 | | 55.5000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 05/26/2020 | | 71.0000 | | 74.2368 |
| Barium, Total | ug/L | MW-1D | 11/06/2020 | | 113.0000 | * | 74.2368 |
| Barium, Total | ug/L | MW-1D | 05/05/2021 | | 77.5000 | * | 74.2368 |
| Barium, Total | ug/L | MW-1D | 11/03/2021 | | 72.0000 | | 74.2368 |
| Cadmium, Total | ug/L | MW-7D | 04/06/2016 | | 2.4000 | * | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/25/2016 | | 2.2000 | * | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 08/09/2016 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 09/27/2016 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 11/29/2016 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 01/25/2017 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/23/2017 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 08/08/2017 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/30/2018 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/15/2019 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 11/06/2019 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/27/2020 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/06/2021 | | 2.1000 | * | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 11/02/2021 | ND | 2.0000 | | 2.0000 |
| Cobalt, Total | ug/L | MW-13D | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 09/27/2016 | ND | 5.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cobalt, Total | ug/L | MW-13D | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/16/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 11/06/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/19/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 11/05/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/06/2021 | | 1.1000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 04/07/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/26/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 08/10/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 09/28/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 11/30/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 01/26/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 08/09/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/15/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 11/07/2019 | | 1.1000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/26/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 11/05/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/05/2021 | | 1.2000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 09/27/2016 | ND | 5.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cobalt, Total | ug/L | MW-7D | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/15/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/06/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/27/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/17/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/02/2021 | | 1.8000 | * | 1.0000 |
| Fluoride | mg/L | MW-10D | 04/06/2016 | | 1.7000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/25/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 08/09/2016 | | 2.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 09/27/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/29/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 01/25/2017 | | 2.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/23/2017 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 08/08/2017 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 09/20/2017 | | 2.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/30/2018 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 09/18/2018 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/16/2019 | | 2.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/05/2019 | | 2.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/19/2020 | | 2.5000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/05/2020 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/06/2021 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/02/2021 | | 2.0000 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 04/07/2016 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/26/2016 | | 0.3700 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-11D | 08/10/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 09/28/2016 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/30/2016 | | 0.2900 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 01/26/2017 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/24/2017 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 08/09/2017 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 09/20/2017 | | 0.4800 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/29/2018 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 09/14/2018 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/14/2019 | | 0.4700 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/07/2019 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/27/2020 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/05/2020 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/05/2021 | | 0.2500 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/01/2021 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 04/06/2016 | | 0.2200 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/25/2016 | | 0.2700 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 08/09/2016 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 09/27/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/29/2016 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 01/25/2017 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/23/2017 | | 0.5000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 08/08/2017 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 09/20/2017 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/30/2018 | | 1.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 09/17/2018 | | 0.9500 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/16/2019 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/06/2019 | | 1.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/18/2020 | | 1.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/05/2020 | | 0.9700 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-12D | 05/03/2021 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/01/2021 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 04/06/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/25/2016 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 08/09/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 09/27/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/29/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 01/25/2017 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/23/2017 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 08/08/2017 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 09/20/2017 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/30/2018 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 09/18/2018 | | 0.4700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/16/2019 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/06/2019 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/19/2020 | | 0.5900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/05/2020 | | 0.6200 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/06/2021 | | 0.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/01/2021 | | 0.5500 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 04/07/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/26/2016 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 08/10/2016 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 09/28/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/30/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 01/26/2017 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/23/2017 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 08/09/2017 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 09/20/2017 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/30/2018 | | 0.3200 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 09/17/2018 | | 0.2300 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-14D | 05/15/2019 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/07/2019 | | 0.2100 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/26/2020 | ND | 0.1000 | | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/05/2020 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/05/2021 | ND | 0.1000 | | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/01/2021 | | 0.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 04/07/2016 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/26/2016 | | 0.4700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 08/09/2016 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 09/27/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/29/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 01/26/2017 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/23/2017 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 08/09/2017 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 09/20/2017 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/29/2018 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 09/17/2018 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/15/2019 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/07/2019 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/26/2020 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/06/2020 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/05/2021 | | 0.2300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/03/2021 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 04/05/2016 | | 2.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/24/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 08/08/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 09/26/2016 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/28/2016 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 01/24/2017 | | 2.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/22/2017 | | 2.6000 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-2D | 08/07/2017 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 09/20/2017 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/29/2018 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 09/17/2018 | | 2.8000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/15/2019 | | 1.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/05/2019 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/19/2020 | | 1.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/04/2020 | | 1.0000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/03/2021 | | 0.8700 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/01/2021 | | 0.8600 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 04/05/2016 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/25/2016 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 08/08/2016 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 09/26/2016 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/28/2016 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 01/24/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/22/2017 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 08/07/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 09/20/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/29/2018 | | 0.2900 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 09/17/2018 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/15/2019 | | 0.2400 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/06/2019 | | 0.2100 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/18/2020 | | 0.2300 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/03/2020 | | 0.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/03/2021 | | 0.1800 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/01/2021 | | 0.1500 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 04/06/2016 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/25/2016 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 08/09/2016 | | 0.3100 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-7D | 09/27/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/29/2016 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 01/25/2017 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/23/2017 | | 0.2500 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 08/08/2017 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 09/20/2017 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/30/2018 | | 0.2900 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 09/18/2018 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/15/2019 | | 0.3200 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/06/2019 | | 0.3500 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/27/2020 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/17/2020 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/06/2021 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/02/2021 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 04/06/2016 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/25/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 08/08/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 09/27/2016 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/29/2016 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 01/25/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/23/2017 | | 0.4600 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 08/08/2017 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 09/20/2017 | | 0.5200 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/30/2018 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 09/17/2018 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/16/2019 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/06/2019 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/19/2020 | | 0.4600 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/04/2020 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/03/2021 | | 0.4000 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-9D | 11/04/2021 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 04/06/2016 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/25/2016 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 08/08/2016 | | 0.5500 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 09/27/2016 | | 0.5800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/28/2016 | | 0.6100 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 01/25/2017 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/23/2017 | | 0.5700 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 08/08/2017 | | 0.5800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 09/20/2017 | | 0.5900 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/30/2018 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 09/17/2018 | | 0.5800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/16/2019 | | 0.6800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/06/2019 | | 0.6900 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/19/2020 | | 0.7300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/04/2020 | | 0.7800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/03/2021 | | 0.9700 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/04/2021 | | 0.9800 | * | 0.1300 |
| Lithium, Total | ug/L | MW-10D | 04/06/2016 | | 123.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/25/2016 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 08/09/2016 | | 96.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 09/27/2016 | | 82.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/29/2016 | | 92.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 01/25/2017 | | 92.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/23/2017 | | 85.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 08/08/2017 | | 86.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/30/2018 | | 63.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 09/18/2018 | | 61.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/16/2019 | | 69.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/05/2019 | | 61.6000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-10D | 05/19/2020 | | 62.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/05/2020 | | 52.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/06/2021 | | 49.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/02/2021 | | 67.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 04/07/2016 | | 127.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/26/2016 | | 122.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 08/10/2016 | | 132.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 09/28/2016 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/30/2016 | | 137.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 01/26/2017 | | 133.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/24/2017 | | 109.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 08/09/2017 | | 124.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/29/2018 | | 122.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 09/14/2018 | | 126.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/14/2019 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/07/2019 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/27/2020 | | 142.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/05/2020 | | 134.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/05/2021 | | 141.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/01/2021 | | 150.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 04/06/2016 | | 141.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/25/2016 | | 152.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 08/09/2016 | | 140.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 09/27/2016 | | 147.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/29/2016 | | 140.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 01/25/2017 | | 166.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/23/2017 | | 129.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 08/08/2017 | | 151.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/30/2018 | | 118.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 09/17/2018 | | 122.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-12D | 05/16/2019 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/06/2019 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/18/2020 | | 113.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/05/2020 | | 108.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/03/2021 | | 69.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/01/2021 | | 95.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 04/06/2016 | | 87.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/25/2016 | | 99.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 08/09/2016 | | 112.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 09/27/2016 | | 133.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/29/2016 | | 176.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 01/25/2017 | | 190.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/23/2017 | | 154.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 08/08/2017 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/30/2018 | | 112.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 09/18/2018 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/16/2019 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/06/2019 | | 85.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/19/2020 | | 96.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/05/2020 | | 79.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/06/2021 | | 72.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/01/2021 | | 84.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 04/07/2016 | | 526.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/26/2016 | | 620.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 08/10/2016 | | 358.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 09/28/2016 | | 355.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/30/2016 | | 352.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 01/26/2017 | | 520.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/23/2017 | | 662.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 08/09/2017 | | 541.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-14D | 05/30/2018 | | 664.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 09/17/2018 | | 610.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/15/2019 | | 567.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/07/2019 | | 479.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/26/2020 | | 820.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/05/2020 | | 445.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/05/2021 | | 809.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/01/2021 | | 751.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 04/07/2016 | | 87.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/26/2016 | | 86.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 08/09/2016 | | 84.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 09/27/2016 | | 68.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/29/2016 | | 70.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 01/26/2017 | | 60.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/23/2017 | | 54.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 08/09/2017 | | 57.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/29/2018 | | 38.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 09/17/2018 | | 31.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/15/2019 | | 53.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/07/2019 | | 29.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/26/2020 | | 37.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/06/2020 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/05/2021 | | 23.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/03/2021 | | 23.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 04/05/2016 | | 108.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/24/2016 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 08/08/2016 | | 103.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 09/26/2016 | | 77.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/28/2016 | | 91.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 01/24/2017 | | 90.2000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-2D | 05/22/2017 | | 73.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 08/07/2017 | | 87.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/29/2018 | | 36.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 09/17/2018 | | 32.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/15/2019 | | 45.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/05/2019 | | 65.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/19/2020 | | 42.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/04/2020 | | 55.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/03/2021 | | 40.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/01/2021 | | 56.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 04/06/2016 | | 150.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/25/2016 | | 132.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 08/09/2016 | | 120.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 09/27/2016 | | 107.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/29/2016 | | 127.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 01/25/2017 | | 150.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/23/2017 | | 136.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 08/08/2017 | | 152.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/30/2018 | | 120.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 09/18/2018 | | 110.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/15/2019 | | 125.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/06/2019 | | 95.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/27/2020 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/17/2020 | | 91.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/06/2021 | | 96.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/02/2021 | | 103.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 04/06/2016 | | 146.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/25/2016 | | 134.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 08/08/2016 | | 123.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 09/27/2016 | | 102.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-9D | 11/29/2016 | | 119.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 01/25/2017 | | 109.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/23/2017 | | 71.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 08/08/2017 | | 65.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/30/2018 | | 48.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 09/17/2018 | | 43.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/16/2019 | | 44.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/06/2019 | | 33.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/19/2020 | | 32.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/04/2020 | | 25.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/03/2021 | | 25.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/04/2021 | | 23.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 04/06/2016 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/25/2016 | | 79.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 08/08/2016 | | 68.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 09/27/2016 | | 58.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/28/2016 | | 62.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 01/25/2017 | | 59.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/23/2017 | | 51.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 08/08/2017 | | 56.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/30/2018 | | 35.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 09/17/2018 | | 37.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/16/2019 | | 38.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/06/2019 | | 30.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/19/2020 | | 30.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/04/2020 | | 23.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/03/2021 | | 30.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/04/2021 | | 28.5000 | * | 20.0000 |
| Molybdenum, Total | ug/L | MW-10D | 04/06/2016 | | 264.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/25/2016 | | 288.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-10D | 08/09/2016 | | 290.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 09/27/2016 | | 259.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/29/2016 | | 274.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 01/25/2017 | | 251.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/23/2017 | | 235.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 08/08/2017 | | 220.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/30/2018 | | 168.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 09/18/2018 | | 141.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/16/2019 | | 99.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/05/2019 | | 76.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/19/2020 | | 72.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/05/2020 | | 88.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/06/2021 | | 97.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/02/2021 | | 84.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 04/06/2016 | | 286.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/25/2016 | | 257.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 08/09/2016 | | 270.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 09/27/2016 | | 274.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/29/2016 | | 249.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 01/25/2017 | | 254.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/23/2017 | | 214.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 08/08/2017 | | 232.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/30/2018 | | 232.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 09/17/2018 | | 239.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/16/2019 | | 219.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/06/2019 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/18/2020 | | 227.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/05/2020 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/03/2021 | | 173.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/01/2021 | | 176.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-13D | 04/06/2016 | | 646.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/25/2016 | | 575.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 08/09/2016 | | 671.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 09/27/2016 | | 647.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/29/2016 | | 695.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 01/25/2017 | | 704.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/23/2017 | | 667.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 08/08/2017 | | 651.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/30/2018 | | 922.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 09/18/2018 | | 857.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/16/2019 | | 1090.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/06/2019 | | 880.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/19/2020 | | 881.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/05/2020 | | 859.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/06/2021 | | 762.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/01/2021 | | 599.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 04/07/2016 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/26/2016 | | 187.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 08/10/2016 | | 254.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 09/28/2016 | | 242.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/30/2016 | | 245.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 01/26/2017 | | 219.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/23/2017 | | 224.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 08/09/2017 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/30/2018 | | 185.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 09/17/2018 | | 185.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/15/2019 | | 188.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/07/2019 | | 267.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/26/2020 | | 187.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/05/2020 | | 259.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-14D | 05/05/2021 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/01/2021 | | 257.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 04/07/2016 | | 234.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/26/2016 | | 205.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 08/09/2016 | | 159.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 09/27/2016 | | 130.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/29/2016 | | 128.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 01/26/2017 | | 121.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/23/2017 | | 97.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 08/09/2017 | | 76.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/29/2018 | | 63.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 09/17/2018 | | 51.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/15/2019 | | 54.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/07/2019 | | 47.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/26/2020 | | 44.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/06/2020 | | 34.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/05/2021 | | 39.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/03/2021 | | 33.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 04/05/2016 | | 289.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/24/2016 | | 286.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 08/08/2016 | | 273.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 09/26/2016 | | 256.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/28/2016 | | 279.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 01/24/2017 | | 262.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/22/2017 | | 263.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 08/07/2017 | | 241.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/29/2018 | | 250.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 09/17/2018 | | 194.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/15/2019 | | 106.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/05/2019 | | 79.6000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-2D | 05/19/2020 | | 89.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/04/2020 | | 76.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/03/2021 | | 56.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/01/2021 | | 56.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 04/06/2016 | | 423.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/25/2016 | | 445.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 08/09/2016 | | 460.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 09/27/2016 | | 448.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/29/2016 | | 488.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 01/25/2017 | | 461.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/23/2017 | | 441.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 08/08/2017 | | 455.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/30/2018 | | 544.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 09/18/2018 | | 574.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/15/2019 | | 616.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/06/2019 | | 617.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/27/2020 | | 736.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/17/2020 | | 697.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/06/2021 | | 704.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/02/2021 | | 688.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 04/06/2016 | | 130.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/25/2016 | | 132.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 08/08/2016 | | 128.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 09/27/2016 | | 122.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/29/2016 | | 140.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 01/25/2017 | | 143.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/23/2017 | | 124.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 08/08/2017 | | 96.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/30/2018 | | 109.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 09/17/2018 | | 85.5000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.


## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-9D | 05/16/2019 | | 50.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/06/2019 | | 53.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/19/2020 | | 55.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/04/2020 | | 45.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/03/2021 | | 49.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/04/2021 | | 41.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 04/06/2016 | | 214.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/25/2016 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 08/08/2016 | | 201.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 09/27/2016 | | 191.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/28/2016 | | 189.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 01/25/2017 | | 157.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/23/2017 | | 130.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 08/08/2017 | | 115.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/30/2018 | | 125.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 09/17/2018 | | 110.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/16/2019 | | 96.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/06/2019 | | 91.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/19/2020 | | 95.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/04/2020 | | 89.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/03/2021 | | 134.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/04/2021 | | 123.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

# False Positive and False Negative Rates for Current Upgradient vs. Downgradient Monitoring Program



**MAY 2022**

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/03/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 11/03/2021 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15I | 05/05/2022 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/03/2020 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 11/03/2021 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15I | 05/05/2022 | ND | 1.0000 | | |
| Barium, Total | ug/L | MW-15I | 09/18/2018 | | 62.1000 | | |
| Barium, Total | ug/L | MW-15I | 11/29/2018 | | 66.0000 | | |
| Barium, Total | ug/L | MW-15I | 02/04/2019 | | 77.1000 | | |
| Barium, Total | ug/L | MW-15I | 03/25/2019 | | 78.8000 | | |
| Barium, Total | ug/L | MW-15I | 05/14/2019 | | 78.1000 | | |
| Barium, Total | ug/L | MW-15I | 07/24/2019 | | 66.2000 | | |
| Barium, Total | ug/L | MW-15I | 11/05/2019 | | 59.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-15I | 01/29/2020 | | 56.6000 | | |
| Barium, Total | ug/L | MW-15I | 05/27/2020 | | 72.8000 | | |
| Barium, Total | ug/L | MW-15I | 11/03/2020 | | 61.9000 | | |
| Barium, Total | ug/L | MW-15I | 05/06/2021 | | 67.4000 | | |
| Barium, Total | ug/L | MW-15I | 11/03/2021 | | 67.9000 | | |
| Barium, Total | ug/L | MW-15I | 05/05/2022 | | 56.0000 | | |
| Beryllium, Total | ug/L | MW-15I | 09/18/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 11/29/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 02/04/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 03/25/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/14/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 07/24/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 11/05/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 01/29/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/27/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 11/03/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/06/2021 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15I | 05/05/2022 | ND | 0.2000 | | |
| Cadmium, Total | ug/L | MW-15I | 09/18/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 11/29/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 02/04/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 03/25/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 05/14/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 07/24/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 11/05/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | 2.0000 | ** |
| Cadmium, Total | ug/L | MW-15I | 05/27/2020 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 05/06/2021 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 11/03/2021 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15I | 05/05/2022 | ND | 2.0000 | | |
| Chromium, Total | ug/L | MW-15I | 09/18/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/29/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 02/04/2019 | ND | 10.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-15I | 03/25/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 05/14/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 07/24/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/05/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 01/29/2020 | ND | 20.0000 | 10.0000 | ** |
| Chromium, Total | ug/L | MW-15I | 05/27/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/03/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 05/06/2021 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 11/03/2021 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15I | 05/05/2022 | ND | 10.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/03/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 11/03/2021 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15I | 05/05/2022 | ND | 1.0000 | | |
| Fluoride | mg/L | MW-15I | 09/18/2018 | | 0.1100 | | |
| Fluoride | mg/L | MW-15I | 11/29/2018 | | 0.1300 | | |
| Fluoride | mg/L | MW-15I | 02/04/2019 | | 0.1200 | | |
| Fluoride | mg/L | MW-15I | 03/25/2019 | | 0.1300 | | |
| Fluoride | mg/L | MW-15I | 05/14/2019 | | 0.1100 | | |
| Fluoride | mg/L | MW-15I | 07/24/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 11/05/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 01/29/2020 | | 0.1200 | | |
| Fluoride | mg/L | MW-15I | 05/27/2020 | | 0.1200 | | |
| Fluoride | mg/L | MW-15I | 11/03/2020 | ND | 0.1000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-15I | 05/06/2021 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 11/03/2021 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15I | 05/05/2022 | | 0.1200 | | |
| Lead, Total | ug/L | MW-15I | 09/18/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/29/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 02/04/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 03/25/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/14/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 07/24/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/05/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 01/29/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/27/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/03/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/06/2021 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 11/03/2021 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15I | 05/05/2022 | ND | 10.0000 | | |
| Lithium, Total | ug/L | MW-15I | 09/18/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/29/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 02/04/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 03/25/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/14/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 07/24/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/05/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 01/29/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/27/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/03/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/06/2021 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 11/03/2021 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15I | 05/05/2022 | ND | 20.0000 | | |
| Mercury | ug/L | MW-15I | 09/18/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 11/29/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 02/04/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 03/25/2019 | ND | 2.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Mercury | ug/L | MW-15I | 05/14/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 07/24/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 11/05/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 01/29/2020 | ND | 0.2000 | 2.0000 | ** |
| Mercury | ug/L | MW-15I | 05/27/2020 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 05/06/2021 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15I | 05/05/2022 | ND | 0.2000 | 2.0000 | ** |
| Molybdenum, Total | ug/L | MW-15I | 09/18/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/29/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 02/04/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 03/25/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 05/14/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 07/24/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/05/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 01/29/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 05/27/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/03/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 05/06/2021 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 11/03/2021 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15I | 05/05/2022 | ND | 10.0000 | | |
| Selenium, Total | ug/L | MW-15I | 09/18/2018 | | 1.9000 | | |
| Selenium, Total | ug/L | MW-15I | 11/29/2018 | | 1.9000 | | |
| Selenium, Total | ug/L | MW-15I | 02/04/2019 | | 2.1000 | | |
| Selenium, Total | ug/L | MW-15I | 03/25/2019 | | 1.9000 | | |
| Selenium, Total | ug/L | MW-15I | 05/14/2019 | | 1.5000 | | |
| Selenium, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 01/29/2020 | | 1.7000 | | |
| Selenium, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 11/03/2020 | | 2.0000 | | |
| Selenium, Total | ug/L | MW-15I | 05/06/2021 | | 1.7000 | | |
| Selenium, Total | ug/L | MW-15I | 11/03/2021 | | 1.0000 | | |
| Selenium, Total | ug/L | MW-15I | 05/05/2022 | | 1.9000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Thallium, Total | ug/L | MW-15I | 09/18/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 11/29/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 02/04/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 03/25/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/14/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 07/24/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 11/05/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 01/29/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/27/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/06/2021 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15I | 05/05/2022 | ND | 1.0000 | | |
| Total Radium | pCi/L | MW-15I | 09/18/2018 | | 0.7100 | | |
| Total Radium | pCi/L | MW-15I | 11/29/2018 | | 0.7930 | | |
| Total Radium | pCi/L | MW-15I | 02/04/2019 | | 0.8490 | | |
| Total Radium | pCi/L | MW-15I | 03/25/2019 | | 1.6500 | | |
| Total Radium | pCi/L | MW-15I | 05/14/2019 | | 1.6300 | | |
| Total Radium | pCi/L | MW-15I | 07/24/2019 | | 1.6200 | | |
| Total Radium | pCi/L | MW-15I | 11/05/2019 | ND | 1.4600 | 1.4100 | ** |
| Total Radium | pCi/L | MW-15I | 01/29/2020 | | 0.5700 | | |
| Total Radium | pCi/L | MW-15I | 05/27/2020 | | 1.0500 | | |
| Total Radium | pCi/L | MW-15I | 11/03/2020 | | 0.6830 | | |
| Total Radium | pCi/L | MW-15I | 05/06/2021 | | 0.9160 | | |
| Total Radium | pCi/L | MW-15I | 11/03/2021 | | 1.1800 | | |
| Total Radium | pCi/L | MW-15I | 05/05/2022 | ND | 1.4100 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10S | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-11S | 05/11/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/06/2022 | | 2.0000 | *** | 1.0000 |
| Antimony, Total | ug/L | MW-13S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1S | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-2S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/02/2022 | | 4.9000 | *** | 1.0000 |
| Antimony, Total | ug/L | MW-4S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-5S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-6S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-7S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-8S | 05/13/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 11/09/2020 | | 7.3000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/02/2022 | | 448.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/11/2022 | | 10.5000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/06/2022 | | 46.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/04/2022 | | 312.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/09/2022 | | 9.6000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/04/2022 | | 8.8000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/02/2022 | | 1.3000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/04/2022 | | 1.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-5S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/04/2022 | | 6.9000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/04/2022 | | 374.0000 | *** | 1.0000 |
| Arsenic, Total | ug/L | MW-8S | 05/13/2022 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 11/09/2020 | ND | 1.0000 | ** | 1.0000 |
| Barium, Total | ug/L | MW-10S | 05/02/2022 | | 75.8000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/11/2022 | | 175.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-12S | 05/06/2022 | | 31.1000 | | 88.7854 |
| Barium, Total | ug/L | MW-13S | 05/04/2022 | | 43.6000 | | 88.7854 |
| Barium, Total | ug/L | MW-1S | 05/09/2022 | | 69.9000 | | 88.7854 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-2S | 05/04/2022 | | 97.1000 | *** | 88.7854 |
| Barium, Total | ug/L | MW-3S | 05/02/2022 | | 31.4000 | | 88.7854 |
| Barium, Total | ug/L | MW-4S | 05/04/2022 | | 90.7000 | * | 88.7854 |
| Barium, Total | ug/L | MW-5S | 05/04/2022 | | 37.4000 | | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/04/2022 | | 132.0000 | *** | 88.7854 |
| Barium, Total | ug/L | MW-7S | 05/04/2022 | | 37.7000 | | 88.7854 |
| Barium, Total | ug/L | MW-8S | 05/13/2022 | | 36.8000 | | 88.7854 |
| Barium, Total | ug/L | MW-9S | 11/09/2020 | | 52.0000 | | 88.7854 |
| Beryllium, Total | ug/L | MW-10S | 05/02/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/11/2022 | | 0.4000 | * | 0.2000 |
| Beryllium, Total | ug/L | MW-12S | 05/06/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-13S | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-1S | 05/09/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-2S | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-3S | 05/02/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-4S | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-5S | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-6S | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-7S | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-8S | 05/13/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-9S | 11/09/2020 | ND | 0.2000 | | 0.2000 |
| Cadmium, Total | ug/L | MW-10S | 05/02/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-11S | 05/11/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-12S | 05/06/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-13S | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-1S | 05/09/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-2S | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-3S | 05/02/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-4S | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-5S | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-6S | 05/04/2022 | ND | 2.0000 | | 2.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cadmium, Total | ug/L | MW-7S | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-8S | 05/13/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-9S | 05/29/2020 | ND | 2.0000 | | 2.0000 |
| Chromium, Total | ug/L | MW-10S | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/11/2022 | | 14.8000 | * | 10.0000 |
| Chromium, Total | ug/L | MW-12S | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-13S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-1S | 05/09/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-2S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-3S | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-4S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-5S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-6S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-7S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-8S | 05/13/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-9S | 11/09/2020 | ND | 10.0000 | | 10.0000 |
| Cobalt, Total | ug/L | MW-10S | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/11/2022 | | 4.9000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-12S | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-1S | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-2S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-3S | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-4S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-5S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/04/2022 | | 1.5000 | *** | 1.0000 |
| Cobalt, Total | ug/L | MW-7S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-8S | 05/13/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-9S | 11/09/2020 | ND | 1.0000 | | 1.0000 |
| Fluoride | mg/L | MW-10S | 05/02/2022 | | 2.6000 | *** | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/11/2022 | | 1.8000 | *** | 0.2434 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-12S | 05/06/2022 | | 2.1000 | *** | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/04/2022 | | 1.1000 | *** | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/09/2022 | | 0.4100 | *** | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/04/2022 | | 0.3900 | *** | 0.2434 |
| Fluoride | mg/L | MW-3S | 05/02/2022 | ND | 0.1000 | | 0.2434 |
| Fluoride | mg/L | MW-4S | 05/04/2022 | ND | 0.1000 | | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/04/2022 | | 1.8000 | *** | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/04/2022 | | 1.3000 | *** | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/04/2022 | | 0.7200 | *** | 0.2434 |
| Fluoride | mg/L | MW-8S | 05/13/2022 | ND | 0.1000 | | 0.2434 |
| Fluoride | mg/L | MW-9S | 11/09/2020 | | 0.2100 | | 0.2434 |
| Lead, Total | ug/L | MW-10S | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-11S | 05/11/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-12S | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-13S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-1S | 05/09/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-2S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-3S | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-4S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-5S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-6S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-7S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-8S | 05/13/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-9S | 11/09/2020 | ND | 10.0000 | | 10.0000 |
| Lithium, Total | ug/L | MW-10S | 05/02/2022 | | 40.8000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/11/2022 | | 25.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/06/2022 | | 67.8000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/04/2022 | | 62.2000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-1S | 05/09/2022 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-2S | 05/04/2022 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-3S | 05/02/2022 | ND | 20.0000 | | 20.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-4S | 05/04/2022 | ND | 20.0000 | ** | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/04/2022 | | 46.5000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/04/2022 | | 71.2000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/04/2022 | | 86.7000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/13/2022 | | 101.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 11/09/2020 | | 72.7000 | *** | 20.0000 |
| Mercury | ug/L | MW-10S | 05/02/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-11S | 05/11/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-12S | 05/06/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-13S | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-1S | 05/09/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-2S | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-3S | 05/02/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-4S | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-5S | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-6S | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-7S | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-8S | 05/13/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-9S | 05/29/2020 | ND | 2.0000 | | 2.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/02/2022 | | 65.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/11/2022 | | 82.5000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/06/2022 | | 118.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/04/2022 | | 557.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/09/2022 | | 25.9000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/04/2022 | | 15.5000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/02/2022 | | 32.9000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-4S | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/04/2022 | | 122.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/04/2022 | | 150.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/04/2022 | | 582.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/13/2022 | | 165.0000 | *** | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-9S | 11/09/2020 | | 201.0000 | *** | 10.0000 |
| Selenium, Total | ug/L | MW-10S | 05/02/2022 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-11S | 05/11/2022 | | 1.1000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/06/2022 | | 26.3000 | *** | 2.1000 |
| Selenium, Total | ug/L | MW-13S | 05/04/2022 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-1S | 05/09/2022 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-2S | 05/04/2022 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/02/2022 | | 26.4000 | *** | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 05/04/2022 | | 119.0000 | *** | 2.1000 |
| Selenium, Total | ug/L | MW-5S | 05/04/2022 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/04/2022 | | 4.4000 | *** | 2.1000 |
| Selenium, Total | ug/L | MW-7S | 05/04/2022 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/13/2022 | | 5.2000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 11/09/2020 | | 15.9000 | *** | 2.1000 |
| Thallium, Total | ug/L | MW-10S | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-11S | 05/11/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-12S | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-13S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-1S | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-2S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-3S | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-4S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-5S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-6S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-7S | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-8S | 05/13/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-9S | 05/29/2020 | ND | 1.0000 | | 1.0000 |
| Total Radium | pCi/L | MW-10S | 05/02/2022 | | 0.9770 | | 2.4106 |
| Total Radium | pCi/L | MW-11S | 05/11/2022 | ND | 1.8300 | | 2.4106 |
| Total Radium | pCi/L | MW-12S | 05/06/2022 | ND | 1.6700 | | 2.4106 |
| Total Radium | pCi/L | MW-13S | 05/04/2022 | ND | 1.4600 | | 2.4106 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-1S | 05/09/2022 | | 0.9560 | | 2.4106 |
| Total Radium | pCi/L | MW-2S | 05/04/2022 | | 1.6700 | | 2.4106 |
| Total Radium | pCi/L | MW-3S | 05/02/2022 | | 0.5310 | | 2.4106 |
| Total Radium | pCi/L | MW-4S | 05/04/2022 | ND | 1.4500 | | 2.4106 |
| Total Radium | pCi/L | MW-5S | 05/04/2022 | | 1.0100 | | 2.4106 |
| Total Radium | pCi/L | MW-6S | 05/04/2022 | ND | 1.8000 | | 2.4106 |
| Total Radium | pCi/L | MW-7S | 05/04/2022 | | 0.7890 | | 2.4106 |
| Total Radium | pCi/L | MW-8S | 05/13/2022 | | 0.5950 | | 2.4106 |
| Total Radium | pCi/L | MW-9S | 11/09/2020 | ND | 1.8600 | | 2.4106 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-3

## Detection Frequencies in Upgradient and Downgradient Wells

| Constituent | Upgradient Detect | Upgradient N | Upgradient Proportion | Downgradient Detect | Downgradient N | Downgradient Proportion |
|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 13 | 0.000 | 43 | 211 | 0.204 |
| Arsenic, Total | 0 | 13 | 0.000 | 134 | 210 | 0.638 |
| Barium, Total | 13 | 13 | 1.000 | 211 | 211 | 1.000 |
| Beryllium, Total | 0 | 12 | 0.000 | 2 | 186 | 0.011 |
| Cadmium, Total | 0 | 12 | 0.000 | 3 | 185 | 0.016 |
| Chromium, Total | 0 | 13 | 0.000 | 9 | 211 | 0.043 |
| Cobalt, Total | 0 | 13 | 0.000 | 17 | 198 | 0.086 |
| Fluoride | 8 | 13 | 0.615 | 206 | 224 | 0.920 |
| Lead, Total | 0 | 13 | 0.000 | 2 | 198 | 0.010 |
| Lithium, Total | 0 | 13 | 0.000 | 165 | 211 | 0.782 |
| Mercury | 0 | 11 | 0.000 | 0 | 173 | 0.000 |
| Molybdenum, Total | 0 | 13 | 0.000 | 196 | 211 | 0.929 |
| Selenium, Total | 10 | 13 | 0.769 | 45 | 211 | 0.213 |
| Thallium, Total | 0 | 11 | 0.000 | 0 | 173 | 0.000 |
| Total Radium | 11 | 13 | 0.846 | 165 | 209 | 0.789 |

N = Total number of measurements in all wells.
Detect = Total number of detections in all wells.
Proportion = Detect/N.

## Table C-4

## Shapiro-Wilk Multiple Group Test of Normality

| Constituent | Detect | N | Detect Freq | G raw | G log | G cbrt | G sqrt | G sqr | G cub | Crit Value | Dist Form | Model Type |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Arsenic, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Barium, Total | 13 | 13 | 1.000 | 0.410 | 0.235 | | | | | 2.326 | normal | normal |
| Beryllium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Cadmium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Chromium, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Cobalt, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Fluoride | 8 | 13 | 0.615 | 1.998 | 2.046 | | | | | 2.326 | normal | normal |
| Lead, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Lithium, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Mercury | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Molybdenum, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Selenium, Total | 10 | 13 | 0.769 | 2.359 | 2.789 | | | | | 2.326 | non-norm | nonpar |
| Thallium, Total | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Total Radium | 11 | 13 | 0.846 | 0.974 | 0.592 | | | | | 2.326 | normal | normal |

* - Distribution override for that constituent.
Fit to distribution is confirmed if G <= critical value.
Model type may not match distributional form when detection frequency < 50%.

## Table C-5

## Summary Statistics and Prediction Limits

| Constituent | Units | Detect | N | Mean | SD | alpha | Factor | Pred Limit | Type | | Conf |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | 0 | 13 | | | | | 1.0000 | nonpar | *** | 0.90 |
| Arsenic, Total | ug/L | 0 | 13 | | | | | 1.0000 | nonpar | *** | 0.90 |
| Barium, Total | ug/L | 13 | 13 | 66.9154 | 7.8729 | 0.0100 | 2.7779 | 88.7854 | normal | | |
| Beryllium, Total | ug/L | 0 | 12 | | | | | 0.2000 | nonpar | *** | 0.89 |
| Cadmium, Total | ug/L | 0 | 12 | | | | | 2.0000 | nonpar | *** | 0.89 |
| Chromium, Total | ug/L | 0 | 13 | | | | | 10.0000 | nonpar | *** | 0.90 |
| Cobalt, Total | ug/L | 0 | 13 | | | | | 1.0000 | nonpar | *** | 0.90 |
| Fluoride | mg/L | 8 | 13 | 0.0738 | 0.0611 | 0.0100 | 2.7779 | 0.2434 | normal | | |
| Lead, Total | ug/L | 0 | 13 | | | | | 10.0000 | nonpar | *** | 0.90 |
| Lithium, Total | ug/L | 0 | 13 | | | | | 20.0000 | nonpar | *** | 0.90 |
| Mercury | ug/L | 0 | 11 | | | | | 2.0000 | nonpar | *** | 0.87 |
| Molybdenum, Total | ug/L | 0 | 13 | | | | | 10.0000 | nonpar | *** | 0.90 |
| Selenium, Total | ug/L | 10 | 13 | | | | | 2.1000 | nonpar | | 0.90 |
| Thallium, Total | ug/L | 0 | 11 | | | | | 1.0000 | nonpar | *** | 0.87 |
| Total Radium | pCi/L | 11 | 13 | 0.8962 | 0.5451 | 0.0100 | 2.7779 | 2.4106 | normal | | |

Conf = confidence level for passing initial test or one verification resample at all downgradient wells for a single constituent (nonparametric test only).
* - Insufficient Data.
** - Calculated limit raised to Manual Reporting Limit.
*** - Nonparametric limit based on ND value.
For transformed data, mean and SD in transformed units and prediction limit in original units.
All sample sizes and statistics are based on outlier free data.
For nonparametric limits, median reporting limits are substituted for extreme reporting limit values.

## Table C-6

## Dixon's Test Outliers
## 1% Significance Level

| Constituent | Units | Well | Date | Result | ND Qualifier | Date Range | N | Critical Value |
|---|---|---|---|---|---|---|---|---|

N = Total number of independent measurements in background at each well.
Date Range = Dates of the first and last measurements included in background at each well.
Critical Value depends on the significance level and on N-1 when the two most extreme values are tested or N for the most extreme value.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-12S | 04/06/2016 | | 6.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/25/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 08/09/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 09/27/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/29/2016 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 01/25/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/23/2017 | | 7.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 08/08/2017 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/30/2018 | ND | 6.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 09/17/2018 | | 3.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/16/2019 | | 4.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/29/2020 | | 2.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/05/2020 | | 2.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 11/01/2021 | | 2.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-12S | 05/06/2022 | | 2.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 04/05/2016 | | 9.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/25/2016 | | 8.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 08/08/2016 | | 8.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 09/26/2016 | | 10.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/28/2016 | | 8.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 01/24/2017 | | 6.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/22/2017 | | 9.6000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 08/07/2017 | | 7.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/29/2018 | | 8.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 09/17/2018 | | 9.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/14/2019 | | 7.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/05/2019 | | 8.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/18/2020 | | 7.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 11/03/2020 | | 7.7000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/03/2021 | | 5.5000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-3S | 11/01/2021 | | 7.3000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-3S | 05/02/2022 | | 4.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 04/06/2016 | | 14.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/25/2016 | | 14.4000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 08/08/2016 | | 13.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 09/27/2016 | | 14.1000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 11/28/2016 | | 11.9000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 01/25/2017 | | 12.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/23/2017 | | 12.6000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 08/08/2017 | | 8.0000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/30/2018 | | 11.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 09/17/2018 | | 11.5000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/16/2019 | | 9.2000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 05/29/2020 | | 8.8000 | * | 1.0000 |
| Antimony, Total | ug/L | MW-9S | 11/09/2020 | | 7.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 04/06/2016 | | 455.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/25/2016 | | 440.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 08/09/2016 | | 484.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 09/27/2016 | | 492.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/29/2016 | | 545.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 01/25/2017 | | 507.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/23/2017 | | 440.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 08/08/2017 | | 494.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/30/2018 | | 444.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 09/18/2018 | | 343.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/16/2019 | | 349.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/05/2019 | | 385.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/19/2020 | | 358.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 11/05/2020 | | 349.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/06/2021 | | 413.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-10S | 11/02/2021 | | 429.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-10S | 05/02/2022 | | 448.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 04/07/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/26/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 08/10/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 09/28/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/30/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 01/26/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/24/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 08/09/2017 | | 12.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/29/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 09/14/2018 | | 2.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/15/2019 | | 3.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/07/2019 | | 2.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/27/2020 | | 13.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/05/2020 | | 2.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/05/2021 | | 2.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 11/01/2021 | | 2.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-11S | 05/11/2022 | | 10.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 04/06/2016 | | 15.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/25/2016 | | 14.7000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 08/09/2016 | | 15.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 09/27/2016 | | 15.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/29/2016 | | 14.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 01/25/2017 | | 18.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/23/2017 | | 19.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 08/08/2017 | | 16.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/30/2018 | | 43.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 09/17/2018 | | 38.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/16/2019 | | 30.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-12S | 05/29/2020 | | 64.7000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/05/2020 | | 46.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 11/01/2021 | | 43.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-12S | 05/06/2022 | | 46.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 04/06/2016 | | 365.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/25/2016 | | 369.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 08/09/2016 | | 376.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 09/27/2016 | | 416.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/29/2016 | | 426.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 01/25/2017 | | 397.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/23/2017 | | 386.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 08/08/2017 | | 371.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/30/2018 | | 375.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 09/18/2018 | | 320.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/15/2019 | | 324.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/07/2019 | | 352.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/19/2020 | | 311.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/05/2020 | | 433.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/06/2021 | | 321.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 11/02/2021 | | 368.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-13S | 05/04/2022 | | 312.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 04/07/2016 | | 49.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/26/2016 | | 22.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 08/09/2016 | | 34.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 09/27/2016 | | 10.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/29/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 01/26/2017 | | 35.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/23/2017 | | 23.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 08/09/2017 | | 14.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/29/2018 | | 168.0000 | *** | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-1S | 09/17/2018 | | 33.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/15/2019 | | 13.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/07/2019 | | 50.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/26/2020 | | 12.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/06/2020 | | 21.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/05/2021 | | 24.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 11/03/2021 | | 7.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-1S | 05/09/2022 | | 9.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 04/05/2016 | | 26.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/24/2016 | | 22.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 08/08/2016 | | 27.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 09/26/2016 | | 22.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/28/2016 | | 21.7000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 01/24/2017 | | 17.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/22/2017 | | 27.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 08/07/2017 | | 19.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/29/2018 | | 18.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 09/17/2018 | | 14.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/14/2019 | | 12.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/05/2019 | | 14.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/19/2020 | | 9.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/04/2020 | | 16.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/03/2021 | | 6.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 11/01/2021 | | 28.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-2S | 05/04/2022 | | 8.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 04/05/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/25/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 08/08/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 09/26/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/28/2016 | ND | 10.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-3S | 01/24/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/22/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 08/07/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/29/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 09/17/2018 | | 2.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/14/2019 | | 2.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/05/2019 | | 1.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/18/2020 | | 1.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/03/2020 | | 1.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/03/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 11/01/2021 | | 1.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-3S | 05/02/2022 | | 1.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 04/05/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/25/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 08/08/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 09/26/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/29/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 01/24/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/22/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 08/07/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/29/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 09/14/2018 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/14/2019 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 06/05/2020 | | 1.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/03/2020 | | 3.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-4S | 05/04/2022 | | 1.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 04/06/2016 | | 28.3000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/25/2016 | | 23.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 08/09/2016 | | 34.3000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-6S | 09/27/2016 | | 30.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/29/2016 | | 35.1000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 01/25/2017 | | 11.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/23/2017 | | 12.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 08/08/2017 | | 11.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/30/2018 | | 13.6000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 09/18/2018 | | 15.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/14/2019 | | 11.4000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/28/2020 | | 23.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/09/2020 | | 39.2000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/05/2021 | | 11.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 11/01/2021 | | 11.8000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-6S | 05/04/2022 | | 6.9000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 04/06/2016 | | 320.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/25/2016 | | 353.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 08/09/2016 | | 365.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 09/27/2016 | | 352.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/29/2016 | | 372.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 01/25/2017 | | 352.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/23/2017 | | 373.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 08/08/2017 | | 359.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/30/2018 | | 383.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 09/18/2018 | | 317.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/15/2019 | | 345.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/06/2019 | | 439.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/27/2020 | | 367.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/17/2020 | | 462.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/06/2021 | | 419.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 11/02/2021 | | 376.0000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-7S | 05/04/2022 | | 374.0000 | * | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-9S | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/25/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 08/08/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 09/27/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 11/28/2016 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 01/25/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/23/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 08/08/2017 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/30/2018 | ND | 10.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 09/17/2018 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/16/2019 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 05/29/2020 | | 1.5000 | * | 1.0000 |
| Arsenic, Total | ug/L | MW-9S | 11/09/2020 | ND | 1.0000 | | 1.0000 |
| Barium, Total | ug/L | MW-11S | 04/07/2016 | | 111.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/26/2016 | | 101.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 08/10/2016 | | 89.5000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 09/28/2016 | | 81.2000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 11/30/2016 | | 161.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 01/26/2017 | | 86.1000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/24/2017 | | 79.7000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 08/09/2017 | | 300.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/29/2018 | | 168.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 09/14/2018 | | 90.6000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/15/2019 | | 81.1000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 11/07/2019 | | 76.7000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/27/2020 | | 304.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-11S | 11/05/2020 | | 76.2000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/05/2021 | | 75.1000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 11/01/2021 | | 74.3000 | | 88.7854 |
| Barium, Total | ug/L | MW-11S | 05/11/2022 | | 175.0000 | * | 88.7854 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-2S | 04/05/2016 | | 205.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/24/2016 | | 158.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 08/08/2016 | | 168.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 09/26/2016 | | 180.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 11/28/2016 | | 185.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 01/24/2017 | | 97.4000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/22/2017 | | 138.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 08/07/2017 | | 127.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/29/2018 | | 90.3000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 09/17/2018 | | 86.0000 | | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/14/2019 | | 123.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 11/05/2019 | | 195.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/19/2020 | | 86.1000 | | 88.7854 |
| Barium, Total | ug/L | MW-2S | 11/04/2020 | | 137.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/03/2021 | | 92.4000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 11/01/2021 | | 103.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-2S | 05/04/2022 | | 97.1000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 04/05/2016 | | 117.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 05/25/2016 | | 136.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 08/08/2016 | | 140.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 09/26/2016 | | 123.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 11/29/2016 | | 128.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 01/24/2017 | | 119.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 05/22/2017 | | 70.3000 | | 88.7854 |
| Barium, Total | ug/L | MW-4S | 08/07/2017 | | 93.8000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 05/29/2018 | | 49.4000 | | 88.7854 |
| Barium, Total | ug/L | MW-4S | 09/14/2018 | | 93.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-4S | 05/14/2019 | | 60.0000 | | 88.7854 |
| Barium, Total | ug/L | MW-4S | 06/05/2020 | | 86.0000 | | 88.7854 |
| Barium, Total | ug/L | MW-4S | 11/03/2020 | | 113.0000 | * | 88.7854 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-4S | 11/01/2021 | | 80.8000 | | 88.7854 |
| Barium, Total | ug/L | MW-4S | 05/04/2022 | | 90.7000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 04/06/2016 | | 150.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/25/2016 | | 112.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 08/09/2016 | | 166.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 09/27/2016 | | 160.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 11/29/2016 | | 189.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 01/25/2017 | | 105.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/23/2017 | | 80.5000 | | 88.7854 |
| Barium, Total | ug/L | MW-6S | 08/08/2017 | | 80.6000 | | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/30/2018 | | 116.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 09/18/2018 | | 132.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/14/2019 | | 103.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/28/2020 | | 141.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 11/09/2020 | | 121.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/05/2021 | | 113.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 11/01/2021 | | 117.0000 | * | 88.7854 |
| Barium, Total | ug/L | MW-6S | 05/04/2022 | | 132.0000 | * | 88.7854 |
| Beryllium, Total | ug/L | MW-11S | 04/07/2016 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/26/2016 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 08/10/2016 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 09/28/2016 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 11/30/2016 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 01/26/2017 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/24/2017 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 08/09/2017 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/29/2018 | ND | 4.0000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/15/2019 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 11/07/2019 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/27/2020 | | 0.7200 | * | 0.2000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Beryllium, Total | ug/L | MW-11S | 11/05/2020 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/05/2021 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11S | 05/11/2022 | | 0.4000 | * | 0.2000 |
| Chromium, Total | ug/L | MW-11S | 04/07/2016 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/26/2016 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 08/10/2016 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 09/28/2016 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 11/30/2016 | | 14.3000 | * | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 01/26/2017 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/24/2017 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 08/09/2017 | | 26.7000 | * | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/29/2018 | | 12.4000 | * | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 09/14/2018 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/15/2019 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 11/07/2019 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/27/2020 | | 34.2000 | * | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 11/05/2020 | ND | 20.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/05/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 11/01/2021 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11S | 05/11/2022 | | 14.8000 | * | 10.0000 |
| Cobalt, Total | ug/L | MW-11S | 04/07/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/26/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 08/10/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 09/28/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 11/30/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 01/26/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/24/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 08/09/2017 | | 10.5000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/29/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/15/2019 | ND | 1.0000 | | 1.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Cobalt, Total | ug/L | MW-11S | 11/07/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/27/2020 | | 10.7000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 11/05/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/05/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 11/01/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11S | 05/11/2022 | | 4.9000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 09/27/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/14/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/28/2020 | | 2.4000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/09/2020 | | 1.6000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/05/2021 | | 1.8000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 11/01/2021 | | 1.6000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-6S | 05/04/2022 | | 1.5000 | * | 1.0000 |
| Fluoride | mg/L | MW-10S | 04/06/2016 | | 3.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 05/25/2016 | | 3.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 08/09/2016 | | 2.2000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 09/27/2016 | | 2.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 11/29/2016 | | 3.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 01/25/2017 | | 2.7000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 05/23/2017 | | 2.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 08/08/2017 | | 2.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 09/20/2017 | | 1.8000 | * | 0.2434 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-10S | 05/30/2018 | | 2.2000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 09/18/2018 | | 2.7000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 05/16/2019 | | 2.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 11/05/2019 | | 2.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 05/19/2020 | | 2.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 11/05/2020 | | 2.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 05/06/2021 | | 2.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 11/02/2021 | | 2.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-10S | 05/02/2022 | | 2.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 04/07/2016 | | 1.2000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/26/2016 | | 1.3000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 08/10/2016 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 09/28/2016 | | 1.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 11/30/2016 | | 1.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 01/26/2017 | | 1.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/24/2017 | | 1.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 08/09/2017 | | 1.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 09/20/2017 | | 1.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/29/2018 | | 1.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 09/14/2018 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/15/2019 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 11/07/2019 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/27/2020 | | 1.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 11/05/2020 | | 1.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/05/2021 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 11/01/2021 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-11S | 05/11/2022 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 04/06/2016 | | 0.3500 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 05/25/2016 | | 0.3700 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 08/09/2016 | | 0.3800 | * | 0.2434 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-12S | 09/27/2016 | | 0.3800 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 11/29/2016 | | 0.4200 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 01/25/2017 | | 0.5200 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 05/23/2017 | | 0.5100 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 08/08/2017 | | 0.5700 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 09/20/2017 | | 0.7500 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 05/30/2018 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 09/17/2018 | | 1.7000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 05/16/2019 | | 1.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 05/29/2020 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 11/05/2020 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 11/01/2021 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-12S | 05/06/2022 | | 2.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 04/06/2016 | | 0.5200 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/25/2016 | | 0.5200 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 08/09/2016 | | 0.4900 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 09/27/2016 | | 0.5200 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 11/29/2016 | | 0.5500 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 01/25/2017 | | 0.5700 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/23/2017 | | 0.6300 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 08/08/2017 | | 0.7200 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 09/20/2017 | | 0.6500 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/30/2018 | | 0.8600 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 09/18/2018 | | 0.8800 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/15/2019 | | 0.8300 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 11/07/2019 | | 0.7800 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/19/2020 | | 0.9300 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 11/05/2020 | | 0.9400 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 05/06/2021 | | 0.9200 | * | 0.2434 |
| Fluoride | mg/L | MW-13S | 11/02/2021 | | 0.8300 | * | 0.2434 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-13S | 05/04/2022 | | 1.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 04/07/2016 | | 0.5200 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/26/2016 | | 0.5700 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 08/09/2016 | | 0.4900 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 09/27/2016 | | 0.5100 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 11/29/2016 | | 0.5800 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 01/26/2017 | | 0.6900 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/23/2017 | | 0.6900 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 08/09/2017 | | 0.7000 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 09/20/2017 | | 0.6200 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/29/2018 | | 0.6200 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 09/17/2018 | | 0.6200 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/15/2019 | | 0.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 11/07/2019 | | 0.4200 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/26/2020 | | 0.3600 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 11/06/2020 | | 0.3500 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/05/2021 | | 0.2400 | | 0.2434 |
| Fluoride | mg/L | MW-1S | 11/03/2021 | | 0.3100 | * | 0.2434 |
| Fluoride | mg/L | MW-1S | 05/09/2022 | | 0.4100 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 04/05/2016 | | 0.8400 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/24/2016 | | 1.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 08/08/2016 | | 1.2000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 09/26/2016 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 11/28/2016 | | 1.3000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 01/24/2017 | | 2.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/22/2017 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 08/07/2017 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 09/20/2017 | | 1.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/29/2018 | | 1.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 09/17/2018 | | 1.8000 | * | 0.2434 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-2S | 05/14/2019 | | 0.9600 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 11/05/2019 | | 0.7000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/19/2020 | | 0.5800 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 11/04/2020 | | 0.2800 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/03/2021 | | 0.4600 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 11/01/2021 | | 0.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-2S | 05/04/2022 | | 0.3900 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 04/06/2016 | | 4.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/25/2016 | | 4.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 08/09/2016 | | 3.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 09/27/2016 | | 3.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 11/29/2016 | | 3.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 01/25/2017 | | 3.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/23/2017 | | 3.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 08/08/2017 | | 3.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 09/20/2017 | | 3.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/30/2018 | | 2.6000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 09/18/2018 | | 3.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/14/2019 | | 2.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/18/2020 | | 2.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 11/05/2020 | | 2.3000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/06/2021 | | 1.7000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 11/01/2021 | | 1.9000 | * | 0.2434 |
| Fluoride | mg/L | MW-5S | 05/04/2022 | | 1.8000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 04/06/2016 | | 0.9300 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/25/2016 | | 0.9400 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 08/09/2016 | | 0.7600 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 09/27/2016 | | 0.8400 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 11/29/2016 | | 0.9100 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 01/25/2017 | | 0.7400 | * | 0.2434 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-6S | 05/23/2017 | | 0.8300 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 08/08/2017 | | 1.1000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 09/20/2017 | | 0.9300 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/30/2018 | | 1.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 09/18/2018 | | 1.2000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/14/2019 | | 0.5500 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/28/2020 | | 1.0000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 11/09/2020 | | 1.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/05/2021 | | 1.3000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 11/01/2021 | | 1.2000 | * | 0.2434 |
| Fluoride | mg/L | MW-6S | 05/04/2022 | | 1.3000 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 04/06/2016 | | 0.3400 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/25/2016 | | 0.3800 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 08/09/2016 | | 0.3400 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 09/27/2016 | | 0.3600 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 11/29/2016 | | 0.3600 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 01/25/2017 | | 0.3400 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/23/2017 | | 0.3700 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 08/08/2017 | | 0.4100 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 09/20/2017 | | 0.4000 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/30/2018 | | 0.4200 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 09/18/2018 | | 0.4500 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/15/2019 | | 0.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 11/06/2019 | | 0.4600 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/27/2020 | | 0.5700 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 11/17/2020 | | 0.5400 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/06/2021 | | 0.5100 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 11/02/2021 | | 0.5000 | * | 0.2434 |
| Fluoride | mg/L | MW-7S | 05/04/2022 | | 0.7200 | * | 0.2434 |
| Lithium, Total | ug/L | MW-10S | 04/06/2016 | | 106.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-10S | 05/25/2016 | | 94.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 08/09/2016 | | 98.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 09/27/2016 | | 79.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/29/2016 | | 96.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 01/25/2017 | | 95.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/23/2017 | | 72.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 08/08/2017 | | 93.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/30/2018 | | 57.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 09/18/2018 | | 59.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/16/2019 | | 69.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/05/2019 | | 60.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/19/2020 | | 75.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/05/2020 | | 49.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/06/2021 | | 45.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 11/02/2021 | | 53.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10S | 05/02/2022 | | 40.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 04/07/2016 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/26/2016 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 08/10/2016 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 09/28/2016 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 11/30/2016 | | 21.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 01/26/2017 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/24/2017 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 08/09/2017 | | 39.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/29/2018 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 09/14/2018 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/15/2019 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 11/07/2019 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/27/2020 | | 41.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 11/05/2020 | ND | 20.0000 | | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-11S | 05/05/2021 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 11/01/2021 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-11S | 05/11/2022 | | 25.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 04/06/2016 | | 215.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/25/2016 | | 196.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 08/09/2016 | | 193.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 09/27/2016 | | 176.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/29/2016 | | 189.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 01/25/2017 | | 158.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/23/2017 | | 155.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 08/08/2017 | | 160.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/30/2018 | | 106.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 09/17/2018 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/16/2019 | | 127.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/29/2020 | | 97.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/05/2020 | | 84.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 11/01/2021 | | 73.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12S | 05/06/2022 | | 67.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 04/06/2016 | | 89.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/25/2016 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 08/09/2016 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 09/27/2016 | | 119.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/29/2016 | | 148.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 01/25/2017 | | 143.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/23/2017 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 08/08/2017 | | 107.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/30/2018 | | 91.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 09/18/2018 | | 84.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/15/2019 | | 99.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/07/2019 | | 75.1000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-13S | 05/19/2020 | | 83.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/05/2020 | | 69.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/06/2021 | | 62.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 11/02/2021 | | 73.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13S | 05/04/2022 | | 62.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 04/05/2016 | | 23.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/25/2016 | | 21.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 08/08/2016 | | 20.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 09/26/2016 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 11/29/2016 | | 25.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 01/24/2017 | | 20.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/22/2017 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 08/07/2017 | | 22.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/29/2018 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 09/14/2018 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/14/2019 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 06/05/2020 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 11/03/2020 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 11/01/2021 | | 23.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-4S | 05/04/2022 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 04/06/2016 | | 89.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/25/2016 | | 78.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 08/09/2016 | | 75.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 09/27/2016 | | 76.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/29/2016 | | 94.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 01/25/2017 | | 85.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/23/2017 | | 57.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 08/08/2017 | | 63.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/30/2018 | | 57.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 09/18/2018 | | 52.8000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-5S | 05/14/2019 | | 59.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/18/2020 | | 54.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/05/2020 | | 41.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/06/2021 | | 42.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 11/01/2021 | | 46.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-5S | 05/04/2022 | | 46.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 04/06/2016 | | 112.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/25/2016 | | 99.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 08/09/2016 | | 102.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 09/27/2016 | | 89.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/29/2016 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 01/25/2017 | | 114.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/23/2017 | | 99.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 08/08/2017 | | 86.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/30/2018 | | 75.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 09/18/2018 | | 58.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/14/2019 | | 117.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/28/2020 | | 84.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/09/2020 | | 61.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/05/2021 | | 62.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 11/01/2021 | | 73.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-6S | 05/04/2022 | | 71.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 04/06/2016 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/25/2016 | | 110.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 08/09/2016 | | 109.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 09/27/2016 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/29/2016 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 01/25/2017 | | 145.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/23/2017 | | 135.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 08/08/2017 | | 131.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-7S | 05/30/2018 | | 103.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 09/18/2018 | | 94.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/15/2019 | | 106.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/06/2019 | | 89.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/27/2020 | | 87.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/17/2020 | | 86.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/06/2021 | | 81.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 11/02/2021 | | 85.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7S | 05/04/2022 | | 86.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 04/07/2016 | | 182.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/26/2016 | | 135.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 08/09/2016 | | 204.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 09/28/2016 | | 184.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/30/2016 | | 184.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 01/26/2017 | | 155.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/23/2017 | | 94.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 08/09/2017 | | 73.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/29/2018 | | 132.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 09/17/2018 | | 147.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/15/2019 | | 124.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/07/2019 | | 174.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/26/2020 | | 124.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/09/2020 | | 188.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/05/2021 | | 123.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 11/04/2021 | | 137.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-8S | 05/13/2022 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 04/06/2016 | | 126.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/25/2016 | | 110.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 08/08/2016 | | 103.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 09/27/2016 | | 84.9000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-9S | 11/28/2016 | | 116.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 01/25/2017 | | 114.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/23/2017 | | 86.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 08/08/2017 | | 90.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/30/2018 | | 93.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 09/17/2018 | | 89.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/16/2019 | | 70.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 05/29/2020 | | 86.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9S | 11/09/2020 | | 72.7000 | * | 20.0000 |
| Molybdenum, Total | ug/L | MW-10S | 04/06/2016 | | 324.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/25/2016 | | 299.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 08/09/2016 | | 279.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 09/27/2016 | | 247.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/29/2016 | | 241.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 01/25/2017 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/23/2017 | | 219.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 08/08/2017 | | 166.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/30/2018 | | 138.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 09/18/2018 | | 117.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/16/2019 | | 93.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/05/2019 | | 93.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/19/2020 | | 82.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/05/2020 | | 77.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/06/2021 | | 72.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 11/02/2021 | | 71.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10S | 05/02/2022 | | 65.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 04/07/2016 | | 77.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/26/2016 | | 81.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 08/10/2016 | | 82.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 09/28/2016 | | 80.7000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-11S | 11/30/2016 | | 82.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 01/26/2017 | | 83.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/24/2017 | | 78.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 08/09/2017 | | 73.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/29/2018 | | 73.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 09/14/2018 | | 74.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/15/2019 | | 73.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/07/2019 | | 75.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/27/2020 | | 83.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/05/2020 | | 80.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/05/2021 | | 77.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 11/01/2021 | | 76.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-11S | 05/11/2022 | | 82.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 04/06/2016 | | 256.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/25/2016 | | 274.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 08/09/2016 | | 279.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 09/27/2016 | | 265.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/29/2016 | | 269.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 01/25/2017 | | 227.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/23/2017 | | 273.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 08/08/2017 | | 283.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/30/2018 | | 287.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 09/17/2018 | | 294.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/16/2019 | | 241.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/29/2020 | | 198.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/05/2020 | | 196.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 11/01/2021 | | 144.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12S | 05/06/2022 | | 118.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 04/06/2016 | | 577.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/25/2016 | | 563.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-13S | 08/09/2016 | | 552.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 09/27/2016 | | 517.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/29/2016 | | 517.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 01/25/2017 | | 481.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/23/2017 | | 508.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 08/08/2017 | | 511.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/30/2018 | | 720.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 09/18/2018 | | 770.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/15/2019 | | 782.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/07/2019 | | 809.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/19/2020 | | 746.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/05/2020 | | 722.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/06/2021 | | 692.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 11/02/2021 | | 553.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13S | 05/04/2022 | | 557.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 04/07/2016 | | 456.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/26/2016 | | 309.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 08/09/2016 | | 199.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 09/27/2016 | | 167.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/29/2016 | | 151.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 01/26/2017 | | 247.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/23/2017 | | 106.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 08/09/2017 | | 88.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/29/2018 | | 57.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 09/17/2018 | | 51.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/15/2019 | | 50.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/07/2019 | | 28.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/26/2020 | | 37.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 11/06/2020 | | 25.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/05/2021 | | 24.8000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-1S | 11/03/2021 | | 28.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1S | 05/09/2022 | | 25.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 04/05/2016 | | 458.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/24/2016 | | 352.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 08/08/2016 | | 248.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 09/26/2016 | | 179.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/28/2016 | | 190.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 01/24/2017 | | 214.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/22/2017 | | 135.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 08/07/2017 | | 141.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/29/2018 | | 78.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 09/17/2018 | | 85.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/14/2019 | | 36.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/05/2019 | | 31.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/19/2020 | | 27.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/04/2020 | | 36.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/03/2021 | | 35.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 11/01/2021 | | 38.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2S | 05/04/2022 | | 15.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 04/05/2016 | | 139.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/25/2016 | | 124.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 08/08/2016 | | 97.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 09/26/2016 | | 77.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/28/2016 | | 98.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 01/24/2017 | | 88.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/22/2017 | | 63.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 08/07/2017 | | 64.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/29/2018 | | 78.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 09/17/2018 | | 52.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/14/2019 | | 43.2000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-3S | 11/05/2019 | | 41.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/18/2020 | | 49.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/03/2020 | | 40.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/03/2021 | | 36.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 11/01/2021 | | 46.7000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-3S | 05/02/2022 | | 32.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 04/06/2016 | | 251.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/25/2016 | | 266.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 08/09/2016 | | 266.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 09/27/2016 | | 275.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 11/29/2016 | | 321.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 01/25/2017 | | 313.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/23/2017 | | 319.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 08/08/2017 | | 307.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/30/2018 | | 265.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 09/18/2018 | | 254.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/14/2019 | | 231.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/18/2020 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 11/05/2020 | | 182.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/06/2021 | | 131.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 11/01/2021 | | 152.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-5S | 05/04/2022 | | 122.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 04/06/2016 | | 309.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/25/2016 | | 261.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 08/09/2016 | | 240.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 09/27/2016 | | 226.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/29/2016 | | 243.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 01/25/2017 | | 166.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/23/2017 | | 142.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 08/08/2017 | | 185.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-6S | 05/30/2018 | | 150.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 09/18/2018 | | 157.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/14/2019 | | 65.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/28/2020 | | 146.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/09/2020 | | 211.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/05/2021 | | 216.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 11/01/2021 | | 186.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-6S | 05/04/2022 | | 150.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 04/06/2016 | | 435.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/25/2016 | | 448.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 08/09/2016 | | 477.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 09/27/2016 | | 468.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/29/2016 | | 486.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 01/25/2017 | | 439.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/23/2017 | | 429.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 08/08/2017 | | 425.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/30/2018 | | 528.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 09/18/2018 | | 518.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/15/2019 | | 575.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/06/2019 | | 608.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/27/2020 | | 705.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/17/2020 | | 681.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/06/2021 | | 676.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 11/02/2021 | | 625.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7S | 05/04/2022 | | 582.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 04/07/2016 | | 258.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/26/2016 | | 210.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 08/09/2016 | | 329.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 09/28/2016 | | 331.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/30/2016 | | 389.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-8S | 01/26/2017 | | 294.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/23/2017 | | 208.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 08/09/2017 | | 150.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/29/2018 | | 419.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 09/17/2018 | | 311.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/15/2019 | | 329.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/07/2019 | | 530.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/26/2020 | | 306.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/09/2020 | | 532.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/05/2021 | | 354.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 11/04/2021 | | 270.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-8S | 05/13/2022 | | 165.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 04/06/2016 | | 519.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/25/2016 | | 438.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 08/08/2016 | | 374.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 09/27/2016 | | 344.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 11/28/2016 | | 368.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 01/25/2017 | | 290.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/23/2017 | | 217.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 08/08/2017 | | 191.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/30/2018 | | 116.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 09/17/2018 | | 98.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/16/2019 | | 118.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 05/29/2020 | | 93.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9S | 11/09/2020 | | 201.0000 | * | 10.0000 |
| Selenium, Total | ug/L | MW-12S | 04/06/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/25/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 08/09/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 09/27/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 11/29/2016 | ND | 10.0000 | | 2.1000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-12S | 01/25/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/23/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 08/08/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/30/2018 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 09/17/2018 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/16/2019 | | 1.4000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/29/2020 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 11/05/2020 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 11/01/2021 | | 10.7000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-12S | 05/06/2022 | | 26.3000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 04/05/2016 | | 11.1000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/25/2016 | | 10.7000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 08/08/2016 | | 15.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 09/26/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 11/28/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 01/24/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/22/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 08/07/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/29/2018 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 09/17/2018 | | 3.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/14/2019 | | 16.5000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 11/05/2019 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/18/2020 | | 8.2000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 11/03/2020 | | 1.5000 | | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/03/2021 | | 9.5000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 11/01/2021 | | 3.6000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-3S | 05/02/2022 | | 26.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 04/05/2016 | | 50.8000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 05/25/2016 | | 31.5000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 08/08/2016 | | 35.6000 | * | 2.1000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-4S | 09/26/2016 | | 13.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 11/29/2016 | | 39.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 01/24/2017 | | 19.6000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 05/22/2017 | | 20.5000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 08/07/2017 | | 19.9000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 05/29/2018 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 09/14/2018 | | 33.8000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 05/14/2019 | | 16.1000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 06/05/2020 | | 12.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 11/03/2020 | | 41.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 11/01/2021 | | 20.3000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-4S | 05/04/2022 | | 119.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 04/06/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/25/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 08/09/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 09/27/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 11/29/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 01/25/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/23/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 08/08/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/30/2018 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 09/18/2018 | | 2.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/14/2019 | | 1.7000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/28/2020 | | 3.7000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 11/09/2020 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/05/2021 | | 3.9000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 11/01/2021 | | 6.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-6S | 05/04/2022 | | 4.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 04/07/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/26/2016 | | 11.0000 | * | 2.1000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.


## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-8S | 08/09/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 09/28/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 11/30/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 01/26/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/23/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 08/09/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/29/2018 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 09/17/2018 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/15/2019 | | 1.6000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 11/07/2019 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/26/2020 | | 2.4000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 11/09/2020 | ND | 1.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/05/2021 | | 2.1000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 11/04/2021 | | 1.3000 | | 2.1000 |
| Selenium, Total | ug/L | MW-8S | 05/13/2022 | | 5.2000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 04/06/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 05/25/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 08/08/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 09/27/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 11/28/2016 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 01/25/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 05/23/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 08/08/2017 | ND | 10.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 05/30/2018 | | 146.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 09/17/2018 | | 66.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 05/16/2019 | | 2.0000 | | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 05/29/2020 | | 120.0000 | * | 2.1000 |
| Selenium, Total | ug/L | MW-9S | 11/09/2020 | | 15.9000 | * | 2.1000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

# False Positive and False Negative Rates for Current Upgradient vs. Downgradient Monitoring Program



# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/03/2020 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 11/03/2021 | ND | 1.0000 | | |
| Antimony, Total | ug/L | MW-15D | 05/11/2022 | ND | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15D | 09/18/2018 | | 1.3000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/29/2018 | | 1.2000 | | |
| Arsenic, Total | ug/L | MW-15D | 02/04/2019 | | 1.3000 | | |
| Arsenic, Total | ug/L | MW-15D | 03/25/2019 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/14/2019 | | 1.0000 | | |
| Arsenic, Total | ug/L | MW-15D | 07/24/2019 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/05/2019 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 01/29/2020 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/27/2020 | | 1.2000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/03/2020 | | 1.7000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/06/2021 | | 1.1000 | | |
| Arsenic, Total | ug/L | MW-15D | 11/03/2021 | | 1.2000 | | |
| Arsenic, Total | ug/L | MW-15D | 05/11/2022 | | 1.2000 | | |
| Barium, Total | ug/L | MW-15D | 09/18/2018 | | 71.4000 | | |
| Barium, Total | ug/L | MW-15D | 11/29/2018 | | 67.8000 | | |
| Barium, Total | ug/L | MW-15D | 02/04/2019 | | 69.6000 | | |
| Barium, Total | ug/L | MW-15D | 03/25/2019 | | 68.4000 | | |
| Barium, Total | ug/L | MW-15D | 05/14/2019 | | 65.6000 | | |
| Barium, Total | ug/L | MW-15D | 07/24/2019 | | 64.6000 | | |
| Barium, Total | ug/L | MW-15D | 11/05/2019 | | 65.3000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-15D | 01/29/2020 | | 65.2000 | | |
| Barium, Total | ug/L | MW-15D | 05/27/2020 | | 64.2000 | | |
| Barium, Total | ug/L | MW-15D | 11/03/2020 | | 63.2000 | | |
| Barium, Total | ug/L | MW-15D | 05/06/2021 | | 68.9000 | | |
| Barium, Total | ug/L | MW-15D | 11/03/2021 | | 69.2000 | | |
| Barium, Total | ug/L | MW-15D | 05/11/2022 | | 75.1000 | | |
| Beryllium, Total | ug/L | MW-15D | 09/18/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 11/29/2018 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 02/04/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 03/25/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/14/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 07/24/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 11/05/2019 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 01/29/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/27/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 11/03/2020 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/06/2021 | ND | 0.2000 | | |
| Beryllium, Total | ug/L | MW-15D | 05/11/2022 | ND | 0.2000 | | |
| Cadmium, Total | ug/L | MW-15D | 09/18/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 11/29/2018 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 02/04/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 03/25/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 05/14/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 07/24/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 11/05/2019 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | 2.0000 | ** |
| Cadmium, Total | ug/L | MW-15D | 05/27/2020 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 05/06/2021 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 11/03/2021 | ND | 2.0000 | | |
| Cadmium, Total | ug/L | MW-15D | 05/11/2022 | ND | 2.0000 | | |
| Chromium, Total | ug/L | MW-15D | 09/18/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/29/2018 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 02/04/2019 | ND | 10.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-15D | 03/25/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 05/14/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 07/24/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/05/2019 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 01/29/2020 | ND | 20.0000 | 10.0000 | ** |
| Chromium, Total | ug/L | MW-15D | 05/27/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/03/2020 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 05/06/2021 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 11/03/2021 | ND | 10.0000 | | |
| Chromium, Total | ug/L | MW-15D | 05/11/2022 | ND | 10.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/03/2020 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 11/03/2021 | ND | 1.0000 | | |
| Cobalt, Total | ug/L | MW-15D | 05/11/2022 | ND | 1.0000 | | |
| Fluoride | mg/L | MW-15D | 09/18/2018 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 11/29/2018 | | 0.1200 | | |
| Fluoride | mg/L | MW-15D | 02/04/2019 | | 0.1200 | | |
| Fluoride | mg/L | MW-15D | 03/25/2019 | | 0.1300 | | |
| Fluoride | mg/L | MW-15D | 05/14/2019 | | 0.1100 | | |
| Fluoride | mg/L | MW-15D | 07/24/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 11/05/2019 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 01/29/2020 | | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 05/27/2020 | | 0.1100 | | |
| Fluoride | mg/L | MW-15D | 11/03/2020 | ND | 0.1000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-15D | 05/06/2021 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 11/03/2021 | ND | 0.1000 | | |
| Fluoride | mg/L | MW-15D | 05/11/2022 | | 0.1200 | | |
| Lead, Total | ug/L | MW-15D | 09/18/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/29/2018 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 02/04/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 03/25/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/14/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 07/24/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/05/2019 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 01/29/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/27/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/03/2020 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/06/2021 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 11/03/2021 | ND | 10.0000 | | |
| Lead, Total | ug/L | MW-15D | 05/11/2022 | ND | 10.0000 | | |
| Lithium, Total | ug/L | MW-15D | 09/18/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/29/2018 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 02/04/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 03/25/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/14/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 07/24/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/05/2019 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 01/29/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/27/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/03/2020 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/06/2021 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 11/03/2021 | ND | 20.0000 | | |
| Lithium, Total | ug/L | MW-15D | 05/11/2022 | ND | 20.0000 | | |
| Mercury | ug/L | MW-15D | 09/18/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 11/29/2018 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 02/04/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 03/25/2019 | ND | 2.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

# Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Mercury | ug/L | MW-15D | 05/14/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 07/24/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 11/05/2019 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 01/29/2020 | ND | 0.2000 | 2.0000 | ** |
| Mercury | ug/L | MW-15D | 05/27/2020 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 05/06/2021 | ND | 2.0000 | | |
| Mercury | ug/L | MW-15D | 05/11/2022 | ND | 0.2000 | 2.0000 | ** |
| Molybdenum, Total | ug/L | MW-15D | 09/18/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/29/2018 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 02/04/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 03/25/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 05/14/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 07/24/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/05/2019 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 01/29/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 05/27/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/03/2020 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 05/06/2021 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 11/03/2021 | ND | 10.0000 | | |
| Molybdenum, Total | ug/L | MW-15D | 05/11/2022 | ND | 10.0000 | | |
| Selenium, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/03/2020 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 11/03/2021 | ND | 1.0000 | | |
| Selenium, Total | ug/L | MW-15D | 05/11/2022 | ND | 1.0000 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

## Table C-1

## Upgradient Data

| Constituent | Units | Well | Date | | Result | Adjusted | |
|---|---|---|---|---|---|---|---|
| Thallium, Total | ug/L | MW-15D | 09/18/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 11/29/2018 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 02/04/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 03/25/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/14/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 07/24/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 11/05/2019 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 01/29/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/27/2020 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/06/2021 | ND | 1.0000 | | |
| Thallium, Total | ug/L | MW-15D | 05/11/2022 | ND | 1.0000 | | |
| Total Radium | pCi/L | MW-15D | 09/18/2018 | | 1.1700 | | |
| Total Radium | pCi/L | MW-15D | 11/29/2018 | | 1.6500 | | |
| Total Radium | pCi/L | MW-15D | 02/04/2019 | | 1.0600 | | |
| Total Radium | pCi/L | MW-15D | 03/25/2019 | | 1.4600 | | |
| Total Radium | pCi/L | MW-15D | 05/14/2019 | | 2.0600 | | |
| Total Radium | pCi/L | MW-15D | 07/24/2019 | | 1.4500 | | |
| Total Radium | pCi/L | MW-15D | 11/05/2019 | | 1.1000 | | |
| Total Radium | pCi/L | MW-15D | 01/29/2020 | | 0.8340 | | |
| Total Radium | pCi/L | MW-15D | 05/27/2020 | | 1.2100 | | |
| Total Radium | pCi/L | MW-15D | 11/03/2020 | | 1.4300 | | |
| Total Radium | pCi/L | MW-15D | 05/06/2021 | | 1.7400 | | |
| Total Radium | pCi/L | MW-15D | 11/03/2021 | | 1.1300 | | |
| Total Radium | pCi/L | MW-15D | 05/11/2022 | ND | 2.1300 | | |

* - Outlier for that well and constituent.
** - ND value replaced with median RL.
*** - ND value replaced with manual RL.
ND = Not detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-11D | 05/10/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-12D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-13D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-14D | 05/11/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-1D | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-2D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-3D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-7D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-9D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Antimony, Total | ug/L | MW-9I | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Arsenic, Total | ug/L | MW-10D | 05/02/2022 | | 140.0000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/10/2022 | | 16.1000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/06/2022 | | 387.0000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/04/2022 | | 245.0000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/11/2022 | | 127.0000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/09/2022 | | 4.5000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/04/2022 | | 4.0000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/02/2022 | | 3.3000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/04/2022 | | 484.0000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/06/2022 | | 21.3000 | *** | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/06/2022 | | 11.3000 | *** | 1.7099 |
| Barium, Total | ug/L | MW-10D | 05/02/2022 | | 33.0000 | | 76.8798 |
| Barium, Total | ug/L | MW-11D | 05/10/2022 | | 25.6000 | | 76.8798 |
| Barium, Total | ug/L | MW-12D | 05/06/2022 | | 26.7000 | | 76.8798 |
| Barium, Total | ug/L | MW-13D | 05/04/2022 | | 30.4000 | | 76.8798 |
| Barium, Total | ug/L | MW-14D | 05/11/2022 | | 44.3000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/09/2022 | | 78.0000 | * | 76.8798 |
| Barium, Total | ug/L | MW-2D | 05/04/2022 | | 44.2000 | | 76.8798 |
| Barium, Total | ug/L | MW-3D | 05/02/2022 | | 66.0000 | | 76.8798 |
| Barium, Total | ug/L | MW-7D | 05/04/2022 | | 42.4000 | | 76.8798 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-9D | 05/06/2022 | | 56.0000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/06/2022 | | 78.1000 | * | 76.8798 |
| Beryllium, Total | ug/L | MW-10D | 05/02/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-11D | 05/10/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-12D | 05/06/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-13D | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-14D | 05/11/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-1D | 05/09/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-2D | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-3D | 05/02/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-7D | 05/04/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-9D | 05/06/2022 | ND | 0.2000 | | 0.2000 |
| Beryllium, Total | ug/L | MW-9I | 05/06/2022 | ND | 0.2000 | | 0.2000 |
| Cadmium, Total | ug/L | MW-10D | 05/02/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-11D | 05/10/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-12D | 05/06/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-13D | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-14D | 05/11/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-1D | 05/09/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-2D | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-3D | 05/02/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-7D | 05/04/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-9D | 05/06/2022 | ND | 2.0000 | | 2.0000 |
| Cadmium, Total | ug/L | MW-9I | 05/06/2022 | ND | 2.0000 | | 2.0000 |
| Chromium, Total | ug/L | MW-10D | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-11D | 05/10/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-12D | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-13D | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-14D | 05/11/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-1D | 05/09/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-2D | 05/04/2022 | ND | 10.0000 | | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-3D | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-7D | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-9D | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Chromium, Total | ug/L | MW-9I | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Cobalt, Total | ug/L | MW-10D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-11D | 05/10/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-12D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-13D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-14D | 05/11/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-1D | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-2D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-3D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/04/2022 | ND | 1.0000 | ** | 1.0000 |
| Cobalt, Total | ug/L | MW-9D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-9I | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Fluoride | mg/L | MW-10D | 05/02/2022 | | 1.9000 | *** | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/10/2022 | | 0.3000 | *** | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/06/2022 | | 1.9000 | *** | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/04/2022 | | 0.7600 | *** | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/11/2022 | | 0.3300 | *** | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/09/2022 | | 0.4200 | *** | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/04/2022 | | 0.9500 | *** | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/02/2022 | | 0.1400 | *** | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/04/2022 | | 0.5100 | *** | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/06/2022 | | 0.4800 | *** | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/06/2022 | | 1.2000 | *** | 0.1300 |
| Lead, Total | ug/L | MW-10D | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-11D | 05/10/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-12D | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-13D | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-14D | 05/11/2022 | ND | 10.0000 | | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lead, Total | ug/L | MW-1D | 05/09/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-2D | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-3D | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-7D | 05/04/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-9D | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Lead, Total | ug/L | MW-9I | 05/06/2022 | ND | 10.0000 | | 10.0000 |
| Lithium, Total | ug/L | MW-10D | 05/02/2022 | | 65.6000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/10/2022 | | 147.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/06/2022 | | 74.8000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/04/2022 | | 76.3000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/11/2022 | | 768.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/09/2022 | ND | 20.0000 | ** | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/04/2022 | | 49.4000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-3D | 05/02/2022 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/04/2022 | | 100.0000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/06/2022 | | 22.6000 | *** | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/06/2022 | | 25.6000 | *** | 20.0000 |
| Mercury | ug/L | MW-10D | 05/02/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-11D | 05/10/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-12D | 05/06/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-13D | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-14D | 05/11/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-1D | 05/09/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-2D | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-3D | 05/02/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-7D | 05/04/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-9D | 05/06/2022 | ND | 0.2000 | | 2.0000 |
| Mercury | ug/L | MW-9I | 05/06/2022 | ND | 0.2000 | | 2.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/02/2022 | | 82.4000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-11D | 05/10/2022 | ND | 10.0000 | | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/06/2022 | | 154.0000 | *** | 10.0000 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-13D | 05/04/2022 | | 565.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/11/2022 | | 203.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/09/2022 | | 37.7000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/04/2022 | | 52.8000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-3D | 05/02/2022 | ND | 10.0000 | | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/04/2022 | | 592.0000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/06/2022 | | 47.5000 | *** | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/06/2022 | | 111.0000 | *** | 10.0000 |
| Selenium, Total | ug/L | MW-10D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-11D | 05/10/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-12D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-13D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-14D | 05/11/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-1D | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-2D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-3D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-7D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-9D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Selenium, Total | ug/L | MW-9I | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-10D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-11D | 05/10/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-12D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-13D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-14D | 05/11/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-1D | 05/09/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-2D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-3D | 05/02/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-7D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-9D | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Thallium, Total | ug/L | MW-9I | 05/06/2022 | ND | 1.0000 | | 1.0000 |
| Total Radium | pCi/L | MW-10D | 05/02/2022 | | 1.2300 | | 2.6419 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-2

## Most Current Downgradient Monitoring Data

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-11D | 05/10/2022 | | 1.5200 | | 2.6419 |
| Total Radium | pCi/L | MW-12D | 05/06/2022 | | 1.3900 | | 2.6419 |
| Total Radium | pCi/L | MW-13D | 05/04/2022 | | 1.5400 | | 2.6419 |
| Total Radium | pCi/L | MW-14D | 05/11/2022 | | 1.0300 | | 2.6419 |
| Total Radium | pCi/L | MW-1D | 05/09/2022 | | 1.0100 | | 2.6419 |
| Total Radium | pCi/L | MW-2D | 05/04/2022 | | 1.8800 | | 2.6419 |
| Total Radium | pCi/L | MW-3D | 05/02/2022 | | 1.0000 | | 2.6419 |
| Total Radium | pCi/L | MW-7D | 05/04/2022 | | 0.9970 | | 2.6419 |
| Total Radium | pCi/L | MW-9D | 05/06/2022 | ND | 1.1800 | | 2.6419 |
| Total Radium | pCi/L | MW-9I | 05/06/2022 | | 1.1100 | | 2.6419 |

* - Current value failed - awaiting verification.
** - Current value passed - previous exceedance not verified.
*** - Current value failed - exceedance verified.
**** - Current value passed - awaiting one more verification.
***** - Insufficient background data to compute prediction limit.
ND = Not Detected, Result = detection limit.

## Table C-3

## Detection Frequencies in Upgradient and Downgradient Wells

| Constituent | Upgradient Detect | Upgradient N | Upgradient Proportion | Downgradient Detect | Downgradient N | Downgradient Proportion |
|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 13 | 0.000 | 1 | 187 | 0.005 |
| Arsenic, Total | 13 | 13 | 1.000 | 144 | 187 | 0.770 |
| Barium, Total | 13 | 13 | 1.000 | 187 | 187 | 1.000 |
| Beryllium, Total | 0 | 12 | 0.000 | 0 | 165 | 0.000 |
| Cadmium, Total | 0 | 12 | 0.000 | 5 | 165 | 0.030 |
| Chromium, Total | 0 | 13 | 0.000 | 4 | 187 | 0.021 |
| Cobalt, Total | 0 | 13 | 0.000 | 4 | 176 | 0.023 |
| Fluoride | 7 | 13 | 0.538 | 196 | 198 | 0.990 |
| Lead, Total | 0 | 13 | 0.000 | 0 | 176 | 0.000 |
| Lithium, Total | 0 | 13 | 0.000 | 177 | 187 | 0.947 |
| Mercury | 0 | 11 | 0.000 | 1 | 154 | 0.006 |
| Molybdenum, Total | 0 | 13 | 0.000 | 166 | 187 | 0.888 |
| Selenium, Total | 0 | 13 | 0.000 | 0 | 187 | 0.000 |
| Thallium, Total | 0 | 11 | 0.000 | 0 | 154 | 0.000 |
| Total Radium | 12 | 13 | 0.923 | 163 | 187 | 0.872 |

N = Total number of measurements in all wells.
Detect = Total number of detections in all wells.
Proportion = Detect/N.

## Table C-4

## Shapiro-Wilk Multiple Group Test of Normality

| Constituent | Detect | N | Detect Freq | G raw | G log | G cbrt | G sqrt | G sqr | G cub | Crit Value | Dist Form | Model Type |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Arsenic, Total | 13 | 13 | 1.000 | 2.918 | 2.260 | | | | | 2.326 | lognor | lognor |
| Barium, Total | 13 | 13 | 1.000 | 0.338 | 0.104 | | | | | 2.326 | normal | normal |
| Beryllium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Cadmium, Total | 0 | 12 | 0.000 | 3.731 | 3.731 | | | | | 2.326 | non-norm | nonpar |
| Chromium, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Cobalt, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Fluoride | 7 | 13 | 0.538 | 2.755 | 2.757 | | | | | 2.326 | non-norm | nonpar |
| Lead, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Lithium, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Mercury | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Molybdenum, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Selenium, Total | 0 | 13 | 0.000 | 3.936 | 3.936 | | | | | 2.326 | non-norm | nonpar |
| Thallium, Total | 0 | 11 | 0.000 | 3.485 | 3.485 | | | | | 2.326 | non-norm | nonpar |
| Total Radium | 12 | 13 | 0.923 | 0.117 | 0.882 | | | | | 2.326 | normal | normal |

* - Distribution override for that constituent.
Fit to distribution is confirmed if G <= critical value.
Model type may not match distributional form when detection frequency < 50%.

## Table C-5

## Summary Statistics and Prediction Limits

| Constituent | Units | Detect | N | Mean | SD | alpha | Factor | Pred Limit | Type | | Conf |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | 0 | 13 | | | | | 1.0000 | nonpar | *** | 0.91 |
| Arsenic, Total | ug/L | 13 | 13 | 0.1739 | 0.1305 | 0.0100 | 2.7779 | 1.7099 | lognor | | |
| Barium, Total | ug/L | 13 | 13 | 67.5769 | 3.3489 | 0.0100 | 2.7779 | 76.8798 | normal | | |
| Beryllium, Total | ug/L | 0 | 12 | | | | | 0.2000 | nonpar | *** | 0.90 |
| Cadmium, Total | ug/L | 0 | 12 | | | | | 2.0000 | nonpar | *** | 0.90 |
| Chromium, Total | ug/L | 0 | 13 | | | | | 10.0000 | nonpar | *** | 0.91 |
| Cobalt, Total | ug/L | 0 | 13 | | | | | 1.0000 | nonpar | *** | 0.91 |
| Fluoride | mg/L | 7 | 13 | | | | | 0.1300 | nonpar | | 0.91 |
| Lead, Total | ug/L | 0 | 13 | | | | | 10.0000 | nonpar | *** | 0.91 |
| Lithium, Total | ug/L | 0 | 13 | | | | | 20.0000 | nonpar | *** | 0.91 |
| Mercury | ug/L | 0 | 11 | | | | | 2.0000 | nonpar | *** | 0.89 |
| Molybdenum, Total | ug/L | 0 | 13 | | | | | 10.0000 | nonpar | *** | 0.91 |
| Selenium, Total | ug/L | 0 | 13 | | | | | 1.0000 | nonpar | *** | 0.91 |
| Thallium, Total | ug/L | 0 | 11 | | | | | 1.0000 | nonpar | *** | 0.89 |
| Total Radium | pCi/L | 12 | 13 | 1.2534 | 0.4998 | 0.0100 | 2.7779 | 2.6419 | normal | | |

Conf = confidence level for passing initial test or one verification resample at all downgradient wells for a single constituent (nonparametric test only).
* - Insufficient Data.
** - Calculated limit raised to Manual Reporting Limit.
*** - Nonparametric limit based on ND value.
For transformed data, mean and SD in transformed units and prediction limit in original units.
All sample sizes and statistics are based on outlier free data.
For nonparametric limits, median reporting limits are substituted for extreme reporting limit values.

## Table C-6

## Dixon's Test Outliers
## 1% Significance Level

| Constituent | Units | Well | Date | Result | ND Qualifier | Date Range | N | Critical Value |
|---|---|---|---|---|---|---|---|---|

N = Total number of independent measurements in background at each well.
Date Range = Dates of the first and last measurements included in background at each well.
Critical Value depends on the significance level and on N-1 when the two most extreme values are tested or N for the most extreme value.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-10D | 04/06/2016 | | 412.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/25/2016 | | 440.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 08/09/2016 | | 464.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 09/27/2016 | | 488.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 11/29/2016 | | 406.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 01/25/2017 | | 433.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/23/2017 | | 399.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 08/08/2017 | | 447.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/30/2018 | | 396.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 09/18/2018 | | 323.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/16/2019 | | 313.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 11/05/2019 | | 275.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/19/2020 | | 268.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 11/05/2020 | | 265.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/06/2021 | | 250.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 11/02/2021 | | 173.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-10D | 05/02/2022 | | 140.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 04/07/2016 | | 10.6000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/26/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 08/10/2016 | | 14.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 09/28/2016 | | 14.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 11/30/2016 | | 12.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 01/26/2017 | | 10.7000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/24/2017 | | 14.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 08/09/2017 | | 14.5000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/29/2018 | | 18.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 09/14/2018 | | 14.6000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/14/2019 | | 14.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 11/07/2019 | | 15.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/27/2020 | | 15.7000 | * | 1.7099 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-11D | 11/05/2020 | | 14.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/05/2021 | | 15.4500 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 11/01/2021 | | 14.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-11D | 05/10/2022 | | 16.1000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 04/06/2016 | | 241.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/25/2016 | | 252.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 08/09/2016 | | 243.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 09/27/2016 | | 257.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 11/29/2016 | | 280.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 01/25/2017 | | 275.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/23/2017 | | 268.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 08/08/2017 | | 204.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/30/2018 | | 223.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 09/17/2018 | | 214.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/16/2019 | | 210.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 11/06/2019 | | 232.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/18/2020 | | 287.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 11/05/2020 | | 513.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/03/2021 | | 463.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 11/01/2021 | | 428.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-12D | 05/06/2022 | | 387.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 04/06/2016 | | 214.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/25/2016 | | 215.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 08/09/2016 | | 245.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 09/27/2016 | | 282.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 11/29/2016 | | 291.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 01/25/2017 | | 315.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/23/2017 | | 306.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 08/08/2017 | | 277.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/30/2018 | | 253.0000 | * | 1.7099 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-13D | 09/18/2018 | | 214.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/16/2019 | | 225.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 11/06/2019 | | 219.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/19/2020 | | 241.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 11/05/2020 | | 224.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/06/2021 | | 242.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 11/01/2021 | | 231.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-13D | 05/04/2022 | | 245.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 04/07/2016 | | 89.1000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/26/2016 | | 87.6000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 08/10/2016 | | 86.5000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 09/28/2016 | | 92.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 11/30/2016 | | 103.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 01/26/2017 | | 116.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/23/2017 | | 124.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 08/09/2017 | | 128.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/30/2018 | | 147.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 09/17/2018 | | 116.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/15/2019 | | 108.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 11/07/2019 | | 111.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/26/2020 | | 131.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 11/05/2020 | | 105.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/05/2021 | | 133.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 11/01/2021 | | 113.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-14D | 05/11/2022 | | 127.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 04/07/2016 | | 10.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/26/2016 | | 12.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 08/09/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 09/27/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 11/29/2016 | ND | 10.0000 | | 1.7099 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-1D | 01/26/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/23/2017 | | 11.7000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 08/09/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/29/2018 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 09/17/2018 | | 4.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/15/2019 | | 4.7000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 11/07/2019 | | 5.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/26/2020 | | 7.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 11/06/2020 | | 50.6000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/05/2021 | | 5.9000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 11/03/2021 | | 3.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-1D | 05/09/2022 | | 4.5000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 04/05/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/24/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 08/08/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 09/26/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 11/28/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 01/24/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/22/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 08/07/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/29/2018 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 09/17/2018 | | 1.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/15/2019 | | 2.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 11/05/2019 | | 3.1000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/19/2020 | | 1.9000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 11/04/2020 | | 3.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/03/2021 | | 2.5000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 11/01/2021 | | 3.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-2D | 05/04/2022 | | 4.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 04/05/2016 | ND | 10.0000 | | 1.7099 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-3D | 05/25/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 08/08/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 09/26/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 11/28/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 01/24/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/22/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 08/07/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/29/2018 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 09/17/2018 | | 2.7000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/15/2019 | | 2.9000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 11/06/2019 | | 2.9000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/18/2020 | | 3.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 11/03/2020 | | 2.9000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/03/2021 | | 3.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 11/01/2021 | | 3.4000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-3D | 05/02/2022 | | 3.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 04/06/2016 | | 428.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/25/2016 | | 435.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 08/09/2016 | | 412.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 09/27/2016 | | 408.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 11/29/2016 | | 417.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 01/25/2017 | | 468.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/23/2017 | | 509.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 08/08/2017 | | 504.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/30/2018 | | 491.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 09/18/2018 | | 433.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/15/2019 | | 471.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 11/06/2019 | | 432.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/27/2020 | | 467.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 11/17/2020 | | 402.0000 | * | 1.7099 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-7D | 05/06/2021 | | 476.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 11/02/2021 | | 457.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-7D | 05/04/2022 | | 484.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 04/06/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/25/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 08/08/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 09/27/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 11/29/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 01/25/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/23/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 08/08/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/30/2018 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 09/17/2018 | | 2.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/16/2019 | | 2.1000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 11/06/2019 | | 3.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/19/2020 | | 5.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 11/04/2020 | | 4.7000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/03/2021 | | 8.7000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 11/04/2021 | | 9.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9D | 05/06/2022 | | 21.3000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 04/06/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/25/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 08/08/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 09/27/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 11/28/2016 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 01/25/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/23/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 08/08/2017 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/30/2018 | ND | 10.0000 | | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 09/17/2018 | | 5.0000 | * | 1.7099 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Arsenic, Total | ug/L | MW-9I | 05/16/2019 | | 3.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 11/06/2019 | | 4.0000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/19/2020 | | 4.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 11/04/2020 | | 4.6000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/03/2021 | | 4.8000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 11/04/2021 | | 5.2000 | * | 1.7099 |
| Arsenic, Total | ug/L | MW-9I | 05/06/2022 | | 11.3000 | * | 1.7099 |
| Barium, Total | ug/L | MW-1D | 04/07/2016 | | 47.2000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/26/2016 | | 49.6000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 08/09/2016 | | 51.6000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 09/27/2016 | | 49.8000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 11/29/2016 | | 39.3000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 01/26/2017 | | 44.2000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/23/2017 | | 48.4000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 08/09/2017 | | 51.3000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/29/2018 | | 49.8000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 09/17/2018 | | 51.7000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/15/2019 | | 61.8000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 11/07/2019 | | 55.5000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/26/2020 | | 71.0000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 11/06/2020 | | 113.0000 | * | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/05/2021 | | 77.5000 | * | 76.8798 |
| Barium, Total | ug/L | MW-1D | 11/03/2021 | | 72.0000 | | 76.8798 |
| Barium, Total | ug/L | MW-1D | 05/09/2022 | | 78.0000 | * | 76.8798 |
| Barium, Total | ug/L | MW-9I | 04/06/2016 | | 36.9000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/25/2016 | | 19.5000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 08/08/2016 | | 19.9000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 09/27/2016 | | 22.8000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 11/28/2016 | | 25.1000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 01/25/2017 | | 30.8000 | | 76.8798 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-9I | 05/23/2017 | | 33.0000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 08/08/2017 | | 34.3000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/30/2018 | | 57.7000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 09/17/2018 | | 53.7000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/16/2019 | | 57.3000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 11/06/2019 | | 56.8000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/19/2020 | | 64.2000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 11/04/2020 | | 67.1000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/03/2021 | | 69.5000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 11/04/2021 | | 73.4000 | | 76.8798 |
| Barium, Total | ug/L | MW-9I | 05/06/2022 | | 78.1000 | * | 76.8798 |
| Cobalt, Total | ug/L | MW-7D | 04/06/2016 | ND | 10.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/25/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 08/09/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 09/27/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/29/2016 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 01/25/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/23/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 08/08/2017 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/30/2018 | ND | 5.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/15/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/06/2019 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/27/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/17/2020 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/06/2021 | ND | 1.0000 | | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 11/02/2021 | | 1.8000 | * | 1.0000 |
| Cobalt, Total | ug/L | MW-7D | 05/04/2022 | ND | 1.0000 | | 1.0000 |
| Fluoride | mg/L | MW-10D | 04/06/2016 | | 1.7000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/25/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 08/09/2016 | | 2.1000 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-10D | 09/27/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/29/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 01/25/2017 | | 2.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/23/2017 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 08/08/2017 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 09/20/2017 | | 2.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/30/2018 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 09/18/2018 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/16/2019 | | 2.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/05/2019 | | 2.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/19/2020 | | 2.5000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/05/2020 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/06/2021 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 11/02/2021 | | 2.0000 | * | 0.1300 |
| Fluoride | mg/L | MW-10D | 05/02/2022 | | 1.9000 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 04/07/2016 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/26/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 08/10/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 09/28/2016 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/30/2016 | | 0.2900 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 01/26/2017 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/24/2017 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 08/09/2017 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 09/20/2017 | | 0.4800 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/29/2018 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 09/14/2018 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/14/2019 | | 0.4700 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/07/2019 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/27/2020 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/05/2020 | | 0.4300 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-11D | 05/05/2021 | | 0.2500 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 11/01/2021 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-11D | 05/10/2022 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 04/06/2016 | | 0.2200 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/25/2016 | | 0.2700 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 08/09/2016 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 09/27/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/29/2016 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 01/25/2017 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/23/2017 | | 0.5000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 08/08/2017 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 09/20/2017 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/30/2018 | | 1.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 09/17/2018 | | 0.9500 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/16/2019 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/06/2019 | | 1.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/18/2020 | | 1.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/05/2020 | | 0.9700 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/03/2021 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 11/01/2021 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-12D | 05/06/2022 | | 1.9000 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 04/06/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/25/2016 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 08/09/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 09/27/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/29/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 01/25/2017 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/23/2017 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 08/08/2017 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 09/20/2017 | | 0.4100 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-13D | 05/30/2018 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 09/18/2018 | | 0.4700 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/16/2019 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/06/2019 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/19/2020 | | 0.5900 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/05/2020 | | 0.6200 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/06/2021 | | 0.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 11/01/2021 | | 0.5500 | * | 0.1300 |
| Fluoride | mg/L | MW-13D | 05/04/2022 | | 0.7600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 04/07/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/26/2016 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 08/10/2016 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 09/28/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/30/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 01/26/2017 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/23/2017 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 08/09/2017 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 09/20/2017 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/30/2018 | | 0.3200 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 09/17/2018 | | 0.2300 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/15/2019 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/07/2019 | | 0.2100 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/26/2020 | ND | 0.1000 | | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/05/2020 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/05/2021 | ND | 0.1000 | | 0.1300 |
| Fluoride | mg/L | MW-14D | 11/01/2021 | | 0.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-14D | 05/11/2022 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 04/07/2016 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/26/2016 | | 0.4700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 08/09/2016 | | 0.3800 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-1D | 09/27/2016 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/29/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 01/26/2017 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/23/2017 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 08/09/2017 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 09/20/2017 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/29/2018 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 09/17/2018 | | 0.3700 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/15/2019 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/07/2019 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/26/2020 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/06/2020 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/05/2021 | | 0.2300 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 11/03/2021 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-1D | 05/09/2022 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 04/05/2016 | | 2.1000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/24/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 08/08/2016 | | 2.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 09/26/2016 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/28/2016 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 01/24/2017 | | 2.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/22/2017 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 08/07/2017 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 09/20/2017 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/29/2018 | | 2.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 09/17/2018 | | 2.8000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/15/2019 | | 1.6000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/05/2019 | | 1.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/19/2020 | | 1.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/04/2020 | | 1.0000 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-2D | 05/03/2021 | | 0.8700 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 11/01/2021 | | 0.8600 | * | 0.1300 |
| Fluoride | mg/L | MW-2D | 05/04/2022 | | 0.9500 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 04/05/2016 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/25/2016 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 08/08/2016 | | 0.4100 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 09/26/2016 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/28/2016 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 01/24/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/22/2017 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 08/07/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 09/20/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/29/2018 | | 0.2900 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 09/17/2018 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/15/2019 | | 0.2400 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/06/2019 | | 0.2100 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/18/2020 | | 0.2300 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/03/2020 | | 0.2000 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/03/2021 | | 0.1800 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 11/01/2021 | | 0.1500 | * | 0.1300 |
| Fluoride | mg/L | MW-3D | 05/02/2022 | | 0.1400 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 04/06/2016 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/25/2016 | | 0.3300 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 08/09/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 09/27/2016 | | 0.3100 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/29/2016 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 01/25/2017 | | 0.2600 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/23/2017 | | 0.2500 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 08/08/2017 | | 0.2800 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 09/20/2017 | | 0.2600 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-7D | 05/30/2018 | | 0.2900 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 09/18/2018 | | 0.3000 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/15/2019 | | 0.3200 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/06/2019 | | 0.3500 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/27/2020 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/17/2020 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/06/2021 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 11/02/2021 | | 0.3800 | * | 0.1300 |
| Fluoride | mg/L | MW-7D | 05/04/2022 | | 0.5100 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 04/06/2016 | | 0.3400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/25/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 08/08/2016 | | 0.3900 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 09/27/2016 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/29/2016 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 01/25/2017 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/23/2017 | | 0.4600 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 08/08/2017 | | 0.4900 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 09/20/2017 | | 0.5200 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/30/2018 | | 0.4500 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 09/17/2018 | | 0.4300 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/16/2019 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/06/2019 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/19/2020 | | 0.4600 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/04/2020 | | 0.4200 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/03/2021 | | 0.4000 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 11/04/2021 | | 0.3600 | * | 0.1300 |
| Fluoride | mg/L | MW-9D | 05/06/2022 | | 0.4800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 04/06/2016 | | 0.4400 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/25/2016 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 08/08/2016 | | 0.5500 | * | 0.1300 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-9I | 09/27/2016 | | 0.5800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/28/2016 | | 0.6100 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 01/25/2017 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/23/2017 | | 0.5700 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 08/08/2017 | | 0.5800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 09/20/2017 | | 0.5900 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/30/2018 | | 0.5300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 09/17/2018 | | 0.5800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/16/2019 | | 0.6800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/06/2019 | | 0.6900 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/19/2020 | | 0.7300 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/04/2020 | | 0.7800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/03/2021 | | 0.9700 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 11/04/2021 | | 0.9800 | * | 0.1300 |
| Fluoride | mg/L | MW-9I | 05/06/2022 | | 1.2000 | * | 0.1300 |
| Lithium, Total | ug/L | MW-10D | 04/06/2016 | | 123.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/25/2016 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 08/09/2016 | | 96.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 09/27/2016 | | 82.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/29/2016 | | 92.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 01/25/2017 | | 92.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/23/2017 | | 85.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 08/08/2017 | | 86.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/30/2018 | | 63.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 09/18/2018 | | 61.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/16/2019 | | 69.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/05/2019 | | 61.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/19/2020 | | 62.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 11/05/2020 | | 52.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/06/2021 | | 49.8000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-10D | 11/02/2021 | | 67.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-10D | 05/02/2022 | | 65.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 04/07/2016 | | 127.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/26/2016 | | 122.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 08/10/2016 | | 132.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 09/28/2016 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/30/2016 | | 137.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 01/26/2017 | | 133.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/24/2017 | | 109.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 08/09/2017 | | 124.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/29/2018 | | 122.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 09/14/2018 | | 126.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/14/2019 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/07/2019 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/27/2020 | | 142.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/05/2020 | | 134.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/05/2021 | | 141.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 11/01/2021 | | 150.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-11D | 05/10/2022 | | 147.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 04/06/2016 | | 141.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/25/2016 | | 152.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 08/09/2016 | | 140.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 09/27/2016 | | 147.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/29/2016 | | 140.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 01/25/2017 | | 166.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/23/2017 | | 129.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 08/08/2017 | | 151.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/30/2018 | | 118.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 09/17/2018 | | 122.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/16/2019 | | 104.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-12D | 11/06/2019 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/18/2020 | | 113.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/05/2020 | | 108.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/03/2021 | | 69.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 11/01/2021 | | 95.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-12D | 05/06/2022 | | 74.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 04/06/2016 | | 87.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/25/2016 | | 99.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 08/09/2016 | | 112.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 09/27/2016 | | 133.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/29/2016 | | 176.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 01/25/2017 | | 190.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/23/2017 | | 154.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 08/08/2017 | | 128.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/30/2018 | | 112.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 09/18/2018 | | 101.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/16/2019 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/06/2019 | | 85.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/19/2020 | | 96.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/05/2020 | | 79.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/06/2021 | | 72.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 11/01/2021 | | 84.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-13D | 05/04/2022 | | 76.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 04/07/2016 | | 526.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/26/2016 | | 620.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 08/10/2016 | | 358.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 09/28/2016 | | 355.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/30/2016 | | 352.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 01/26/2017 | | 520.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/23/2017 | | 662.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-14D | 08/09/2017 | | 541.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/30/2018 | | 664.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 09/17/2018 | | 610.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/15/2019 | | 567.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/07/2019 | | 479.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/26/2020 | | 820.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/05/2020 | | 445.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/05/2021 | | 809.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 11/01/2021 | | 751.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-14D | 05/11/2022 | | 768.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 04/07/2016 | | 87.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/26/2016 | | 86.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 08/09/2016 | | 84.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 09/27/2016 | | 68.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/29/2016 | | 70.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 01/26/2017 | | 60.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/23/2017 | | 54.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 08/09/2017 | | 57.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/29/2018 | | 38.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 09/17/2018 | | 31.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/15/2019 | | 53.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/07/2019 | | 29.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/26/2020 | | 37.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/06/2020 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/05/2021 | | 23.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 11/03/2021 | | 23.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-1D | 05/09/2022 | ND | 20.0000 | | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 04/05/2016 | | 108.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/24/2016 | | 105.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 08/08/2016 | | 103.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-2D | 09/26/2016 | | 77.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/28/2016 | | 91.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 01/24/2017 | | 90.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/22/2017 | | 73.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 08/07/2017 | | 87.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/29/2018 | | 36.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 09/17/2018 | | 32.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/15/2019 | | 45.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/05/2019 | | 65.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/19/2020 | | 42.8000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/04/2020 | | 55.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/03/2021 | | 40.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 11/01/2021 | | 56.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-2D | 05/04/2022 | | 49.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 04/06/2016 | | 150.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/25/2016 | | 132.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 08/09/2016 | | 120.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 09/27/2016 | | 107.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/29/2016 | | 127.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 01/25/2017 | | 150.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/23/2017 | | 136.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 08/08/2017 | | 152.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/30/2018 | | 120.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 09/18/2018 | | 110.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/15/2019 | | 125.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/06/2019 | | 95.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/27/2020 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/17/2020 | | 91.7000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 05/06/2021 | | 96.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-7D | 11/02/2021 | | 103.0000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-7D | 05/04/2022 | | 100.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 04/06/2016 | | 146.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/25/2016 | | 134.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 08/08/2016 | | 123.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 09/27/2016 | | 102.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/29/2016 | | 119.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 01/25/2017 | | 109.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/23/2017 | | 71.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 08/08/2017 | | 65.9000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/30/2018 | | 48.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 09/17/2018 | | 43.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/16/2019 | | 44.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/06/2019 | | 33.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/19/2020 | | 32.1000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/04/2020 | | 25.2000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/03/2021 | | 25.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 11/04/2021 | | 23.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9D | 05/06/2022 | | 22.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 04/06/2016 | | 104.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/25/2016 | | 79.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 08/08/2016 | | 68.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 09/27/2016 | | 58.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/28/2016 | | 62.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 01/25/2017 | | 59.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/23/2017 | | 51.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 08/08/2017 | | 56.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/30/2018 | | 35.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 09/17/2018 | | 37.0000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/16/2019 | | 38.4000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/06/2019 | | 30.2000 | * | 20.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-9I | 05/19/2020 | | 30.6000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/04/2020 | | 23.3000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/03/2021 | | 30.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 11/04/2021 | | 28.5000 | * | 20.0000 |
| Lithium, Total | ug/L | MW-9I | 05/06/2022 | | 25.6000 | * | 20.0000 |
| Molybdenum, Total | ug/L | MW-10D | 04/06/2016 | | 264.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/25/2016 | | 288.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 08/09/2016 | | 290.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 09/27/2016 | | 259.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/29/2016 | | 274.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 01/25/2017 | | 251.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/23/2017 | | 235.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 08/08/2017 | | 220.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/30/2018 | | 168.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 09/18/2018 | | 141.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/16/2019 | | 99.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/05/2019 | | 76.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/19/2020 | | 72.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/05/2020 | | 88.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/06/2021 | | 97.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 11/02/2021 | | 84.1000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-10D | 05/02/2022 | | 82.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 04/06/2016 | | 286.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/25/2016 | | 257.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 08/09/2016 | | 270.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 09/27/2016 | | 274.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/29/2016 | | 249.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 01/25/2017 | | 254.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/23/2017 | | 214.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 08/08/2017 | | 232.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-12D | 05/30/2018 | | 232.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 09/17/2018 | | 239.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/16/2019 | | 219.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/06/2019 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/18/2020 | | 227.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/05/2020 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/03/2021 | | 173.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 11/01/2021 | | 176.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-12D | 05/06/2022 | | 154.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 04/06/2016 | | 646.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/25/2016 | | 575.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 08/09/2016 | | 671.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 09/27/2016 | | 647.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/29/2016 | | 695.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 01/25/2017 | | 704.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/23/2017 | | 667.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 08/08/2017 | | 651.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/30/2018 | | 922.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 09/18/2018 | | 857.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/16/2019 | | 1090.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/06/2019 | | 880.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/19/2020 | | 881.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/05/2020 | | 859.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/06/2021 | | 762.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 11/01/2021 | | 599.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-13D | 05/04/2022 | | 565.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 04/07/2016 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/26/2016 | | 187.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 08/10/2016 | | 254.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 09/28/2016 | | 242.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-14D | 11/30/2016 | | 245.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 01/26/2017 | | 219.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/23/2017 | | 224.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 08/09/2017 | | 200.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/30/2018 | | 185.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 09/17/2018 | | 185.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/15/2019 | | 188.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/07/2019 | | 267.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/26/2020 | | 187.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/05/2020 | | 259.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/05/2021 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 11/01/2021 | | 257.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-14D | 05/11/2022 | | 203.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 04/07/2016 | | 234.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/26/2016 | | 205.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 08/09/2016 | | 159.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 09/27/2016 | | 130.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/29/2016 | | 128.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 01/26/2017 | | 121.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/23/2017 | | 97.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 08/09/2017 | | 76.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/29/2018 | | 63.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 09/17/2018 | | 51.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/15/2019 | | 54.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/07/2019 | | 47.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/26/2020 | | 44.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/06/2020 | | 34.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/05/2021 | | 39.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 11/03/2021 | | 33.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-1D | 05/09/2022 | | 37.7000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-2D | 04/05/2016 | | 289.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/24/2016 | | 286.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 08/08/2016 | | 273.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 09/26/2016 | | 256.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/28/2016 | | 279.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 01/24/2017 | | 262.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/22/2017 | | 263.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 08/07/2017 | | 241.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/29/2018 | | 250.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 09/17/2018 | | 194.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/15/2019 | | 106.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/05/2019 | | 79.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/19/2020 | | 89.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/04/2020 | | 76.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/03/2021 | | 56.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 11/01/2021 | | 56.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-2D | 05/04/2022 | | 52.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 04/06/2016 | | 423.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/25/2016 | | 445.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 08/09/2016 | | 460.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 09/27/2016 | | 448.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/29/2016 | | 488.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 01/25/2017 | | 461.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/23/2017 | | 441.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 08/08/2017 | | 455.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/30/2018 | | 544.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 09/18/2018 | | 574.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/15/2019 | | 616.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/06/2019 | | 617.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/27/2020 | | 736.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-7D | 11/17/2020 | | 697.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/06/2021 | | 704.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 11/02/2021 | | 688.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-7D | 05/04/2022 | | 592.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 04/06/2016 | | 130.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/25/2016 | | 132.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 08/08/2016 | | 128.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 09/27/2016 | | 122.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/29/2016 | | 140.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 01/25/2017 | | 143.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/23/2017 | | 124.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 08/08/2017 | | 96.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/30/2018 | | 109.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 09/17/2018 | | 85.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/16/2019 | | 50.4000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/06/2019 | | 53.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/19/2020 | | 55.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/04/2020 | | 45.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/03/2021 | | 49.6000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 11/04/2021 | | 41.3000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9D | 05/06/2022 | | 47.5000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 04/06/2016 | | 214.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/25/2016 | | 218.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 08/08/2016 | | 201.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 09/27/2016 | | 191.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/28/2016 | | 189.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 01/25/2017 | | 157.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/23/2017 | | 130.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 08/08/2017 | | 115.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/30/2018 | | 125.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.


## Table C-7

## Historical Downgradient Data for Constituent-Well Combinations that Failed the Current Statistical Evaluation or are in Verification Resampling Mode

| Constituent | Units | Well | Date | | Result | | Pred. Limit |
|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-9I | 09/17/2018 | | 110.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/16/2019 | | 96.8000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/06/2019 | | 91.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/19/2020 | | 95.9000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/04/2020 | | 89.2000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/03/2021 | | 134.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 11/04/2021 | | 123.0000 | * | 10.0000 |
| Molybdenum, Total | ug/L | MW-9I | 05/06/2022 | | 111.0000 | * | 10.0000 |

* - Significantly increased over background.
** - Detect at limit for 100% NDs in background (NPPL only).
*** - Manual exclusion.
ND = Not Detected, Result = detection limit.

# False Positive and False Negative Rates for Current Upgradient vs. Downgradient Monitoring Program



## 95% LCL DOCUMENTATION

**NOVEMBER 2021**

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-11S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-12S | 4 | 3.025 | 0.974 | 1.176 | 1.879 | 4.171 | 6.000 | | |
| Antimony, Total | ug/L | MW-13S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-1S | 4 | 3.050 | 0.252 | 1.176 | 2.754 | 3.346 | 6.000 | | |
| Antimony, Total | ug/L | MW-2S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-3S | 4 | 6.900 | 0.966 | 1.176 | 5.764 | 8.036 | 6.000 | | |
| Antimony, Total | ug/L | MW-4S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-5S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-6S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-7S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-8S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-9S | 4 | 9.200 | 1.738 | 1.176 | 7.156 | 11.244 | 6.000 | dec | ** |
| Arsenic, Total | ug/L | MW-10S | 4 | 387.250 | 39.685 | 1.176 | 340.569 | 433.931 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-11S | 4 | 5.250 | 5.702 | 1.176 | 0.000 | 11.958 | 10.000 | | |
| Arsenic, Total | ug/L | MW-12S | 4 | 46.250 | 14.295 | 1.176 | 29.435 | 63.065 | 10.000 | inc | ** |
| Arsenic, Total | ug/L | MW-13S | 4 | 358.250 | 55.686 | 1.176 | 292.747 | 423.753 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-1S | 4 | 16.400 | 7.901 | 1.176 | 7.106 | 25.694 | 10.000 | | |
| Arsenic, Total | ug/L | MW-2S | 4 | 15.300 | 9.940 | 1.176 | 3.608 | 26.992 | 10.000 | dec | |
| Arsenic, Total | ug/L | MW-3S | 4 | 2.325 | 1.791 | 1.176 | 0.218 | 4.432 | 10.000 | | |
| Arsenic, Total | ug/L | MW-4S | 4 | 3.625 | 1.804 | 1.176 | 1.503 | 5.747 | 10.000 | | |
| Arsenic, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 10.000 | | |
| Arsenic, Total | ug/L | MW-6S | 4 | 21.675 | 12.971 | 1.176 | 6.418 | 36.932 | 10.000 | | |
| Arsenic, Total | ug/L | MW-7S | 4 | 406.000 | 43.688 | 1.176 | 354.610 | 457.390 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-8S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 10.000 | | |
| Arsenic, Total | ug/L | MW-9S | 4 | 4.125 | 1.750 | 1.176 | 2.066 | 6.184 | 10.000 | | |
| Barium, Total | ug/L | MW-10S | 4 | 72.250 | 17.972 | 1.176 | 51.110 | 93.390 | 2000.000 | | |
| Barium, Total | ug/L | MW-11S | 4 | 132.400 | 114.403 | 1.176 | 0.000 | 266.971 | 2000.000 | | |
| Barium, Total | ug/L | MW-12S | 4 | 31.425 | 2.901 | 1.176 | 28.013 | 34.837 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-13S | 4 | 37.075 | 4.801 | 1.176 | 31.428 | 42.722 | 2000.000 | | |
| Barium, Total | ug/L | MW-1S | 4 | 92.900 | 30.102 | 1.176 | 57.491 | 128.309 | 2000.000 | | |
| Barium, Total | ug/L | MW-2S | 4 | 104.625 | 22.682 | 1.176 | 77.945 | 131.305 | 2000.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-3S | 4 | 45.625 | 6.907 | 1.176 | 37.500 | 53.750 | 2000.000 | | |
| Barium, Total | ug/L | MW-4S | 4 | 84.950 | 21.815 | 1.176 | 59.290 | 110.610 | 2000.000 | | |
| Barium, Total | ug/L | MW-5S | 4 | 28.225 | 4.894 | 1.176 | 22.468 | 33.982 | 2000.000 | | |
| Barium, Total | ug/L | MW-6S | 4 | 123.000 | 12.437 | 1.176 | 108.371 | 137.629 | 2000.000 | | |
| Barium, Total | ug/L | MW-7S | 4 | 39.975 | 4.381 | 1.176 | 34.822 | 45.128 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-8S | 4 | 34.175 | 4.178 | 1.176 | 29.260 | 39.090 | 2000.000 | | |
| Barium, Total | ug/L | MW-9S | 4 | 52.550 | 1.923 | 1.176 | 50.288 | 54.812 | 2000.000 | inc | |
| Beryllium, Total | ug/L | MW-10S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-11S | 4 | 1.680 | 0.640 | 1.176 | 0.927 | 2.433 | 4.000 | | |
| Beryllium, Total | ug/L | MW-12S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-13S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-1S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-2S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-3S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-4S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-5S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-6S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-7S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-8S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-9S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Cadmium, Total | ug/L | MW-10S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-11S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-12S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-13S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-1S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-2S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-3S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-4S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-5S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-6S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-7S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-8S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Cadmium, Total | ug/L | MW-9S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Chromium, Total | ug/L | MW-10S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-11S | 4 | 12.300 | 14.600 | 1.176 | 0.000 | 29.474 | 100.000 | | |
| Chromium, Total | ug/L | MW-12S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-13S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-1S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-2S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-3S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-4S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-6S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-7S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-8S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-9S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Cobalt, Total | ug/L | MW-10S | 4 | 2.175 | 0.650 | 1.176 | 1.410 | 2.940 | 6.000 | | |
| Cobalt, Total | ug/L | MW-11S | 4 | 4.550 | 4.100 | 1.176 | 0.000 | 9.373 | 6.000 | | |
| Cobalt, Total | ug/L | MW-12S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-13S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-1S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-2S | 4 | 2.200 | 0.600 | 1.176 | 1.494 | 2.906 | 6.000 | | |
| Cobalt, Total | ug/L | MW-3S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-4S | 4 | 2.150 | 0.700 | 1.176 | 1.327 | 2.973 | 6.000 | | |
| Cobalt, Total | ug/L | MW-5S | 4 | 1.825 | 0.789 | 1.176 | 0.897 | 2.753 | 6.000 | | |
| Cobalt, Total | ug/L | MW-6S | 4 | 1.850 | 0.379 | 1.176 | 1.405 | 2.295 | 6.000 | | |
| Cobalt, Total | ug/L | MW-7S | 4 | 2.250 | 0.500 | 1.176 | 1.662 | 2.838 | 6.000 | | |
| Cobalt, Total | ug/L | MW-8S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-9S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Fluoride | mg/L | MW-10S | 4 | 2.350 | 0.238 | 1.176 | 2.070 | 2.630 | 4.000 | | |
| Fluoride | mg/L | MW-11S | 4 | 1.500 | 0.115 | 1.176 | 1.364 | 1.636 | 4.000 | | |
| Fluoride | mg/L | MW-12S | 4 | 1.725 | 0.150 | 1.176 | 1.549 | 1.901 | 4.000 | inc | |
| Fluoride | mg/L | MW-13S | 4 | 0.905 | 0.051 | 1.176 | 0.845 | 0.965 | 4.000 | inc | |
| Fluoride | mg/L | MW-1S | 4 | 0.315 | 0.054 | 1.176 | 0.251 | 0.379 | 4.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-2S | 4 | 0.455 | 0.127 | 1.176 | 0.306 | 0.604 | 4.000 | | |
| Fluoride | mg/L | MW-3S | 4 | 0.195 | 0.052 | 1.176 | 0.134 | 0.256 | 4.000 | dec | |
| Fluoride | mg/L | MW-4S | 4 | 0.080 | 0.036 | 1.176 | 0.038 | 0.122 | 4.000 | | |
| Fluoride | mg/L | MW-5S | 4 | 2.075 | 0.330 | 1.176 | 1.686 | 2.464 | 4.000 | dec | |
| Fluoride | mg/L | MW-6S | 4 | 1.225 | 0.171 | 1.176 | 1.024 | 1.426 | 4.000 | | |
| Fluoride | mg/L | MW-7S | 4 | 0.530 | 0.032 | 1.176 | 0.493 | 0.567 | 4.000 | inc | |
| Fluoride | mg/L | MW-8S | 4 | 0.108 | 0.042 | 1.176 | 0.058 | 0.157 | 4.000 | dec | |
| Fluoride | mg/L | MW-9S | 4 | 0.118 | 0.081 | 1.176 | 0.023 | 0.212 | 4.000 | | |
| Lead, Total | ug/L | MW-10S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-11S | 4 | 7.600 | 5.200 | 1.176 | 1.483 | 13.717 | 15.000 | | |
| Lead, Total | ug/L | MW-12S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-13S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-1S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-2S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-3S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-4S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-6S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-7S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-8S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-9S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lithium, Total | ug/L | MW-10S | 4 | 56.075 | 13.552 | 1.176 | 40.133 | 72.017 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-11S | 4 | 17.825 | 15.650 | 1.176 | 0.000 | 36.234 | 40.000 | | |
| Lithium, Total | ug/L | MW-12S | 4 | 95.575 | 23.183 | 1.176 | 68.305 | 122.845 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-13S | 4 | 72.175 | 8.825 | 1.176 | 61.794 | 82.556 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-1S | 4 | 10.000 | 0.000 | 1.176 | 10.000 | 10.000 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-2S | 4 | 13.250 | 6.500 | 1.176 | 5.604 | 20.896 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-3S | 4 | 10.000 | 0.000 | 1.176 | 10.000 | 10.000 | 40.000 | | |
| Lithium, Total | ug/L | MW-4S | 4 | 13.350 | 6.700 | 1.176 | 5.469 | 21.231 | 40.000 | | |
| Lithium, Total | ug/L | MW-5S | 4 | 46.250 | 6.108 | 1.176 | 39.065 | 53.435 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-6S | 4 | 70.500 | 10.624 | 1.176 | 58.003 | 82.997 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-7S | 4 | 85.350 | 2.496 | 1.176 | 82.414 | 88.286 | 40.000 | dec | ** |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-8S | 4 | 143.000 | 30.670 | 1.176 | 106.923 | 179.077 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-9S | 4 | 79.600 | 9.506 | 1.176 | 68.418 | 90.782 | 40.000 | dec | ** |
| Mercury | ug/L | MW-10S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-11S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-12S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-13S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-1S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-2S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-3S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-4S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-5S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-6S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-7S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-8S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-9S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Molybdenum, Total | ug/L | MW-10S | 4 | 75.875 | 5.300 | 1.176 | 69.641 | 82.109 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-11S | 4 | 79.400 | 3.203 | 1.176 | 75.632 | 83.168 | 100.000 | | |
| Molybdenum, Total | ug/L | MW-12S | 4 | 194.750 | 39.694 | 1.176 | 148.059 | 241.441 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-13S | 4 | 678.250 | 86.373 | 1.176 | 576.651 | 779.849 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-1S | 4 | 28.875 | 5.733 | 1.176 | 22.132 | 35.618 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-2S | 4 | 34.300 | 4.562 | 1.176 | 28.934 | 39.666 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-3S | 4 | 43.150 | 5.928 | 1.176 | 36.177 | 50.123 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-4S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Molybdenum, Total | ug/L | MW-5S | 4 | 170.750 | 37.819 | 1.176 | 126.264 | 215.236 | 100.000 | dec | ** |
| Molybdenum, Total | ug/L | MW-6S | 4 | 189.750 | 31.983 | 1.176 | 152.129 | 227.371 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-7S | 4 | 671.750 | 33.639 | 1.176 | 632.181 | 711.319 | 100.000 | inc | ** |
| Molybdenum, Total | ug/L | MW-8S | 4 | 365.500 | 116.211 | 1.176 | 228.802 | 502.198 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-9S | 4 | 127.825 | 49.893 | 1.176 | 69.137 | 186.513 | 100.000 | dec | |
| Selenium, Total | ug/L | MW-10S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-11S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-12S | 4 | 5.525 | 3.845 | 1.176 | 1.002 | 10.048 | 50.000 | | |
| Selenium, Total | ug/L | MW-13S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-1S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-2S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-3S | 4 | 5.700 | 3.774 | 1.176 | 1.260 | 10.140 | 50.000 | | |
| Selenium, Total | ug/L | MW-4S | 4 | 22.550 | 12.974 | 1.176 | 7.288 | 37.812 | 50.000 | | |
| Selenium, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-6S | 4 | 4.650 | 1.066 | 1.176 | 3.396 | 5.904 | 50.000 | | |
| Selenium, Total | ug/L | MW-7S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-8S | 4 | 2.700 | 1.602 | 1.176 | 0.815 | 4.585 | 50.000 | | |
| Selenium, Total | ug/L | MW-9S | 4 | 50.975 | 53.600 | 1.176 | 0.000 | 114.025 | 50.000 | | |
| Thallium, Total | ug/L | MW-10S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-11S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-12S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-13S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-1S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-2S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-3S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-4S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-5S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-6S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-7S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-8S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-9S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Total Radium | pCi/L | MW-10S | 4 | 1.771 | 1.538 | 1.176 | 0.000 | 3.579 | 5.000 | | |
| Total Radium | pCi/L | MW-11S | 4 | 1.197 | 0.331 | 1.176 | 0.807 | 1.586 | 5.000 | | |
| Total Radium | pCi/L | MW-12S | 4 | 1.203 | 0.391 | 1.176 | 0.744 | 1.663 | 5.000 | | |
| Total Radium | pCi/L | MW-13S | 4 | 1.525 | 0.527 | 1.176 | 0.905 | 2.145 | 5.000 | | |
| Total Radium | pCi/L | MW-1S | 4 | 2.167 | 1.335 | 1.176 | 0.597 | 3.737 | 5.000 | | |
| Total Radium | pCi/L | MW-2S | 4 | 2.219 | 1.602 | 1.176 | 0.335 | 4.103 | 5.000 | | |
| Total Radium | pCi/L | MW-3S | 4 | 0.785 | 0.000 | 1.176 | 0.785 | 0.785 | 5.000 | | |
| Total Radium | pCi/L | MW-4S | 4 | 1.035 | 0.242 | 1.176 | 0.751 | 1.319 | 5.000 | | |
| Total Radium | pCi/L | MW-5S | 4 | 1.059 | 0.149 | 1.176 | 0.883 | 1.234 | 5.000 | | |
| Total Radium | pCi/L | MW-6S | 4 | 0.832 | 0.037 | 1.176 | 0.788 | 0.875 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-7S | 4 | 1.221 | 0.277 | 1.176 | 0.895 | 1.547 | 5.000 | | |
| Total Radium | pCi/L | MW-8S | 4 | 0.969 | 0.127 | 1.176 | 0.819 | 1.119 | 5.000 | | |
| Total Radium | pCi/L | MW-9S | 4 | 1.277 | 0.464 | 1.176 | 0.732 | 1.823 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-11D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-12D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-13D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-14D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-1D | 4 | 3.025 | 0.050 | 1.176 | 2.966 | 3.084 | 6.000 | | |
| Antimony, Total | ug/L | MW-2D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-3D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-7D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-9D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-9I | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Arsenic, Total | ug/L | MW-10D | 4 | 239.000 | 44.699 | 1.176 | 186.421 | 291.579 | 10.000 | dec | ** |
| Arsenic, Total | ug/L | MW-11D | 4 | 15.087 | 0.595 | 1.176 | 14.388 | 15.787 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-12D | 4 | 422.750 | 96.989 | 1.176 | 308.663 | 536.837 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-13D | 4 | 234.500 | 8.583 | 1.176 | 224.404 | 244.596 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-14D | 4 | 120.500 | 13.699 | 1.176 | 104.386 | 136.614 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-1D | 4 | 16.825 | 22.577 | 1.176 | 0.000 | 43.382 | 10.000 | | |
| Arsenic, Total | ug/L | MW-2D | 4 | 3.000 | 0.956 | 1.176 | 1.876 | 4.124 | 10.000 | | |
| Arsenic, Total | ug/L | MW-3D | 4 | 3.350 | 0.370 | 1.176 | 2.915 | 3.785 | 10.000 | | |
| Arsenic, Total | ug/L | MW-7D | 4 | 450.500 | 33.252 | 1.176 | 411.387 | 489.613 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-9D | 4 | 6.925 | 2.240 | 1.176 | 4.291 | 9.559 | 10.000 | | |
| Arsenic, Total | ug/L | MW-9I | 4 | 4.700 | 0.416 | 1.176 | 4.210 | 5.190 | 10.000 | | |
| Barium, Total | ug/L | MW-10D | 4 | 31.450 | 4.048 | 1.176 | 26.688 | 36.212 | 2000.000 | | |
| Barium, Total | ug/L | MW-11D | 4 | 27.150 | 3.359 | 1.176 | 23.199 | 31.101 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-12D | 4 | 27.525 | 0.660 | 1.176 | 26.748 | 28.302 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-13D | 4 | 37.200 | 11.326 | 1.176 | 23.878 | 50.522 | 2000.000 | | |
| Barium, Total | ug/L | MW-14D | 4 | 57.950 | 9.850 | 1.176 | 46.364 | 69.536 | 2000.000 | | |
| Barium, Total | ug/L | MW-1D | 4 | 83.375 | 19.956 | 1.176 | 59.901 | 106.849 | 2000.000 | inc | |
| Barium, Total | ug/L | MW-2D | 4 | 67.125 | 29.601 | 1.176 | 32.306 | 101.944 | 2000.000 | | |
| Barium, Total | ug/L | MW-3D | 4 | 52.300 | 11.390 | 1.176 | 38.902 | 65.698 | 2000.000 | | |
| Barium, Total | ug/L | MW-7D | 4 | 44.250 | 6.920 | 1.176 | 36.110 | 52.390 | 2000.000 | | |
| Barium, Total | ug/L | MW-9D | 4 | 50.275 | 4.021 | 1.176 | 45.545 | 55.005 | 2000.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-9I | 4 | 68.550 | 3.892 | 1.176 | 63.972 | 73.128 | 2000.000 | inc | |
| Beryllium, Total | ug/L | MW-10D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-11D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-12D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-13D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-14D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-1D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-2D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-3D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-7D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-9D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-9I | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Cadmium, Total | ug/L | MW-10D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-11D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-12D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-13D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-14D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-1D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-2D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-3D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-7D | 4 | 1.275 | 0.550 | 1.176 | 0.628 | 1.922 | 5.000 | | |
| Cadmium, Total | ug/L | MW-9D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-9I | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Chromium, Total | ug/L | MW-10D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-12D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-13D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-14D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-1D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-2D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-7D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-9D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-9I | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Cobalt, Total | ug/L | MW-10D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-11D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-12D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-13D | 4 | 2.150 | 0.700 | 1.176 | 1.327 | 2.973 | 6.000 | | |
| Cobalt, Total | ug/L | MW-14D | 4 | 2.175 | 0.650 | 1.176 | 1.410 | 2.940 | 6.000 | | |
| Cobalt, Total | ug/L | MW-1D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-2D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-3D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-7D | 4 | 2.325 | 0.350 | 1.176 | 1.913 | 2.737 | 6.000 | | |
| Cobalt, Total | ug/L | MW-9D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-9I | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Fluoride | mg/L | MW-10D | 4 | 2.425 | 0.287 | 1.176 | 2.087 | 2.763 | 4.000 | | |
| Fluoride | mg/L | MW-11D | 4 | 0.353 | 0.075 | 1.176 | 0.264 | 0.441 | 4.000 | | |
| Fluoride | mg/L | MW-12D | 4 | 1.168 | 0.162 | 1.176 | 0.977 | 1.358 | 4.000 | inc | |
| Fluoride | mg/L | MW-13D | 4 | 0.590 | 0.029 | 1.176 | 0.555 | 0.625 | 4.000 | inc | |
| Fluoride | mg/L | MW-14D | 4 | 0.140 | 0.107 | 1.176 | 0.014 | 0.266 | 4.000 | dec | |
| Fluoride | mg/L | MW-1D | 4 | 0.283 | 0.046 | 1.176 | 0.229 | 0.336 | 4.000 | dec | |
| Fluoride | mg/L | MW-2D | 4 | 0.983 | 0.158 | 1.176 | 0.796 | 1.169 | 4.000 | | |
| Fluoride | mg/L | MW-3D | 4 | 0.190 | 0.034 | 1.176 | 0.150 | 0.230 | 4.000 | dec | |
| Fluoride | mg/L | MW-7D | 4 | 0.387 | 0.025 | 1.176 | 0.358 | 0.417 | 4.000 | | |
| Fluoride | mg/L | MW-9D | 4 | 0.410 | 0.042 | 1.176 | 0.361 | 0.459 | 4.000 | | |
| Fluoride | mg/L | MW-9I | 4 | 0.865 | 0.129 | 1.176 | 0.714 | 1.016 | 4.000 | inc | |
| Lead, Total | ug/L | MW-10D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-12D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-13D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-14D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-1D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-2D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead, Total | ug/L | MW-7D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-9D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-9I | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lithium, Total | ug/L | MW-10D | 4 | 57.975 | 8.356 | 1.176 | 48.145 | 67.805 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-11D | 4 | 141.750 | 6.551 | 1.176 | 134.044 | 149.456 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-12D | 4 | 96.525 | 19.400 | 1.176 | 73.705 | 119.345 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-13D | 4 | 83.450 | 10.168 | 1.176 | 71.489 | 95.411 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-14D | 4 | 706.250 | 176.777 | 1.176 | 498.309 | 914.191 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-1D | 4 | 23.675 | 11.311 | 1.176 | 10.370 | 36.980 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-2D | 4 | 48.650 | 8.267 | 1.176 | 38.926 | 58.374 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-3D | 4 | 10.000 | 0.000 | 1.176 | 10.000 | 10.000 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-7D | 4 | 98.900 | 5.735 | 1.176 | 92.154 | 105.646 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-9D | 4 | 26.325 | 3.976 | 1.176 | 21.648 | 31.002 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-9I | 4 | 28.225 | 3.423 | 1.176 | 24.199 | 32.251 | 40.000 | dec | |
| Mercury | ug/L | MW-10D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-11D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-12D | 4 | 1.200 | 0.400 | 1.176 | 0.729 | 1.671 | 2.000 | | |
| Mercury | ug/L | MW-13D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-14D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-1D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-2D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-3D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-7D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-9D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-9I | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Molybdenum, Total | ug/L | MW-10D | 4 | 85.675 | 10.159 | 1.176 | 73.725 | 97.625 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Molybdenum, Total | ug/L | MW-12D | 4 | 194.000 | 25.100 | 1.176 | 164.475 | 223.525 | 100.000 | dec | ** |
| Molybdenum, Total | ug/L | MW-13D | 4 | 775.250 | 128.370 | 1.176 | 624.250 | 926.250 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-14D | 4 | 230.250 | 34.461 | 1.176 | 189.714 | 270.786 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-1D | 4 | 38.225 | 5.214 | 1.176 | 32.091 | 44.359 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-2D | 4 | 69.725 | 16.253 | 1.176 | 50.607 | 88.843 | 100.000 | dec | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-3D | 4 | 6.500 | 3.000 | 1.176 | 2.971 | 10.029 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-7D | 4 | 706.250 | 20.887 | 1.176 | 681.681 | 730.819 | 100.000 | inc | ** |
| Molybdenum, Total | ug/L | MW-9D | 4 | 47.900 | 6.096 | 1.176 | 40.729 | 55.071 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-9I | 4 | 110.525 | 21.411 | 1.176 | 85.339 | 135.711 | 100.000 | dec | |
| Selenium, Total | ug/L | MW-10D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-12D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-13D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-14D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-1D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-2D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-7D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-9D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-9I | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Thallium, Total | ug/L | MW-10D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-11D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-12D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-13D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-14D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-1D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-2D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-3D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-7D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-9D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-9I | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Total Radium | pCi/L | MW-10D | 4 | 1.224 | 0.502 | 1.176 | 0.633 | 1.815 | 5.000 | | |
| Total Radium | pCi/L | MW-11D | 4 | 0.939 | 0.187 | 1.176 | 0.718 | 1.159 | 5.000 | | |
| Total Radium | pCi/L | MW-12D | 4 | 0.937 | 0.151 | 1.176 | 0.759 | 1.114 | 5.000 | | |
| Total Radium | pCi/L | MW-13D | 4 | 1.432 | 0.338 | 1.176 | 1.034 | 1.829 | 5.000 | | |
| Total Radium | pCi/L | MW-14D | 4 | 1.773 | 0.261 | 1.176 | 1.465 | 2.080 | 5.000 | | |
| Total Radium | pCi/L | MW-1D | 4 | 1.880 | 1.055 | 1.176 | 0.639 | 3.121 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-2D | 4 | 2.300 | 1.113 | 1.176 | 0.991 | 3.609 | 5.000 | | |
| Total Radium | pCi/L | MW-3D | 4 | 1.140 | 0.428 | 1.176 | 0.637 | 1.643 | 5.000 | | |
| Total Radium | pCi/L | MW-7D | 4 | 1.125 | 0.247 | 1.176 | 0.835 | 1.415 | 5.000 | | |
| Total Radium | pCi/L | MW-9D | 4 | 1.306 | 0.304 | 1.176 | 0.948 | 1.664 | 5.000 | | |
| Total Radium | pCi/L | MW-9I | 4 | 1.586 | 0.677 | 1.176 | 0.790 | 2.383 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1 | 88.9314 | 0.2 | 2 | 10 | 1 | 0.2453 | 10 | 20 | 2 | 10 | 3.6792 | 1 | 2.3657 |
| MW-1S | September 2018 | 2 | 0 | 7 | 2 | 1 | 5 | 2 | 0.593 | 5 | 7 | 1 | 46 | 5 | 1 | 0.896 |
| | May 2019 | 2 | 0 | 3 | 2 | 1 | 5 | 2 | 0.519 | 5 | 7 | 1 | 41 | 5 | 1 | 0.648 |
| | November 2019 | 1 | 0 | 33 | 2 | 1 | 5 | 2 | 0.425 | 5 | 5 | 1 | 32 | 5 | 1 | 1.431 |
| | May 2020 | 1 | 6 | 51 | 2 | 1 | 5 | 2 | 0.343 | 5 | 5 | 1 | 29 | 5 | 1 | 0.304 |
| | November 2020 | 2 | 3 | 54 | 2 | 1 | 5 | 2 | 0.326 | 5 | 5 | 1 | 22 | 5 | 1 | 0.508 |
| | May 2021 | 2 | 8 | 76 | 2 | 1 | 5 | 2 | 0.254 | 5 | 10 | 1 | 22 | 5 | 1 | 1.088 |
| | November 2021 | 2.754 | 7.106<br>**12.950 (N=8)** | 57.491 | 2.000 | 1.000 | 5.000 | 2.500 | 0.251 | 5.000 | 10.000 | 1.000 | 22.132 | 5.000 | 1.000 | 0.597<br>1.758 (N=8) |
| MW-2S | September 2018 | 3 | **14** | 80 | 2 | 1 | 5 | 2 | 1.186 | 5 | 17 | 1 | 71 | 5 | 1 | 1.152 |
| | May 2019 | 3 | **12** | 81 | 2 | 1 | 5 | 2 | 0.895 | 5 | 1 | 1 | 35 | 5 | 1 | 0.973 |
| | November 2019 | 3 | **12** | 64 | 2 | 1 | 5 | 2 | 0.587 | 5 | 13 | 1 | 25 | 5 | 1 | 1.000 |
| | May 2020 | 3 | **10** | 62 | 2 | 1 | 5 | 2 | 0.363 | 5 | 7 | 1 | 14 | 5 | 1 | 0.990 |
| | November 2020 | 3 | 9 | 82 | 2 | 1 | 5 | 1 | 0.298 | 5 | 7 | 1 | 28 | 5 | 1 | 1.106 |
| | May 2021 | 3 | 6 | 68 | 2 | 1 | 5 | 1 | 0.294 | 5 | 7 | 1 | 28 | 5 | 1 | 0.429 |
| | November 2021 | 3.000 | 3.608<br>**10.671 (N=8)** | 77.945 | 2.000 | 1.000 | 5.000 | 1.494 | 0.306 | 5.000 | 5.604 | 1.000 | 28.934 | 5.000 | 1.000 | 0.335 |
| MW-3S | September 2018 | **8** | 2 | 24 | 2 | 1 | 5 | 2 | 0.349 | 5 | 10 | 1 | 52 | 4 | 1 | 0.491 |
| | May 2019 | **7** | 2 | 25 | 2 | 1 | 5 | 2 | 0.217 | 5 | 10 | 1 | 41 | 0 | 1 | 0.549 |
| | November 2019 | **8** | 1 | 28 | 2 | 1 | 5 | 2 | 0.197 | 5 | 10 | 1 | 34 | 0 | 1 | 0.615 |
| | May 2020 | **7** | 2 | 35 | 2 | 1 | 5 | 2 | 0.223 | 5 | 10 | 1 | 41 | 1 | 1 | 0.615 |
| | November 2020 | **7** | 1 | 36 | 2 | 1 | 5 | 2 | 0.214 | 5 | 10 | 1 | 39 | 0 | 1 | 0.733 |
| | May 2021 | **6** | 0 | 39 | 2 | 1 | 5 | 2 | 0.174 | 5 | 10 | 1 | 35 | 2 | 1 | 0.785 |
| | November 2021 | 5.764<br>**6.903 (N=8)** | 0.218 | 37.500 | 2.000 | 1.000 | 5.000 | 2.500 | 0.134 | 5.000 | 10.000 | 1.000 | 36.177 | 1.260 | 1.000 | 0.785 |
| MW-4S | September 2018 | 3 | 5 | 52 | 2 | 1 | 5 | 2 | 0.108 | 5 | 6 | 1 | 5 | 6 | 1 | 0.721 |
| | May 2019 | 3 | 5 | 47 | 2 | 1 | 5 | 2 | 0.108 | 5 | 6 | 1 | 5 | 5 | 1 | 0.601 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 3 | 2 | 48 | 2 | 1 | 5 | 2 | 0.060 | 5 | 10 | 1 | 5 | 2 | 1 | 0.812 |
| | November 2020 | 3 | 2 | 62 | 2 | 1 | 5 | 1 | 0.037 | 5 | 10 | 1 | 5 | 10 | 1 | 0.838 |
| | May 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | November 2021 | 3.000 | 1.503 | 59.290 | 2.000 | 1.000 | 5.000 | 1.327 | 0.038 | 5.000 | 5.469 | 1.000 | 5.000 | 7.288 | 1.000 | 0.751 |



**Final Date: 5/6/2022**

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1 | 88.9314 | 0.2 | 2 | 10 | 1 | 0.2453 | 10 | 20 | 2 | 10 | 3.6792 | 1 | 2.3657 |
| MW-5S | September 2018 | 3 | 5 | 24 | 2 | 1 | 5 | 2 | 2.65 | 5 | **53** | 1 | **249** | 5 | 1 | 1.047 |
| | May 2019 | 3 | 5 | 25 | 2 | 1 | 5 | 1 | 2.391 | 5 | **53** | 1 | **227** | 5 | 1 | 1.073 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 3 | 5 | 28 | 2 | 1 | 5 | 1 | 2.316 | 5 | **53** | 1 | **217** | 5 | 1 | 0.942 |
| | November 2020 | 3 | 5 | 25 | 2 | 1 | 5 | 1 | 2.184 | 5 | **43** | 1 | **186** | 5 | 1 | 0.880 |
| | May 2021 | 3 | 5 | 24 | 2 | 1 | 5 | 1 | 1.802 | 5 | 39 | 1 | **138** | 5 | 1 | 0.875 |
| | November 2021 | 3.000 | 5.000 | 22.468 | 2.000 | 1.000 | 5.000 | 0.897 | 1.686 | 5.000 | 39.065<br>**46.853 (N=8)** | 1.000 | **126.264** | 5.000 | 1.000 | 0.883 |
| MW-6S | September 2018 | 3 | **11** | 72 | 2 | 1 | 5 | 2 | 0.919 | 5 | **60** | 1 | **137** | 2 | 1 | 0.553 |
| | May 2019 | 1 | **11** | 82 | 2 | 1 | 5 | 2 | 0.600 | 5 | **55** | 1 | 79 | 1 | 1 | 0.662 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 1 | **10** | 103 | 2 | 1 | 5 | 2 | 0.614 | 5 | **55** | 1 | 79 | 1 | 1 | 0.846 |
| | November 2020 | 1 | 8 | 105 | 2 | 1 | 5 | 2 | 0.610 | 5 | **49** | 1 | 74 | 1 | 1 | 0.700 |
| | May 2021 | 1 | 6 | 101 | 2 | 1 | 5 | 2 | 0.614 | 5 | **51** | 1 | 77 | 2 | 1 | 0.434 |
| | November 2021 | 3.000 | 6.418<br>**10.746 (N=8)** | 108.371 | 2.000 | 1.000 | 5.000 | 1.405 | 1.024 | 5.000 | **58.003** | 1.000 | **152.129** | 3.396 | 1.000 | 0.788 |
| MW-7S | September 2018 | 3 | **324** | 38 | 2 | 1 | 5 | 2 | 0.395 | 5 | **92** | 1 | **410** | 5 | 1 | 1.138 |
| | May 2019 | 3 | **319** | 34 | 2 | 1 | 5 | 1 | 0.391 | 5 | **90** | 1 | **438** | 5 | 1 | 1.180 |
| | November 2019 | 3 | **309** | 35 | 2 | 1 | 5 | 1 | 0.419 | 5 | **89** | 1 | **508** | 5 | 1 | 1.272 |
| | May 2020 | 3 | **306** | 33 | 2 | 1 | 5 | 1 | 0.431 | 5 | **84** | 1 | **509** | 5 | 1 | 1.080 |
| | November 2020 | 3 | **337** | 32 | 2 | 1 | 5 | 1 | 0.461 | 5 | **82** | 1 | **571** | 5 | 1 | 0.979 |
| | May 2021 | 3 | **374** | 34 | 2 | 1 | 5 | 1 | 0.465 | 5 | **82** | 1 | **619** | 5 | 1 | 0.965 |
| | November 2021 | 3.000 | **354.610** | 37.822 | 2.000 | 1.000 | 5.000 | 1.662 | 0.493 | 5.000 | **82.414** | 1.000 | **632.181** | 5.000 | 1.000 | 0.895 |
| MW-8S | September 2018 | 3 | 5 | 18 | 2 | 1 | 5 | 2 | 0.066 | 5 | **72** | 1 | **133** | 5 | 1 | 0.702 |
| | May 2019 | 3 | 5 | 35 | 2 | 1 | 5 | 2 | 0.066 | 5 | **82** | 1 | **171** | 2 | 1 | 0.702 |
| | November 2019 | 3 | 5 | 36 | 2 | 1 | 5 | 2 | 0.062 | 5 | **118** | 1 | **279** | 2 | 1 | 0.620 |
| | May 2020 | 3 | 5 | 36 | 2 | 1 | 5 | 2 | 0.056 | 5 | **114** | 1 | **242** | 1 | 1 | 0.620 |
| | November 2020 | 3 | 5 | 36 | 2 | 1 | 5 | 2 | 0.11 | 5 | **113** | 1 | **279** | 1 | 1 | 0.687 |
| | May 2021 | 3 | 5 | 31 | 2 | 1 | 5 | 2 | 0.059 | 5 | **113** | 1 | **292** | 2 | 1 | 0.687 |
| | November 2021 | 3.000 | 5.000 | 29.260 | 2.000 | 1.000 | 5.000 | 2.500 | 0.058 | 5.000 | **106.923** | 1.000 | **228.802** | 0.815 | 1.000 | 0.819 |
| MW-9S | September 2018 | **9** | 5 | 41 | 2 | 1 | 5 | 2 | 0.05 | 5 | **87** | 1 | 88 | 0 | 1 | 0.663 |
| | May 2019 | **8** | 5 | 47 | 2 | 1 | 5 | 2 | 0.013 | 5 | **74** | 1 | 83 | 0 | 1 | 0.801 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | **9** | 2 | 49 | 2 | 1 | 5 | 2 | 0.013 | 5 | **73** | 1 | 92 | 9 | 1 | 0.801 |
| | November 2020 | **7** | 2 | 50 | 2 | 1 | 5 | 2 | 0.023 | 5 | **68** | 1 | 69 | 0 | 1 | 0.732 |
| | May 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | November 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1 | 88.9314 | 0.2 | 2 | 10 | 1 | 0.2453 | 10 | 20 | 2 | 10 | 3.6792 | 1 | 2.3657 |
| MW-10S | September 2018 | 3 | **356** | 42 | 2 | 1 | 5 | 2 | 1.76 | 5 | **51** | 1 | **108** | 5 | 1 | 1.019 |
| | May 2019 | 3 | **321** | 37 | 2 | 1 | 5 | 2 | 1.839 | 5 | **50** | 1 | 92 | 5 | 1 | 0.965 |
| | November 2019 | 3 | **326** | 41 | 2 | 1 | 5 | 2 | 2.051 | 5 | **55** | 1 | 85 | 5 | 1 | 0.596 |
| | May 2020 | 3 | **337** | 38 | 2 | 1 | 5 | 1 | 1.936 | 5 | **57** | 1 | 80 | 5 | 1 | 0.544 |
| | November 2020 | 3 | **340** | 35 | 2 | 1 | 5 | 1 | 1.97 | 5 | **51** | 1 | 77 | 5 | 1 | 0 |
| | May 2021 | 3 | **342** | 42 | 2 | 1 | 5 | 1 | 1.97 | 5 | **42** | 1 | 71 | 5 | 1 | 0 |
| | November 2021 | 3.000 | **340.569** | 51.110 | 2.000 | 1.000 | 5.000 | 1.410 | 2.070 | 5.000 | **40.133** | 1.000 | 69.641<br>77.437 (N=8) | 5.000 | 1.000 | 0.000 |
| MW-11S | September 2018 | 3 | 2 | 40 | 2 | 1 | 0.242 | 0 | 1.404 | 2 | 0.194 | 1 | 72 | 5 | 1 | 1.321 |
| | May 2019 | 3 | 1 | 41 | 2 | 1 | 0 | 0 | 1.362 | 2 | 0 | 1 | 73 | 5 | 1 | 1.068 |
| | November 2019 | 3 | 2 | 54 | 2 | 1 | 2 | 0 | 1.366 | 2 | 10 | 1 | 73 | 5 | 1 | 0.597 |
| | May 2020 | 3 | 0 | 8 | 1 | 1 | 0 | 0 | 1.332 | 1 | 0 | 1 | 71 | 5 | 1 | 0.471 |
| | November 2020 | 3 | 0 | 2 | 1 | 1 | 0 | 0 | 1.364 | 1 | 0 | 1 | 73 | 5 | 1 | 0.589 |
| | May 2021 | 3 | 0 | 0 | 1 | 1 | 0 | 0 | 1.364 | 1 | 0 | 1 | 76 | 5 | 1 | 0.642 |
| | November 2021 | 3.000 | 0.000 | 0.000 | 0.927 | 1.000 | 5.000 | 0.000 | 1.364 | 1.483 | 0.000 | 1.000 | 75.632 | 5.000 | 1.000 | 0.807 |
| MW-12S | September 2018 | 2 | **13** | 28 | 2 | 1 | 5 | 2 | 0.458 | 5 | **102** | 1 | **274** | 5 | 1 | 0.889 |
| | May 2019 | 3 | **18** | 26 | 2 | 1 | 5 | 2 | 0.879 | 5 | **100** | 1 | **248** | 2 | 1 | 0.897 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 2 | **27** | 27 | 2 | 1 | 5 | 2 | 1.534 | 5 | **97** | 1 | **202** | 2 | 1 | 0.897 |
| | November 2020 | 2 | **27** | 28 | 2 | 1 | 5 | 2 | 1.534 | 5 | **84** | 1 | **178** | 2 | 1 | 0.938 |
| | May 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | November 2021 | 1.879 | **29.435** | 28.013 | 2.000 | 1.000 | 5.000 | 2.500 | 1.549 | 5.000 | **68.305** | 1.000 | **148.059** | 1.002 | 1.000 | 0.744 |

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1 | 88.9314 | 0.2 | 2 | 10 | 1 | 0.2453 | 10 | 20 | 2 | 10 | 3.6792 | 1 | 2.3657 |
| MW-13S | September 2018 | 3 | **328** | 24 | 2 | 1 | 5 | 2 | 0.647 | 5 | **83** | 1 | **466** | 5 | 1 | 0.713 |
| | May 2019 | 3 | **313** | 25 | 2 | 1 | 5 | 2 | 0.681 | 5 | **84** | 1 | **547** | 5 | 1 | 0.725 |
| | November 2019 | 3 | **312** | 26 | 2 | 1 | 5 | 2 | 0.786 | 5 | **75** | 1 | **726** | 5 | 1 | 0.732 |
| | May 2020 | 3 | **306** | 25 | 2 | 1 | 5 | 2 | 0.779 | 5 | **74** | 1 | **746** | 5 | 1 | 0.883 |
| | November 2020 | 3 | **291** | 28 | 2 | 1 | 5 | 2 | 0.778 | 5 | **66** | 1 | **720** | 5 | 1 | 0.855 |
| | May 2021 | 3 | **289** | 29 | 2 | 1 | 5 | 2 | 0.804 | 5 | **62** | 1 | **684** | 5 | 1 | 0.861 |
| | November 2021 | 3.000 | **292.747** | 31.428 | 2.000 | 1.000 | 5.000 | 2.500 | 0.845 | 5.000 | **61.794** | 1.000 | **576.651** | 5.000 | 1.000 | 0.905 |

Notes:
LCL = Lower Confidence Limit
**Bold font** with gray shading indicates 95% LCL of the mean of the last four measurements that is in exceedance of GWPS.
**Bold font** with green shading indicates 95% LCL of the mean of the last eight measurements that is in exceedance of GWPS; trend analyses did not identify a decreasing trend to override the exceedance identified from an expanded dataset.
ug/L = micrograms per liter (ppb)
mg/L = milligrams per liter (ppm)
Std. Units = Standard Units
*USEPA'S *Amendments to the National Minimum Criteria (Phase One, Part One), Disposal of Coal Combustion Residuals from Electric Utilities* ; effective August 29, 2018.
The 95% LCL statistic is based on the rolling set of the four most recent individual sample results for a parameter.
LCL calculations utilize 1/2 the median non-detect (ND) reporting limit (RL) from the full date range of non-detect sample results. If RL levels changed over time, the current calculated LCL value may be larger than the most recent four ND results.
DUMPStat summary table output limits the number of significant digits reported for a calculated LCL. An exceedingly small calculated LCL value (e.g. 0.00001 mg/L) may simply be reported as 0 in the output summary.
**Reporting units of measure for certain constituents in DUMPStat output tables were changed from units of mg/L (ppm) to ug/L (ppb) beginning with November 2021 LCL analysis to allow for reporting of calculated LCLs to more significant digits.**
**Table updated to include November 2021 assessment sampling results.**



**Final Date: 5/6/2022**

# Table 2: 95% LCL Compared to GWPS - Deep Zone

Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1.7471 | 74.2368 | 0.2 | 2 | 10 | 1 | 0.13 | 10 | 20 | 2 | 10 | 1 | 1 | 2.3237 |
| MW-1D | September 2018 | 3 | 2 | 49 | 2 | 1 | 5 | 2 | 0.362 | 5 | 31 | 1 | 49 | 5 | 1 | 0.886 |
| | May 2019 | 3 | 4 | 47 | 2 | 1 | 5 | 2 | 0.336 | 5 | 31 | 1 | 48 | 5 | 1 | 0.900 |
| | November 2019 | 3 | 4 | 48 | 2 | 1 | 5 | 2 | 0.314 | 5 | 25 | 1 | 46 | 5 | 1 | 0.852 |
| | May 2020 | 3 | 4 | 50 | 2 | 1 | 5 | 2 | 0.265 | 5 | 25 | 1 | 45 | 5 | 1 | 0.961 |
| | November 2020 | 3 | 0 | 45 | 2 | 1 | 5 | 2 | 0.268 | 5 | 11 | 1 | 36 | 5 | 1 | 0.421 |
| | May 2021 | 3 | 0 | 51 | 2 | 1 | 5 | 2 | 0.229 | 5 | 11 | 1 | 35 | 5 | 1 | 0.838 |
| | November 2021 | 2.966 | 0.000<br>0.000 (N=8) | 59.901 | 2.000 | 1.000 | 5.000 | 2.500 | 0.229 | 5.000 | 10.37<br>22.268 (N=8) | 1.000 | 32.091 | 5.000 | 1.000 | 0.639 |
| MW-2D | September 2018 | 3 | 2 | 27 | 2 | 1 | 5 | 2 | 2.532 | 5 | 35 | 1 | **202** | 5 | 1 | 0.958 |
| | May 2019 | 3 | 1 | 39 | 2 | 1 | 5 | 2 | 1.763 | 5 | 20 | 1 | **120** | 5 | 1 | 0.990 |
| | November 2019 | 3 | 1 | 48 | 2 | 1 | 5 | 2 | 1.209 | 5 | 28 | 1 | 65 | 5 | 1 | 0.905 |
| | May 2020 | 3 | 2 | 52 | 2 | 1 | 5 | 2 | 0.859 | 5 | 30 | 1 | 56 | 5 | 1 | 1.427 |
| | November 2020 | 3 | 2 | 63 | 2 | 1 | 5 | 2 | 0.981 | 5 | **40** | 1 | 72 | 5 | 1 | 1.486 |
| | May 2021 | 3 | 2 | 39 | 2 | 1 | 5 | 2 | 0.865 | 5 | 37 | 1 | 59 | 5 | 1 | 1.458 |
| | November 2021 | 3.000 | 1.876 | 32.306 | 2.000 | 1.000 | 5.000 | 2.500 | 0.796 | 5.000 | 38.926<br>39.230 (N=8)<br>57.936 (N=16)[1] | 1.000 | 50.607<br>66.352 (N=8) | 5.000 | 1.000 | 0.991 |
| MW-3D | September 2018 | 3 | 3 | 61 | 2 | 1 | 5 | 2 | 0.264 | 5 | 7 | 1 | 14 | 5 | 1 | 0.808 |
| | May 2019 | 3 | 2 | 64 | 2 | 1 | 5 | 2 | 0.222 | 5 | 7 | 1 | 5 | 5 | 1 | 0.794 |
| | November 2019 | 3 | 2 | 54 | 2 | 1 | 5 | 2 | 0.212 | 5 | 6 | 1 | 10 | 5 | 1 | 0.482 |
| | May 2020 | 3 | 3 | 46 | 2 | 1 | 5 | 2 | 0.205 | 5 | 6 | 1 | 10 | 5 | 1 | 0.355 |
| | November 2020 | 3 | 3 | 45 | 2 | 1 | 5 | 2 | 0.199 | 5 | 6 | 1 | 6 | 5 | 1 | 0.347 |
| | May 2021 | 3 | 3 | 41 | 2 | 1 | 5 | 2 | 0.181 | 5 | 10 | 1 | 4 | 5 | 1 | 0.000 |
| | November 2021 | 3.000 | 2.915 | 38.902 | 2.000 | 1.000 | 5.000 | 2.500 | 0.15 | 5.000 | 10.000 | 1.000 | 2.971 | 5.000 | 1.000 | 0.637 |
| MW-7D | September 2018 | 3 | **443** | 48 | 2 | 1 | 5 | 2 | 0.262 | 5 | **108** | 1 | **426** | 5 | 1 | 1.280 |
| | May 2019 | 3 | **438** | 41 | 2 | 1 | 5 | 2 | 0.263 | 5 | **106** | 1 | **467** | 5 | 1 | 0.777 |
| | November 2019 | 3 | **422** | 42 | 2 | 1 | 5 | 2 | 0.284 | 5 | **97** | 1 | **546** | 5 | 1 | 0.877 |
| | May 2020 | 3 | **426** | 42 | 2 | 1 | 5 | 2 | 0.294 | 5 | **94** | 1 | **554** | 5 | 1 | 0.831 |
| | November 2020 | 3 | **405** | 39 | 2 | 1 | 5 | 2 | 0.318 | 5 | **87** | 1 | **596** | 5 | 1 | 0.687 |
| | May 2021 | 3 | **404** | 38 | 2 | 1 | 5 | 2 | 0.343 | 5 | **91** | 1 | **629** | 5 | 1 | 0.855 |
| | November 2021 | 3.000 | **411.387** | 36.11 | 2.000 | 0.628 | 5.000 | 1.913 | 0.358 | 5.000 | **92.154** | 1.000 | **681.681** | 5.000 | 1.000 | 0.835 |
| MW-9D | September 2018 | 3 | 3 | 32 | 2 | 1 | 5 | 2 | 0.425 | 5 | **41** | 1 | 84 | 5 | 1 | 0.803 |
| | May 2019 | 3 | 2 | 36 | 2 | 1 | 5 | 2 | 0.412 | 5 | 38 | 1 | 56 | 5 | 1 | 0.770 |
| | November 2019 | 3 | 2 | 45 | 2 | 1 | 5 | 2 | 0.430 | 5 | 35 | 1 | 42 | 5 | 1 | 0.808 |
| | May 2020 | 3 | 2 | 45 | 2 | 1 | 5 | 2 | 0.428 | 5 | 31 | 1 | 42 | 5 | 1 | 0.822 |
| | November 2020 | 3 | 2 | 44 | 2 | 1 | 5 | 2 | 0.421 | 5 | 24 | 1 | 46 | 5 | 1 | 0.876 |
| | May 2021 | 3 | 3 | 46 | 2 | 1 | 5 | 2 | 0.400 | 5 | 24 | 1 | 46 | 5 | 1 | 0.795 |
| | November 2021 | 3.000 | 4.291 | 45.545 | 2.000 | 1.000 | 5.000 | 2.500 | 0.361 | 5.000 | 21.648<br>27.763 (N=8) | 1.000 | 40.729 | 5.000 | 1.000 | 0.948 |



**Final Date: 5/6/2022**

# Table 2: 95% LCL Compared to GWPS - Deep Zone

Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1.7471 | 74.2368 | 0.2 | 2 | 10 | 1 | 0.13 | 10 | 20 | 2 | 10 | 1 | 1 | 2.3237 |
| MW-9I | September 2018 | 3 | 5 | 30 | 2 | 1 | 5 | 2 | 0.538 | 5 | 33 | 1 | **109** | 5 | 1 | 0.946 |
| | May 2019 | 3 | 4 | 38 | 2 | 1 | 5 | 2 | 0.522 | 5 | 30 | 1 | 98 | 5 | 1 | 0.934 |
| | November 2019 | 3 | 4 | 54 | 2 | 1 | 5 | 2 | 0.528 | 5 | 31 | 1 | 88 | 5 | 1 | 0.738 |
| | May 2020 | 3 | 4 | 53 | 2 | 1 | 5 | 2 | 0.595 | 5 | 29 | 1 | 89 | 5 | 1 | 0.544 |
| | November 2020 | 3 | 4 | 55 | 2 | 1 | 5 | 2 | 0.667 | 5 | 23 | 1 | 89 | 5 | 1 | 0.600 |
| | May 2021 | 3 | 4 | 58 | 2 | 1 | 5 | 2 | 0.647 | 5 | 24 | 1 | 78 | 5 | 1 | 0.480 |
| | November 2021 | 3.000 | 4.21 | 63.972 | 2.000 | 1.000 | 5.000 | 2.500 | 0.714 | 5.000 | 24.199<br>28.414 (N=8) | 1.000 | 85.339<br>96.532 (N=8)<br>122.452 (N=16)[1] | 5.000 | 1.000 | 0.79 |
| MW-10D | September 2018 | 3 | **331** | 23 | 2 | 1 | 5 | 2 | 2.066 | 5 | **58** | 1 | **139** | 5 | 1 | 1.123 |
| | May 2019 | 3 | **295** | 26 | 2 | 1 | 5 | 2 | 2.147 | 5 | **57** | 1 | 97 | 5 | 1 | 1.048 |
| | November 2019 | 3 | **267** | 28 | 2 | 1 | 5 | 2 | 2.299 | 5 | **60** | 1 | 73 | 5 | 1 | 0.943 |
| | May 2020 | 3 | **263** | 27 | 2 | 1 | 5 | 2 | 2.298 | 5 | **59** | 1 | 60 | 5 | 1 | 0.743 |
| | November 2020 | 3 | **254** | 28 | 2 | 1 | 5 | 2 | 2.298 | 5 | **53** | 1 | 70 | 5 | 1 | 0.779 |
| | May 2021 | 3 | **252** | 26 | 2 | 1 | 5 | 2 | 2.334 | 5 | **49** | 1 | 71 | 5 | 1 | 0.674 |
| | November 2021 | 3.000 | **186.421** | 26.688 | 2.000 | 1.000 | 5.000 | 2.500 | 2.087 | 5.000 | **48.145** | 1.000 | 73.725<br>80.904 (N=8) | 5.000 | 1.000 | 0.633 |
| MW-11D | September 2018 | 3 | **13** | 32 | 2 | 1 | 5 | 2 | 0.333 | 5 | **111** | 1 | 5 | 5 | 1 | 0.912 |
| | May 2019 | 3 | **13** | 31 | 2 | 1 | 5 | 2 | 0.334 | 5 | **122** | 1 | 5 | 5 | 1 | 0.887 |
| | November 2019 | 3 | **14** | 31 | 2 | 1 | 5 | 2 | 0.326 | 5 | **123** | 1 | 5 | 5 | 1 | 0.834 |
| | May 2020 | 3 | **14** | 28 | 2 | 1 | 5 | 2 | 0.311 | 5 | **122** | 1 | 5 | 5 | 1 | 0.782 |
| | November 2020 | 3 | **14** | 27 | 2 | 1 | 5 | 2 | 0.371 | 5 | **125** | 1 | 5 | 5 | 1 | 0.834 |
| | May 2021 | 3 | **15** | 26 | 2 | 1 | 5 | 2 | 0.27 | 5 | **129** | 1 | 5 | 5 | 1 | 0.680 |
| | November 2021 | 3.000 | **14.388** | 23.199 | 2.000 | 1.000 | 5.000 | 2.500 | 0.264 | 5.000 | **134.044** | 1.000 | 5.000 | 5.000 | 1.000 | 0.718 |
| MW-12D | September 2018 | 3 | **194** | 24 | 2 | 1 | 5 | 2 | 0.379 | 5 | **113** | 1 | **217** | 5 | 1 | 0.960 |
| | May 2019 | 3 | **203** | 24 | 2 | 1 | 5 | 2 | 0.515 | 5 | **101** | 1 | **221** | 5 | 1 | 0.669 |
| | November 2019 | 3 | **208** | 24 | 2 | 1 | 5 | 2 | 0.962 | 5 | **101** | 1 | **215** | 5 | 1 | 0.794 |
| | May 2020 | 3 | **194** | 24 | 2 | 1 | 5 | 2 | 0.962 | 5 | **101** | 1 | **214** | 5 | 1 | 0.721 |
| | November 2020 | 3 | **147** | 25 | 2 | 1 | 5 | 2 | 0.977 | 5 | **102** | 1 | **203** | 5 | 1 | 0.727 |
| | May 2021 | 3 | **215** | 27 | 2 | 1 | 5 | 2 | 0.977 | 5 | **75** | 1 | **176** | 5 | 1 | 0.727 |
| | November 2021 | 3.000 | **308.663** | 26.748 | 2.000 | 1.000 | 5.000 | 2.500 | 0.977 | 5.000 | **73.705** | 0.729 | **164.475** | 5.000 | 1.000 | 0.759 |
| MW-13D | September 2018 | 3 | **217** | 20 | 2 | 1 | 5 | 2 | 0.410 | 5 | **97** | 1 | **614** | 5 | 1 | 1.058 |
| | May 2019 | 3 | **209** | 21 | 2 | 1 | 5 | 2 | 0.415 | 5 | **97** | 1 | **666** | 5 | 1 | 1.366 |
| | November 2019 | 3 | **207** | 20 | 2 | 1 | 5 | 2 | 0.452 | 5 | **87** | 1 | **813** | 5 | 1 | 1.022 |
| | May 2020 | 3 | **211** | 19 | 2 | 1 | 5 | 2 | 0.446 | 5 | **87** | 1 | **799** | 5 | 1 | 0.852 |
| | November 2020 | 3 | **216** | 24 | 2 | 1 | 5 | 2 | 0.468 | 5 | **78** | 1 | **800** | 5 | 1 | 0.866 |
| | May 2021 | 3 | **218** | 20 | 2 | 1 | 5 | 1 | 0.507 | 5 | **72** | 1 | **779** | 5 | 1 | 0.837 |
| | November 2021 | 3.000 | **224.404** | 23.878 | 2.000 | 1.000 | 5.000 | 1.327 | 0.555 | 5.000 | **71.489** | 1.000 | **624.25** | 5.000 | 1.000 | 1.034 |

# Table 2: 95% LCL Compared to GWPS - Deep Zone

Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01115

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through November 2021) | 1 | 1.7471 | 74.2368 | 0.2 | 2 | 10 | 1 | 0.13 | 10 | 20 | 2 | 10 | 1 | 1 | 2.3237 |
| MW-14D | September 2018 | 3 | **113** | 49 | 2 | 1 | 5 | 2 | 0.246 | 5 | **551** | 1 | **177** | 5 | 1 | 1.154 |
| | May 2019 | 3 | **105** | 46 | 2 | 1 | 5 | 2 | 0.235 | 5 | **532** | 1 | **181** | 5 | 1 | 1.198 |
| | November 2019 | 3 | **99** | 47 | 2 | 1 | 5 | 1 | 0.202 | 5 | **488** | 1 | **159** | 5 | 1 | 1.163 |
| | May 2020 | 3 | **104** | 46 | 2 | 1 | 5 | 1 | 0.076 | 5 | **449** | 1 | **159** | 5 | 1 | 1.302 |
| | November 2020 | 3 | **100** | 46 | 2 | 1 | 5 | 1 | 0.077 | 5 | **378** | 1 | **174** | 5 | 1 | 1.366 |
| | May 2021 | 3 | **103** | 48 | 2 | 1 | 5 | 1 | 0.015 | 5 | **398** | 1 | **189** | 5 | 1 | 1.605 |
| | November 2021 | 3.000 | **104.386** | 46.364 | 2.000 | 1.000 | 5.000 | 1.41 | 0.014 | 5.000 | **498.309** | 1.000 | **189.714** | 5.000 | 1.000 | 1.465 |

Notes:
LCL = Lower Confidence Limit
**Bold font** with gray shading indicates 95% LCL of the mean of the last four measurements that is in exceedance of GWPS.
**Bold font** with green shading indicates 95% LCL of the mean of the last eight or sixteen measurements that is in exceedance of GWPS; trend analyses did not identify a decreasing trend to override the exceedance identified from an expanded dataset.
ug/L = micrograms per liter (ppb)
mg/L = milligrams per liter (ppm)
Std. Units = Standard Units
*USEPA'S *Amendments to the National Minimum Criteria (Phase One, Part One), Disposal of Coal Combustion Residuals from Electric Utilities* ; effective August 29, 2018.
The 95% LCL statistic is based on the rolling set of the four most recent individual sample results for a parameter.
1 - Exceedance not declared due to decreasing trend identified over the corresponding dataset. A decreasing trend indicates improvements in water quality are occuring and the use of an expanded dataset does not accurately reflect current conditions.
LCL calculations utilize 1/2 the median non-detect (ND) reporting limit (RL) from the full date range of non-detect sample results. If RL levels changed over time, the current calculated LCL value may be larger than the most recent four ND results.
DUMPStat summary table output limits the number of significant digits reported for a calculated LCL. An exceedingly small calculated LCL value (e.g. 0.00001 mg/L) may simply be reported as 0 in the output summary.
**Reporting units of measure for certain constituents in DUMPStat output tables were changed from units of mg/L (ppm) to ug/L (ppb) beginning with November 2021 LCL analysis to allow for reporting of calculated LCLs to more significant digits.**
**Table updated to include November 2021 assessment sampling results.**



**Final Date: 5/6/2022**

**MAY 2022**

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-11S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-12S | 4 | 2.425 | 0.435 | 1.176 | 1.913 | 2.937 | 6.000 | | |
| Antimony, Total | ug/L | MW-13S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-1S | 4 | 3.050 | 0.252 | 1.176 | 2.754 | 3.346 | 6.000 | | |
| Antimony, Total | ug/L | MW-2S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-3S | 4 | 6.350 | 1.360 | 1.176 | 4.750 | 7.950 | 6.000 | | |
| Antimony, Total | ug/L | MW-4S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-5S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-6S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-7S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-8S | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-9S | 4 | 9.200 | 1.738 | 1.176 | 7.156 | 11.244 | 6.000 | dec | ** |
| Arsenic, Total | ug/L | MW-10S | 4 | 409.750 | 42.952 | 1.176 | 359.225 | 460.275 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-11S | 4 | 4.425 | 4.053 | 1.176 | 0.000 | 9.193 | 10.000 | | |
| Arsenic, Total | ug/L | MW-12S | 4 | 50.250 | 9.747 | 1.176 | 38.785 | 61.715 | 10.000 | inc | ** |
| Arsenic, Total | ug/L | MW-13S | 4 | 358.500 | 55.405 | 1.176 | 293.328 | 423.672 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-1S | 4 | 15.700 | 8.477 | 1.176 | 5.729 | 25.671 | 10.000 | | |
| Arsenic, Total | ug/L | MW-2S | 4 | 15.250 | 9.983 | 1.176 | 3.507 | 26.993 | 10.000 | dec | |
| Arsenic, Total | ug/L | MW-3S | 4 | 2.275 | 1.825 | 1.176 | 0.129 | 4.421 | 10.000 | | |
| Arsenic, Total | ug/L | MW-4S | 4 | 2.650 | 1.866 | 1.176 | 0.455 | 4.845 | 10.000 | | |
| Arsenic, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 10.000 | | |
| Arsenic, Total | ug/L | MW-6S | 4 | 17.450 | 14.687 | 1.176 | 0.174 | 34.726 | 10.000 | | |
| Arsenic, Total | ug/L | MW-7S | 4 | 407.750 | 41.700 | 1.176 | 358.698 | 456.802 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-8S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 10.000 | | |
| Arsenic, Total | ug/L | MW-9S | 4 | 4.125 | 1.750 | 1.176 | 2.066 | 6.184 | 10.000 | | |
| Barium, Total | ug/L | MW-10S | 4 | 70.925 | 17.284 | 1.176 | 50.594 | 91.256 | 2000.000 | | |
| Barium, Total | ug/L | MW-11S | 4 | 100.150 | 49.906 | 1.176 | 41.446 | 158.854 | 2000.000 | | |
| Barium, Total | ug/L | MW-12S | 4 | 32.250 | 1.779 | 1.176 | 30.158 | 34.342 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-13S | 4 | 39.100 | 5.563 | 1.176 | 32.556 | 45.644 | 2000.000 | | |
| Barium, Total | ug/L | MW-1S | 4 | 92.925 | 30.077 | 1.176 | 57.546 | 128.304 | 2000.000 | | |
| Barium, Total | ug/L | MW-2S | 4 | 107.375 | 20.221 | 1.176 | 83.590 | 131.160 | 2000.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-3S | 4 | 43.325 | 9.984 | 1.176 | 31.580 | 55.070 | 2000.000 | | |
| Barium, Total | ug/L | MW-4S | 4 | 92.625 | 14.172 | 1.176 | 75.954 | 109.296 | 2000.000 | | |
| Barium, Total | ug/L | MW-5S | 4 | 30.425 | 6.746 | 1.176 | 22.490 | 38.360 | 2000.000 | | |
| Barium, Total | ug/L | MW-6S | 4 | 120.750 | 8.180 | 1.176 | 111.128 | 130.372 | 2000.000 | | |
| Barium, Total | ug/L | MW-7S | 4 | 40.200 | 4.182 | 1.176 | 35.281 | 45.119 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-8S | 4 | 34.375 | 4.312 | 1.176 | 29.303 | 39.447 | 2000.000 | | |
| Barium, Total | ug/L | MW-9S | 4 | 52.550 | 1.923 | 1.176 | 50.288 | 54.812 | 2000.000 | inc | |
| Beryllium, Total | ug/L | MW-10S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-11S | 4 | 1.280 | 0.842 | 1.176 | 0.290 | 2.270 | 4.000 | | |
| Beryllium, Total | ug/L | MW-12S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-13S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-1S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-2S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-3S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-4S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-5S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-6S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-7S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-8S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-9S | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Cadmium, Total | ug/L | MW-10S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-11S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-12S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-13S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-1S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-2S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-3S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-4S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-5S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-6S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-7S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-8S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Cadmium, Total | ug/L | MW-9S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Chromium, Total | ug/L | MW-10S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-11S | 4 | 7.450 | 4.900 | 1.176 | 1.686 | 13.214 | 100.000 | | |
| Chromium, Total | ug/L | MW-12S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-13S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-1S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-2S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-3S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-4S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-6S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-7S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-8S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-9S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Cobalt, Total | ug/L | MW-10S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-11S | 4 | 3.100 | 1.200 | 1.176 | 1.688 | 4.512 | 6.000 | | |
| Cobalt, Total | ug/L | MW-12S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-13S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-1S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-2S | 4 | 2.200 | 0.600 | 1.176 | 1.494 | 2.906 | 6.000 | | |
| Cobalt, Total | ug/L | MW-3S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-4S | 4 | 2.150 | 0.700 | 1.176 | 1.327 | 2.973 | 6.000 | | |
| Cobalt, Total | ug/L | MW-5S | 4 | 2.200 | 0.600 | 1.176 | 1.494 | 2.906 | 6.000 | | |
| Cobalt, Total | ug/L | MW-6S | 4 | 1.625 | 0.126 | 1.176 | 1.477 | 1.773 | 6.000 | | |
| Cobalt, Total | ug/L | MW-7S | 4 | 2.250 | 0.500 | 1.176 | 1.662 | 2.838 | 6.000 | | |
| Cobalt, Total | ug/L | MW-8S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-9S | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Fluoride | mg/L | MW-10S | 4 | 2.500 | 0.082 | 1.176 | 2.404 | 2.596 | 4.000 | | |
| Fluoride | mg/L | MW-11S | 4 | 1.550 | 0.191 | 1.176 | 1.325 | 1.775 | 4.000 | | |
| Fluoride | mg/L | MW-12S | 4 | 1.875 | 0.150 | 1.176 | 1.699 | 2.051 | 4.000 | inc | |
| Fluoride | mg/L | MW-13S | 4 | 0.948 | 0.112 | 1.176 | 0.815 | 1.080 | 4.000 | inc | |
| Fluoride | mg/L | MW-1S | 4 | 0.327 | 0.071 | 1.176 | 0.244 | 0.411 | 4.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Fluoride | mg/L | MW-2S | 4 | 0.408 | 0.096 | 1.176 | 0.294 | 0.521 | 4.000 | | |
| Fluoride | mg/L | MW-3S | 4 | 0.143 | 0.068 | 1.176 | 0.063 | 0.222 | 4.000 | dec | |
| Fluoride | mg/L | MW-4S | 4 | 0.063 | 0.025 | 1.176 | 0.033 | 0.092 | 4.000 | | |
| Fluoride | mg/L | MW-5S | 4 | 1.925 | 0.263 | 1.176 | 1.616 | 2.234 | 4.000 | dec | |
| Fluoride | mg/L | MW-6S | 4 | 1.300 | 0.082 | 1.176 | 1.204 | 1.396 | 4.000 | | |
| Fluoride | mg/L | MW-7S | 4 | 0.568 | 0.103 | 1.176 | 0.446 | 0.689 | 4.000 | inc | |
| Fluoride | mg/L | MW-8S | 4 | 0.093 | 0.051 | 1.176 | 0.033 | 0.152 | 4.000 | dec | |
| Fluoride | mg/L | MW-9S | 4 | 0.118 | 0.081 | 1.176 | 0.023 | 0.212 | 4.000 | | |
| Lead, Total | ug/L | MW-10S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-11S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-12S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-13S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-1S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-2S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-3S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-4S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-6S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-7S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-8S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-9S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lithium, Total | ug/L | MW-10S | 4 | 47.325 | 5.447 | 1.176 | 40.918 | 53.732 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-11S | 4 | 13.775 | 7.550 | 1.176 | 4.894 | 22.656 | 40.000 | | |
| Lithium, Total | ug/L | MW-12S | 4 | 80.775 | 13.167 | 1.176 | 65.287 | 96.263 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-13S | 4 | 66.825 | 5.421 | 1.176 | 60.449 | 73.201 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-1S | 4 | 10.000 | 0.000 | 1.176 | 10.000 | 10.000 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-2S | 4 | 13.250 | 6.500 | 1.176 | 5.604 | 20.896 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-3S | 4 | 10.000 | 0.000 | 1.176 | 10.000 | 10.000 | 40.000 | | |
| Lithium, Total | ug/L | MW-4S | 4 | 13.350 | 6.700 | 1.176 | 5.469 | 21.231 | 40.000 | | |
| Lithium, Total | ug/L | MW-5S | 4 | 44.150 | 2.551 | 1.176 | 41.149 | 47.151 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-6S | 4 | 67.175 | 5.741 | 1.176 | 60.422 | 73.928 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-7S | 4 | 85.250 | 2.409 | 1.176 | 82.416 | 88.084 | 40.000 | dec | ** |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lithium, Total | ug/L | MW-8S | 4 | 137.250 | 36.936 | 1.176 | 93.803 | 180.697 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-9S | 4 | 79.600 | 9.506 | 1.176 | 68.418 | 90.782 | 40.000 | dec | ** |
| Mercury | ug/L | MW-10S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-11S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-12S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-13S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-1S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-2S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-3S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-4S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-5S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-6S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-7S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-8S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-9S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Molybdenum, Total | ug/L | MW-10S | 4 | 71.450 | 5.087 | 1.176 | 65.466 | 77.434 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-11S | 4 | 79.200 | 2.888 | 1.176 | 75.803 | 82.597 | 100.000 | | |
| Molybdenum, Total | ug/L | MW-12S | 4 | 164.000 | 39.564 | 1.176 | 117.461 | 210.539 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-13S | 4 | 631.000 | 88.623 | 1.176 | 526.754 | 735.246 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-1S | 4 | 26.050 | 1.439 | 1.176 | 24.358 | 27.742 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-2S | 4 | 31.225 | 10.580 | 1.176 | 18.780 | 43.670 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-3S | 4 | 39.075 | 5.985 | 1.176 | 32.035 | 46.115 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-4S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Molybdenum, Total | ug/L | MW-5S | 4 | 146.750 | 26.651 | 1.176 | 115.401 | 178.099 | 100.000 | dec | ** |
| Molybdenum, Total | ug/L | MW-6S | 4 | 190.750 | 30.170 | 1.176 | 155.261 | 226.239 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-7S | 4 | 641.000 | 46.769 | 1.176 | 585.986 | 696.014 | 100.000 | inc | ** |
| Molybdenum, Total | ug/L | MW-8S | 4 | 330.250 | 155.139 | 1.176 | 147.761 | 512.739 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-9S | 4 | 127.825 | 49.893 | 1.176 | 69.137 | 186.513 | 100.000 | dec | |
| Selenium, Total | ug/L | MW-10S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-11S | 4 | 4.025 | 1.950 | 1.176 | 1.731 | 6.319 | 50.000 | | |
| Selenium, Total | ug/L | MW-12S | 4 | 11.750 | 10.065 | 1.176 | 0.000 | 23.590 | 50.000 | | |
| Selenium, Total | ug/L | MW-13S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Selenium, Total | ug/L | MW-1S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-2S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-3S | 4 | 10.250 | 11.287 | 1.176 | 0.000 | 23.526 | 50.000 | | |
| Selenium, Total | ug/L | MW-4S | 4 | 48.275 | 48.713 | 1.176 | 0.000 | 105.576 | 50.000 | | |
| Selenium, Total | ug/L | MW-5S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-6S | 4 | 4.825 | 0.903 | 1.176 | 3.763 | 5.887 | 50.000 | | |
| Selenium, Total | ug/L | MW-7S | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-8S | 4 | 3.400 | 1.992 | 1.176 | 1.057 | 5.743 | 50.000 | | |
| Selenium, Total | ug/L | MW-9S | 4 | 50.975 | 53.600 | 1.176 | 0.000 | 114.025 | 50.000 | | |
| Thallium, Total | ug/L | MW-10S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-11S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-12S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-13S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-1S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-2S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-3S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-4S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-5S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-6S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-7S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-8S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-9S | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Total Radium | pCi/L | MW-10S | 4 | 1.768 | 1.539 | 1.176 | 0.000 | 3.579 | 5.000 | | |
| Total Radium | pCi/L | MW-11S | 4 | 1.229 | 0.280 | 1.176 | 0.899 | 1.558 | 5.000 | | |
| Total Radium | pCi/L | MW-12S | 4 | 1.172 | 0.424 | 1.176 | 0.673 | 1.670 | 5.000 | | |
| Total Radium | pCi/L | MW-13S | 4 | 1.525 | 0.527 | 1.176 | 0.905 | 2.145 | 5.000 | | |
| Total Radium | pCi/L | MW-1S | 4 | 2.172 | 1.329 | 1.176 | 0.608 | 3.735 | 5.000 | | |
| Total Radium | pCi/L | MW-2S | 4 | 2.297 | 1.553 | 1.176 | 0.470 | 4.124 | 5.000 | | |
| Total Radium | pCi/L | MW-3S | 4 | 0.722 | 0.127 | 1.176 | 0.572 | 0.871 | 5.000 | | |
| Total Radium | pCi/L | MW-4S | 4 | 0.948 | 0.235 | 1.176 | 0.671 | 1.224 | 5.000 | | |
| Total Radium | pCi/L | MW-5S | 4 | 1.095 | 0.093 | 1.176 | 0.986 | 1.204 | 5.000 | | |
| Total Radium | pCi/L | MW-6S | 4 | 0.832 | 0.037 | 1.176 | 0.788 | 0.875 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-7S | 4 | 1.186 | 0.330 | 1.176 | 0.798 | 1.574 | 5.000 | | |
| Total Radium | pCi/L | MW-8S | 4 | 0.827 | 0.155 | 1.176 | 0.645 | 1.010 | 5.000 | | |
| Total Radium | pCi/L | MW-9S | 4 | 1.277 | 0.464 | 1.176 | 0.732 | 1.823 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Antimony, Total | ug/L | MW-10D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-11D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-12D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-13D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-14D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-1D | 4 | 3.025 | 0.050 | 1.176 | 2.966 | 3.084 | 6.000 | | |
| Antimony, Total | ug/L | MW-2D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-3D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-7D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-9D | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Antimony, Total | ug/L | MW-9I | 4 | 3.000 | 0.000 | 1.176 | 3.000 | 3.000 | 6.000 | | |
| Arsenic, Total | ug/L | MW-10D | 4 | 207.000 | 60.161 | 1.176 | 136.233 | 277.767 | 10.000 | dec | ** |
| Arsenic, Total | ug/L | MW-11D | 4 | 15.188 | 0.747 | 1.176 | 14.309 | 16.066 | 10.000 | inc | ** |
| Arsenic, Total | ug/L | MW-12D | 4 | 447.750 | 53.450 | 1.176 | 384.877 | 510.623 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-13D | 4 | 235.500 | 9.747 | 1.176 | 224.035 | 246.965 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-14D | 4 | 119.500 | 12.793 | 1.176 | 104.451 | 134.549 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-1D | 4 | 16.100 | 23.023 | 1.176 | 0.000 | 43.181 | 10.000 | | |
| Arsenic, Total | ug/L | MW-2D | 4 | 3.525 | 0.690 | 1.176 | 2.714 | 4.336 | 10.000 | | |
| Arsenic, Total | ug/L | MW-3D | 4 | 3.350 | 0.370 | 1.176 | 2.915 | 3.785 | 10.000 | | |
| Arsenic, Total | ug/L | MW-7D | 4 | 454.750 | 36.945 | 1.176 | 411.292 | 498.208 | 10.000 | | ** |
| Arsenic, Total | ug/L | MW-9D | 4 | 10.925 | 7.189 | 1.176 | 2.469 | 19.381 | 10.000 | | |
| Arsenic, Total | ug/L | MW-9I | 4 | 6.475 | 3.226 | 1.176 | 2.680 | 10.270 | 10.000 | | |
| Barium, Total | ug/L | MW-10D | 4 | 30.750 | 3.198 | 1.176 | 26.988 | 34.512 | 2000.000 | | |
| Barium, Total | ug/L | MW-11D | 4 | 26.850 | 3.453 | 1.176 | 22.788 | 30.912 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-12D | 4 | 27.350 | 0.785 | 1.176 | 26.426 | 28.274 | 2000.000 | dec | |
| Barium, Total | ug/L | MW-13D | 4 | 36.500 | 11.735 | 1.176 | 22.697 | 50.303 | 2000.000 | | |
| Barium, Total | ug/L | MW-14D | 4 | 54.075 | 11.746 | 1.176 | 40.259 | 67.891 | 2000.000 | | |
| Barium, Total | ug/L | MW-1D | 4 | 85.125 | 18.781 | 1.176 | 63.033 | 107.217 | 2000.000 | inc | |
| Barium, Total | ug/L | MW-2D | 4 | 61.850 | 31.831 | 1.176 | 24.408 | 99.292 | 2000.000 | | |
| Barium, Total | ug/L | MW-3D | 4 | 56.350 | 12.975 | 1.176 | 41.088 | 71.612 | 2000.000 | | |
| Barium, Total | ug/L | MW-7D | 4 | 43.925 | 6.984 | 1.176 | 35.709 | 52.141 | 2000.000 | | |
| Barium, Total | ug/L | MW-9D | 4 | 52.325 | 4.410 | 1.176 | 47.137 | 57.513 | 2000.000 | inc | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Barium, Total | ug/L | MW-9I | 4 | 72.025 | 4.811 | 1.176 | 66.366 | 77.684 | 2000.000 | inc | |
| Beryllium, Total | ug/L | MW-10D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-11D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-12D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-13D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-14D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-1D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-2D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-3D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-7D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-9D | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Beryllium, Total | ug/L | MW-9I | 4 | 2.000 | 0.000 | 1.176 | 2.000 | 2.000 | 4.000 | | |
| Cadmium, Total | ug/L | MW-10D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-11D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-12D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-13D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-14D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-1D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-2D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-3D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-7D | 4 | 1.275 | 0.550 | 1.176 | 0.628 | 1.922 | 5.000 | | |
| Cadmium, Total | ug/L | MW-9D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Cadmium, Total | ug/L | MW-9I | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 5.000 | | |
| Chromium, Total | ug/L | MW-10D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-12D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-13D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-14D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-1D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-2D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-7D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Chromium, Total | ug/L | MW-9D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Chromium, Total | ug/L | MW-9I | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Cobalt, Total | ug/L | MW-10D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-11D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-12D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-13D | 4 | 2.150 | 0.700 | 1.176 | 1.327 | 2.973 | 6.000 | | |
| Cobalt, Total | ug/L | MW-14D | 4 | 2.175 | 0.650 | 1.176 | 1.410 | 2.940 | 6.000 | | |
| Cobalt, Total | ug/L | MW-1D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-2D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-3D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-7D | 4 | 2.325 | 0.350 | 1.176 | 1.913 | 2.737 | 6.000 | | |
| Cobalt, Total | ug/L | MW-9D | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Cobalt, Total | ug/L | MW-9I | 4 | 2.500 | 0.000 | 1.176 | 2.500 | 2.500 | 6.000 | | |
| Fluoride | mg/L | MW-10D | 4 | 2.275 | 0.377 | 1.176 | 1.831 | 2.719 | 4.000 | | |
| Fluoride | mg/L | MW-11D | 4 | 0.335 | 0.078 | 1.176 | 0.244 | 0.426 | 4.000 | | |
| Fluoride | mg/L | MW-12D | 4 | 1.368 | 0.388 | 1.176 | 0.912 | 1.823 | 4.000 | inc | |
| Fluoride | mg/L | MW-13D | 4 | 0.633 | 0.090 | 1.176 | 0.527 | 0.738 | 4.000 | inc | |
| Fluoride | mg/L | MW-14D | 4 | 0.210 | 0.119 | 1.176 | 0.070 | 0.350 | 4.000 | dec | |
| Fluoride | mg/L | MW-1D | 4 | 0.323 | 0.078 | 1.176 | 0.231 | 0.414 | 4.000 | dec | |
| Fluoride | mg/L | MW-2D | 4 | 0.920 | 0.067 | 1.176 | 0.841 | 0.999 | 4.000 | | |
| Fluoride | mg/L | MW-3D | 4 | 0.168 | 0.028 | 1.176 | 0.135 | 0.200 | 4.000 | dec | |
| Fluoride | mg/L | MW-7D | 4 | 0.418 | 0.067 | 1.176 | 0.339 | 0.496 | 4.000 | inc | |
| Fluoride | mg/L | MW-9D | 4 | 0.415 | 0.050 | 1.176 | 0.356 | 0.474 | 4.000 | | |
| Fluoride | mg/L | MW-9I | 4 | 0.982 | 0.172 | 1.176 | 0.780 | 1.185 | 4.000 | inc | |
| Lead, Total | ug/L | MW-10D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-12D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-13D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-14D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-1D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-2D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Lead, Total | ug/L | MW-7D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-9D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lead, Total | ug/L | MW-9I | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 15.000 | | |
| Lithium, Total | ug/L | MW-10D | 4 | 58.750 | 9.032 | 1.176 | 48.125 | 69.375 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-11D | 4 | 143.000 | 7.071 | 1.176 | 134.682 | 151.318 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-12D | 4 | 86.975 | 17.934 | 1.176 | 65.880 | 108.070 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-13D | 4 | 78.325 | 5.099 | 1.176 | 72.327 | 84.323 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-14D | 4 | 693.250 | 167.281 | 1.176 | 496.479 | 890.021 | 40.000 | | ** |
| Lithium, Total | ug/L | MW-1D | 4 | 16.750 | 7.795 | 1.176 | 7.581 | 25.919 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-2D | 4 | 50.300 | 7.313 | 1.176 | 41.697 | 58.903 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-3D | 4 | 10.000 | 0.000 | 1.176 | 10.000 | 10.000 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-7D | 4 | 97.900 | 4.826 | 1.176 | 92.224 | 103.576 | 40.000 | dec | ** |
| Lithium, Total | ug/L | MW-9D | 4 | 23.950 | 1.340 | 1.176 | 22.373 | 25.527 | 40.000 | dec | |
| Lithium, Total | ug/L | MW-9I | 4 | 26.975 | 3.170 | 1.176 | 23.246 | 30.704 | 40.000 | dec | |
| Mercury | ug/L | MW-10D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-11D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-12D | 4 | 1.200 | 0.400 | 1.176 | 0.729 | 1.671 | 2.000 | | |
| Mercury | ug/L | MW-13D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-14D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-1D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-2D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-3D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-7D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-9D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Mercury | ug/L | MW-9I | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Molybdenum, Total | ug/L | MW-10D | 4 | 88.075 | 6.622 | 1.176 | 80.286 | 95.864 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | | |
| Molybdenum, Total | ug/L | MW-12D | 4 | 175.750 | 18.875 | 1.176 | 153.548 | 197.952 | 100.000 | dec | ** |
| Molybdenum, Total | ug/L | MW-13D | 4 | 696.250 | 138.437 | 1.176 | 533.408 | 859.092 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-14D | 4 | 234.250 | 28.111 | 1.176 | 201.183 | 267.317 | 100.000 | | ** |
| Molybdenum, Total | ug/L | MW-1D | 4 | 36.425 | 2.848 | 1.176 | 33.075 | 39.775 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-2D | 4 | 60.600 | 10.995 | 1.176 | 47.667 | 73.533 | 100.000 | dec | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Molybdenum, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-7D | 4 | 670.250 | 52.576 | 1.176 | 608.405 | 732.095 | 100.000 | inc | ** |
| Molybdenum, Total | ug/L | MW-9D | 4 | 45.900 | 3.554 | 1.176 | 41.719 | 50.081 | 100.000 | dec | |
| Molybdenum, Total | ug/L | MW-9I | 4 | 114.300 | 19.189 | 1.176 | 91.728 | 136.872 | 100.000 | dec | |
| Selenium, Total | ug/L | MW-10D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-11D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-12D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-13D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-14D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-1D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-2D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-3D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-7D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-9D | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Selenium, Total | ug/L | MW-9I | 4 | 5.000 | 0.000 | 1.176 | 5.000 | 5.000 | 50.000 | | |
| Thallium, Total | ug/L | MW-10D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-11D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-12D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-13D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-14D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-1D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-2D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-3D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-7D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-9D | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Thallium, Total | ug/L | MW-9I | 4 | 1.000 | 0.000 | 1.176 | 1.000 | 1.000 | 2.000 | | |
| Total Radium | pCi/L | MW-10D | 4 | 1.300 | 0.464 | 1.176 | 0.754 | 1.846 | 5.000 | | |
| Total Radium | pCi/L | MW-11D | 4 | 1.069 | 0.352 | 1.176 | 0.655 | 1.483 | 5.000 | | |
| Total Radium | pCi/L | MW-12D | 4 | 1.063 | 0.263 | 1.176 | 0.753 | 1.372 | 5.000 | | |
| Total Radium | pCi/L | MW-13D | 4 | 1.575 | 0.135 | 1.176 | 1.416 | 1.734 | 5.000 | | |
| Total Radium | pCi/L | MW-14D | 4 | 1.555 | 0.428 | 1.176 | 1.051 | 2.059 | 5.000 | | |
| Total Radium | pCi/L | MW-1D | 4 | 1.840 | 1.094 | 1.176 | 0.554 | 3.126 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

## Table 1

## Confidence Intervals for Comparing the Mean of the Last 4 Measurements to an Assessment Monitoring Standard

| Constituent | Units | Well | N | Mean | SD | Factor | 95% LCL | 95% UCL | Standard | Trend | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Total Radium | pCi/L | MW-2D | 4 | 2.315 | 1.105 | 1.176 | 1.016 | 3.614 | 5.000 | | |
| Total Radium | pCi/L | MW-3D | 4 | 1.198 | 0.374 | 1.176 | 0.758 | 1.637 | 5.000 | | |
| Total Radium | pCi/L | MW-7D | 4 | 1.097 | 0.255 | 1.176 | 0.796 | 1.397 | 5.000 | | |
| Total Radium | pCi/L | MW-9D | 4 | 1.220 | 0.455 | 1.176 | 0.684 | 1.756 | 5.000 | | |
| Total Radium | pCi/L | MW-9I | 4 | 1.546 | 0.706 | 1.176 | 0.716 | 2.377 | 5.000 | | |

* - Insufficient Data
** - Significant Exceedance
LCL = Lower Confidence Limit
UCL = Upper Confidence Limit

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1 | 88.7854 | 0.2 | 2 | 10 | 1 | 0.2434 | 10 | 20 | 2 | 10 | 2.1 | 1 | 2.4106 |
| MW-1S | September 2018 | 2 | 0 | 7 | 2 | 1 | 5 | 2 | 0.593 | 5 | 7 | 1 | 46 | 5 | 1 | 0.896 |
| | May 2019 | 2 | 0 | 3 | 2 | 1 | 5 | 2 | 0.519 | 5 | 7 | 1 | 41 | 5 | 1 | 0.648 |
| | November 2019 | 1 | 0 | 33 | 2 | 1 | 5 | 2 | 0.425 | 5 | 5 | 1 | 32 | 5 | 1 | 1.431 |
| | May 2020 | 1 | 6 | 51 | 2 | 1 | 5 | 2 | 0.343 | 5 | 5 | 1 | 29 | 5 | 1 | 0.304 |
| | November 2020 | 2 | 3 | 54 | 2 | 1 | 5 | 2 | 0.326 | 5 | 5 | 1 | 22 | 5 | 1 | 0.508 |
| | May 2021 | 2 | 8 | 76 | 2 | 1 | 5 | 2 | 0.254 | 5 | 10 | 1 | 22 | 5 | 1 | 1.088 |
| | November 2021 | 2.754 | 7.106<br>**12.950 (N=8)** | 57.491 | 2.000 | 1.000 | 5.000 | 2.500 | 0.251 | 5.000 | 10.000 | 1.000 | 22.132 | 5.000 | 1.000 | 0.597<br>1.758 (N=8) |
| | May 2022 | 2.754 | 5.729<br>**11.84 (N=8)** | 57.546 | 2.000 | 1.000 | 5.000 | 2.500 | 0.244 | 5.000 | 10.000 | 1.000 | 24.358 | 5.000 | 1.000 | 0.608 |
| MW-2S | September 2018 | 3 | **14** | 80 | 2 | 1 | 5 | 2 | 1.186 | 5 | 17 | 1 | 71 | 5 | 1 | 1.152 |
| | May 2019 | 3 | **12** | 81 | 2 | 1 | 5 | 2 | 0.895 | 5 | 1 | 1 | 35 | 5 | 1 | 0.973 |
| | November 2019 | 3 | **12** | 64 | 2 | 1 | 5 | 2 | 0.587 | 5 | 13 | 1 | 25 | 5 | 1 | 1.000 |
| | May 2020 | 3 | **10** | 62 | 2 | 1 | 5 | 2 | 0.363 | 5 | 7 | 1 | 14 | 5 | 1 | 0.990 |
| | November 2020 | 3 | 9 | 82 | 2 | 1 | 5 | 1 | 0.298 | 5 | 7 | 1 | 28 | 5 | 1 | 1.106 |
| | May 2021 | 3 | 6 | 68 | 2 | 1 | 5 | 1 | 0.294 | 5 | 7 | 1 | 28 | 5 | 1 | 0.429 |
| | November 2021 | 3.000 | 3.608<br>**10.671 (N=8)** | 77.945 | 2.000 | 1.000 | 5.000 | 1.494 | 0.306 | 5.000 | 5.604 | 1.000 | 28.934 | 5.000 | 1.000 | 0.335 |
| | May 2022 | 3.000 | 3.507<br>9.341 (N=8)<br>**13.893 (N=14)** | 83.59 | 2.000 | 1.000 | 5.000 | 1.494 | 0.294 | 5.000 | 5.604 | 1.000 | 18.78 | 5.000 | 1.000 | 0.470 |
| MW-3S | September 2018 | **8** | 2 | 24 | 2 | 1 | 5 | 2 | 0.349 | 5 | 10 | 1 | 52 | 4 | 1 | 0.491 |
| | May 2019 | **7** | 2 | 25 | 2 | 1 | 5 | 2 | 0.217 | 5 | 10 | 1 | 41 | 0 | 1 | 0.549 |
| | November 2019 | **8** | 1 | 28 | 2 | 1 | 5 | 2 | 0.197 | 5 | 10 | 1 | 34 | 0 | 1 | 0.615 |
| | May 2020 | **7** | 2 | 35 | 2 | 1 | 5 | 2 | 0.223 | 5 | 10 | 1 | 41 | 1 | 1 | 0.615 |
| | November 2020 | **7** | 1 | 36 | 2 | 1 | 5 | 2 | 0.214 | 5 | 10 | 1 | 39 | 0 | 1 | 0.733 |
| | May 2021 | **6** | 0 | 39 | 2 | 1 | 5 | 2 | 0.174 | 5 | 10 | 1 | 35 | 2 | 1 | 0.785 |
| | November 2021 | 5.764<br>**6.903 (N=8)** | 0.218 | 37.500 | 2.000 | 1.000 | 5.000 | 2.500 | 0.134 | 5.000 | 10.000 | 1.000 | 36.177 | 1.260 | 1.000 | 0.785 |
| | May 2022 | 4.75<br>**6.242 (N=8)** | 0.129 | 31.580 | 2.000 | 1.000 | 5.000 | 2.500 | 0.063 | 5.000 | 10.000 | 1.000 | 32.035 | 0.000 | 1.000 | 0.572 |
| MW-4S | September 2018 | 3 | 5 | 52 | 2 | 1 | 5 | 2 | 0.108 | 5 | 6 | 1 | 5 | 6 | 1 | 0.721 |
| | May 2019 | 3 | 5 | 47 | 2 | 1 | 5 | 2 | 0.108 | 5 | 6 | 1 | 5 | 5 | 1 | 0.601 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 3 | 2 | 48 | 2 | 1 | 5 | 2 | 0.060 | 5 | 10 | 1 | 5 | 2 | 1 | 0.812 |
| | November 2020 | 3 | 2 | 62 | 2 | 1 | 5 | 1 | 0.037 | 5 | 10 | 1 | 5 | 10 | 1 | 0.838 |
| | May 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | November 2021 | 3.000 | 1.503 | 59.290 | 2.000 | 1.000 | 5.000 | 1.327 | 0.038 | 5.000 | 5.469 | 1.000 | 5.000 | 7.288 | 1.000 | 0.751 |
| | May 2022 | 3.000 | 0.455 | 75.954 | 2.000 | 1.000 | 5.000 | 1.327 | 0.033 | 5.000 | 5.469 | 1.000 | 5.000 | 0 | 1.000 | 0.671 |

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1 | 88.7854 | 0.2 | 2 | 10 | 1 | 0.2434 | 10 | 20 | 2 | 10 | 2.1 | 1 | 2.4106 |
| MW-5S | September 2018 | 3 | 5 | 24 | 2 | 1 | 5 | 2 | 2.65 | 5 | **53** | 1 | **249** | 5 | 1 | 1.047 |
| | May 2019 | 3 | 5 | 25 | 2 | 1 | 5 | 1 | 2.391 | 5 | **53** | 1 | **227** | 5 | 1 | 1.073 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 3 | 5 | 28 | 2 | 1 | 5 | 1 | 2.316 | 5 | **53** | 1 | **217** | 5 | 1 | 0.942 |
| | November 2020 | 3 | 5 | 25 | 2 | 1 | 5 | 1 | 2.184 | 5 | **43** | 1 | **186** | 5 | 1 | 0.880 |
| | May 2021 | 3 | 5 | 24 | 2 | 1 | 5 | 1 | 1.802 | 5 | 39 | 1 | **138** | 5 | 1 | 0.875 |
| | November 2021 | 3.000 | 5.000 | 22.468 | 2.000 | 1.000 | 5.000 | 0.897 | 1.686 | 5.000 | 39.065<br>**46.853 (N=8)** | 1.000 | **126.264** | 5.000 | 1.000 | 0.883 |
| | May 2022 | 3.000 | 5.000 | 22.49 | 2.000 | 1.000 | 5.000 | 1.494 | 1.616 | 5.000 | **41.149** | 1.000 | **115.401** | 5.000 | 1.000 | 0.986 |
| MW-6S | September 2018 | 3 | **11** | 72 | 2 | 1 | 5 | 2 | 0.919 | 5 | **60** | 1 | **137** | 2 | 1 | 0.553 |
| | May 2019 | 1 | **11** | 82 | 2 | 1 | 5 | 2 | 0.600 | 5 | **55** | 1 | 79 | 1 | 1 | 0.662 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 1 | **10** | 103 | 2 | 1 | 5 | 2 | 0.614 | 5 | **55** | 1 | 79 | 1 | 1 | 0.846 |
| | November 2020 | 1 | 8 | 105 | 2 | 1 | 5 | 2 | 0.610 | 5 | **49** | 1 | 74 | 1 | 1 | 0.700 |
| | May 2021 | 1 | 6 | 101 | 2 | 1 | 5 | 2 | 0.614 | 5 | **51** | 1 | 77 | 2 | 1 | 0.434 |
| | November 2021 | 3.000 | 6.418<br>**10.746 (N=8)** | 108.371 | 2.000 | 1.000 | 5.000 | 1.405 | 1.024 | 5.000 | **58.003** | 1.000 | **152.129** | 3.396 | 1.000 | 0.788 |
| | May 2022 | 3.000 | 0.174<br>9.881 (N=8)<br>**15.420 (N=16)** | 111.128 | 2.000 | 1.000 | 5.000 | 1.477 | 1.204 | 5.000 | **60.422** | 1.000 | **155.261** | 3.763 | 1.000 | 0.788 |
| MW-7S | September 2018 | 3 | **324** | 38 | 2 | 1 | 5 | 2 | 0.395 | 5 | **92** | 1 | **410** | 5 | 1 | 1.138 |
| | May 2019 | 3 | **319** | 34 | 2 | 1 | 5 | 1 | 0.391 | 5 | **90** | 1 | **438** | 5 | 1 | 1.180 |
| | November 2019 | 3 | **309** | 35 | 2 | 1 | 5 | 1 | 0.419 | 5 | **89** | 1 | **508** | 5 | 1 | 1.272 |
| | May 2020 | 3 | **306** | 33 | 2 | 1 | 5 | 1 | 0.431 | 5 | **84** | 1 | **509** | 5 | 1 | 1.080 |
| | November 2020 | 3 | **337** | 32 | 2 | 1 | 5 | 1 | 0.461 | 5 | **82** | 1 | **571** | 5 | 1 | 0.979 |
| | May 2021 | 3 | **374** | 34 | 2 | 1 | 5 | 1 | 0.465 | 5 | **82** | 1 | **619** | 5 | 1 | 0.965 |
| | November 2021 | 3.000 | **354.610** | 37.822 | 2.000 | 1.000 | 5.000 | 1.662 | 0.493 | 5.000 | **82.414** | 1.000 | **632.181** | 5.000 | 1.000 | 0.895 |
| | May 2022 | 3.000 | **358.698** | 35.281 | 2.000 | 1.000 | 5.000 | 1.662 | 0.446 | 5.000 | **82.416** | 1.000 | **585.986** | 5.000 | 1.000 | 0.798 |
| MW-8S | September 2018 | 3 | 5 | 18 | 2 | 1 | 5 | 2 | 0.066 | 5 | **72** | 1 | **133** | 5 | 1 | 0.702 |
| | May 2019 | 3 | 5 | 35 | 2 | 1 | 5 | 2 | 0.066 | 5 | **82** | 1 | **171** | 2 | 1 | 0.702 |
| | November 2019 | 3 | 5 | 36 | 2 | 1 | 5 | 2 | 0.062 | 5 | **118** | 1 | **279** | 2 | 1 | 0.620 |
| | May 2020 | 3 | 5 | 36 | 2 | 1 | 5 | 2 | 0.056 | 5 | **114** | 1 | **242** | 1 | 1 | 0.620 |
| | November 2020 | 3 | 5 | 36 | 2 | 1 | 5 | 2 | 0.11 | 5 | **113** | 1 | **279** | 1 | 1 | 0.687 |
| | May 2021 | 3 | 5 | 31 | 2 | 1 | 5 | 2 | 0.059 | 5 | **113** | 1 | **292** | 2 | 1 | 0.687 |
| | November 2021 | 3.000 | 5.000 | 29.260 | 2.000 | 1.000 | 5.000 | 2.500 | 0.058 | 5.000 | **106.923** | 1.000 | **228.802** | 0.815 | 1.000 | 0.819 |
| | May 2022 | 3.000 | 5.000 | 29.303 | 2.000 | 1.000 | 5.000 | 2.500 | 0.033 | 5.000 | **93.803** | 1.000 | **147.761** | 1.057 | 1.000 | 0.645 |

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1 | 88.7854 | 0.2 | 2 | 10 | 1 | 0.2434 | 10 | 20 | 2 | 10 | 2.1 | 1 | 2.4106 |
| MW-9S | September 2018 | **9** | 5 | 41 | 2 | 1 | 5 | 2 | 0.05 | 5 | **87** | 1 | 88 | 0 | 1 | 0.663 |
| | May 2019 | **8** | 5 | 47 | 2 | 1 | 5 | 2 | 0.013 | 5 | **74** | 1 | 83 | 0 | 1 | 0.801 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | **9** | 2 | 49 | 2 | 1 | 5 | 2 | 0.013 | 5 | **73** | 1 | 92 | 9 | 1 | 0.801 |
| | November 2020 | **7** | 2 | 50 | 2 | 1 | 5 | 2 | 0.023 | 5 | **68** | 1 | 69 | 0 | 1 | 0.732 |
| | May 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | November 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2022 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| MW-10S | September 2018 | 3 | **356** | 42 | 2 | 1 | 5 | 2 | 1.76 | 5 | **51** | 1 | **108** | 5 | 1 | 1.019 |
| | May 2019 | 3 | **321** | 37 | 2 | 1 | 5 | 2 | 1.839 | 5 | **50** | 1 | 92 | 5 | 1 | 0.965 |
| | November 2019 | 3 | **326** | 41 | 2 | 1 | 5 | 2 | 2.051 | 5 | **55** | 1 | 85 | 5 | 1 | 0.596 |
| | May 2020 | 3 | **337** | 38 | 2 | 1 | 5 | 1 | 1.936 | 5 | **57** | 1 | 80 | 5 | 1 | 0.544 |
| | November 2020 | 3 | **340** | 35 | 2 | 1 | 5 | 1 | 1.97 | 5 | **51** | 1 | 77 | 5 | 1 | 0 |
| | May 2021 | 3 | **342** | 42 | 2 | 1 | 5 | 1 | 1.97 | 5 | **42** | 1 | 71 | 5 | 1 | 0 |
| | November 2021 | 3.000 | **340.569** | 51.110 | 2.000 | 1.000 | 5.000 | 1.410 | 2.070 | 5.000 | **40.133** | 1.000 | 69.641<br>77.437 (N=8) | 5.000 | 1.000 | 0.000 |
| | May 2022 | 3.000 | **359.225** | 50.594 | 2.000 | 1.000 | 5.000 | 2.500 | 2.404 | 5.000 | **40.918** | 1.000 | 65.466 | 5.000 | 1.000 | 0.000 |
| MW-11S | September 2018 | 3 | 2 | 40 | 2 | 1 | 0.242 | 0 | 1.404 | 2 | 0.194 | 1 | 72 | 5 | 1 | 1.321 |
| | May 2019 | 3 | 1 | 41 | 2 | 1 | 0 | 0 | 1.362 | 2 | 0 | 1 | 73 | 5 | 1 | 1.068 |
| | November 2019 | 3 | 2 | 54 | 2 | 1 | 2 | 0 | 1.366 | 2 | 10 | 1 | 73 | 5 | 1 | 0.597 |
| | May 2020 | 3 | 0 | 8 | 1 | 1 | 0 | 0 | 1.332 | 1 | 0 | 1 | 71 | 5 | 1 | 0.471 |
| | November 2020 | 3 | 0 | 2 | 1 | 1 | 0 | 0 | 1.364 | 1 | 0 | 1 | 73 | 5 | 1 | 0.589 |
| | May 2021 | 3 | 0 | 0 | 1 | 1 | 0 | 0 | 1.364 | 1 | 0 | 1 | 76 | 5 | 1 | 0.642 |
| | November 2021 | 3.000 | 0.000 | 0.000 | 0.927 | 1.000 | 5.000 | 0.000 | 1.364 | 1.483 | 0.000 | 1.000 | 75.632 | 5.000 | 1.000 | 0.807 |
| | May 2022 | 3.000 | 0.000 | 41.446 | 0.29 | 1.000 | 1.686 | 1.688 | 1.325 | 5 | 4.894 | 1.000 | 75.803 | 1.731 | 1.000 | 0.899 |
| MW-12S | September 2018 | 2 | **13** | 28 | 2 | 1 | 5 | 2 | 0.458 | 5 | **102** | 1 | **274** | 5 | 1 | 0.889 |
| | May 2019 | 3 | **18** | 26 | 2 | 1 | 5 | 2 | 0.879 | 5 | **100** | 1 | **248** | 2 | 1 | 0.897 |
| | November 2019 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | May 2020 | 2 | **27** | 27 | 2 | 1 | 5 | 2 | 1.534 | 5 | **97** | 1 | **202** | 2 | 1 | 0.897 |
| | November 2020 | 2 | **27** | 28 | 2 | 1 | 5 | 2 | 1.534 | 5 | **84** | 1 | **178** | 2 | 1 | 0.938 |
| | May 2021 | DRY WELL; NOT SAMPLED | | | | | | | | | | | | | | |
| | November 2021 | 1.879 | **29.435** | 28.013 | 2.000 | 1.000 | 5.000 | 2.500 | 1.549 | 5.000 | **68.305** | 1.000 | **148.059** | 1.002 | 1.000 | 0.744 |
| | May 2022 | 1.913 | **38.785** | 30.158 | 2.000 | 1.000 | 5.000 | 2.500 | 1.699 | 5.000 | **65.287** | 1.000 | **117.461** | 0 | 1.000 | 0.673 |

**Table 1: 95% LCL Compared to GWPS - Shallow Zone**
Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1 | 88.7854 | 0.2 | 2 | 10 | 1 | 0.2434 | 10 | 20 | 2 | 10 | 2.1 | 1 | 2.4106 |
| MW-13S | September 2018 | 3 | **328** | 24 | 2 | 1 | 5 | 2 | 0.647 | 5 | **83** | 1 | **466** | 5 | 1 | 0.713 |
| | May 2019 | 3 | **313** | 25 | 2 | 1 | 5 | 2 | 0.681 | 5 | **84** | 1 | **547** | 5 | 1 | 0.725 |
| | November 2019 | 3 | **312** | 26 | 2 | 1 | 5 | 2 | 0.786 | 5 | **75** | 1 | **726** | 5 | 1 | 0.732 |
| | May 2020 | 3 | **306** | 25 | 2 | 1 | 5 | 2 | 0.779 | 5 | **74** | 1 | **746** | 5 | 1 | 0.883 |
| | November 2020 | 3 | **291** | 28 | 2 | 1 | 5 | 2 | 0.778 | 5 | **66** | 1 | **720** | 5 | 1 | 0.855 |
| | May 2021 | 3 | **289** | 29 | 2 | 1 | 5 | 2 | 0.804 | 5 | **62** | 1 | **684** | 5 | 1 | 0.861 |
| | November 2021 | 3.000 | **292.747** | 31.428 | 2.000 | 1.000 | 5.000 | 2.500 | 0.845 | 5.000 | **61.794** | 1.000 | **576.651** | 5.000 | 1.000 | 0.905 |
| | May 2022 | 3.000 | **293.328** | 32.556 | 2.000 | 1.000 | 5.000 | 2.500 | 0.815 | 5.000 | **60.449** | 1.000 | **526.754** | 5.000 | 1.000 | 0.905 |

Notes:
LCL = Lower Confidence Limit
**Bold font** with gray shading indicates 95% LCL of the mean of the last four measurements that is in exceedance of GWPS.
**Bold font** with green shading indicates 95% LCL of the mean of the last eight measurements that is in exceedance of GWPS.
**Bold font** with gold shading indicates 95% LCL of the mean based on a qualitative evaluation of dataset that may or may not have triggered a mean/LCL conflict but visually warranted evaluation of a larger dataset.
ug/L = micrograms per liter (ppb)
mg/L = milligrams per liter (ppm)
Std. Units = Standard Units
*USEPA'S *Amendments to the National Minimum Criteria (Phase One, Part One), Disposal of Coal Combustion Residuals from Electric Utilities* ; effective August 29, 2018.
The 95% LCL statistic is based on the rolling set of the four most recent individual sample results for a parameter.
LCL calculations utilize 1/2 the median non-detect (ND) reporting limit (RL) from the full date range of non-detect sample results. If RL levels changed over time, the current calculated LCL value may be larger than the most recent four ND results.
DUMPStat summary table output limits the number of significant digits reported for a calculated LCL. An exceedingly small calculated LCL value (e.g. 0.00001 mg/L) may simply be reported as 0 in the output summary.
Reporting units of measure for certain constituents in DUMPStat output tables were changed from units of mg/L (ppm) to ug/L (ppb) beginning with November 2021 LCL analysis to allow for reporting of calculated LCLs to more significant digits.
**Table updated to include May 2022 assessment sampling results.**



**Final Date: 10/24/2022**

# Table 2: 95% LCL Compared to GWPS - Deep Zone

Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1.7099 | 76.8798 | 0.2 | 2 | 10 | 1 | 0.13 | 10 | 20 | 2 | 10 | 1 | 1 | 2.6419 |
| MW-1D | September 2018 | 3 | 2 | 49 | 2 | 1 | 5 | 2 | 0.362 | 5 | 31 | 1 | 49 | 5 | 1 | 0.886 |
| | May 2019 | 3 | 4 | 47 | 2 | 1 | 5 | 2 | 0.336 | 5 | 31 | 1 | 48 | 5 | 1 | 0.900 |
| | November 2019 | 3 | 4 | 48 | 2 | 1 | 5 | 2 | 0.314 | 5 | 25 | 1 | 46 | 5 | 1 | 0.852 |
| | May 2020 | 3 | 4 | 50 | 2 | 1 | 5 | 2 | 0.265 | 5 | 25 | 1 | 45 | 5 | 1 | 0.961 |
| | November 2020 | 3 | 0 | 45 | 2 | 1 | 5 | 2 | 0.268 | 5 | 11 | 1 | 36 | 5 | 1 | 0.421 |
| | May 2021 | 3 | 0 | 51 | 2 | 1 | 5 | 2 | 0.229 | 5 | 11 | 1 | 35 | 5 | 1 | 0.838 |
| | November 2021 | 2.966 | 0.000<br>0.000 (N=8) | 59.901 | 2.000 | 1.000 | 5.000 | 2.500 | 0.229 | 5.000 | 10.37<br>22.268 (N=8) | 1.000 | 32.091 | 5.000 | 1.000 | 0.639 |
| | May 2022 | 2.966 | 0<br>(N=8)<br>3.714 (N=16) | 63.033 | 2.000 | 1.000 | 5.000 | 2.500 | 0.231 | 5.000 | 7.581<br>19.947 (N=9) | 1.000 | 33.075 | 5.000 | 1.000 | 0.554 |
| MW-2D | September 2018 | 3 | 2 | 27 | 2 | 1 | 5 | 2 | 2.532 | 5 | 35 | 1 | **202** | 5 | 1 | 0.958 |
| | May 2019 | 3 | 1 | 39 | 2 | 1 | 5 | 2 | 1.763 | 5 | 20 | 1 | **120** | 5 | 1 | 0.990 |
| | November 2019 | 3 | 1 | 48 | 2 | 1 | 5 | 2 | 1.209 | 5 | 28 | 1 | 65 | 5 | 1 | 0.905 |
| | May 2020 | 3 | 2 | 52 | 2 | 1 | 5 | 2 | 0.859 | 5 | 30 | 1 | 56 | 5 | 1 | 1.427 |
| | November 2020 | 3 | 2 | 63 | 2 | 1 | 5 | 2 | 0.981 | 5 | **40** | 1 | 72 | 5 | 1 | 1.486 |
| | May 2021 | 3 | 2 | 39 | 2 | 1 | 5 | 2 | 0.865 | 5 | 37 | 1 | 59 | 5 | 1 | 1.458 |
| | November 2021 | 3.000 | 1.876 | 32.306 | 2.000 | 1.000 | 5.000 | 2.500 | 0.796 | 5.000 | 38.926<br>39.230 (N=8)<br>57.936 (N=16)[1] | 1.000 | 50.607<br>66.352 (N=8) | 5.000 | 1.000 | 0.991 |
| | May 2022 | 3.000 | 2.714 | 24.408 | 2.000 | 1.000 | 5.000 | 2.500 | 0.841 | 5.000 | **41.697** | 1.000 | 47.667 | 5.000 | 1.000 | 1.016 |
| MW-3D | September 2018 | 3 | 3 | 61 | 2 | 1 | 5 | 2 | 0.264 | 5 | 7 | 1 | 14 | 5 | 1 | 0.808 |
| | May 2019 | 3 | 2 | 64 | 2 | 1 | 5 | 2 | 0.222 | 5 | 7 | 1 | 5 | 5 | 1 | 0.794 |
| | November 2019 | 3 | 2 | 54 | 2 | 1 | 5 | 2 | 0.212 | 5 | 6 | 1 | 10 | 5 | 1 | 0.482 |
| | May 2020 | 3 | 3 | 46 | 2 | 1 | 5 | 2 | 0.205 | 5 | 6 | 1 | 10 | 5 | 1 | 0.355 |
| | November 2020 | 3 | 3 | 45 | 2 | 1 | 5 | 2 | 0.199 | 5 | 6 | 1 | 6 | 5 | 1 | 0.347 |
| | May 2021 | 3 | 3 | 41 | 2 | 1 | 5 | 2 | 0.181 | 5 | 10 | 1 | 4 | 5 | 1 | 0.000 |
| | November 2021 | 3.000 | 2.915 | 38.902 | 2.000 | 1.000 | 5.000 | 2.500 | 0.15 | 5.000 | 10.000 | 1.000 | 2.971 | 5.000 | 1.000 | 0.637 |
| | May 2022 | 3.000 | 2.915 | 41.088 | 2.000 | 1.000 | 5.000 | 2.500 | 0.135 | 5.000 | 10.000 | 1.000 | 5 | 5.000 | 1.000 | 0.758 |
| MW-7D | September 2018 | 3 | **443** | 48 | 2 | 1 | 5 | 2 | 0.262 | 5 | **108** | 1 | **426** | 5 | 1 | 1.280 |
| | May 2019 | 3 | **438** | 41 | 2 | 1 | 5 | 2 | 0.263 | 5 | **106** | 1 | **467** | 5 | 1 | 0.777 |
| | November 2019 | 3 | **422** | 42 | 2 | 1 | 5 | 2 | 0.284 | 5 | **97** | 1 | **546** | 5 | 1 | 0.877 |
| | May 2020 | 3 | **426** | 42 | 2 | 1 | 5 | 2 | 0.294 | 5 | **94** | 1 | **554** | 5 | 1 | 0.831 |
| | November 2020 | 3 | **405** | 39 | 2 | 1 | 5 | 2 | 0.318 | 5 | **87** | 1 | **596** | 5 | 1 | 0.687 |
| | May 2021 | 3 | **404** | 38 | 2 | 1 | 5 | 2 | 0.343 | 5 | **91** | 1 | **629** | 5 | 1 | 0.855 |
| | November 2021 | 3.000 | **411.387** | 36.11 | 2.000 | 0.628 | 5.000 | 1.913 | 0.358 | 5.000 | **92.154** | 1.000 | **681.681** | 5.000 | 1.000 | 0.835 |
| | May 2022 | 3.000 | **411.292** | 35.709 | 2.000 | 0.628 | 5.000 | 1.913 | 0.339 | 5.000 | **92.224** | 1.000 | **608.405** | 5.000 | 1.000 | 0.796 |



**Final Date: 10/24/2022**

# Table 2: 95% LCL Compared to GWPS - Deep Zone

Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1.7099 | 76.8798 | 0.2 | 2 | 10 | 1 | 0.13 | 10 | 20 | 2 | 10 | 1 | 1 | 2.6419 |
| MW-9D | September 2018 | 3 | 3 | 32 | 2 | 1 | 5 | 2 | 0.425 | 5 | **41** | 1 | 84 | 5 | 1 | 0.803 |
| | May 2019 | 3 | 2 | 36 | 2 | 1 | 5 | 2 | 0.412 | 5 | 38 | 1 | 56 | 5 | 1 | 0.770 |
| | November 2019 | 3 | 2 | 45 | 2 | 1 | 5 | 2 | 0.430 | 5 | 35 | 1 | 42 | 5 | 1 | 0.808 |
| | May 2020 | 3 | 2 | 45 | 2 | 1 | 5 | 2 | 0.428 | 5 | 31 | 1 | 42 | 5 | 1 | 0.822 |
| | November 2020 | 3 | 2 | 44 | 2 | 1 | 5 | 2 | 0.421 | 5 | 24 | 1 | 46 | 5 | 1 | 0.876 |
| | May 2021 | 3 | 3 | 46 | 2 | 1 | 5 | 2 | 0.400 | 5 | 24 | 1 | 46 | 5 | 1 | 0.795 |
| | November 2021 | 3.000 | 4.291 | 45.545 | 2.000 | 1.000 | 5.000 | 2.500 | 0.361 | 5.000 | 21.648<br>27.763 (N=8) | 1.000 | 40.729 | 5.000 | 1.000 | 0.948 |
| | May 2022 | 3.000 | 2.469<br>3.287 (N=6) | 47.137 | 2.000 | 1.000 | 5.000 | 2.500 | 0.356 | 5.000 | 22.373 | 1.000 | 41.719 | 5.000 | 1.000 | 0.684 |
| MW-9I | September 2018 | 3 | 5 | 30 | 2 | 1 | 5 | 2 | 0.538 | 5 | 33 | 1 | **109** | 5 | 1 | 0.946 |
| | May 2019 | 3 | 4 | 38 | 2 | 1 | 5 | 2 | 0.522 | 5 | 30 | 1 | 98 | 5 | 1 | 0.934 |
| | November 2019 | 3 | 4 | 54 | 2 | 1 | 5 | 2 | 0.528 | 5 | 31 | 1 | 88 | 5 | 1 | 0.738 |
| | May 2020 | 3 | 4 | 53 | 2 | 1 | 5 | 2 | 0.595 | 5 | 29 | 1 | 89 | 5 | 1 | 0.544 |
| | November 2020 | 3 | 4 | 55 | 2 | 1 | 5 | 2 | 0.667 | 5 | 23 | 1 | 89 | 5 | 1 | 0.600 |
| | May 2021 | 3 | 4 | 58 | 2 | 1 | 5 | 2 | 0.647 | 5 | 24 | 1 | 78 | 5 | 1 | 0.480 |
| | November 2021 | 3.000 | 4.21 | 63.972 | 2.000 | 1.000 | 5.000 | 2.500 | 0.714 | 5.000 | 24.199<br>28.414 (N=8) | 1.000 | 85.339<br>96.532 (N=8)<br>122.452 (N=16)[1] | 5.000 | 1.000 | 0.79 |
| | May 2022 | 3.000 | 2.68 | 66.366 | 2.000 | 1.000 | 5.000 | 2.500 | 0.78 | 5.000 | 23.246 | 1.000 | 91.728<br>95.644 (N=8)<br>**106.599 (N=14)** | 5.000 | 1.000 | 0.716 |
| MW-10D | September 2018 | 3 | **331** | 23 | 2 | 1 | 5 | 2 | 2.066 | 5 | **58** | 1 | **139** | 5 | 1 | 1.123 |
| | May 2019 | 3 | **295** | 26 | 2 | 1 | 5 | 2 | 2.147 | 5 | **57** | 1 | 97 | 5 | 1 | 1.048 |
| | November 2019 | 3 | **267** | 28 | 2 | 1 | 5 | 2 | 2.299 | 5 | **60** | 1 | 73 | 5 | 1 | 0.943 |
| | May 2020 | 3 | **263** | 27 | 2 | 1 | 5 | 2 | 2.298 | 5 | **59** | 1 | 60 | 5 | 1 | 0.743 |
| | November 2020 | 3 | **254** | 28 | 2 | 1 | 5 | 2 | 2.298 | 5 | **53** | 1 | 70 | 5 | 1 | 0.779 |
| | May 2021 | 3 | **252** | 26 | 2 | 1 | 5 | 2 | 2.334 | 5 | **49** | 1 | 71 | 5 | 1 | 0.674 |
| | November 2021 | 3.000 | **186.421** | 26.688 | 2.000 | 1.000 | 5.000 | 2.500 | 2.087 | 5.000 | **48.145** | 1.000 | 73.725<br>80.904 (N=8) | 5.000 | 1.000 | 0.633 |
| | May 2022 | 3.000 | **136.233** | 26.988 | 2.000 | 1.000 | 5.000 | 2.500 | 1.831 | 5.000 | **48.125** | 1.000 | 80.286<br>78.271 (N=8) | 5.000 | 1.000 | 0.754 |
| MW-11D | September 2018 | 3 | **13** | 32 | 2 | 1 | 5 | 2 | 0.333 | 5 | **111** | 1 | 5 | 5 | 1 | 0.912 |
| | May 2019 | 3 | **13** | 31 | 2 | 1 | 5 | 2 | 0.334 | 5 | **122** | 1 | 5 | 5 | 1 | 0.887 |
| | November 2019 | 3 | **14** | 31 | 2 | 1 | 5 | 2 | 0.326 | 5 | **123** | 1 | 5 | 5 | 1 | 0.834 |
| | May 2020 | 3 | **14** | 28 | 2 | 1 | 5 | 2 | 0.311 | 5 | **122** | 1 | 5 | 5 | 1 | 0.782 |
| | November 2020 | 3 | **14** | 27 | 2 | 1 | 5 | 2 | 0.371 | 5 | **125** | 1 | 5 | 5 | 1 | 0.834 |
| | May 2021 | 3 | **15** | 26 | 2 | 1 | 5 | 2 | 0.27 | 5 | **129** | 1 | 5 | 5 | 1 | 0.680 |
| | November 2021 | 3.000 | **14.388** | 23.199 | 2.000 | 1.000 | 5.000 | 2.500 | 0.264 | 5.000 | **134.044** | 1.000 | 5.000 | 5.000 | 1.000 | 0.718 |
| | May 2022 | 3.000 | **14.309** | 22.788 | 2.000 | 1.000 | 5.000 | 2.500 | 0.244 | 5.000 | **134.682** | 1.000 | 5.000 | 5.000 | 1.000 | 0.655 |

# Table 2: 95% LCL Compared to GWPS - Deep Zone

Multiunit Ash Pond System
AES Indiana
Harding Street Generating Station, Indianapolis, Indiana
ATC Project No. 170LF01277

| Sample ID | Through Sample Date | Antimony | Arsenic | Barium | Beryllium | Cadmium | Chromium | Cobalt | Fluoride | Lead | Lithium | Mercury | Molybdenum | Selenium | Thallium | Radium 226/228 Combined |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | mg/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | pCi/L |
| | **GWPS (greater of MCL/USEPA Amendment Level, or background PL)** | **6** | **10** | **2000** | **4** | **5** | **100** | **6** | **4** | **15** | **40** | **2** | **100** | **50** | **2** | **5** |
| | MCL | 6 | 10 | 2000 | 4 | 5 | 100 | - | 4 | 15 | - | 2 | - | 50 | 2 | 5 |
| | USEPA'S Amendments to the National Minimum Criteria* | - | - | - | - | - | - | 6 | - | 15 | 40 | - | 100 | - | - | - |
| | Prediction Limit (based on background data through May 2022) | 1 | 1.7099 | 76.8798 | 0.2 | 2 | 10 | 1 | 0.13 | 10 | 20 | 2 | 10 | 1 | 1 | 2.6419 |
| MW-12D | September 2018 | 3 | **194** | 24 | 2 | 1 | 5 | 2 | 0.379 | 5 | **113** | 1 | **217** | 5 | 1 | 0.960 |
| | May 2019 | 3 | **203** | 24 | 2 | 1 | 5 | 2 | 0.515 | 5 | **101** | 1 | **221** | 5 | 1 | 0.669 |
| | November 2019 | 3 | **208** | 24 | 2 | 1 | 5 | 2 | 0.962 | 5 | **101** | 1 | **215** | 5 | 1 | 0.794 |
| | May 2020 | 3 | **194** | 24 | 2 | 1 | 5 | 2 | 0.962 | 5 | **101** | 1 | **214** | 5 | 1 | 0.721 |
| | November 2020 | 3 | **147** | 25 | 2 | 1 | 5 | 2 | 0.977 | 5 | **102** | 1 | **203** | 5 | 1 | 0.727 |
| | May 2021 | 3 | **215** | 27 | 2 | 1 | 5 | 2 | 0.977 | 5 | **75** | 1 | **176** | 5 | 1 | 0.727 |
| | November 2021 | 3.000 | **308.663** | 26.748 | 2.000 | 1.000 | 5.000 | 2.500 | 0.977 | 5.000 | **73.705** | 0.729 | **164.475** | 5.000 | 1.000 | 0.759 |
| | May 2022 | 3.000 | **384.877** | 26.426 | 2.000 | 1.000 | 5.000 | 2.500 | 0.912 | 5.000 | **65.88** | 0.729 | **153.548** | 5.000 | 1.000 | 0.753 |
| MW-13D | September 2018 | 3 | **217** | 20 | 2 | 1 | 5 | 2 | 0.410 | 5 | **97** | 1 | **614** | 5 | 1 | 1.058 |
| | May 2019 | 3 | **209** | 21 | 2 | 1 | 5 | 2 | 0.415 | 5 | **97** | 1 | **666** | 5 | 1 | 1.366 |
| | November 2019 | 3 | **207** | 20 | 2 | 1 | 5 | 2 | 0.452 | 5 | **87** | 1 | **813** | 5 | 1 | 1.022 |
| | May 2020 | 3 | **211** | 19 | 2 | 1 | 5 | 2 | 0.446 | 5 | **87** | 1 | **799** | 5 | 1 | 0.852 |
| | November 2020 | 3 | **216** | 24 | 2 | 1 | 5 | 2 | 0.468 | 5 | **78** | 1 | **800** | 5 | 1 | 0.866 |
| | May 2021 | 3 | **218** | 20 | 2 | 1 | 5 | 1 | 0.507 | 5 | **72** | 1 | **779** | 5 | 1 | 0.837 |
| | November 2021 | 3.000 | **224.404** | 23.878 | 2.000 | 1.000 | 5.000 | 1.327 | 0.555 | 5.000 | **71.489** | 1.000 | **624.25** | 5.000 | 1.000 | 1.034 |
| | May 2022 | 3.000 | **224.035** | 22.697 | 2.000 | 1.000 | 5.000 | 1.327 | 0.527 | 5.000 | **72.327** | 1.000 | **533.408** | 5.000 | 1.000 | 1.416 |
| MW-14D | September 2018 | 3 | **113** | 49 | 2 | 1 | 5 | 2 | 0.246 | 5 | **551** | 1 | **177** | 5 | 1 | 1.154 |
| | May 2019 | 3 | **105** | 46 | 2 | 1 | 5 | 2 | 0.235 | 5 | **532** | 1 | **181** | 5 | 1 | 1.198 |
| | November 2019 | 3 | **99** | 47 | 2 | 1 | 5 | 1 | 0.202 | 5 | **488** | 1 | **159** | 5 | 1 | 1.163 |
| | May 2020 | 3 | **104** | 46 | 2 | 1 | 5 | 1 | 0.076 | 5 | **449** | 1 | **159** | 5 | 1 | 1.302 |
| | November 2020 | 3 | **100** | 46 | 2 | 1 | 5 | 1 | 0.077 | 5 | **378** | 1 | **174** | 5 | 1 | 1.366 |
| | May 2021 | 3 | **103** | 48 | 2 | 1 | 5 | 1 | 0.015 | 5 | **398** | 1 | **189** | 5 | 1 | 1.605 |
| | November 2021 | 3.000 | **104.386** | 46.364 | 2.000 | 1.000 | 5.000 | 1.41 | 0.014 | 5.000 | **498.309** | 1.000 | **189.714** | 5.000 | 1.000 | 1.465 |
| | May 2022 | 3.000 | **104.451** | 40.259 | 2.000 | 1.000 | 5.000 | 1.41 | 0.07 | 5.000 | **496.479** | 1.000 | **201.183** | 5.000 | 1.000 | 1.051 |

Notes:
LCL = Lower Confidence Limit
**Bold font** with gray shading indicates 95% LCL of the mean of the last four measurements that is in exceedance of GWPS.
**Bold font** with green shading indicates 95% LCL of the mean of the last eight or sixteen measurements that is in exceedance of GWPS.
**Bold font** with gold shading indicates 95% LCL of the mean based on a qualitative evaluation of dataset that may or may not have triggered a mean/LCL conflict but visually warranted evaluation of a larger dataset.
ug/L = micrograms per liter (ppb)
mg/L = milligrams per liter (ppm)
Std. Units = Standard Units
*USEPA'S *Amendments to the National Minimum Criteria (Phase One, Part One), Disposal of Coal Combustion Residuals from Electric Utilities* ; effective August 29, 2018.
The 95% LCL statistic is based on the rolling set of the four most recent individual sample results for a parameter.
1 - Exceedance not declared due to trend identified over the corresponding dataset. Datasets containing trends do not display stationality and are not appropriate to utilize for LCL calculations.
LCL calculations utilize 1/2 the median non-detect (ND) reporting limit (RL) from the full date range of non-detect sample results. If RL levels changed over time, the current calculated LCL value may be larger than the most recent four ND results.
DUMPStat summary table output limits the number of significant digits reported for a calculated LCL. An exceedingly small calculated LCL value (e.g. 0.00001 mg/L) may simply be reported as 0 in the output summary.
Reporting units of measure for certain constituents in DUMPStat output tables were changed from units of mg/L (ppm) to ug/L (ppb) beginning with November 2021 LCL analysis to allow for reporting of calculated LCLs to more significant digits.
**Table updated to include May 2022 assessment sampling results.**



**Final Date: 10/24/2022**